

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

VVCMC / FIRE / 09 / 2010-11

DATE: 28/03/2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.

Sub. :- No Objection Certificate for occupation of Proposed "Residential Building No. 4 (Wing A & B)", On Plot bearing S. No. / H. No. 34/1, 2, 35/2/1, 37/4 at village Barampur Tal. Vasai Dist. Thane.

BUILDING KNOWN AS "SAPPHIRE wing A & B"

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/709/2010/11 Dated: 03/03/2011.
2) A Letter from Deputy Director Town Planning No. VVCM/NR/709/2010/11 Dated: 03/03/2011.
3) An Application received from M/s. EN CON Architectural, Dated: 03/02/2011.
4) Built up Area Certificate M/s. EN CON Architectural, Dated: 03/02/2011.
5) Revised C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ RDP/BP-3548/ W/4495 Dated: 20/07/2009.
6) Fire Fighting Installation Certificate of M/s. Sadanand Fire Controls Dated: 03/02/2011.
7) Building Completion Certificate from M/s EN CON Architectural, Dated: 03/02/2011.
8) Structure Stability Certificate of M/s. Sanjay Narang & Associates, Dated: 31/01/2011.
9) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 96989, Dated : 24/11/2010 & No. 100108 Dated: 21/03/2011.
10) A letter of M/s EN CON Architectural, Dated: 25/03/2011.
11) An Affidavit of M/s Happy Home Housing Corporation, Dated: 25/03/2011.

Please refer to C. C. issued by CIDCO No. CIDCO / VVSR/ CC/ BP - 3548/ W /4495 Dt.: 29/03/2007. The party has constructed "Residential Building No. 4 (Wing A & B) Stilt + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s HAPPY HOME HOUSING CORPORATION" Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
a) On every floor hose reel hose & landing valve / Hydrant Valve
b) Booster pump on terrace
c) Hose Box, Cotton Hose & Branch Pipe On alternate Floor.
d) Fire Brigade inlet at ground floor.
B) Fire Extinguishers
C) Court Yard Hydrant

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 45,200/- as per the letter given by the party (Ref. No. 10) & the additional minimum capitation fees of Rs. 1,94,800/- vide receipt No. 64665 Dated: 25/03/2011 for the total gross built up area 4534.00 Sq. Mtr. as per the letter given by the party dated 25/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect & Fire Fighting Contractor

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.

2

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

VVCMC / FIRE / 10 / 2010-11

DATE: 28 / 03 / 2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.

Sub. :- No Objection Certificate for occupation of Proposed "Residential Building No. 1 (Wing A, B & C)", On Plot bearing S. No. / H. No. 69/1 to 6, 71/9, 10, 73 / 4 to 7, 12 to 14, 74 / 9, 12, 13 at village Manickpur Tal. Vasai Dist. Thane.

BUILDING KNOWN AS " ARUM Wing A, B & C "

- Ref. :-** 1) A Letter from Deputy Director Town Planning No. VVCM/NR/822/2010/11 Dated: 16/03/2011.
2) An Application received from M/s. EN CON Architectural, Dated: 02/03/2011.
3) Built up Area Certificate M/s. EN CON Architectural, Dated: 03/03/2011.
4) Revised C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ RDP/BP-4258/ W/339 Dated: 19/05/2010.
5) Fire Fighting Installation Certificate of M/s. Sadanand Fire Controls Dated: 02/03/2011.
6) Building Completion Certificate from M/s EN CON Architectural, Dated: 03/03/2011.
7) Structure Stability Certificate of M/s. Sanjay Narang & Associates, Dated: 03/03/2011.
8) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 98949, 98951 Dated : 21/02/2011 & No. 100108 Dated: 21/03/2011.
9) Provisional N.O.C. Issued By City & Industrial Development Corporation Ltd No. CIDCO/FIRE/ KLM/ 2008/541 Dated: 11/09/2008.
10) A letter of M/ s EN CON Architectural, Dated: 25/03/2011.
11) An Affidavit of M/s Ajmera Developers, Dated: 25/03/2011.

Please refer to Revised C. C. issued by CIDCO No. CIDCO / VVSR / RDP/ BP - 4258/ W/ 339, Dated: 19/05/2010. The party has constructed " Residential Building No.1 (Wing A, B & C) Stilt + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by " M/s AJMERA DEVELOPERS ." Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve
 - b) Booster pump on terrace 5HP
 - c) Hose Box , Cotton Hose & Branch Pipe On alternate Floor.
 - d) Fire Brigade inlet at ground floor.
- B) Fire Extinguishers
- C) Court Yard Hydrant

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 76,900 as per the letter given by the party (Ref. No. 10) & the additional minimum capitation fees of Rs. 2,83,100/- vide receipt No. 64662 Dated: 25/03/2011 for the total gross built up area 7694.00 Sq. Mtr. as per the letter given by the party dated 25/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect & Fire Fighting

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.

28/3/11

3

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

VVCMC / FIRE / / / 2010-11

DATE: 28/03/2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist. Thane.

Sub. :- No Objection Certificate for occupation of Proposed "Residential Building No. 3 (Wing B & C)", On Plot bearing S. No. / H. No. 69/1 to 6, 71/9, 10, 73 / 4 to 7, 12 to 14, 74 / 9, 12, 13 at village Manickpur Tal. Vasai Dist. Thane.

BUILDING KNOWN AS "IRIS Wing B & C"

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/820/2010/11 Dated: 16/03/2011.
2) An Application received from M/s. EN CON Architectural, Dated: 02/03/2011.
3) Built up Area Certificate M/s. EN CON Architectural, Dated: 03/03/2011.
4) Revised C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ RDP/BP-4258/ W/339 Dated: 19/05/2010.
5) Fire Fighting Installation Certificate of M/s. Sadañand Fire Controls Dated: 02/03/2011.
6) Building Completion Certificate from M/s EN CON Architectural, Dated: 03/03/2011.
7) Structure Stability Certificate of M/s. Sanjay Narang & Associates, Dated: 03/03/2011.
8) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 98943, 98953 Dated : 21/02/2011.
9) Provisional N.O.C. Issued By City & Industrial Development Corporation Ltd No. CIDCO/FIRE/ KLM/ 2009/724 Dated: 20/06/2009.
10) A letter of M/s EN CON Architectural, Dated: 25/03/2011.
11) An Affidavit of M/s Ajmera Developers, Dated: 25/03/2011.

Please refer to Revised C. C. issued by CIDCO No. CIDCO / VVSR / RDP/ BP - 4258/ W/ 339, Dated: 19/05/2010. The party has constructed "Residential Building No.3 (Wing B & C) Stilt + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s AJMERA DEVELOPERS." Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve
 - b) Booster pump on terrace
 - c) Hose Box, Cotton Hose & Branch Pipe On alternate Floor.
 - d) Fire Brigade inlet at ground floor.
- B) Fire Extinguishers
- C) Court Yard Hydrant

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 31,900 as per the letter given by the party (Ref. No. 10) & the additional minimum capitation fees of Rs. 2,08,100/- vide receipt No. 64661 Dated: 25/03/2011 for the total gross built up area 3195.00 Sq. Mtr. as per the letter given by the party dated 25/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.



Copy to Architect & Fire Fighting Contractor

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.


CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

4

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

OK

VVCMC / FIRE / 12 / 2010-11

DATE: 25 / 03 / 2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.

Sub. :- No Objection Certificate for occupation of Proposed "Residential Building No. 2 (Wing A & B)", On Plot bearing S. No. / H. No. 69/1 to 6, 71/9, 10, 73 / 4 to 7, 12 to 14, 74 / 9, 12, 13 at village Manickpur Tal. Vasai Dist. Thane.

BUILDING KNOWN AS "ASPEN Wing A & B"

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/820/2010/11 Dated: 16/03/2011.
2) An Application received from M/s. EN CON Architectural, Dated: 02/03/2011.
3) Built up Area Certificate M/s. EN CON Architectural, Dated: 03/03/2011.
4) Revised C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ RDP/BP-4258/ W/339 Dated: 19/05/2010.
5) Fire Fighting Installation Certificate of M/s. Sadanand Fire Controls Dated: 02/03/2011.
6) Building Completion Certificate from M/s EN CON Architectural, Dated: 03/03/2011.
7) Structure Stability Certificate of M/s. Sanjay Narang & Associates, Dated: 03/03/2011.
8) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 98943, 98953 Dated : 21/02/2011.
9) Provisional N.O.C. Issued By City & Industrial Development Corporation Ltd No. CIDCO/FIRE/ KLM/ 2008/541 Dated: 11/09/2008.
10) A letter of M/s EN CON Architectural, Dated: 25/03/2011.
11) An Affidavit of M/s Ajmera Developers, Dated: 25/03/2011.

Please refer to Revised C. C. issued by CIDCO No. CIDCO / VVSR / RDP/ BP - 4258/ W/ 339, Dated: 19/05/2010. The party has constructed "Residential Building No.2 (Wing A & B) Stilt + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s AJMERA DEVELOPERS ." Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve
 - b) Booster pump on terrace
 - c) Hose Box , Cotton Hose & Branch Pipe On alternate Floor.
 - d) Fire Brigade inlet at ground floor.
- B) Fire Extinguishers
- C) Court Yard Hydrant

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 52,600 as per the letter given by the party (Ref. No. 10) & the additional minimum capitation fees of Rs. 1,87,400/- vide receipt No. 64664 Dated: 25/03/2011 for the total gross built up area 5266.00 Sq. Mtr. as per the letter given by the party dated 25/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect & Fire Fighting Contractor

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.

THE SECRETARY OF THE ARMY
WASHINGTON, D. C. 20315



OFFICE OF THE SECRETARY
OF THE ARMY

[Handwritten signature]

MEMORANDUM FOR THE SECRETARY OF THE ARMY
SUBJECT: [Illegible]

1. [Illegible text]

2. [Illegible text]

3. [Illegible text]

4. [Illegible text]

5. [Illegible text]

6. [Illegible text]

7. [Illegible text]

8. [Illegible text]

9. [Illegible text]

10. [Illegible text]

11. [Illegible text]

12. [Illegible text]

13. [Illegible text]

14. [Illegible text]

15. [Illegible text]

16. [Illegible text]

17. [Illegible text]

18. [Illegible text]

19. [Illegible text]

20. [Illegible text]

21. [Illegible text]

22. [Illegible text]

23. [Illegible text]

24. [Illegible text]

25. [Illegible text]

26. [Illegible text]

27. [Illegible text]

28. [Illegible text]

29. [Illegible text]

30. [Illegible text]

31. [Illegible text]

32. [Illegible text]

33. [Illegible text]

34. [Illegible text]

35. [Illegible text]

36. [Illegible text]

37. [Illegible text]

38. [Illegible text]

39. [Illegible text]

40. [Illegible text]

41. [Illegible text]

42. [Illegible text]

43. [Illegible text]

44. [Illegible text]

45. [Illegible text]

46. [Illegible text]

47. [Illegible text]

48. [Illegible text]

49. [Illegible text]

50. [Illegible text]

51. [Illegible text]

52. [Illegible text]

53. [Illegible text]

54. [Illegible text]

55. [Illegible text]

56. [Illegible text]

57. [Illegible text]

58. [Illegible text]

59. [Illegible text]

60. [Illegible text]

61. [Illegible text]

62. [Illegible text]

63. [Illegible text]

64. [Illegible text]

65. [Illegible text]

66. [Illegible text]

67. [Illegible text]

68. [Illegible text]

69. [Illegible text]

70. [Illegible text]

5

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

VVCMC / FIRE / 13 / 2010-11

DATE: 23 / 03 / 2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.

Sub. :- No Objection Certificate for occupation of Proposed " Residential Cum Commercial Building Type D, E & G (Wing A, B & C)", On Plot bearing S. No. / H. No. 414pt, 414pt at village Bolinj Tal. Vasai Dist. Thane.

BUILDING KNOWN AS " KRISHNA RESIDENCY - VIVA VRINDAVAN TOWNSHIP"

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/893/2010/11 Dated: 24/03/2011.
2) An Application received from M/s. Shah Gattani Consultant, Dated: 15/03/2011.
3) Built up Area Certificate M/s. Shah Gattani Consultant, Dated: 15/03/2011.
4) C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/CC/BP-3486/W/2067 Dated: 29/03/2007.
5) C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/CC/BP-3486/W/2064 Dated: 29/03/2007.
6) Fire Fighting Installation Certificate of M/s. Sadanand Fire Controls Dated: 15/03/2011.
7) Building Completion Certificate from M/s Shah Gattani Consultant, Dated: 15/03/2011.
8) Structure Stability Certificate of M/s. Shah Gattani Consultant, Dated: 15/03/2011.
9) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 97561, 97560 Dated: 16/12/2010, No. 98044 Dated : 05/01/2011.
10) A letter of M/s Shah Gattani Consultant, Dated: 25/03/2011.
11) An Affidavit of M/s Viva Vrindavan Builders, Dated: 25/03/2011.

Please refer to C. C. issued by CIDCO No. CIDCO / VVSR/ CC/ BP - 3486/ W / 2067 Dt.: 29/03/2007. The party has constructed " Residential Building Type D, E & G (Wing A, B & C) Stilt + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by " M/s VIVA VRINDAVAN BUILDERS ." Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve
 - b) Booster pump on terrace
 - c) Hose Box , Cotton Hose & Branch Pipe On alternate Floor.
 - d) Fire Brigade inlet at ground floor.
 - e) Main pump on ground level
- B) Fire Extinguishers
- C) Court Yard Hydrant

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid capitation fees of Rs. 3,60,000/- vide receipt No. 64651 Dated: 25/03/2011 for the total gross built up area 8847.24 Sq. Mtr. as per the letter given by the party dated 25/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect & Fire Fighting Contractor

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.

6

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

VVCMC / FIRE / 14 / 2010-11

DATE: 28 / 03 / 2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.

Sub. :- No Objection Certificate for occupation of Proposed " Residential Building Type J, J, G, L, G, E, O & P (Wing A To H)", On Plot bearing S. No. / H. No. 414pt, 414pt at village Bolinj Tal. Vasai Dist. Thane.

BUILDING KNOWN AS " KRISHNA GARDEN - VIVA VRINDAVAN TOWNSHIP"

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/892/2010/11 Dated: 24/03/2011.
2) An Application received from M/s. Shah Gattani Consultant, Dated: 15/03/2011.
3) Built up Area Certificate M/s. Shah Gattani Consultant, Dated: 15/03/2011.
4) C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/CC/BP-3486/W/2067 Dated: 29/03/2007.
5) C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/CC/BP-3486/W/2064 Dated: 29/03/2007.
6) Fire Fighting Installation Certificate of M/s. Sadanand Fire Controls Dated: 15/03/2011.
7) Building Completion Certificate from M/s Shah Gattani Consultant, Dated: 15/03/2011.
8) Structure Stability Certificate of M/s. Shah Gattani Consultant, Dated: 15/03/2011.
9) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 98035 Dated: 05/01/2011, No. 99809, 99810, 99808 Dated : 14/03/2011, No. 99525 Dated : 22/02/2011, No. 99690, 99691 Dated : 05/03/2011, No. 99675 Dated : 03/03/2011
10) A letter of M/ s EN CON Architectural, Dated: 25/03/2011.
11) An Affidavit of M/s Viva Vrindavan Builders, Dated: 25/03/2011.

Please refer to C. C. issued by CIDCO No. CIDCO / VVSR/ CC/ BP - 3486/ W / 2067 Dt.: 29/03/2007. The party has constructed " Residential Building Type J, J, G, L, G, E, O & P (Wing A To H) Stilt + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by " M/s VIVA VRINDAVAN BUILDERS " Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve
 - b) Booster pump on terrace
 - c) Hose Box , Cotton Hose & Branch Pipe On alternate Floor.
 - d) Fire Brigade inlet at ground floor.
- B) Fire Extinguishers
- C) Court Yard Hydrant

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 75,100/- vide receipt No. 23861 Dated: 30/10/2009, Rs. 1,51,500/- vide receipt No. 18044 Dated: 29/03/2007, Rs. 70,000/- vide receipt No. 24012 Rs. 75,500/- vide receipt No. 13681 Dated: 18/10/2007, & the additional minimum capitation fees of Rs. 5,87,900/- vide receipt No. 64650 Dated: 25/03/2011 for the total gross built up area 18304.75 Sq. Mtr. as per the letter given by the party dated 25/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect & Fire Fighting Contractor

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.

VASAI VIRAR CITY MUNICIPAL CORPORATION

FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

VVCMC / FIRE / 3 / 2010-11

DATE: 29/03/2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.



Sub. :- No Objection Certificate for occupation of Proposed "Residential Cum Commercial Building No. 3 (Wing A, B, C & H)", On Plot bearing S. No. / H. No. 35 at village Sopara Tal. Vasai Dist. Thane.

BUILDING KNOWN AS "VINI HEIGHTS"

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/651/2010/11 Dated: 03/03/2011.
2) An Application received from M/s. Ajay Wade & Associates, Dated: 07/02/2011.
3) Built up Area Certificate M/s. Ajay Wade & Associates.
4) Revised C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ RDP/BP-1936/ W/3737 Dated: 13/04/2009.
5) Fire Fighting Installation Certificate of M/s. Viva Enterprises, Dated: 28/01/2011.
6) Building Completion Certificate from M/s Ajay Wade & Associates.
7) Structure Stability Certificate No. RSC/DGN/234/2010/01, 02, 03 & 4 of M/s. Raje Structure Consultants, Dated: 22/11/2010.
8) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 96142, 96143, 96140, 96235, 96234, 96233, 96232 & 96141 Dated : 13/10/2010.
9) A letter of M/ s Ajay Wade & Associates, Dated: 28/03/2011.
10) An Affidavit of Shree Nipun Thakkar, Dated: 14/03/2011.
11) Revised C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ RDP/BP-1936/ W/185 Dated: 23/04/2009.
12) Provisional N.O.C. Issued By City & Industrial Development Corporation Ltd No. CIDCO/FIRE/ KLM/ 1174/2009 Dated: 01/10/2009.

Please refer to Revised C. C. issued by CIDCO No. CIDCO / VVSR / RDP / BP - 1936 / W / 185 Dt.: 29/03/2007. The party has constructed " Residential Cum Commercial Building No. 3 (Wing A, B, C & H) G + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s AMI CORPORATION" Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve for Each wing.
 - b) Booster pump on terrace for Each wing
 - c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
 - d) Main pump on ground level.
- B) Fire Extinguishers
- C) Court Yard Hydrant
- D) D. G. Set- KVA-125

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renew the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 1,14,600/- as per the provisional N.O.C. (Ref. No. 12) & the additional minimum capitation fees of Rs. 1,35,900/- vide receipt No. 64692 & Rs. 2,29,500/- vide receipt No. 64691 Dated: 28/03/2011 for the total gross built up area 11460.34 Sq. Mtr. as per the letter given by the party dated 25/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.

[Signature]

[Signature]

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect & Fire Fighting Contractor

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.

VASAI VIRAR CITY MUNICIPAL CORPORATION

FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

8

VVCMC / FIRE / 32 / 2010-11

DATE: 30/03/2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.



Sub. :- No Objection Certificate for occupation of Proposed "Residential Cum Commercial Building No.17 (wing A, B & C)", On Plot bearing S. No. 7 H. No. 64/1, 70/5, 71/1, 4 to 8, 10 to 15, 17, 72/1 to 21, 73/2, 4 to 11, 75/3 to 7, 9 to 14, 76/1, 2, 4, 6, 8 to 12, 77/1 to 8, 78/1, 4, to 6, 8 to 15, 79/3 to 6, 81/2, 4, 5, 80/, 82/1pt, 2 to 6, 83/1 to 11, 84/1 to 5, 85/1, 3, 4, 86/2, 2b, 3, 7, 8, 90/1, 2/1, 3, 4 to 9, 91/3 to 8 at village Chulne Tal. Vasai Dist. Thane.

BUILDING KNOWN AS "KAUL'S HERITAGE CITY"

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/706/2010/11 Dated: 03/03/2011.
2) An Application received from M/s. Ajay Wade & Associates, Dated: 11/02/2011.
3) Built up Area Certificate M/s. Ajay Wade & Associates, Dated: 11/02/2011.
4) C.C. Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ AM/ BP-1231/ W/2895 Dated: 16/07/2007.
5) Fire Fighting Installation Certificate of M/s. Sadanand Fire Engineering, Dated: 03/02/2011.
6) Building Completion Certificate from M/s. Ajay Wade & Associates, Dated: 11/02/2011.
7) Structure Stability Certificate of M/s. Suresh Panicker & Associates, Dated: 28/02/2011.
8) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 93150, 93149 & 93148 Dated : 04/08/2010.
9) A letter of M/s. Ajay Wade & Associates, Dated: 28/03/2011.
10) An Affidavit of M/s Mahavir Enterprise, Dated: 25/03/2011.
11) Provisional N.O.C. Issued By City & Industrial Development Corporation Ltd No. CIDCO/FIRE/ KLM/ 2008/231 Dated: 22/04/2008.
12) C.C. Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/RDP/ BP-1698/ W/4058 Dated: 04/05/2009.

Please refer to C. C. issued by CIDCO No. CIDCO/VVSR/AM/ BP - 1231/ W/ 2895 Dt.: 16/07/2007. The party has constructed "Residential Cum Commercial Building No. 17 wing A, B & C Part G + 7 Floors" as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s MAHAVIR ENTERPRISE". Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve for Each wing.
 - b) Booster pump on terrace for Each wing
 - c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
 - d) Main pump on ground level.
- B) Fire Extinguishers
- C) Court Yard Hydrant

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 60,800/- as per Ref. No. 4 & the additional minimum capitation fees of Rs. 2,99,200/- vide receipt No. 64699 Dated: 29/03/2011 for the total gross built up area 6278.93 Sq. Mtr. as per the letter given by the party dated 28/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.

CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect & Fire Fighting Contractor

Please Note:- The Developer/Owner/Occupier have to submit the next Testing Certificate of fire fighting system's from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July 2011.

VASAI VIRAR CITY MUNICIPAL CORPORATION

12/14/74
12/14/74

C

C

9


VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2525101/02/03/04/05/06

VVCMC / FIRE / 35 / 2010-11

DATE: 30 / 03 / 2011

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist: Thane.



Sub. :- No Objection Certificate for occupation of Proposed " Residential Building Type F, G & H (wing A, B & C) ", On Plot bearing S. No. / F. No. 355 / 8 to 23 at village Bolinj Tal. Vasai Dist. Thane.

BUILDING KNOWN AS " POONAM ATUMS "

- Ref. :- 1) A Letter from Deputy Director Town Planning No. VVCM/NR/819/2010/11 Dated: 16/03/2011.
2) An Application received from M/s. Shah Gattani Consultant, Dated: 25/02/2011.
3) Built up Area Certificate M/s. Shah Gattani Consultant, Dated: 25/02/2011.
4) Revised C.C Issued by City & Industrial Development Corporation Ltd No. CIDCO/VVSR/ RDP/BP-3545/ W/4045 Dated: 02/06/2009.
5) Fire Fighting Installation Certificate of M/s. Sadanand Fire Engineering, Dated: 25/02/2011.
6) Building Completion Certificate from M/s. Shah Gattani Consultant, Dated: 25/02/2011.
7) Structure Stability Certificate of M/s. Shah Gattani Consultant, Dated: 25/02/2011.
8) Licence to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 96438, 96440 & 96439 Dated : 28/10/2010.
9) A letter of M/s. Shah Gattani Consultant, Dated: 29/03/2011.
10) An Affidavit of M/s Poonam Skyline Construction, Dated: 26/03/2011.

Please refer to Revised C. C. issued by CIDCO No. CIDCO / VVSR / RDP / BP - 3545 / W / 4045 Dt.: 02/06/2009. The party has constructed " Residential Type F- wing A, Type G- wing B & Type H- wing C Part G + 7 Floors " as per sanctioned Plan.

With reference to above on 22/03/2011 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by " M/s POONAM SKYLINE CONSTRUCTION " Following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Down comer system for Each wing
 - a) On every floor hose reel hose & landing valve / Hydrant Valve for Each wing.
 - b) Booster pump on terrace for Each wing
 - c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
 - d) Main pump on ground level.
- B) Fire Extinguishers
- C) Court Yard Hydrant
- D) D. G. Set- KVA-45

Considering the same this Office is issuing a final No Objection certificate for the above mentioned building. This Certificate shall be treated valid upto 31/12/2011. It is the responsibility of the owner / Architect / occupier to submit the fire fighting system maintenance report from Licensed Agency appointed by Vasai Virar City Municipal Corporation on 1st July every year. It is the responsibility of the owner / Architect / occupier to renewed the N.O.C. on 1st January of 2012. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate. It is the duty of the Developer / Architect to inform the Occupier / Residence. In failure of fulfilling the requirement of Fire Department, the owner / Architect / occupier will be personally responsible.

The Chief Fire Officer Reserves right to amend any additional recommendations deemed fit during the year due to statutory provision amended from time to time and in the interest of the protection of the building / People.

The Party has paid the Fire Cess Fees of Rs. 18,300/- vide receipt No. 19394 Dated: 02/01/2008, Rs. 28,650/- vide receipt No. 17678 Dated: 07/04/2007, Rs. 36,500/- vide receipt No. 13680 Dated: 26/10/2007 & Rs. 21,000/- vide receipt No. 14814 Dated: 30/01/2008 & the additional minimum capitation fees of Rs. 2,55,550/- vide receipt No. 64700 Dated: 29/03/2011 for the total gross built up area 6028.60 Sq. Mtr. as per the letter given by the party dated 29/03/2011.

Town Planning Dept. is requested to verify the gross built-up area and inform this department if it is more for the purpose of levying additional capitation fee, if necessary.

Handwritten signature

Conv to Architect & Fire Fighting Contractor

Handwritten signature
CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION



वसई - विरार, शहर महानगरपालिका

अग्निशमन दल

मुख्य कार्यालय, विरार (पूर्व), ता. वसई जि.ठाणे
दूरध्वनी : ०२५०-२५२५१०१/०२/०३/०४/०५/०६

जाक्र/वविश/मनपा/अग्नि/ ९६ /२०१०-११

दिनांक : २७ /०८ /२०११.

प्रति,
मे. रॉयल फ्रेंच पॉलीश,
शॉप नं. ३४, ए विंग,
लॉरेन्स ट्रेड सेंटर को. ऑ. हौ. सो.,
प्लॉट क्र. ४६ ते ४९ नवघर, स्टेशन रोड,
वसई (प.), ता. वसई, जि. ठाणे



- संदर्भ :- १) श्री. सेबेस्टीयन मायकल लोपीस यांचा दि. ०८/०७/२०११ रोजीचा अर्ज.
२) मे. श्री फायरगार्ड कं. यांचेकडील दि. १३/०८/२०११ रोजीचे प्रमाणपत्र
३) सन २०११-१२ रोजीची कर भरणा पावती.
४) नवघर-माणीकपुर नगरपरिषद यांचेकडिल दि. २८/१०/१९९९ रोजीचा दाखला.

“ना हरकत दाखला नुतनीकरण”

वसई - विरार शहर महानगरपालिकेचे क्षेत्रातील मे. रॉयल फ्रेंच पॉलीश, शॉप नं. ३४, ए विंग, लॉरेन्स ट्रेड सेंटर को. ऑ. हौ. सो., प्लॉट क्र. ४६ ते ४९ नवघर, स्टेशन रोड, वसई (प.), ता. वसई, जि. ठाणे विभागात आपल्या अर्जानुसार वरील ठिकाणी “फ्रेंच पॉलीश” या व्यवसायासाठी अग्निशमन विषयक खालील अटीशर्तीस अधीन राहून ना हरकत दाखला देण्यात येत आहे.

- उपरोक्त ठिकाणी **ABC TYPE (5 KG.) 2** नग फायर एक्स्टिंग्युशर्स ठेवण्यात आले आहेत.
- परवाना जागा पध्दत यामध्ये बदल झाल्यास हा दाखला रद्द करण्यात येईल.
- फ्रेंच पॉलीश या व्यवसायासाठी करिता वसई - विरार शहर महानगरपालिकेचा आवश्यक तो वेगळा परवाना असावयास हवा व इतर काही कारणासाठी कायद्यान्वये नियमाप्रमाणे आपल्याकडे शासकीय परवानगी पत्र किंवा परवाना असणे आवश्यक आहे.
- मंजुर साठ्यानुसारच साठा करण्यात यावा.
- आपत प्रसंगी पाण्याचा वापर चटकन करता यावा म्हणून जवळपास पाण्याचा पुरेसा साठा करणाऱ्या टाक्या ठेवाव्यात.
- नाहरकत दाखला दि. ३१/१२/२०११ रोजी पर्यंत वैध आहे. दरवर्षी नुतनीकरण करण्यात यावे.
- मुख्य अग्निशमन अधिकारी महानगरपालिका यांचेकडून वार्षिक तपासणी करून त्याबद्दल प्रमाणपत्र घेणे बंधनकारक राहील.
- वसई - विरार, शहर अनधिकृत बांधकाम कारवाईस बाधा न येता हा दाखला फक्त अग्निशमन बाबीसाठीच देण्यात येत आहे.
- मुख्य अग्निशमन अधिकारी तपासणीस येतील त्यावेळी जर वरील बाबींमध्ये त्रुटी आढळल्यास कोणत्याही प्रकारची सूचना न देता जागेवर दाखला रद्द करण्याचा अधिकार मुख्य अग्निशमन अधिकारी यांना राहील.
- सदरचा ना हरकत दाखला प्राप्त झाल्यावर असणाऱ्या त्रुटी वा कमतरतेबद्दल व्यवसायधारक व्यक्तीशः जबाबदार असून याबाबत अग्निशमन अधिकारी वा महापालिका जबाबदार राहणार नाही.
- भविष्यात गरज वाटल्यास मुख्य अग्निशमन अधिकारी हयांच्या सुचनेनुसार आवश्यक ते फेरबदल / अतिरिक्त अग्निशमन उपाययोजना करणे बंधनकारक आहे.

Signatures

मुख्य अग्निशमन अधिकारी
अग्निशमन व आणीबाणी सेवा
वसई - विरार शहर महानगरपालिका

