VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 01/2014 DATE: 18/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of School Bilding on Land bearing S.No.343,344,345 of village -Bolinj, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1176/2014 Dated:10/06/2014.
2) An application received by M/s. Ameya Builders&Property Developers , Dated:22/07/2013..
3) Revised c.c. Issued By VVCMC No. VVCMC/TP/RDP/VP- 0147/0147/2012-13, Dated:14/12/2012.
4) Certificate from License Agency M/s Sadanand fire controls , Dated:08/01/2014.. (Form A)
5) Building Completion certificate No. VVCMC/TP/VP-0147 of MR.Abhay Raut Architect, Dated:22/07/2013.
6) Built up area certificate No. VVCMC/TP/VP-0147 of MR.Abhay Raut Architect, Dated:22/07/2013...
7) Structure Stability certificate No. VVCMC/TP/AM/BP-2762/VP-0147/W/VP-0147/04/2010-11 of M/s. –Nimisha structurel Design Academy Dated:15/12/2012.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 132271&132272 Dated:10/07/2013..

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your-School Building at above mentioned address. As per c.c issued by VVCMC No. VVCMC/TP/RDP/VP0147/0147/2012-13, Dated:14/12/2012.The party has constructed **"School Building G+5 Floors"** as per sanctioned Plan.

With reference to above on Dated: 11/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. Sadanand fire controls **bearing License No. MFS-LA/F-216dated 1/05/ 2013 issued by this office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A)Vertical Wet Riser Down Comer Hydrant System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace 1 nos
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Main Pump 1 nos
e) Jockey pump 1 nos
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants
D) Siamese connection

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 7260.69 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

Recd:

The Party has paid already paid the Rs.5,00,000/- vide Receipt No. 187117 Dated 16/06/2014 DD.NO.106855& Rs.5,00,000/- vide Receipt No. 187118 Dated 16/06/2014 DD.NO.106856 Capitation & Scrutiny fees for the total gross built up area 7266.67 Sq.Mtr. as per the letter given by the party Dated -16/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 02/2014 DATE: 18/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial Bilding on Land bearing S.No.72+75/1+75/2+77/1(p)+ 77/2+65+69/1+70+71(p)+78+213/2(p) at village - Pelhar, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/658/2013- 14 Dated:03/06/2013
2) An application received by M/s. Himesh Gupta & Associates , Dated:26/08/2013..
3) plinth completion Issued By VVCMC No. VVCMC/TP/PCC/VP- 0833/559/2012-13, Dated:25/03 /2013..
4) Certificate from License Agency M/s Fire work Engineering, Dated:31/03/2014.. (Form A)
5) Building Completion certificate No. VP-o833/ of M/s. Himesh Gupta & Associates Architect, Dated:26/08/2013.
6) Built up area certificate No. VP-0833 of M/s Himesh Gupta & Associates Architect, Dated:18/06/2014..
7) Structure Stability certificate No. VP-833 of M/s. Rajesh I.Ankleshwaria, Dated:14/08/2013.
9) This office Provisional No objection Certificate No. VVCMC/FIRE/ 132 /2012-13 Dated:18/10/2012

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Industrial** Building at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e.M/s. Fire work Engineering **bearing License No. MFS-LA/F-0227 dated -16.08. 2013 issued by this office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to-2515.21 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Received & Dated 18/6/14

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 003/2014 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial building known as 'GLORY' Wing A (Type N), Wing B (Type O) and Wing C (Type P) in the project known as ' VIVA GOKUL COMPLEX' on Land bearing S.No. 334, at Village- Bolinj, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1348/2014 Dated:20/06/2014
2) An application received by M/s. Viva Gokul Builders, Dated:20/06/2014
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-3357/w/3741, Dated:21/05 /2009
4) Certificate from License Agency Shri Sainath Enterprises, Dated:01/05/2014 (Form A)
5) Building Completion certificate & Built up area certificate of Shah Cattani Consultants Dated:13/06/2014
6) Structure Stability certificate Shah Cattani Consultants Dated:13/06/2014
7) License to work the Lift From Govt. of Maharashtra Industries, License no.130601,130602,130603 Dated 24 /05/2013..,

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential / Residential Cum Commercial building known as 'GLORY' Wing A (Type N), Wing B (Type O) and Wing C (Type P) in the project known as ' VIVA GOKUL COMPLEX'** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/RDP/BP-3357/w/3741, Dated:21/05 /2009. The party has constructed **"Residential / Residential Cum Commercial building known as 'GLORY' Wing A (Type N), Wing B (Type O) and Wing C (Type P) in the project known as ' VIVA GOKUL COMPLEX" Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **Shree Sainath Enterprises Engineers & Contractors bearing License No. MFS-LA/RF-0076, issued by this office and has submitted on dated 01/05/2014 Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser with Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **6064.29** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.5,20,800/- vide Receipt No. 187138 Dated 20/06/2014 & DD No.39661 Axis Bank for the total gross built up area **6064.29** Sq.Mtrs as per the letter given by the party Dated 20/06/2014.

Receiving

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 004/2014 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL WITH CUM COMMERCIAL BUILDING Wing A (Type 6), Wing B (Type 6), & Wing C (Type 2A) , Wing D (Type 5), Wing E (Type 5), Wing F (Type 3) , (Project- VRINDAVAN TOWNSHIP) on Land bearing S.No.354 & S.No. 383, at village Bolinj, Tal. Vasai, Dist- Thane.

Ref:- 1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1347/2014 Dated:20/06/2014.
2) An application received by M/s. Shah Gatani Consultant / Tanay Developers, Dated:-20/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/AM/BP-3022 & 3466/W/ W/ 2614, Dated:-13/02/2009.
4) Certificate from License Agency M/s. Shree Sainath Enterprises Engineers & Contractors, Dated: 05/05/2014. (Form A)
5) Building Completion certificate of M/s. Shah Gatani Consultant , Dated:-13/06/2014
6) Built up area certificate No. of M/s. Shah Gatani Consultant , Dated:-13/06/2014
7) Structure Stability certificate of M/s. Shah Gatani Consultant , Dated:-13/06/2014
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 120898, 120899, 120897 Dated:-03/05/2013., 135493, 135494, Dated:-24/10/2014. 139171, Dated:-20/01/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL WITH CUM COMMERCIAL BUILDING Wing A (Type 6), Wing B (Type 6), & Wing C (Type 2A) , Wing D (Type 5), Wing E (Type 5), Wing F (Type 3) ,** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/AM/BP-3022 & 3466/W/ W/ 2614, Dated:-13/02/2009.** The party has constructed **"RESIDENTIAL WITH CUM COMMERCIAL BUILDING G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. **Shree Sainath Enterprises Engineers & Contractors bearing License No. MFS-LA/RF-0076, dated 01/05/2014 issued by this office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser with Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **4566.66 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Received

The Party has paid already paid the Rs.6,60,000 /- vide Receipt No. 187137, Dated 20/06/2014.DD.bearing No. 039660 Issued by Axis Bank Ltd., in favour of VVCMC additional Capitation & Scrutiny fees for the total gross Construction area 4566.66 Sq.Mtrs. as per the letter given by the party Dated 13/01/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 005/2014 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL BUILDING No.2,WING -C on land bearing S.No. 347 A, H.No.6,7 & 8 of village Boling, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1346/ 2014 Dated: 20 / 06 / 2014.
2) An application received by M/s. Star Builders &developers Dated:20/06/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP- 0412/110, Dated:-5/9/2012.
4) Certificate from License Agency M/s. Shri Sainath Enterprises, Dated:01/05/2014 (Form A)
5) Building Completion certificate of M/s . Abhay Raut Architect , Dated:-28/08/2013.
6) Built up area certificate No.VVCMC/TP/ VP-0412, of M/s . Abhay Raut Architect , Dated:-16/06/2014.
7) Structure Stability certificate Harish I. Patel, Dated:18/04/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 133015, Dated:-08/07/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL BUILDING No.2,** Building at above mentioned address. As per c.c issued by VVCMC/TP/CC/VP- 0412/1309, Dated:-15/10/2011.The party has constructed **"RESIDENTIAL BUILDING No.2, Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: -18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Shri Sainath Enterprises,bearing License No. MFS-LA/RF-0076, issued by this office and has submitted Certificate of dated o1/05/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 1617.37 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,20,000 /- vide Receipt No. 187103, Dated 15/04//2014.DD.bearing No. 002707, Issued by the Shamrao Vittal co.op.Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **1617.37** Sq.Mtr. as per the letter given by the party Dated 15/4/2914.

Received

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

25/6/2019

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 006/2014 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building 7 Wings on Land bearing S.No.338/A2 ,at New Virar NallaSopara, Link Road, Virar (E) Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1263/2014 Dated:17/06/2014
2) An application received by M/s. V.M.S enterprises, Dated:06/02/2014
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-2853/E/948, Dated:07/07/2010
4) Certificate from License Agency M/s Fire Works Engineering, Dated:31/03/2014.. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. J.P. Mehta Associates Dated:-1/02/2014.
6) Structure Stability certificate M/s. J.P. Mehta Associates Dated:-1/02/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License no.135758,135753, Dated 30/10/2013, 137477,137478, 137479,137476 Dated 26/12/2013., 137335 Dated 19/12/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building 7 Wings** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/RDP/BP-2853/E/948, Dated:07/07/2010. The party has constructed **"Residential Cum Commercial Building 7 Wings Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. M/s.Fire Works Engineering **bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 31/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP- 7 No.
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump- 50 HP-1 No.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to12615.496 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.5,60,000/- vide Receipt No. 187135 Dated 19/6/2014 & DD No. 121789 Corporation Bank.& Rs.6,00,000/- vide Receipt No. 187136 Dated 19/6/2014 & DD No. 121790 Corporation Bank for the total gross built up area 12615.496 Sq.Mtr. as per the letter given by the party Dated 19/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

CIPAL CORPORATION
ED

27/06/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 007/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residincial Cum Commercial Bilding No.1 Wing A,B & C & Bilding No.2 Wing A,B ,C & D & Residincial Wing E on Plot bearing S.No. 97/1/2+4/6/2+4/7/3+4/12/2+4/13/2+4/15(p), S.No.97,H.No. 2, 5 at village Waliv ,Tal-Vasai, Dist- Thane.

Ref :-
1. **A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1171 / 2014, Dated:-10/06/2014.**
2. **An application received by M/s. Himesh Gupta & Associates, Dated: 25/02/2014.**
3. **Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0800 / 0233 / 2012-13. Dated: 16/03/2013.**
4. **Certificate from License Agency M/s, Fire worx Engineering, Dated: 18/06/2014 (Form A).**
5. **Building Completion certificate No. VP-0800, of M/s. Himesh Gupta & Associates, ,Dated:25/02/2014.**
6. **Built up area certificate No. VP-0800, of M/s. Himesh Gupta & Associates, ,Dated:24/06/2014.**
7. **Structure Stability certificate No. VP/ 0800 of M/s. umesh d tayshetye, Dated:28/08/2013.**
8. **License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 141798, 141799, 141800, Dated:- 28/05/2014. & No.136528, 136519, 136520, 136521, 136522. Dated:- 08/05/2013.**
9. **This office Provisional No objection Certificate No. VVCMC / FIRE / 223/ 2012-13, Dated:29/01/2013.**

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residincial Cum Commercial Bilding No.1 Wing A,B & C & Bilding No.2 Wing A,B ,C & D & Residincial Wing E** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 18/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 5216.91&7008.55 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Rec 25/06/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 008/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Automobile Shops & Godowns Unit No. 06 on land bearing S.No.72+75/1+75/2+77/1 (pt) -77/2+65+69/1+78+213/2 (pt) , of village Pelhar, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1201/ 2014 Dated: 11/ 06 / 2014.
2) An application received by M/s. Himesh Gupta & Associates, Dated:26/02/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP - 0898/660/2012-13,Dated:-07/06/2012.
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:31/03/2014. (Form A)
5) Building Completion certificate No. VVCMC/TP/CC/VP - 0898/660/2012-13, of M/s . Himesh Gupta & Associates, Dated:-25/02/2014.
6) Consturction area certificate No. VVCMC/TP/CC/VP - 0898/660/2012-13,Of M/s . Himesh Gupta & Associates, Dated:-25/02/2014.
7) Structure Stability certificate of M/s. Umesh D. Tayshetye Sturctural Engineer, Dated:-28/02/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Automobile Shops & Godowns Unit No. 06 on land bearing S.No.72+75/1+75/2+77/1 (pt) - 77/2+65+69/1+78+213/2 (pt)** Building at above mentioned address. As per c.c issued by **VVCMC/TP/CC/VP - 0898/660/2012-13,Dated:-07/06/2012.** The party has constructed **"Automobile Shops & Godowns Unit No. 06 , G Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, issued by this office and has submitted Certificate of dated 31/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor Hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Control Panel for Pump-1 No.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 244.59 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 80,000 /- vide Receipt No. 187142, Dated 21/06/2014. DD.bearing No. 542575, dated: 14/06/2014. Issued by Bank Of Baroda ., Mumbai in favour

Rec
25/06/14

of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to 244.59 Sq.Mtrs** as per the letter given by the party Dated 21/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 009/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building Type KG1, Wing A,& Residential Building KG1 Wing B &C IN AVENUE-A3B, Know as "Bachraj paradise" Global City, On plot Bearing S.No.5,5B,5D,5F, at village Dongre, Virar (w), Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1299 / 2014, Dated:- 19/06/2014.
2. An application received by M/s. Shah Gattani Consultants , Dated: 15/03/2014..
3. Revised c.c. Issued By VVCMC No. VVCMC / AM / VP/0453/0296/2011-12, Dated: 31/03/2012.
4. Certificate from License Agency M/s, Sadanand Fire Controls, Dated: 18/03/2014. (Form A).
5. Building Completion certificate of M/s. Shah Gattani Consultants, Dated: 15/03/2014.
6. Built up area certificate of M/s. Shah Gattani Consultants, Dated:15/03/2014.
7. Structure Stability certificate of M/s. Shah Gattani Consultants, Dated: 15/03/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 139199,139197,139198 Dated: 20/01/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE /206G / 2011-12, Dated:30/03/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building Type KG1, Wing A,& Residential Building KG1 Wing B &C IN AVENUE-A3B,** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Sadanand Fire Controls bearing License No. MFS-LA/F- 216, dated 01/05/2013 issued by this office and has submitted Certificate On 18/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 8237.58Sq. Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 010/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL BUILDING No.2, on land bearing S.No. 347 A, H.No.6,7 & 8 of village Boling, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1341/ 2014 Dated: 20 / 06 / 2014.
2) An application received by M/s. Abhay Raut Architect/ Ashthavinayak Builders, Dated:22/05/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP- 0412/1309, Dated:-15/10/2011.
4) Certificate from License Agency M/s. Sadanand Fire Controls, Dated:25/04/2014. (Form A)
5) Building Completion certificate of M/s . Abhay Raut Architect , Dated:-13/03/2014..
6) Built up area certificate No.VVCMC/TP/ VP-0412, of M/s . Abhay Raut Architect , Dated:-13/03/2014.
7) Structure Stability certificate No. VVCMC/TP/CC/VP- 0412/W/1307 of M/s. Harish I. Patel, Dated:18/04/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 139464, Dated:-07/02/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL BUILDING No.2,** Building at above mentioned address. As per c.c issued by VVCMC/TP/CC/VP- 0412/1309, Dated:-15/10/2011.The party has constructed **"RESIDENTIAL BUILDING No.2, Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Sadanand Fire Controls bearing License No. MFS-LA/F-216, dated 01/05/2013 issued by this office and has submitted Certificate of dated 25/05/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 1297.26 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,20,000 /- vide Receipt No. 169223, Dated 10/03//2014.DD.bearing No. 100065, dated: 04/03/2014. Issued by Bank & Branch Vasai Janta Sahakari Bank Ltd., Virar (E) in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **1297.26** Sq.Mtr. as per the letter given by the party Dated 10/03/2014.

25/06/14

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

NICIPAL CORPORATION
E
AED
ie.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 011/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL BUILDING Type Z-740, on land bearing New S.No. 1,2,3,4, S.No. 101,103,104,106,104 of village Gokhiware, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1339/ 2014 Dated: 20 / 06 / 2014.
2) An application received by M/s. Shah Gatani Consultants, Dated:23/04/2014..
3) Revised c.c. Issued By CIDCO/,VVSR/RDP/BP/ZCC-20/E/124, Dated:-20/04/2010.
4) Certificate from License Agency M/s. Sadanand Fire Controls, Dated:29/03/2014. (Form A)
5) Building Completion certificate of M/s . Shah Gatani Consultants, Dated: 29/03/2014.
6) Built up area certificate of M/s . Shah Gatani Consultants, Dated: 29/03/2014.
7) Structure Stability certificate of M/s . Shah Gatani Consultants, Dated: 29/03/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 140599, Dated:-25/03/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL BUILDING Type Z-740,** Building at above mentioned address. As per c.c issued by **CIDCO/,VVSR/RDP/BP/ZCC-20/E/124, Dated:-20/04/2010.** The party has constructed **"RESIDENTIAL BUILDING Type Z-740, Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Controls bearing License No. MFS-LA/F-216, dated 01/05/2013 issued by this office and has submitted Certificate of dated 29/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 1416.29 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.2,00,000 /- vide Receipt No. 187102, Dated 15/04/2014 & .DD.bearing No. 017874, Issued by Bassein Catholic Co-Op Bank Ltd., Gokhiware in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **1416.29 Sq.Mtrs.** as per the letter given by the party Dated 15/04/2014.

25/06/14

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

25/6/2019

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

NICIPAL CORPORATION
'E
IED
e.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 012/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential Cum Commercial building Type T1-08,S1-39,Y1-10 in Avenue 'J' , Type T1-31, S1-40 Avenue 'J' & Type U2-15 Avenue 'M' known as 'GLOBAL CITY' on Land bearing New S.No.5, 5B, 5F, 5G, 5D at Village- Dongre, Virar (W), Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1343/2014 Dated:20/06/2014
2) An application received by M/s. SHAH GATTANI CONSULTANTS, Dated:20/06/2014
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-3519/W/4122, Dated:15/06 /2009
4) Certificate from License Agency M/s Sadanand Fire Controls, Dated:01/05/2013 (Form A)
5) Building Completion certificate & Built up area certificate of M/s. SHAH GATTANI CONSULTANTS, Dated:-10/10/2013 & Dated- 17/10/2013.
6) Structure Stability certificate M/s. JW Consultants LLP Dated:-05/05/2012.& Mahimtura Consultants pvt.Ltd. Dated- 05/05/2012
7) License to work the Lift From Govt. of Maharashtra Industries, License no.137225,137226 Dated 12/12/2013, 136538,136544 Dated 08/11/2013., 132393 Dated 15/07/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential Cum Commercial building Type T1- 08,S1-39,Y1-10 in Avenue 'J' , Type T1-31, S1-40 Avenue 'J' & Type U2-15 Avenue 'M' known as 'GLOBAL CITY'** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/RDP/BP-3519/W/4122, Dated:15/06 /2009. The party has constructed **"Residential Cum Commercial building Type T1- 08,S1-39,Y1-10 in Avenue 'J' , Type T1-31, S1-40 Avenue 'J' & Type U2-15 Avenue 'M' known as 'GLOBAL CITY' Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. M/s Sadanand Fire Controls **bearing License No. MFS-LA/F-0216, Dated 01/05/2013. issued by this office and has submitted Certificate on dated 13/12/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Wet Riser Down Comer Hydrant System
2) Courtyard single hydrant valve
3) Internal single landing valve
4) Hose reel drum set
5) Hose box set
6) Siamese connection
7) Booster main pump
8) Hydrant main pump
9) ABC type fire extinguishers 5kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **Type T1- 08,S1-39,Y1-10 in Avenue 'J', 4338.73** Sq.Mtrs.& **Type T1-31, S1-40 Avenue 'J' & Type U2-15 Avenue 'M' 4212.81 sq.mt.** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained,

25/6/14

retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.293623/- vide Receipt No. 187151 Dated - 23/06/2014 & DD No. 758283 of HDFC- Bank & Rs.184249/- vide Receipt No. 187152 Dated - 23/06/2014 & DD No. 758284 of HDFC- Bank & Rs.182990/- vide Receipt No. 187153 Dated - 23/06/2014 & DD No. 758285 of HDFC- Bank & Rs.476613/- vide Receipt No. 187150 Dated - 23/06/2014 & DD No. 758285 of HDFC- Bank for the total gross built up area **11639.60** Sq.Mtrs & **2043.54sq.mt.** Sq.Mtr. as per the letter given by the party Dated 19/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 013/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building, Building No-1 Wing A on Land bearing S.No. 73, H.No. 3, S.No.74, H.No.12, 13, 14/2 & 15, S.No.75, H.No.2 at village Chulne ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1364 / 2014, Dated:- 21/06/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 19/06/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP- 598/099/ 2013-14. Dated: 14/06/2013.
4. Certificate from License Agency M/s, Fire Works, Dated:20/06/2014 (Form A).
5. Building Completion certificate No. VP-0598/78 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated: 22/04/2014.
6. Built up area certificate No. VP-0598/79/ of M/s. Sanjay Narang & Associates, Dated: 22/04/2014.
7. Structure Stability certificate of M/s. Epicons Consultants pvt. ltd, Dated: 22/04/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 143162, Dated:14/06/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 199 / 2012-13, Dated: 10/01/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building, Building No-1 Wing A** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Works, bearing License No. MFS-LA/F-o227, dated -16/08/2013 issued by this office and has submitted Certificate on20/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 3694.69 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

25/06/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 014/2014-15 DATE: 25/oc/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residincial Bilding No.6 Wing E,F,G & H on Land bearing S.No.177, H.No.1, 2 S.No.81 H.No.1B, S.No.182 at village Nilemore ,Tal-Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1204 / 2014, Dated:-13/06/2014.
2. An application received by M/s. Himesh Gupta & Associates, Dated: 29/10/2013.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0335 / 128 / 2011-12. Dated: 03/10/2011.
4. Certificate from License Agency M/s, Fire Worx Engineering, Dated: 31/03/2014 (Form A).
5. Building Completion certificate No. VP-0335, of M/s. Himesh Gupta & Associates, ,Dated:17/10/2013
6. Built up area certificate No. VP-0335 of M/s. Himesh Gupta & Associates, Dated: - 24/06/2014
7. Structure Stability certificate No. VP0335 of M/s. umesh d tayshetye, Dated:17/10/2013.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 135551, & No. 135554, Dated:- 24/10/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 95 / 2012-13, Dated:04/09/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residincial Bilding No.6 Wing E,F,G & H** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 31/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 8836.02Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 015/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residincial Building Type-RSA1-5 Wing A IN AVENUE A1 Of Group Housing Scheme On New S.No.5,5B,5F,5G,5D, at village Dongre, Virar (w), Tal- Vasai, Dist- Thane.

Ref :-
1. **A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1306 / 2014, Dated:- 19/06/2014.**
2. **An application received by M/s. Shah Gattani / Kamaya Creeyetion Consultants , Dated: 20/02/2014.**
3. **Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP/0453/0229/2012-13 .Dated: 14/03/2013**
4. **Certificate from License Agency M/s, fire worx Engineering, Dated:20/06/2014 (Form A).**
5. **Building Completion certificate of M/s. Shah Gattani Consultants, Dated: 20/02/2014.**
6. **Built up area certificate of M/s. Shah Gattani Consultants, Dated:20/02/2014.**
7. **Structure Stability certificate of M/s. Shah Gattani Consultants, Dated: 20/02/2014.**
8. **License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 139110 Dated: 20/01/2014.**
9. **This office Provisional No objection Certificate No. VVCMC / FIRE /110 / 2012-13, Dated:27/09/2012.**

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residincial Building Type-RSA1-5 Wing A IN AVENUE A1** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. , fire worx Engineering bearing License No. MFS-LA/F- 0227 issued by this office and has submitted Certificate on 20/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 2337.20 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Rec
25/06/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 016/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No. 14 Wing A & B on Land bearing S.No.205 A , H.No. 1/1, 1/2, 2 to 5, 7 to 9, 11to 29 at Village Bolinj Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/108/2014 Dated:-10/06/1014.
2) An application received by M/s. sanat Mehta & Associates, Dated:20/02/2013
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-0108/070/2011-12, Dated:02/08/2011.
4) Certificate from License Agency M/s. Aayush Fire & safety services. Dated:05/07/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. sanat Mehta & Associates, Dated:-20/12/2013.
6) Structure Stability certificate M/s. A-CUBE CONSULTANT,Dated:-20/12/2014
7) License to work the Lift From Govt. of Maharashtra Industries, License no.135340, 135339,Dated 15/11/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No. 14 Wing A & B** Building at above mentioned address. As per c.c issued by CIDCO/ VVSR/RDP/BP-0108/070/2011-12, Dated:02/08/2011.The party has constructed **"Residential Cum Commercial Building No. 14 Wing A & B, Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2012 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. M/s. M/s. Aayush Fire & safety services **bearing License No. MFS-LA/F-0132, MFS-LA/D-19 issued by this office and has submitted Certificate on dated 05/07/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on 450 LPM.
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump- 1800 LPM.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to12615.496 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.25000/- vide Receipt No. 24136 Dated -23/12/2009.& Rs.-1700/- vide Receipt No. -26294Dated -13/05/2010 & Rs.-213300/- vide Receipt No. -112137Dated -13/06/2011 for the total gross built up area -2828.33 Sq.Mtr. as per the letter given by the party .

25/6/14

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGADE
Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 017/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building, Wing A,&B on Land bearing S.No.139, H.No. 2,3 , at village Virar ,Tal- Vasai, Dist-Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1365 / 2014, Dated:- 21/06/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 21/06/2014..
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0045/ 078 / 2013-14. Dated: 31/05/2013.
4. Certificate from License Agency M/s, Ronak Fire Industries, Dated:23/06/2014 (Form A).
5. Building Completion certificate No. VP-0045/49 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:21/06/2014
6. Built up area certificate No. VP-0045/49 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:21/06/2014..
7. Structure Stability certificate No. VP0045/44 of M/s. Sanjay Narang & Associates, Dated:23/06/2014.
8. This office Provisional No objection Certificate No. VVCMC / FIRE / 20 / 2012-13, Dated:01/06/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building, Wing A & B** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Ronak Fire Industries bearing License No. MFS-LA/RF/0157, dated 18/07/2013 issued by this office and has submitted Certificate on23/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 2719.58 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 018/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING on Land bearing S.No.59(29)/1/3 , S.NO. 61(15)/1, at village Achole ,Tal- Vasai, Dist-Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1298 / 2014, Dated:- 19/06/2014.
2. An application received by M/s. Shah Gattani Consultants , Dated: 14/05/2013.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP /ZCC-20/E/ VP-0743 / 0109 / 2011-12 .Dated: 15/10/2011.
4. Certificate from License Agency of M/s, Fire Ext. Engineering, Dated:10/05/2013 (Form A).
5. Building Completion certificate of M/s. Shah Gattani Consultants , Dated: 15/04/2013.
6. Built up area certificate of Shah Gattani Consultants, Dated: 15/04/2013.
7. Structure Stability certificate No. Shah Gattani Consultants, Dated:14/05/2013.
8. License to work the Lift From Govt. of Maharashtra Industries, Licence, No. 135549,135548
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 38 / 2013-14, Dated:29/04/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your RESIDENTIAL CUM COMMERCIAL BUILDING at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Ext. Engineering,License No. MFS-LA/ 0001/F-0028, dated 10/05/2013, issued by this office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009**, this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 4243.09 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

25/06/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 019/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building, Building no-2 Wing A,&B on Land bearing S.No.139, H.No. 2,3 , at village Virar ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1379 / 2014, Dated:- 21/06/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 20/06/2014..
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0895/ 047 / 2012-13. Dated: 22/05/2012.
4. Certificate from License Agency M/s, Ronak Fire Industries, Dated:23/06/2014 (Form A).
5. Building Completion certificate No. VP-0895/98 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:12/06/2014
6. Built up area certificate No. VP-0895/97 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:12/06/2014..
7. Structure Stability certificate No. VP-0895/100 of M/s. Sanjay Narang & Associates, Dated:12/06/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 140645,140644,Dated:28/03/2014
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 197 / 2011-12, Dated:22/03/2012

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building, Wing A & B** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Ronak Fire Industries bearing License No. MFS-LA/RF/0157, dated 18/07/2013 issued by this office and has submitted Certificate on23/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009**, this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 6845.39 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to the Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

25/6/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 020/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residincial Bilding Wing A & B on Land bearing S.No.10, H.No. 2/3 at village Nilemore ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1202 / 2014, Dated:- 11/06/2014.
2. An application received by M/s. Himesh Gupta & Associates, Dated: 13/01/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0087 / 0180 / 2013-14. Dated: 18/07/2013.
4. Certificate from License Agency M/s, Aayush Fire & Safety Services, Dated: 16/06/2014 (Form A).
5. Building Completion certificate No. VP-0087, of M/s. Himesh Gupta & Associates, ,Dated:13/01/2014
6. Built up area certificate No. VP-0087 of M/s. Himesh Gupta & Associates, Dated: 13/01/2014.
7. Structure Stability certificate No. VP0087 of M/s. A-CUBE Consultant, Dated:13/01/2014
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 132585, Dated:- 23/07/2013. & No. 120905, Dated:- 03/05/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 05 / 2011-12, Dated:17/09/2011.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residincial Bilding Wing A & B** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Aayush Fire & Safety Services bearing License No. MFS-LA/RF- 0132, & MFS-LA/D- 191, dated 16/06/2014, issued by this office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 4962.42 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

25/6/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 021/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL BUILDING Type SR2 (Wing B & C) Known as ' Ornate Classic' on land bearing S.No. 1,2,3,4, Of Vilage: Achole, S.No. 101,103,104, 106, 107 of village:Gokhiware, Tal. Vasai, Dist- Thane. S.No. 254, H.No. 3,6,7/1,7/2,13, 14,15 & 16 of Village: Achole, S.No. 128, H.No.8/1, of Village: Gokhiware, Tal: Vasai, Dist:Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1371/ 2014 Dated: 21/ 06 / 2014.
2) An application received by M/s. Shah Gattani Consultants, Dated: 18/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0743, VP-0184, VP-0459,VP-0319,VP-732/053/2012-13., Dated: 22/05/2014.
4) Certificate from License Agency M/s. Sadanand Fire Controls, Dated: 18/06/2014 (Form A)
5) Building Completion certificate of M/s . Shah Gattani Consultants, Dated: 18/06/2014.
6) Builtup area certificate of M/s . Shah Gattani Consultants, Dated: 18/06/2014.
7) Structure Stability certificate of M/s. Shah Gattani Consultants, Dated: 18/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 141055,Dated:- 17/04/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL BUILDING Type SR2 (Wing B & C) Known as ' Ornate Classic'** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0743, VP-0184, VP-0459,VP-0319,VP-732/053/2012-13., Dated: 22/05/2014.** The party has constructed **"RESIDENTIAL BUILDING, G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s Sadanand Fire Controls bearing License No. MFS-LA/RF-216, Dated: 01/05/2014 issued by this office and has submitted Certificate of dated 18/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Wet Riser Down Comer Hydrant System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Hydrant Main Pump
   e) Internal Single Hydrant Valve:-14 Nos
   d) Siamese Conection
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants:-04 Nos

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to 3251.00 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 2,40,000 /- vide Receipt No. 11977, Dated 06/11/2012., DD.bearing No. 272967, Bank of India. Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to 3251.00 Sq.Mtrs.** as per the letter given by the party Dated: 23/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/022/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING Type SR1 (Wing A) & RESIDENTIAL BUILDING Type SR2 (Wing A) known as 'SHEETAL DHAM' on land bearing S.No.1,2,3,4 of village Achole, S.No. 101,103,104,106,107 of village- Gokhiware,Tal. Vasai, Dist- Thane, S.No. 254, H.No.3,6,7/1,7/2,13,14,15 & 16 of village Achole, S.No.128, H.No.8/1 of village- Gokhiware, Tal- Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1340/ 2014 Dated: 20/ 06 / 2014.
2) An application received by M/s. SHAH GATTANI Consultant, Dated: 03/03/2014.
3) Revised c.c. Issued By VVMC/TP/RDP/VP-0743, VP-0184, VP-0459, VP-0319, VP732/053/2012-13, Dated:-22/05/2012
4) Certificate from License Agency M/s. Sadanand Fire Controls, Dated:01/05/2013 (Form A)
5) Building Completion certificate of M/s . SHAH GATTANI Consultant, Dated: 03/03/2014.
6) Builtup area certificate M/s.SHAH GATTANI Consultant, Dated: 03/03/2014
7) Structure Stability certificate of M/s. SHAH GATTANI Consultant, Dated: 03/03/2014
8) License to work the Lift From Govt. of Maharashtra Industries, License No.135162,135163 Dated:- 5/10/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING Type SR1 (Wing A) & RESIDENTIAL BUILDING Type SR2 (Wing A) known as 'SHEETAL DHAM'** Building at above mentioned address. As per c.c issued by **VVMC/TP/RDP/VP-0743, VP-0184, VP-0459, VP-0319, VP732/053/2012-13, Dated:-22/05/2012.** The party has constructed **"RESIDENTIAL CUM COMMERCIAL BUILDING Type SR1 (Wing A) & RESIDENTIAL BUILDING Type SR2 (Wing A) known as 'SHEETAL DHAM', G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s Sadanand Fire Controls bearing License No. MFS-LA/F216,Date- 01/05/2013 issued by this office and has submitted Certificate of dated 03/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) vertical wet riser Down Comer System for wing
   a) on every floor hose reel set & landing fire Hydrant valve for each wing.
   b) Booster pump on terrace level for each wing
   c) Siamese connection, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump on ground level
B) Fire Extinguishers
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to RESIDENTIAL CUM COMMERCIAL BUILDING Type SR1 (Wing A) Resi Builtup 1035.20 Sq.Mtrs., Comm. Built up 116.82 Sq.Mtrs., RESIDENTIAL BUILDING Type SR2(Wing A) Resi Builtup 2009.39 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the (**RESIDENTIAL CUM COMMERCIAL BUILDING Type SR1 (Wing A)** Rs. 2, 00,000 /- vide Receipt No. 169204, Dated 27/12/2013., DD.bearing No. 089956,& (**RESIDENTIAL BUILDING Type SR2(Wing A)** Rs. 1, 20,000 /- vide Receipt No. 169205, Dated 27/12/2013., DD.bearing No. 089955, Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to** (**RESIDENTIAL CUM COMMERCIAL BUILDING Type SR1 (Wing A) Resi Builtup 1035.20 Sq.Mtrs., Comm. Built up 116.82 Sq.Mtrs.,** (**RESIDENTIAL BUILDING Type SR2(Wing A) Resi Builtup 2009.39 Sq.Mtrs**. as per the letter given by the party Dated 27/12/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

25/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 023/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of CFC BUILDING on land bearing S.No. 59,H.NO.1,2/1,2/2,2/3,3,4,5,6,7,9,10,11,12/1,12/2,13,14&15,S.NO-62,H.NO-4 At village-chulne .Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1344/ 2014 Dated: 20 / 06 / 2014.
2) An application received by M/s. EN CON CONSULTANTS, Dated:19/06/2014..
3) Revised c.c. Issued By CIDCO/VVSR/SR/CC/BP-3870/W/1560 Dated:-24/06/2008.
4) Certificate from License Agency M/s. Sadanand fire controls, Dated:19/06/2014. (Form A)
5) Building Completion certificate of M/s . EN CON CONSULTANTS, Dated: 19/06/2014
6) Built up area certificate of M/s . EN CON CONSULTANTS, Dated: 19/06/2014.
7) Structure Stability certificate of M/s .SANJAY NARANG & ASSOCIATES, Dated: 19/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 137230 Dated:-12/12/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **CFC BUILDING,** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/SR/CC/BP-3870/W/1560 Dated:-24/06/2008.** The party has constructed **"CIDCO/VVSR/SR/CC/BP-3870/W/1560 Dated:-24/06/2008. Building S+ 2 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Controls bearing License No. MFS-LA/F-0216, dated 01/05/2014 issued by this office and has submitted Certificate of dated 19/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical riser cum Down Comer System
- a) on every floor hose reel hose & landing valve / Hydrant valve
- b) Booster pump on terrace- 1 NOs
- c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe
- d) main pump- 1 NOs

B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 564.98 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.40,000 /- vide Receipt No. 187128, Dated 19/06/2014 & .DD.bearing No. 010860, Issued by Basin catholic Bank& Rs.40,000 /- vide Receipt No. 187129, Dated 19/06/2014 & .DD.bearing No. 010859, Issued by Basin catholic Bank .in favour of

VVCMC additional Capitation & Scrutiny fees for the total Built up area 564.98 **Sq.Mtrs.** as per the letter given by the party Dated 20/11/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGADE
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 024/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential building Type-G Known as 'Jyoti Basera' on Land bearing S.No. 1,2,3,4 of village- Achole, S.No. 101,102,103,104,106,107 of village- Manikpur, S.no. 97B, 105B,106B , of village Gokhiware, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1345/ 2014 Dated: 20/ 06 / 2014.
2) An application received by M/s. Shah Gattani Consultants, Dated:05/02/2014.
3) Revised c.c. Issued By –CIDCO/VVSR/AM/BP/-ZCC-20/E/771,Dated:- 30/11/2004
4) Certificate from License Agency M/s –Sadanand Fire Controls , Dated:01/05/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. Shah Gattani Consultants, Dated:12/12/2013.
6) Structure Stability certificate of M/s. Shah Gattani Consultants, Dated:12/12/2013.
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 135439, 135438 Dated:19/10/2013.,

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential building Type-G Known as 'Jyoti Basera'.** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/AM/BP/-ZCC-20/E/771,Dated:- 30/11/2004.** The party has constructed **"Residential building Type-G Known as 'Jyoti Basera', G +7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Controls bearing License No. MFS-LA/F-216, Dated- 01/05/2013. issued by this office and has submitted Certificate of dated 12/12/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical wet Riser Down Comer Hydrant System
2. Courtyard Single Hydrant Valve
3. Internal Single Landing Valve
4. Hose reel drum set
5. Hose box set
6. Siamese Connection
7. Booster Pump on Terrace Level
8. ABC Type Fire Extinguishers 5kg Capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 2495.92 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 2,40,000 /- vide Receipt No. 169206, Dated 04/01/2014, DD.bearing No. 942262 Issued by Union Bank fees for the total Construction area admeasuring **to 2495.92 Sq.Mtrs** as per the letter given by the party Dated 04/01/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/025/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERTIAL BUILDING Type SR1 wing- c,Known As "VIMAL DARSHAN" on land bearing New S.No. 1,2,3,4, of village Achole. S.No. 101,103,104,106,107 of village Gokhiware, S.NO.254, H.No.3,6,7/1,7/2,13,14,15 &16 of village Achole, S.NO.128, H.NO.8/1 of village Gokhiware.Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1342/ 2014 Dated: 20 / 06 / 2014.
2) An application received by M/s. Shah Gatani Consultants, Dated:21/06/2014..
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0743,VP-0459,VP-0319,VP-732/053/2012-13, Dated:-22/05/2012.
4) Certificate from License Agency M/s. Sadanand fire controls, Dated:14/06/2014. (Form A)
5) Building Completion certificate of M/s . Shah Gatani Consultants, Dated: 14/06/2014
6) Built up area certificate of M/s . Shah Gatani Consultants, Dated: 14/06/2014.
7) Structure Stability certificate of M/s . Shah Gatani Consultants, Dated: 14/06/2014.
8) lift completion affidavit

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERTIAL BUILDING Type SR1 wing- c,Known As "VIMAL DARSHAN",** Building at above mentioned address. As per c.c issued by **CIDCO/,VVSR/RDP/BP/ZCC-20/E/124, Dated:-20/04/2010.** The party has constructed **"VVCMC/TP/RDP/VP-0743,VP-0459,VP-0319,VP-732/053/2012-13, Dated:-22/05/2012. Building S+G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Controls bearing License No. MFS-LA/F-0216, dated 01/05/2014 issued by this office and has submitted Certificate of dated 14/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical riser cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 1 NOs
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe
   d) main pump- 1 NOs
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 1354.77 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.2,00,000 /- vide Receipt No. 12080, Dated 20/11/2012 & .DD.bearing No. 801394, Issued by corporation Bank .in favour of VVCMC additional

Capitation & Scrutiny fees for the total Built up area **1354.77 Sq.Mtrs.** as per the letter given by the party Dated 20/11/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

25/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORRORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 026/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL WITH CUM COMMERCIAL BUILDING No.5 (Wings A,B,C & D) in sector V in ' Yeshwant Viva Township' on land bearing S.No.49,50,51,52,53,54,55,56 & S.No. 77 of village Achole, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1361/ 2014 Dated: 21/ 06 / 2014.
2) An application received by M/s. EN CON Consultant, Dated: 03/05/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-687/E/1036, Dated: 07/07/2010.
4) Certificate from License Agency M/s. Sadanand Fire Controls, Dated: 25/04/2014 (Form A)
5) Building Completion certificate No. CIDCO/VVSR/RDP/BP-687/E/1036, of M/s . EN CON Consultant, Dated: 03/05/2014.
6) Builtup area certificate No. CIDCO/VVSR/RDP/BP-687/E/1036, of M/s . EN CON Consultant, Dated: 03/05/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 138828,138833, 138824, 138842, Dated:- 25/11//2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL WITH CUM COMMERCIAL BUILDING No.5 (Wings A,B,C & D),** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/RDP/BP-687/E/1036, Dated:- 07/07/2010.** The party has constructed **"RESIDENTIAL WITH CUM COMMERCIAL BUILDING, G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s Sadanand Fire Controls bearing License No. MFS-LA/F-216, Dated: 01/05/2013 issued by this office and has submitted Certificate of dated 25/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Wet Riser Down Comer Hydrant System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Hydrant Main Pump
   e) Internal Single Hydrant Valve
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to Wing A:1597.25 Sq.Mtrs., Wing B:1190.28 Sq.Mtrs., Wing C:2263.87 Sq.Mtrs., Wing D:1692.25 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 8,00,000 /- vide Receipt No. 187114, Dated 12/06/2014., DD.bearing No. 039608, Axis Bank Ltd. Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to Wing A:1597.25 Sq.Mtrs., Wing B:1190.28 Sq.Mtrs., Wing C:2263.87 Sq.Mtrs., Wing D:1692.25 Sq.Mtrs.** as per the letter given by the party Dated: 03/05/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 027/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial building (Plot No.3) on land bearing S.No.77(pt) of village Waliv, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1413/ 2014 Dated: 24/ 06 / 2014.
2) An application received by M/s. EN CON Consultants, Dated:21/06/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP-5223/2001/2012-13,Dated:- 09/11/2012.
4) Certificate from License Agency M/s- Neo Enterprises, Dated:26/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-10/06/2014.
6) Structure Stability certificate of M/s. Sanjay Narang & Associates, Dated:-10/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial building (Plot No.3).** Building at above mentioned address. As per c.c issued by **VVCMC/TP/CC/VP-5223/2001/2012-13,Dated:- 09/11/2012.** The party has constructed **"Industrial building (Plot No.3), G +2/ (pt). Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185,Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 26/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 4" Raiser Ground + 2nd floor
2. Landing valve each floor
3. Courtyard Hydrant
4. Hose Reel Set
5. Branch pipe
6. Hose box
7. R.R.L 15 mts. Canvas hose pipe
8. Fire services inlet
9. Booster pump 5HP
10. Main Electrical pump 20HP
11. Fire extinguisher ABC – 5kg
12. Fire extinguisher Co2 – 3kg

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to 696.82 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

25/06/14.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40,000 /- vide Receipt No. 187166, Dated 24/06/2014, DD.bearing No. 877428 & Rs. 40,000 /- vide Receipt No. 187167, Dated 24/06/2014, DD.bearing No. 877429 Issued by Bharat Bank fees for the total Builtup area admeasuring **to 696.82 Sq.Mtrs** as per the letter given by the party Dated 21/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 028/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial building no.1 on land bearing S.No.47, H.No. 2/4, & 2/5, of village Gokhivare, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1417/ 2014 Dated: 24/ 06 / 2014.
2) An application received by M/s. En Con Consultants, Dated:25/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP - 0654/0158/2012-13,Dated:-18/12/2012.
4) Certificate from License Agency M/s- Neo Enterprises, Dated:25/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-30/05/2013.
6) Structure Stability certificate of M/s. Sanjay Narang & Associates, Dated:-30/05/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial building no.1.** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP- 0654/0158/2012-13,Dated:-18/12/2012.** The party has constructed **"Industrial building no.1. G +2 pt. Floors"** as per sanctioned Plan.

With reference to above on Dated: -18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185,Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 25/04/2014. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 4" Raiser Ground + 2nd floor
2. Landing valve each floor
3. Courtyard Hydrant
4. Hose Reel Set
5. Branch pipe
6. Hose Box
7. R.R.L 15 mts. Canvas hose pipe
8. Fire services inlet
9. Booster pump 5HP
10. Main Electrical pump 30HP
11. Fire extinguisher ABC – 5kg
12. Fire extinguisher Co2 – 3kg

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to 2290.33 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 1,50,000 /- vide Receipt No. 169201, Dated 30/11/2013, DD.bearing No. 194906 & Rs. 1,50,000 /- vide Receipt No. 169202, Dated 30/11/2013, DD.bearing No. 194905 Issued by Syndicate Bank fees for the total Builtup area admeasuring **to 2290.33 Sq.Mtrs** as per the letter given by the party Dated 30/11/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 029/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of CFC building, on land bearing CTS No.1107,Pardi No.1 & 2, CTS No.1160, Pardi No.252 of village Malonde, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1414/ 2014 Dated: 24/ 06 / 2014.
2) An application received by M/s.En Con Consultants, Dated:25/06/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP-0669/760/2012-13,Dated:- 15/6/2012.
4) Certificate from License Agency M/s- Neo Enterprises, Dated:26/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s.En Con Consultants, Dated:20/06/2014
6) Structure Stability certificate of M/s Sanjay Narang & Associates, Dated:- 20/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **CFC building.** Building at above mentioned address. As per c.c issued by **VVCMC/TP/CC/VP-0669/760/2012-13,Dated:-15/6/2012.** The party has constructed **"CFC building, G +3 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185, Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 26/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 4" Raiser Ground + 2nd floor
2. Landing valve each floor
3. Courtyard Hydrant
4. Hose Reel Set
5. Branch pipe
6. Hose box
7. R.R.L 15 mts. Canvas hose pipe
8. Fire services inlet
9. Booster pump 5HP
10. Fire extinguisher ABC – 5kg
11. Fire extinguisher Co2 – 3kg

O/C 25/06/14

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to 213.76 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40,000 /- vide Receipt No. 187172, Dated 24/06/2014, DD.bearing No. 008921 & Rs. 40,000 /- vide Receipt No. 187173, Dated 24/06/2014, Issued by Bassein Catholic Co-op Bank Ltd. fees for the total Builtup area admeasuring **to 213.76 Sq.Mtrs** as per the letter given by the party Dated 24/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

IPAL CORPORATION E AED Thane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 030/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial building No.2 (Plot No.2)on land bearing S.No.36, H.No. 9 of village Waliv, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1416/ 2014 Dated: 24/ 06 / 2014.
2) An application received by M/s. EN CON Consultants, Dated:25/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-4427/E/6033,Dated:-15/03/2010.
4) Certificate from License Agency M/s- Neo Enterprises, Dated:25/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-18/01/2014.
6) Structure Stability certificate of M/s. Sanjay Narang & Associates, Dated:-18/01/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial building No.2 (Plot No.2).** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/RDP/BP-4427/E/6033,Dated:-15/03/2010.** The party has constructed **"Industrial building No.2 (Plot No.2), G +1/ pt. Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185,Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 25/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 4" Riser Ground + 2nd floor
2. Landing valve each floor
3. Courtyard Hydrant
4. Hose Reel Set
5. Branch pipe
6. Hose box
7. R.R.L 15 mts. Canvas hose pipe
8. Fire services inlet
9. Booster pump 5HP
10. Main Electrical pump 20HP
11. Fire extinguisher ABC – 5kg
12. Fire extinguisher Co2 – 3kg

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to 1492.00 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 62,000 /- vide Receipt No. 187164, Dated 24/06/2014, DD.bearing No. 751243 & Rs. 85,000 /- vide Receipt No. 187165, Dated 24/06/2014, DD.bearing No. 751242 Issued by Union Bank fees for the total Builtup area admeasuring **to 1492.00Sq.Mtrs** as per the letter given by the party Dated 24/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 031/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of welfare centre building in R.G. on land bearing S.No.33,42/1&43/1 of village Gokhiware, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1296/ 2014 Dated: 19/ 06 / 2014.
2) An application received by M/s.Ajay Wade & Associates, Dated:19/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/CC/BP- 2307/E/673,Dated:- 12/02/2008.
4) Certificate from License Agency M/s- Neo Enterprises, Dated:25/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. Ajay Wade & Associates Dated:-18/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Welfare centre building.** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/CC/BP- 2307/E/673,Dated:- 12/02/2008.**The party has constructed **"Welfare centre building, S+1 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185,Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 25/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 4" Raiser Ground + 2nd floor
2. Landing valve each floor
3. Courtyard Hydrant
4. Hose Reel Set
5. Branch pipe
6. Hose box
7. R.R.L 15 mts. Canvas hose pipe
8. Fire services inlet
9. Booster pump 5HP
10. Main Electrical pump 20HP
11. Fire extinguisher ABC – 5kg
12. Fire extinguisher Co2 – 3kg

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 207.19 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 80,000 /- vide Receipt No. 187127, Dated 19/06/2014, DD.bearing No. 018028 Issued by Basin Catholic Bank fees for the total Construction area admeasuring **to 207.19 Sq.Mtrs** as per the letter given by the party Dated 24/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 032/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial building no 1B on land bearing S.No.33,42/1&43/1 of village Gokhiware, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1309/ 2014 Dated: 19/ 06 / 2014.
2) An application received by M/s.Ajay Wade & Associates, Dated:13/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP- 2307/E/5684,Dated:- 21/01/2010.
4) Certificate from License Agency M/s- Neo Enterprises, Dated:25/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. Ajay Wade & Associates Dated:-13/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial building.** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/RDP/BP- 2307/E/5684,Dated:- 21/01/2010.**The party has constructed **"Industrial building, G+ 2 pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185,Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 25/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 4" Raiser Ground + 2nd floor
2. Landing valve each floor
3. Courtyard Hydrant
4. Hose Reel Set
5. Branch pipe
6. Hose box
7. R.R.L 15 mts. Canvas hose pipe
8. Fire services inlet
9. Booster pump 5HP
10. Main Electrical pump 20HP
11. Fire extinguisher ABC – 5kg
12. Fire extinguisher Co2 – 3kg

O/c.
25/06/14

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 1358.30 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 149600 /- vide Receipt No. 141887, Dated 05/07/2013, DD.bearing No. 949339 Issued by Syndicate Bank fees for the total Construction area admeasuring **to 1358.30 Sq.Mtrs** as per the letter given by the party Dated 05/07/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 033/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building, Building No-1 Wing C in Plot no.4 on Land bearing S.No.48, H.No. 1A To 1D/2(pt) & 1A To 1D/3 at village Sativali ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1363 / 2014, Dated:- 21/06/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 09/06/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0339/043 / 2013-14. Dated: 08/05/2013.
4. Certificate from License Agency M/s, M/s- Neo Enterprises, Dated:26/04/2014, (Form A).
5. Building Completion certificate No. VP-0339 / 116 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated: 09/06/2014.
6. Built up area certificate No. VP-0339/115 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:09/06/2014.
7. Structure Stability certificate of M/s. Epicons Consultants pvt. ltd, Dated: 20/02/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 134454, Dated:31/08/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 165 / 2012-13, Dated: 09/11/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building, Building No-1 Wing C in Plot no.4** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185,Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 26/04/2014. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 1663.42 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 034/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial building, Type- A on land bearing S.No.85, H.No. 5, S.No.86, H.No. 1/2,2/2,3, S.No.87, H.No. 4,5/1,5/2,6A,6B, S.No.90, H.No. 1 to 13, 14A,14B,16, S.No.91, H.No. 2,3,6 to 8, S.No.92, H.No. 3, 9A,9B,10 to 19,21,22,23, S.No.96, H.No. 2,3,6 to 12, S.No.95, H.No. 4,10, of village Gokhiware, Tal. Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1415/ 2014 Dated: 24/ 06 / 2014.
2) An application received by M/s.Ajay Wade & Associates, Dated: 25/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/E/VP-0736/110/2011-12,Dated:-15/10/2011.
4) Certificate from License Agency M/s- Neo Enterprises, Dated:26/04/2014. (Form A)
5) Building Completion certificate & Condtruction area certificate of M/s. Ajay Wade & Associates Dated:-23/06/2014.
6) lift completion affidavit .

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial building, Type- A.** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/E/VP-0736/110/2011-12,Dated:-15/10/2011.** The party has constructed **"Residential Cum Commercial building, Type- A., G +7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Neo Enterprises bearing License No. MFS-LA/F-220 & License No. MFS-LA/D-185,Dated- 01/05/2013 issued by this office and has submitted Certificate of dated 26/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 4" Raiser Ground + 2nd floor
2. Landing valve each floor
3. Courtyard Hydrant
4. Hose Reel Set
5. Branch pipe
6. Hose box
7. R.R.L 15 mts. Canvas hose pipe
8. Fire services inlet
9. Booster pump 5HP
10. Main Electrical pump 20HP
11. Fire extinguisher ABC – 5kg
12. Fire extinguisher Co2 – 3kg

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 1785.70 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 80,000 /- vide Receipt No. 187163, Dated 24/06/2014, DD.bearing No. 003690 & Rs. 1,20,000 /- vide Receipt No. 187162, Dated 24/06/2014, DD.bearing No. 003691 Issued by IDBI Bank fees for the total Construction area admeasuring **to 1785.70 Sq.Mtrs** as per the letter given by the party Dated 24/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane

25/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 035/2014-15 DATE: 25/06/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential Cum Commercial building no.4 (wings A to f) in sector IV in Yeshwant viva Township on Land bearing S.No. 49 to 56 & 77, at Village- Achole, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1351/ 2014 Dated: 20/ 06 / 2014.
2) An application received by M/s. EN CON project Consultants for Architectural & Structural Works, Dated:20/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-687/E/1036,Dated:- 07/07/2010.
4) Certificate from License Agency M/sSadanand Fire Systems , Dated:15/10/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-21/04/2014 & Dated:-03/05/2014
6) Structure Stability certificate of M/s. Hansal parikh & Associates, Structural Consultants, Dated:27/6/2014
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 137730 Dated:27/12/2013., 135743 Dated:30/10/2013., 134116 Dated:08/08/2013., 130007 Dated:08/05/2013., 130256 Dated:15/05/2013., 130010 Dated:08/05/2013.,

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial building no.4 (wings A to f) in sector IV in Yeshwant viva Township.** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/RDP/BP-687/E/1036,Dated:-07/07/2010.** The party has constructed **"Residential Cum Commercial building no.4 (wings A to f) in sector IV in Yeshwant viva Township, St/G +7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Systems bearing License No. LA/F-0252 ,Dated- 15/10/2013 issued by this office and has submitted Certificate of dated 17/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical riser
2. ISI Landing vlaves on each floor
3. Courtyard hydrant
4. Hose box set with Canvas hose
5. Hose reel drum sets with shut up nozzle on each floor
6. Booster pump
7. Hydrant main pump
8. Siamese connection at main gate

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to wing A-1481.58 Sq.Mtrs, wing B-2330.74 Sq.Mtrs, wing C-1451.99 Sq.Mtrs, wing D- 1222.60 Sq.Mtrs, wing E-2330.74 Sq.Mtrs, wing F-1481.58 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 10,78,100 /- vide Receipt No. 187141, Dated 20/06/2014, DD.bearing No. 039673 Axix Bank & Rs. 1,21,900 /- vide Challan No. C-14936, Issued by in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to wing A-1481.58 Sq.Mtrs, wing B-2330.74 Sq.Mtrs, wing C-1451.99 Sq.Mtrs, wing D- 1222.60 Sq.Mtrs, wing E-2330.74 Sq.Mtrs, wing F-1481.58 Sq.Mtrs** as per the letter given by the party Dated 20/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGAED
VASAI VIRAR CITY MUNICIPAL CORPORATION Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 036/2014-15 DATE: 25/06/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial building no.1 (wings A to I) in sector V in Yeshwant viva Township on Land bearing S.No. 49 to 56 & 77, at Village- Achole, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1350/2014 Dated:20/06/2014
2) An application received by M/s. EN CON Consultants, Dated:17/06/2014
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-687/E/4712, Dated:18/08 /2009
4) Certificate from License Agency **Sadanand Fire Systems, Dated:17/06/2014 (Form A)**
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-03/05/2014.
6) Structure Stability certificate A-cube consultant date- 20/06/2013.
7) License to work the Lift From Govt. of Maharashtra Industries, License no.136436,136434,136435. Dated 02 /11/2013., 138869,138868138867 Dated 25/11/2013, 137267,137266,137265 Dated 19 /12/2013

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential / Residential Cum Commercial building no.1 (wings A to I) in sector V in Yeshwant viva Township** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/RDP/BP-687/E/4712, Dated:18/08 /2009. The party has constructed **"Residential / Residential Cum Commercial building no.1 (wings A to I) in sector V in Yeshwant viva Township" Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s.Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, dated 15/10/2013 issued by this office and has submitted Certificate on 17/06/2014in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Riser
2) ISI Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) Hydrant main pump
8) Siamese connection at main gate

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **11535.61** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.13,27,700/- vide Receipt No. 187133 Dated 19/06/2014 & DD No.24801 basin katholic Bank & Rs.72,300/- with cidco challan no 14968 Date-26/08/2014 for the total gross built up area **11535.61** Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 038/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial building on Pardi No.-7,H.No.-2 & Pardi No-7pt at Village- Agashi, Tal- Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1426/2014 Dated:24/06/2014
2) An application received by M/s. M Baria developers , Dated:21/06/2014
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0274/063/2013-14 Dated:20/05 /2013
4) Certificate from License Agency –Sadanand fire controls , Dated: 16/06/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s.EN CON Dated:-19/04/2014.
6) Structure Stability certificate – Nimisha Stuctural design Academy Dated:- 19/03/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License no.135495 Dated -24/10/2013.,& no.139684 Dated -21/02/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential / Residential Cum Commercial** Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP-0274/063/2013-14 Dated:20/05 /2013. The party has constructed **"Residential / Residential Cum Commercial Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e- Sadanand fire controls **bearing License No. MFS-LA/F-216, Dated -01/05/2014. issued by this office and has submitted Certificate on dated – 16/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Reiser cum down comer
2) ISI Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) Hydrant main pump
8) Siamese connection at main gate
9) Fire extinguisher ABC type

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3388.25** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,20,000/- vide Receipt No. 187175 Dated 25/06/2014 & DD No.011446 basin catholic Bank & Rs 2,00,000/- vide Receipt No. 187176 Dated 25/06/2014 & DD No.011447 basin catholic Bank for the total gross built up area **3388.25** Sq.Mtrs as per the letter given by the party Dated 25/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

CIPAL CORPORATION
RE
GAED
Thane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 039/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for CFC building on Land bearing No S.No-157/B, S.No-423 H.No-A2,A3,&A4, S.No-316/B, at Village- Bolinj, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1537/2014 Dated:30/06/2014
2) An application received by M/s. Magnates Enterprises , Dated:23/06/2014
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0489/051/2013-14 Dated:14/05/2013
4) Certificate from License Agency –Sadanand fire controls , Dated: 25/06/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. Abhay Raut Dated:-16/06/2014.
6) Structure Stability certificate – Nimisha Stuctural design Academy Dated:- 25/06/2014.
7) lift completion Affidavit. Dated- 02/07/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for CFC** Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP-0274/063/2013-14 Dated:20/05 /2013. The party has constructed **"CFC Building Gr+ 5 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e- Sadanand fire controls **bearing License No. MFS-LA/F-216, Dated -01/05/2014. issued by this office and has submitted Certificate on dated – 25/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Reiser cum down comer
2) ISI Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) Hydrant main pump
8) Siamese connection at main gate
9) Fire extinguisher ABC type.
10) Sprinkler & Smoke Detector

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **453.80** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.80,000/- vide Receipt No. 226609 Dated 01/07/2014 & DD No.002836 The Shamrao Vitthal co.op.bank for the total gross built up area **453.80** Sq.Mtrs as per the letter given by the party Dated 01/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If **any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

IPAL CORPORATION
E
AED
Thane

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 040/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial building no.12 A & CFC Building on Land bearing S.No. 151 , H.No- 4&5, S.No. 153 , H.No- 2/1,3,4&5, S.No. 155 , H.No- 1,2A,3, S.No. 156 , H.No- 1A& S.No. 179 , H.No- 1/10 at Village- Virar, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1423/2014 Dated:24/06/2014
2) An application received by M/s. M Baria developers , Dated:23/06/2014
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0165/226/2011-12, Dated:21/02/2012
4) Certificate from License Agency –Sadanand fire controls , Dated: 17/06/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s.Abhay Raut Dated:-16/06/2014.
6) Structure Stability certificate – Kaivant C.Shah Dated:- 18/06/2013.
7) License to work the Lift From Govt. of Maharashtra Industries, License no.135496 & 135497 Dated -24/10/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential / Residential Cum Commercial building no.12 A & CFC Building** Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP-0165/226/2011-12, Dated:21/02/2012. The party has constructed **"Residential / Residential Cum Commercial building no.12 A & CFC Building Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e- Sadanand fire controls **bearing License No. MFS-LA/F-216, Dated -01/05/2014. issued by this office and has submitted Certificate on dated – 17/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Reiser cum down comer
2) ISI Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) Hydrant main pump
8) Siamese connection at main gate
9) Fire extinguisher ABC type

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2257.10** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.2,00,000/- vide Receipt No. 187177 Dated 25/06/2014 & DD No.011449 basin catholic Bank & Rs.80,000/- vide Receipt No. 187178 Dated 25/06/2014 & DD No.011448 basin catholic Bank for the total gross built up area **2257.10** Sq.Mtrs as per the letter given by the party Dated 25/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 041 / 2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building Type EG1, Wing A,B& Type EG2 -C,D & E IN AVENUE-E, Of Group Housing Scheme On New S.No.5,5B,5F,5G,5D, at village Dongre, Virar (w), Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1177 / 2014, Dated:- 10/06/2014.
2. An application received by M/s. Shah Gattani Consultants , Dated: 03/04/2014..
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP/0453/0296/2011-12, Dated: 31/03/2012. & VVCMC No. VVCMC / TP / RDP / VP/0453/0228/2012-13, Dated: 14/03/2013.& VVCMC / TP / RDP / VP/0453/077/2014-15, Dated: 02/07/2014.
4. Certificate from License Agency M/s, Sadanand Fire Controls, Dated:23/04/2014. (Form A).
5. Building Completion certificate of M/s. Shah Gattani Consultants, Dated: 03/04/2014.
6. Built up area certificate of M/s. Shah Gattani Consultants, Dated:03/04/2014..
7. Structure Stability certificate of M/s. Shah Gattani Consultants, Dated: -----.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 134455, 134456, Dated: 13/08/2013 &. No. 136527, 136529, 136518, 136524,136539, Dated: 08/11/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building Type EG2, Wing A,B& EG1-C,D & E IN AVENUE-E** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Sadanand Fire Controls bearing License No. MFS-LA/F- 216, dated 01/05/2013 issued by this office and has submitted Certificate On 23/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 10882.04 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

2/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 042/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING ,WingA,B,C& D Type T,S,S,R Known as Krishana Galaxy on land bearing S.No. 414 B, at village Bolinj, Tal.Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1556/ 2014 Dated: 30 / 06 / 2014.
2) An application received by M/s. Balaji Developers , Dated:25/06/2014.
3) Revised c.c. Issued CIDCO/VVSR/CC/BP-3486/W/5200,Dated:-11/11/2009.
4) Certificate from License Agency M/s. Shree Sainath Enterprise, Dated:01/06/2014 (Form A)
5) Building Completion certificate of M/s . Shah Gattani consultants , Dated:-26 /06/2014.
6) Built up area certificate M/S Shah Gattani consultants, Dated:-26 /06/2014
7) Structure Stability certificate of M/s. Shah Gattani consultants, Dated: 26/06/2014.
8) Lift Completion Affidavit. Dated -26/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING WingA,B,C& D Type T,S,S,R Known as Krishana Galaxy on land bearing S.No. 414 B** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/CC/BP-3486/W/5200,Dated:-11/11/2009 The party has constructed **"RESIDENTIAL CUM COMMERCIAL Building Wing-A,B,C,&D G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Shree Sainath Enterprise bearing License No. MFS-LA/RF-0076, issued by this office and has submitted Certificate of dated 01/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) main Pump- 25 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants.

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 7114.18 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Received

The Party has paid already paid the Rs 4,14,900 /- vide Receipt No. 226617, Dated 02/07/2014 .DD.bearing No. 039736, Issued by Axis Bank Limited & Rs-70,000/- vide Cidco Challan No – 24012 Dated -10/11/2009 & Rs-75,100/- vide Cidco Challan No – 23861 Dated -30/10/2009

additional Capitation & Scrutiny fees for the total Built up area **7114.18** Sq.Mtr. as per the letter given by the party.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 043/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING No.1,PH-I,Sector-V,Wing C Known as Strawberry on land bearing S.No. 255/1,2,3,4,257/1,259/1,260/pt & 261 at village Nilemore, Tal.Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1554/ 2014 Dated: 30 / 06 / 2014.
2) An application received by M/s. Shree Sai Drusti Enterprises, Dated:28/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP- 0022/287/2011-12,Dated:-22/03/2012.
4) Certificate from License Agency M/s. Shree Sainath Enterprise, Dated:01/05/2013 (Form A)
5) Building Completion certificate of M/s . Sanat Mehta & Associates , Dated:-30/06/2014.
6) Built up area certificate No.VVCMC/TP/ VP-0412, of M/s . Sanat Mehta & Associates, Dated:-30/06/2014.
7) Structure Stability certificate of M/s. A-cube Consultant, Dated: 28/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 117285, Dated:-28/12/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.1,PH-I,Sector-V,Wing C Known as Strawberry on land bearing S.No. 255/1,2,3,4,257/1,259/1,260/pt & 261**Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP- 0022/287/2011-12,Dated:-22/03/2012 The party has constructed **"RESIDENTIAL CUM COMMERCIAL Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Shree Sainath Enterprise bearing License No. MFS-LA/RF-0076, issued by this office and has submitted Certificate of dated 01/05/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants.

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 2375.75 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the, case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Received

The Party has paid already paid the Rs 2,00,000 /- vide Receipt No. 227315, Dated 30/04/2012.DD.bearing No. 063506, Issued by The Vasai Janta Sahkari Bank Limited additional Capitation & Scrutiny fees for the total Built up area **2375.75**Sq.Mtr. as per the letter given by the party Dated 30/04/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 044/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING No.1, ,WingA,B& C Known as Agarwal meadows on land bearing S.No. 162,H.No-1,S.No.333,H.No-1,2,3,4,5,6,7,8,9,10,11,12&13,S.No.337,H.No-1,2,3,4,5,6,7,8 at village Bolinj, Tal.Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1557/ 2014 Dated: 30 / 06 / 2014.
2) An application received by M/s. Agarwal Builders, Dated:27/06/2014.
3) Revised c.c. Issued CIDCO/VVSR/CC/BP-3343/W/3696,Dated:-06/01/2009.
4) Certificate from License Agency M/s. Shree Sainath Enterprise, Dated:01/06/2014 (Form A)
5) Building Completion certificate of M/s.. EN CON , Dated:-25 /06/2014.
6) Built up area certificate M/S EN CON , Dated:-25 /06/2014
7) Structure Stability certificate of M/s. Sanjay Narag & Associates, Dated: 25/06/2014.
8) Lift Completion Affidavit. Dated -26/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.1, ,WingA,B& C Known as Agarwal meadows on land bearing S.No. 162,H.No-1,S.No.333,H.No-1,2,3,4,5,6,7,8,9,10,11,12&13,S.No.337,H.No-1,2,3,4,5,6,7,8** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/CC/BP-3343/W/3696,Dated:-06/01/2009 The party has constructed **"RESIDENTIAL CUM COMMERCIAL Building Wing-A,B& C, G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Shree Sainath Enterprise bearing License No. MFS-LA/RF-0076, issued by this office and has submitted Certificate of dated 01/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) main Pump- 25 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants.

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 4250.13 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Received

The Party has paid already paid the Rs 4,65,500 /- vide Receipt No. 226616, Dated 02/07/2014 .DD.bearing No. 039737, Issued by Axis Bank Limited & Rs-41,100/- vide Cidco Challan No – 16562 Dated -27/12/2008 & Rs-13,400/- vide Cidco Challan No – 23415 Dated -14/09/2009 additional Capitation & Scrutiny fees for the total Built up area **4250.13** Sq.Mtr. as per the letter given by the party.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

ICIPAL CORPORATION
RE
GAED
Thane

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 045/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING NO-2,WingA&B Known as Samarpan on land bearing S.No. 49 to 56& 77,in sector 5 in Yashwant viva Township at village Achole, Tal.Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1555/ 2014 Dated: 30 / 06 / 2014.
2) An application received by M/s. Sai Shakti Developers , Dated:25/06/2014.
3) Revised c.c. Issued VVCMC/TP/CC/VP-0127/2320,Dated:-21/02/2012.
4) Certificate from License Agency M/s. Shree Sainath Enterprise, Dated:01/06/2014 (Form A)
5) Building Completion certificate of M/s . EN CON , Dated:-28 /06/2014.
6) Built up area certificate M/S EN CON , Dated:-28 /06/2014.
7) Structure Stability certificate of M/s. Tyshettye, Dated:30/06/2014.
8) Lift Completion Affidavit. Dated -27/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING NO- 2,WingA&B Known as Samarpan** Building at above mentioned address. As per c.c issued by VVCMC/TP/CC/VP-0127/2320,Dated:-21/02/2012. The party has constructed **"RESIDENTIAL CUM COMMERCIAL Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Shree Sainath Enterprise bearing License No. MFS-LA/RF-0076, issued by this office and has submitted Certificate of dated 01/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) main Pump- 20 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants.

This office is issuing a **"Final No Objection Certificate"** for your following building having **Builtup** area admeasuring **to 3405.55 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Received

The Party has paid already paid the Rs 3,20,000 /- vide Receipt No. 226618, Dated 02/07/2014 .DD.bearing No. 001611, Issued by Saraswat Bank & Rs 80,000 /- vide Receipt No. 226619, Dated 02/07/2014 .DD.bearing No. 001610, Issued by Saraswat Bank additional Capitation & Scrutiny fees for the total Built up area **3405.55 Sq.Mtrs.**as per the letter given by the party.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 046/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial building no.5 (wings A to D) in sector III in Yeshwant viva Township on Land bearing S.No. 49 to 56 & 77, at Village- Achole, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1528/2014 Dated:30/06/2014
2) An application received by M/s. EN CON Consultants, Dated:16/09/2013
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-687/E/1036, Dated: 07/07/2010 & VVCMC/TP/RDP/VP- 0127/224/2011-12,. Dated: 21/02/2012.
4) Certificate from License Agency **Sadanand Fire Systems, Dated:17/06/2014 (Form A)**
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-26/02/2013..
6) Structure Stability certificate Hansal Parikh and Associates, date- 21/08/2012.
7) License to work the Lift From Govt. of Maharashtra Industries, License no.132586, 132578, Dated:23/07/2013. & 116324, 116323, Dated 21 /12/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential / Residential Cum Commercial building no.5 (wings A to D) in sector III in Yeshwant viva Township on Land bearing S.No. 49 to 56 & 77,** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/RDP/BP-687/E/1036, Dated: 07/07/2010 &VVCMC/TP/RDP/VP- 0127/224/2011-12,. Dated: 21/02/2012.The party has constructed **"Residential / Residential Cum Commercial building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s.Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, dated 15/10/2013 issued by this office and has submitted Certificate on 17/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Riser
2) ISI Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) Hydrant main pump
8) Siamese connection at main gate

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **6997.53** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.7,07,900/- vide Receipt No. 153445 Dated 19/09/2013 & DD No.576922 Dena Bank & Rs.92,100/- with cidco challan no 15301, Date-26/08/2014

Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total gross built up area **6997.53** Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 047/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential With Shopling building no.9 (wings A & B) on Land bearing S.No. 165, H.No. 1,2,3,4,5,6,7,8,9,10,11,12,13, S.No. 167, H.No. 1,2, S.No. 168, H.No.1,2,S.No. 169, H.No. 1,2,3, S.No. 1,2. S.No.173 H.No.1,2, S.No.365, at Village- Bolinj, Tal-Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1540 / 2014, Dated:-30/06/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 27/06/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0607 / 092 / 2011-12. Dated: 28/09/2011.
4. Certificate from License Agency M/s, Sadanand Fire Systems, Dated:20/06/2014 (Form A).
5. Building Completion certificate of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:26/06/2014.
6. Built up area certificate of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:26/06/2014.
7. Structure Stability certificate of M/s. Hiren M.Tanna, Dated:22/02/2013.
8. License to work the Lift From Govt. of Maharashtra Industries, License No. 120900 & 120901, Dated: 03/05/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 174 / 2011-12, Dated: 03/02/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential With Shopling building no.9** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s.Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, dated 20/06/2014 issued by this office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3164.49 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

2/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 048/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial Building , on Land Bearing S,No. 72+74, Piot No. 22 of village Waliv, Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1182 / 2014, Dated:- 10/06/2014.
2. An application received by M/s. Ajay Wade & Associates, Dated: 11/12/2013.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / CC / VP-0870 / 059 / 2012-13. Dated: 10/04/2012.
4. Certificate from License Agency M/s, Sadanand Fire Systems, Dated:11/12/2013 (Form A).
5. Building Completion certificate M/s. Ajay Wade & Associates, Dated: 09/12/2013.
6. Construction area certificate of M/s. Ajay Wade & Associates, Dated: 09/12/2013.
7.Structure Stability certificate of M/s. Suresh kumar m. Panicker Dated: 05/08/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building , on Land Bearing S,No. 72+74, Piot No. 22** Building at above mentioned address. As per c.c issued by **VVCMC / TP / CC / VP-0870 / 059 / 2012-13. Dated: 10/04/2012.** The party has constructed **"Industrial Building, (G+2) Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building s ituated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. **Sadanand Fire Systems, bearing License No. MFS-LA/F.0252 issued by this office and has submitted Certificate of Dated 11/12/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical Riser- 1 nos
2. Landing Valves on each floor – 1nos
3. Courtyard Hydrant- 5 nos
4. Hose box set with canvas hose- 4 nos.
5. Hose Reel drum sets with shut up Nozzle on each floor- 2 nos
6. Booster Pump- 1 nos
7. Main pump- 1 nos
8. Simense Connection at main gate- 1 nos
9. Fire Extingushers- 2 nos

This office is issuing **"Final No Objection Certificate"** for your following building having Construction area admeasuring to **1657.09 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 1,70,000 /- vide Receipt No. 187141, Dated 20/06/2014 .DD.bearing No. 059746, Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Construction area **1657.09 Sq.Mtrs.** as per the letter given by the party Dated 09/12/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 049/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential building no.6 (wings A,B) on Land bearing S.No. 165, H.No. 1,2,3,4,5,6,7,8,9,10,11,12,13, S.No. 173, H.No. 1,2, S.No. 365, at Village- Bolinj, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1502/2014 Dated:24/06/2014
2) An application received by M/s. EN CON Consultants, Dated:24/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP- 3647, 4226, & 4437/W/ 5967 Dated: 08/03/2010 .
4) Certificate from License Agency Sadanand Fire Systems, Dated: 20/06/2014 (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-20/06/2014..
6) Structure Stability certificate Hiren m. Tanna, date- 22/02/2013.
7) License to work the Lift From Govt. of Maharashtra Industries, License no.137124,137123, Dated:16/12//2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential building no.6 (wings A,B)on Land bearing S.No. 165, H.No. 1,2,3,4,5,6,7,8,9,10,11,12,13, S.No. 173, H.No. 1,2, S.No. 365,** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/RDP/BP- 3647, 4226, & 4437/W/ 5967 Dated:08/03/2010 The party has constructed **"Residential building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s.Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, dated 15/10/2013 issued by this office and has submitted Certificate on 20/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Riser
2) ISI Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) Hydrant main pump
8) Siamese connection at main gate

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **5351.36** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.4,80,000/- vide Receipt No. 226612 Dated 01/07/2014 & DD No.039763, Axis Bank Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total gross built up area 5351.36 Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 050/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial Building no.8A.S.No.45,H.No.2 &5, S.No.46,H.No.1/1, S.No.47, H.No. 1/1 & ½, S.No. 50 (pt) at village Bilalpada ,Tal-Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1527 / 2014, Dated:-30/06/2014.
2. An application received by M/s. Vasundara Enterprises, Dated: 02/01/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / PCC / VP-0112 / 04 / 2012-13. Dated: 07/04/2012.
4. Certificate from License Agency M/s, Sadanad Fire Syatem, Dated:12/12/2013 (Form A).
5. Building Completion certificate M/s. J.P. Mehta & Associates, Dated: 12/12/2013.
6. Built up area certificate of M/s. M/s. J.P. Mehta & Associates, Dated: 12/12/2013.
7. Structure Stability certificate of M/s. J.P. Mehta & Associates, Dated: 12/12/2013..
8. License to work the Lift From Govt. of Maharashtra Industries, License No. 144474, Dated:17/4/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building no.8A.S.No.45,H.No.2 &5, S.No.46,H.No.1/1, S.No.47, H.No. 1/1 & ½, S.No. 50 (pt)** Building at above mentioned address. As per c.c issued by **VVCMC / TP / PCC / VP-0112 / 04 / 2012-13. Dated: 07/04/2012.** The party has constructed **"Industrial Building ,Gr.+2 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. Viva Enterprise **bearing License No. MFS-LA/F-0252, issued by this office and has submitted Certificate of Dated 12/12/2013. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical Riser- 1 nos
2. Landing Valves on each floor – 1nos
3. Courtyard Hydrant- 5 nos
4. Hose box set with canvas hose- 4 nos.
5. Hose Reel drum sets with shut up Nozzle on each floor- 2 nos
6. Booster Pump- 1 nos
7. Main pump- 1 nos
8. Simense Connection at main gate- 1 nos
9. Fire Extingushers- 2 nos

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring to **1571.535 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,70,000 /- vide Receipt No. 187132, Dated19/06/2014.DD.bearing No. 195382 Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **1571.535 Sq.Mtr**. as per the letter given by the party Dated 12/12/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

CIPAL CORPORATION ★ E AED ne.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 061/2014-15 DATE: 02/07/2014

TO,

M/s. VIVA GOKUL BUILDERS,
Shop No. 9, Gokul Annexe, Opp. Muljibhai Metha School,
Agarwal Gardens, Gokul Township, Bolinj, Virar (W).
Dist- Thane

Sub:- "Renewal of Final No Objection Certificate" of Commercial Building Type J (Gr+4) Known as ' VIVA GOKUL ARCADE' Situated at VIVA GOKUL COMPLEX, Gokul Township on Land bearing S.No.334, H.No. 1 to 33, 6/2, at village: Bolinj, Tal: Vasai, Dist: Thane.

Ref :- 1. An application received by M/s. VIVA GOKUL BUILDERS, Dated: 27/06/2014.
2. Certificate from License Agency M/s, Shree Sainath Enterprises , Dated:21/06/2014 (Form B).
3. This office final No objection Certificate No. VVCMC / FIRE /21/ 2011-12, Dated:25/04/2011.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Commercial Building Type J (Gr+4) Known as ' VIVA GOKUL ARCADE' Situated at VIVA GOKUL COMPLEX, Gokul Township** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Shree Sainath Enterprises bearing License No. MFS-LA/RF-0076 , issued by this office and has submitted Certificate on dated- 21/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per Final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.66,000 /- vide Receipt No. 226620, Dated 02/07/2014.DD.bearing No. `039745. Issued by Axis Bank, renewal fees for the said building..

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 062/2014-15 DATE: 02/07/2014

TO,

M/s. OM DEVELOPERS
9, Gokul Annexe, Opp. Muljibhai Metha School,
Agarwal Gardens, Gokul Township, Bolinj, Virar (W).
Dist- Thane.

Sub:- "Renewal of Final No Objection Certificate" of Residential Building Known as ' GOKUL SOLITAIRE' Wing A (Type W), Wing B (Type V), Wing C (Type U) on Land bearing S.No.164, Gokul Township, Bolinj, Virar (W).

Ref :- 1. An application received by M/s. OM DEVELOPERS, Dated: 27/06/2014.
2. Certificate from License Agency M/s, Shree Sainath Enterprises , Dated:21/06/2014 (Form B).
3. This office final No objection Certificate No. VVCMC / FIRE /136/ 2012-13, Dated:19/10/2012.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Residential Building Known as ' GOKUL SOLITAIRE' Wing A (Type W), Wing B (Type V), Wing C (Type U)** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Shree Sainath Enterprises bearing License No. MFS-LA/RF-0076 , issued by this office and has submitted Certificate on dated- 21/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per Final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.72,000 /- vide Receipt No. 226622, Dated 02/07/2014.DD.bearing No. `039747. Issued by Axis Bank Ltd., renewal fees for the said building..

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 063/2014-15 DATE: 02/07/2014

TO,

M/s. A.M.K. ASSOCIATES,
Shop No. 9, Gokul Annexe Bldg,
Agarwal Gardens, Phase- II, Gokul Township,
Virar (W).-401 303.

Sub:- "Renewal of Final No Objection Certificate" of Residential Cum Commercial Building Known as ' VRINDAVAN GARDENS' Wing N in building No.4 in sector 5 in Yashwant Viva Township on Land bearing S.No.49 to 56 & 77, at village: Achole, Tal: Vasai, Dist: Thane.

Ref :- 1. An application received by M/s. A.M.K. ASSOCIATES, Dated: 27/06/2014.
2. Certificate from License Agency M/s, Shree Sainath Enterprises , Dated:21/06/2014 (Form B).
3. This office final No objection Certificate No. VVCMC / FIRE /36/ 2013-14, Dated:29/04/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Residential Cum Commercial Building Known as ' VRINDAVAN GARDENS' Wing N in building No.4 in sector 5 in Yashwant Viva Township** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Shree Sainath Enterprises bearing License No. MFS-LA/RF-0076 , issued by this office and has submitted Certificate on dated- 21/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per Final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.22,000 /- vide Receipt No. 226625, Dated 02/07/2014.DD.bearing No. `671248. Issued by Oriental Bank of Commerce., renewal fees for the said building..

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 064/2014-15 DATE: 02/07/2014

TO,

M/s A.M.K. Associates,
Agarwal Group,Shop No-9. Gokul Annexe, Agarwal Gardens,
(phase-II),Gokul Township,Bolinj,Virar (West),Dist-Thane.

Sub:- Renewal of "Final No Objection Certificate" of Residential cum Commertial Building known as Vrindawan Gardens wing G,H,I,J,K,L,& M in Building No-4 in Sector 5 in Yashwant viva Township Situated At landbearing S.No.49 To 56 &, 77, at village Achole ,Tal- Vasai, Dist- Thane.

Ref :- 1. An application received by A.M.K. Associates, Dated: 27/06/2014.
2. Certificate from License Agency M/s, Shree Sainath Enterprises , Dated:21/06/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/34 / 2013-14, Dated:29/04/2013

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Residential cum Commertial Building known as Vrindawan Gardens wing G,H,I,J,K,L,& M in Building No-4 in Sector 5 in Yashwant viva Township** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Shree Sainath Enterprises bearing License No. MFS-LA/RF-0076 , issued by this office and has submitted Certificate on dated-21/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.84,000 /- vide Receipt No.-226621, Dated 02/07/2014.DD.bearing No. 671246 Issued by Oriantal Bank Of comers., renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 065/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of CFC Building No.11 & 11A on land bearing S.No.80, H.No. 1 (pt), 1 (pt) & 2 (pt) of village Waliv, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1297/ 2014 Dated: 19/ 06 / 2014.
2) An application received by M/s. Ajay Wade & Associates, Dated:19/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP- 0631/393/2012-13,Dated:-16/05/2012.
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:22/04/2014. (Form A)
5) Building Completion certificate No.VVCMC/TP/CC/VP-0631, of M/s . Ajay Wade & Associates, Dated: 12/06/2014.
6) Consturction area certificate, of M/s . Ajay Wade & Associates, Dated:-12/06/2014.
7) Structure Stability certificate of M/s. Suresh Kumar M. Paniker, Dated: 12/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **CFC Building No.11A on land bearing S.No.80, H.No. 1 (pt), 1 (pt) & 2 (pt)** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP- 0631/393/2012-13,Dated:-16/05/2012.** The party has constructed **"CFC Building G+2 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, issued by this office and has submitted Certificate of dated 22/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor; Hose Box, Cotton Hose & Branch Pipe.
d) 1500 Lpm, 70 Mtr head Main ShbmersiblePump
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to Building No. 11 - 1877.03 Sq.Mtrs.** & **Building No. 11A - 783.97 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Building 11A, Rs.40,000 /- vide Receipt No. 187122, Dated 16/06/2014. & Rs.40,000 /- vide Receipt No. 187121, Dated 16/06/2014., DD.bearing No. 059696, 059697, & Building 11, Rs. 85,000 /- vide Receipt No. 187120, Dated 16/06/2014. & Rs.85,000 /- vide Receipt No. 187119, Dated 16/06/2014., DD.bearing No. 059690, & 0596991, Issued by Bassein Catholic Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to Building No. 11 - 1877.03 Sq.Mtrs.** & **Building No. 11A - 783.97 Sq.Mtrs.** as per the letter given by the party Dated 10/06/2014.

Received

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

25/6/2019

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 066/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residental Cum Commercial Building no.2 wing B, on Land Bearing S.No.321, & H.No. 1 & S.No. 322, H,No. 9 at village Virar ,Tal-Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1424 / 2014, Dated:-24/06/2014.
2. An application received by M/s. Abhay raut, Dated: 28/11/2013.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0279 / 262 / 2011-12. Dated: 02/03/2013.
4. Certificate from License Agency M/s, Aayush Fire and Services, Dated:28/11/2013 (Form A).
5. Building Completion certificate M/s. Abhay raut, Dated: 25/11/2013.
6. Built up area certificate of M/s. M/s. Abhay raut, Dated: 25/11/2013.
7. Structure Stability certificate of M/s.Umesh d Tayshetey, Dated: 08/4/2012.
8. License to work the Lift From Govt. of Maharashtra Industries, License No. 130600, Dated:24/05/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residental Cum Commercial Building no.2 wing B, on Land Bearing S.No.321, & H.No. 1 & S.No. 322, H,No. 9** Building at above mentioned address. As per c.c issued by **VVCMC / TP / RDP / VP-0279 / 2262 / 2011-12. Dated: 02/03/2013.** The party has constructed **"Residental Cum Commercial Building, Gr.+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 24/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. **Aayush Fire and Services, bearing License No. MFS-LA/F-0132,& MFS-LA/D-191, issued by this office and has submitted Certificate of Dated 28/11/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 2250 LPM Subercibal pump- 1 nos
2. Wet Riser(GIC Class Pipe) - 1 nos
3. Booster pump 450 Lpm 23 mm head - 1 nos
4. Star Delta starter for main pump- 1
5. Dol Starter for Booster pump- 1 Nos
6. Butter fly valve 100 mm Dia- 3 nos
7. Butter fly valve 80 mm Dia- 1 nos
8. Wafar Type non return walve 100 mm dia – 1nos
9. Wafar Type non return walve 80 mm dia – 1nos
10. Pressure Gage - 1 nos.
11. 2 way Inlate Connection with Gunmatal male adapter - 1 nos
12. Single Hydrent Valve-10 nos
13. First aid hose reel-7 nos
14. Sprinkler (For 1st Floor)-120 nos
15. Hose box - 4 nos
16. Canvas hose pipe as per IS:636 15 mtr long - 4 nos
17. ABC Type Fire ExtinguSher 5 kg Capacity-4 nos.

This office is issuing **"Final No Objection Certificate"** for your following building having Builtup area admeasuring to **1990.00 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.2,00,000 /- vide Receipt No. 154319, Dated 25/11/2913 .DD.bearing No. 001038 Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **1990.00 Sq.Mtr**. as per the letter given by the party Dated 25/11/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 067/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of School Building (Stilt+5) (CFC plot Type HF-47). On New S.No. 1,2,3,4 of village Achole, s.No.101, 103, 104, 106, 107 of village mnikpur S.No. 97B, 105B,106B,of village:Gokhiware ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1421 / 2014, Dated:- 21/06/2014.
2. An application received by M/s. Shah Gattani Consultant, Dated: 18/06/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0743 / 0206 / 2012-13. Dated: 02/03/2013.
4. Certificate from License Agency M/s, Aayush Fire and Services, Dated:16/06/2013 (Form A).
5. Building Completion certificate M/s. Shah Gattani Consultant, Dated: 18/06/2014.
6. Built up area certificate of M/s. M/s. Shah Gattani Consultant, Dated: 18/06/2014..
7. Structure Stability certificate of M/s. Shah Gattani Consultant, Dated: 18/06/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, Lift Fitting permission, Dated:16/08/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **School Building (CFC plot Type HF-47). On New S.No. 1,2,3,4, S.No.101, 103, 104, 106, 107, S.No. 97B, 105B,106B,of village:Gokhiware** Building at above mentioned address. As per c.c issued by **VVCMC / TP / RDP / VP-0743 / 0206 / 2012-13 Dated: 02/03/2013.**The party has constructed **"Residental Cum Commercial Building, (Stilt+5) Floors"** as per sanctioned Plan.

With reference to above on Dated: ..... representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. **Aayush Fire and Services, bearing License No. MFS-LA/RF.0132,& MFS-LA/D.191, issued by this office and has submitted Certificate of Dated 16/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Main Fire pump- 1 nos
2. Main Fire Starter- 1 nos
3. Butter fly valve 100 mm Dia- 2 nos
4. NRV valve 100 mm Dia – 1nos
5. Wet Riser 100 mm Dia - 1 nos
6. Hydrent valve - 8 nos.
7. Hose box - 4 nos
8. Canvas hose pipe as per IS:636 15 mtr long - 4 nos
9. Short branch pipe- 4 nos
10. First aid hose reel With 30 mtr long x20 Dia hose pipe with Shutoff Nozzle- 4 nos
11. 2 way Fire Inlat- 1 nos
12. ABC Type Fire ExtinguSher 5 kg Capacity-2 nos.

This office is issuing **"Final No Objection Certificate"** for your following building having Builtup area admeasuring to **2079.08 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.3,00,000 /- vide Receipt No. 153420, Dated 04/09/2013.DD.bearing No. 024585 Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **2079.08 Sq.Mtr**. as per the letter given by the party Dated 18/06/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 069/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building (G+7) on Land bearing S.No. 2, H.No.1 & 2, at village: Dongre ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 137214 / 2014, Dated:- 21/06/2014.
2. An application received by M/s. Sameer R. Desai, Dated: 21/06/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / CC/ VP- 0609/1897 Dated: 26/12/2011.
4. Certificate from License Agency M/s, Alpha National Fire Safety Services pvt.Ltd. Dated:24/06/2014. (Form A).
5. Building Completion certificate of M/s. Sameer R. Desai, Dated: 20/06/2014.
6. Built up area certificate of M/s. Sameer R. Desai, Dated: 20/06/2014.
7. Structure Stability certificate of Suresh kumar m paniker, Dated: 04/06/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, License, No. 141389, Dated:05/05/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 60 / 2011-12, Dated: 13/07/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Alpha National Fire Safety Services pvt.Ltd., bearing License No. MFS-LA/RD- 0017, MFS-LA/RD- 0020, issued by this office and has submitted Certificate of 24/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2179.56 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

2/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

received

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 070/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERTIAL BUILDING Type SR1 wing- D & E ,Known As "Sai Ashish Tower " on land bearing New S.No.1,2,3,4, of village Achole. S.No. 101,103,104,106,107 of village Gokhiware, S.NO.254, H.No.3,6,7/1,7/2,13,14,15 &16 of village Achole, S.NO.128, H.NO.8/1 of village:Gokhiware.Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1550/ 2014 Dated: 30 / 06 / 2014.
2) An application received by M/s. Shah Gatani Consultants, Dated:27/06/2014..
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0743,/0335/20/2013-14,Dated:- 09/01/2014.
4) Certificate from License Agency M/s. Sadanand fire controls, Dated:14/06/2014. (Form A)
5) Building Completion certificate of M/s . Shah Gatani Consultants, Dated: 14/06/2014
6) Built up area certificate of M/s . Shah Gatani Consultants, Dated: 14/06/2014.
7) Structure Stability certificate of M/s . Shah Gatani Consultants, Dated: 14/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 140988,140987, Dated:-17/04/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERTIAL BUILDING Type SR1 wing- D & E ,Known As "Sai Ashish Tower ",** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0743,/0335/20/2013-14,Dated:-09/01/2014.** The party has constructed **"RESIDENTIAL CUM COMMERTIAL BUILDING Type SR1 wing- D & E ,Known As "Sai Ashish Tower ", Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Controls bearing License No. MFS-LA/RF-216, dated 01/05/2014 issued by this office and has submitted Certificate of dated 14/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical riser cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 1 NOs
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe
   d) main pump- 1 NOs
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to SR1(wing D) 2962.91 Sq.Mtrs. & SR1(wing E) 416.73 Sq.Mtrs.**This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.4,00,000 /- vide Receipt No. 226613, Dated 01/07/2014 .DD.bearing No. 071280, Issued by Vasai janta Sahakari Bank ltd .in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **SR1(wing D) 2962.91 Sq.Mtrs. & SR1(wing E) 416.73 Sq.Mtrs.** as per the letter given by the party Dated : 14/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 071/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL BUILDING No.2 on land bearing S.No.343A, H.No. 6,7 & 8 of village: Bolinj, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1552/2014 , Dated: 30 / 06 / 2014.
2) An application received by M/s.Abhay Raut Architect, Dated:27/06/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP-0412,/1309,Dated:- 15/10/2011.
4) Certificate from License Agency M/s. Sadanand fire controls, Dated:26/06/2014. (Form A)
5) Building Completion certificate of M/s . Abhay Raut Architect, Dated:26/06/2014.
6) Built up area certificate of M/s . Abhay Raut Architect, Dated:26/06/2014.
7) Structure Stability certificate of M/s . Harish L. patel Consultants, Dated: 26/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 140333, Dated:-15/03/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL BUILDING No.2,** Building at above mentioned address. As per c.c issued by **VVCMC/TP/CC/VP-0412,/1309, Dated:-15/10/2011.**The party has constructed **"RESIDENTIAL BUILDING NO.2, G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Controls bearing License No. MFS-LA/RF-216, dated 01/05/2014 issued by this office and has submitted Certificate of dated 26/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical riser cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 1 NOs
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe
d) main pump- 1 NOs
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 1297.26 Sq.Mtrs.**This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,20,000 /- vide Receipt No. 187109, Dated 06/05//2014 .DD.bearing No. 559279, Issued by Bank Of Maharashtra .in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **1297.26 Sq.Mtrs.** as per the letter given by the party Dated : 26/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

CIPAL CORPORATION
E
ED

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 072/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING Type A,B known as ' VENU MADHAV' on land bearing S.No.370, H.No. 1,2,3,/1,3,4 to 16,18, to 30 of village: Bolinj(old), & S.No. 101 Of Village: kharodi (New) Tal. Vasai, Dist- Thane.

Ref:- 1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1550/2014 , Dated: 30 / 06 / 2014.
2) An application received by M/s.Shah Gattani Consultant, Dated:27/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0457/0217/ 2012-13,Dated:- 08/03/2013.
4) Certificate from License Agency M/s. Sadanand fire controls, Dated:26/06/2014. (Form A)
5) Building Completion certificate of M/s .Shah Gattani consultant, Dated:26/06/2014.
6) Built up area certificate of M/s . Shah Gattani consultant, Dated:26/06/2014.
7) Structure Stability certificate of M/s . Shah Gattani consultant, Dated:26/06/2014.
8) Lift Affidavit (Undertaking) by Shantinath Developers dated 30/06/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 166/ 2011-12, Dated:27/01/2912.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING Type A,B known as ' VENU MADHAV' (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Sadanand Fire Controls bearing License No. MFS-LA/RF-216, dated 01/05/2014 issued by this office and has submitted Certificate of dated 26/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **4300.46 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & Jury [illegible] maintenance of fire prevention and life safety measure in good repair and efficient condition as sp[illegible]ied in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

Dattadaya 2/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 073/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of INDUSTRIAL BUILDING No.8B & 8C on land bearing S.No.45, H.No. 2 & 5, S.No. 46, H.No. 1/1 & 1/3, S.No.47, H.No. 1/1 & ½ & S.No. 50, H.No. 6, of village: Bilalpada, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1553/2014 , Dated: 30 / 06 / 2014.
2) An application received by M/s.J.P.Mehata Associates, Dated:27/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-2087/E/5730,Dated:- 28/01/2010.
4) Certificate from License Agency M/s. Sadanand fire controls, Dated:26/06/2014. (Form A)
5) Building Completion certificate of M/s . J.P.Mehata Associates, Dated:23/06/2014.
6) Built up area certificate of M/s . J.P.Mehata Associates, Dated:23/06/2014.
7) Structure Stability certificate of M/s . J.P.Mehata Associates, Dated:27/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL BUILDING No.8B & 8C** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/RDP/BP-2087/E/5730,Dated:- 28/01/2010.** The party has constructed **"INDUSTRIAL BUILDING, G+2 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Controls bearing License No. MFS-LA/RF-216, dated 01/05/2014 issued by this office and has submitted Certificate of dated 26/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical riser cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 1 NOs
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe
   d) main pump- 1 NOs
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to Building No. 8B, 2430.330 Sq.Mtrs.& Building No. 8C, 2429.194 Sq.Mtrs.**This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.3,00,000 /- vide Receipt No. 226638, Dated 02/07//2014 .DD.bearing No. 035114, & Rs.3,00,000 /- vide Receipt No. 2266389 Dated 02/07//2014 .DD.bearing No. 035115, Issued by PMC Bank.in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **Building No. 8B, 2430.330 Sq.Mtrs.& Building No. 8C, 2429.194 Sq.Mtrs.** as per the letter given by the party Dated : 26/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 074/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.2 on Land bearing S.No.29 H.No. 1/2 at village Waliv, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1302/2014 Dated:19/06/2014
2) An application received by M/s. J.P.Mehta & Associates, Dated:28/6/2013
3) Revised c.c. Issued By VVCMC No. VVCMC/TP/RDP/VP-0015/043/2012-13, Dated:08/05/2012
4) Certificate from License Agency M/s. ,Ronak Fire Industries, Dated:27/06/2014.(Form A)
5) Building Completion certificate BP No.1756(VP No.-0015)/ of M/s. J.P.Mehta & Associates Architect, Dated:-28/03/2013.
6) Built up area certificate BP No.1756(VP No.-0015)/ of M/s. J.P.Mehta & Associates Architect, Dated:-28/03/2013.
7) Structure Stability certificate BP No.1756(VP No.-0015)/ of M/s.. J.P.Mehta & Associates Architect, Dated:-28/03/2013.
8) License to work the Lift From Govt. of Maharashtra Industries, License, No. 134356 Dated:31/08/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.2** Building at above mentioned address. As per c.c issued by VVCMC No. VVCMC/TP/RDP/VP-0015/043/2012-13, Dated:08/05/2012. The party has constructed **"Residential Cum Commercial Building No.2 Building G+6 part Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. Ronak Fire Industries **bearing License No. MFS-LA/RF-0157 dated 18/07/2013 issued by this office and has submitted Certificate on date 27/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A)Vertical Riser Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1479.276 Sq.**Mtr This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.2,00,000/- vide Receipt No. 141813 Dated 28/6/2013 & DD No. 016423 Basin Kathaulik Bank. for the total gross built up area **1479.276 Sq.**Mtr. as per the letter given by the party Dated 28/06/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 075/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential Cum Commercial building Type XX (wing E &F) known as 'REGAL HEIGHT' on Land bearing New S.No. 1,2,3,4 of village :Achole, S.No. 101,103,104,106,107 of village: Manikpur, S.No. 97B,105B,106B of Village: Gokhiware Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1477/ 2014 Dated: 27/ 06 / 2014.
2) An application received by M/s. SHAH GATTANI Consultants Architects & engineer, Dated:26/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/REVI/BP/ZCC-20/E/3755,Dated:- 16/04/2009.
4) Certificate from License Agency M/s. Ronak Fire Industries, Dated:18/07/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. SHAH GATTANI Consultants Architects & engineer, Dated:26/06/2014.
6) Structure Stability certificate of M/s. SHAH GATTANI Consultants Architects & engineer, Dated:26/06/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 137468, 137469 Dated:26/12/2013.,

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial building Type XX (wing E &F) known as 'EEGAL HEIGHT' .** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/REVI/BP/ZCC-20/E/3755,Dated:- 16/04/2009.** The party has constructed **"Residential Cum Commercial building Type XX (wing E &F) known as 'REGAL HEIGHT' , G/S +7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Ronak Fire Industries bearing License No. MFS/LA/RF-0157, Dated- 27/06/2014 issued by this office and has submitted Certificate of dated 27/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. G.I.pipe 'c' class pipe welding of GI elbow fitting & painting
2. Fire hydrant valve
3. Tow way inlet
4. Butterfly vlave 100mm
5. Butterfly valve 80mm
6. GM Air Release valve
7. Good Quality hose reel drum with 30 mtr.ISI pipe & get valve
8. Ms single Door hose box with 15 mtr. Cp hose with M/F coupling and short branch pipe
9. Pressure guage
10. Main pump
11. Booster pump
12. ABC Type fire Extinguisher ISI mark

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to 3019.04 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Received.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 4,00,000 /- vide Receipt No. 187181, Dated 27/06/2014, DD.bearing No. 018060 Issued by Bassein Catholic Co- Bank in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to 3019.04 Sq.Mtrs** as per the letter given by the party Dated 26/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

27/6/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 976/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial building Type R-22 (wing A & B) known as 'PANKIL APARTMENT' on Land bearing New S.No. 1,2,3,4 of village :Achole, S.No. 101,103,104,106,107 of village: Manikpur, S.No. 97B,105B,106B of Village: Gokhiware Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1300/ 2014 Dated: 19/ 06 / 2014.
2) An application received by M/s. SHAH GATTANI Consultants Architects & engineer, Dated:19/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP/ZCC-20/E/126,Dated:- 20/04/2010.
4) Certificate from License Agency M/s. Ronak Fire Industries, Dated:27/06/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. SHAH GATTANI Consultants Architects & engineer, Dated:23/10/2013.
6) Structure Stability certificate of M/s. SHAH GATTANI Consultants Architects & engineer, Dated:25/06/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 135787& 135786, Dated:30/10/2013.,

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential / Residential Cum Commercial building Type R-22 (wing A & B) known as 'PANKIL APARTMENT'.** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/RDP/BP/ZCC-20/E/126,Dated:-20/04/2010.** The party has constructed **"Residential / Residential Cum Commercial building Type R-22 (wing A & B) known as 'PANKIL APARTMENT', St/G +7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Ronak Fire Industries bearing License No. MFS/LA/RF-0157, Dated- 18/07/2013 issued by this office and has submitted Certificate of dated 27/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. G.I.pipe 'c' class pipe welding of GI elbow fitting & painting
2. Fire hydrant valve
3. Tow way inlet
4. Butterfly vlave 100mm
5. Butterfly valve 80mm
6. GM Air Release valve
7. Good Quality hose reel drum with 30 mtr.ISI pipe & get valve
8. Ms single Door hose box with 15 mtr. Cp hose with M/F coupling and short branch pipe
9. Pressure guage
10. Main pump
11. Booster pump
12. ABC Type fire Extinguisher ISI mark

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to 2493.65 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Received.

Under **sub-section (3) of section 3** of " **Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 3,20,000 /- vide Receipt No. 76292, Dated 22/03/2013, DD.bearing No. 185794 Issued by Oriantal Bank of Commerce in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to 2493.65 Sq.Mtrs** as per the letter given by the party Dated 23/10/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 077/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING Bilding No.3, Wing-A,B,C&D, on Land bearing S.No.3, H.No.11, 12, S.No. 4, H.No. 1, 2(p), 3,4,5,8,9,14 at village Walive, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1301 / 2014 Dated: 19 / 06 / 2014.
2) An application received by M/s. En-Con,project Consultants, Dated:19/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0214/087/2012-13,Dated:-27/06/2012.
4) Certificate from License Agency M/s. Ronak Fire Industries, Dated:27/06/2014.(Form A)
5) Building Completion certificate No. VP-0214/087/2012-13 of M/s. En-Con,project Consultants, Dated:-25/04/2013.
6) Built up area certificate No.VVCMC/TP/RDP/ VP-0214/087/2012-13 of M/s. En-Con,project Consultants, Dated:-27/06/2013.
7) Structure Stability certificate No. VVCMC/TP/RDP/ VP-0214/087/2012-13 of M/s. Sanjay Narang & Associates, Dated:-27/06/2013.
8) Installation Permission given by pwd as a. A74498, A4499, Dated:30/10/2013 & A2472, A2473 Dated: 16/08/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING, Bilding No.3, Wing-A,B,C&D,** Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP-0214/087/2012-13,Dated:-27/06/2012 The party has constructed **"RESIDENTIAL CUM COMMERCIAL Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. Ronak Fire Industries **bearing License No. MFS-LA/RF-0157 dated 18/07/2013 issued by this office and has submitted Certificate on date 27/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

Fire Hydrant System:

1. G.I.Pipe 'C' class pipe welding of GI Elbow fitting & painting
2. Fire hydrant valve
3. Two way Inlet
4. Butterfly valve 100mm
5. Butterfly valve 80mm
6. GM Air Release valve
7. Good quality hose reel drum with 30 mtr. ISI pipe & get valve
8. MS single door hose box with 15 mtr. CP hose with M/F coupling and short branch pipe
9. Pressure guage
10. Main pump 25 HP
11. Booster pump 5 HP
12. ABC Type fire Extinguisher ISI mark

This office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **5840.03 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained,

retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.80,000 /- vide Receipt No. 167677, Dated 17/01/2012.DD.bearing No. 938063, Issued by Sindicate Bank,& Rs.10,40,000 /- vide Receipt No. 167678, Dated 17/01/2012.DD.bearing No. 938062, Issued by Sindicate Bank,Branch, & 3,20,000 /- vide Receipt No. 104806, Dated 23/04/2013.DD.bearing No. 016412, Issued by Sindicate Bank,in favour of VVCMC additional Capitation & Scrutiny fees for the Built up area 5840.03 Sq.Mtr. as per the letter given by the party **Dated 25/04/2013.**

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

HCIPAL CORPORATION
RE
AED

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 079/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Commercial building known as "SUN PLAZA" on Land bearing S.No. 38/1A/8, 62A/2 at Village- Navghar, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1337/2014 Dated:20/06/2014
2) An application received by M/s. SUN ENTERPRISES, Dated:12/06/2014
3) Revised c.c. Issued By CIDCO/VVSR/CC/BP-4063/E/6087, Dated:31/03 /2010
4) Certificate from License Agency M/s VIVA ENTERPRISE, Dated:11/06/2014 (Form A)
5) Building Completion certificate & Built up area certificate of M/s. PRITHVI ARCH CONSULTANTS Dated:-01/02/2014.
6) Structure Stability certificate M/s. PRITHVI ARCH CONSULTANTS Dated:-01/02/2014.
7) Lift Affidavit (Undertaking) of M/S. Sun Enterprise, Dated:02/07/2014

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Commercial building known as "SUN PLAZA"** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/CC/BP-4063/E/6087, Dated:31/03/2010. The party has constructed **"Commercial building known as "SUN PLAZA" Building Gr+ 5 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s VIVA ENTERPRISE bearing License No. MFS-LA/F-0139, License No. MFS-LA/D-0107 Dated 11/06/2014. issued by this office and has submitted Certificate on dated 11/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Booster pump 5Hp
2) Wet Riser with main pump
3) Riser system 100 mm dia
4) Hydrant system with accessories on each floor
5) Breaching system
6) Fire extinguisher
7) First aid hose reels & canvas hose pipe

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **327.221** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.80.000 /- vide Receipt No. 187124 Dated 17/06/2014 & DD No.251634 Bank of Baroda for the total gross built up area **327.221** Sq.Mtrs as per the letter given by the party Dated 01/02/2014.

Received two copy.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

CIPAL CORP... RE BRIGAED ... Dist. Thane.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 080/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1, Wing D on Land bearing S.No.269 H.No. 1,2, S.No.270 H.No. 1A, 1B & S.No.272 H.No.2, at village :Nilemore, Waliv, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR / 1304/ 2014 Dated:19/06/2014
2) An application received by M/s. Ajay Wade & Associates, Dated:12/06/2014
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-3202/W/539, Dated:09/06/2010
4) Certificate from License Agency M/s VIVA ENTERPRISE Dated:10/02/2014.. (Form A)
5) Building Completion certificate CIDCO/VVSR/RDP/BP-3202/W/539,/ of M/s. Ajay Wade & Associates Architect, Dated:-3/03/2014.
6) Built up area certificate CIDCO/VVSR/RDP/BP-3202/W/539, / of M/s. Ajay Wade & Associates Architect, Dated:-03/03/2014.
7) Structure Stability certificate Of M/S. Umesh D. Tayshetye, Dated:10/06/2013.
8) Lift License Affidavit (Undertaking) of M/S. Srushti Enterprise, Dated:02/07/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your **Residential Cum Commercial Building No.1, Wing D** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/RDP/BP-3202/W/539, Dated:09/06/2010. The party has constructed **"Residential Cum Commercial Building No.1, Wing D Building Stilt+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s VIVA ENTERPRISE bearing License No. MFS-LA/F0139& MFS-LA/D 0107 issued by this office and has submitted Certificate on dated 10/02/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Costruction area admeasuring **to 1272.46 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,20,000/- vide Receipt No. 187123 Dated 17/6/2014 , DD No. 007872 HDFC Bank. for the total gross Construction area **1272.46 Sq.Mtr**. as per the letter given by the party Dated 03/03/2014.

Received two Copy.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION * Dist. Thane. * FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 081/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Commercial Cum Residential Building .On Land Bearing S. No.39/ A, H. No. 2, S. NO.39/ B, S.No. 39/ C, H.No. 1 at village: Navghar,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 340 / 2014, Dated:- 06/05/2013.
2. **An application received by M/s. Himesh Gupta & Associates ,Dated: 16/04/2014.**
3. **Revised c.c. Issued By VVCMC/TP/RDP/VP-0414/016/2011-12,Dated:- 25/05/2011**
4. **Certificate from License Agency M/s, Fire worx Engineering ,Dated: 30/06/2014.(Form A)**
5. **Building Completion certificate of Himesh Gupta & Associates ,Dated: 16/04/2014.**
6. **Built up area certificate M/s. Himesh Gupta & Associates ,Dated: 16/04/2014.**
7. **Structure Stability certificate of M/s. Umesh D. Tayshetye ,Dated:16/04/2014..**
8. **Lift Completion Undertaking by M/s Gupta Developers, Dated:02/07/2014.**
9. **This office Provisional No objection Certificate No. CIDCO / FIRE / KLM/ 320/ 2010, Dated: 11/03/2010.**

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Commercial Cum Residential Building (G+6pt)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 31/03/2014. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to ~~4103.25~~ 3946.17 **Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 082/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for INDUSTRIAL building no.2 on Land bearing S.No. 151, H.No.1/5, Village: Pelhar Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1535/ 2014 Dated: 30/ 06 / 2014.
2) An application received by M/s. AJAY WADE & ASSOCIATES, Architects, Engineers & Surveyors Dated:20/02/2014.
3) Revised c.c. Issued By CIDCO/VVSR/CC/BP-4614/E/457, Dated:- 28/05/2010
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. AJAY WADE & ASSOCIATES, Architects, Engineers & Surveyors Dated:13/02/2014.
6) Structure Stability certificate LIC No. STR/S/171 of M/s. Suresh Kumar M.Panicker Consultanting Structural Engineers Dated:05/08/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL building no.2 .** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/CC/BP-4614/E/457, Dated:-28/05/2010.** The party has constructed **"INDUSTRIAL building no.2" , G +1 Floors** as per sanctioned Plan.

With reference to above on Dated: 11/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 08/02/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A. Fire Hydrant System.
1. 1400 LPM, 70 mtr. Head 30 HP Subersible pump main pump
2. 450 LPM, 5 HP Booster Pump
3. Electronic motor starter control panel for pump
4. S.S. single Hydrant valve ISI Marked
5. Branch pipe
6. Canvas hose pipe with male female coupling
7. Single door hose box
8. Two way breeching
9. Hose reel drum with tehrmoplast pipe with shut off nozzle
10. ABC Type fire Extinguisher 4 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having **Construction area** admeasuring **to 2461.27 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 1,50,640 /- vide Receipt No. 169215, Dated 03/02/2014, DD.bearing No. 001984 , Rs. 1,50,000 /- vide Receipt No. 170017, Dated 03/02/2014, DD.bearing No. 001983, Issued by HDFC Bank in Favour of VVCMC, Fire Brigade fees for the total **Construction area** admeasuring **to 2461.27 Sq.Mtrs** as per the letter given by the party Dated 03/02/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

2/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 083/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for CFC Building on Land bearing S.No. 123, H.No. 3 & S.No.122,124, Plot No. 1 to 17 at Village: Nilemore, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1374/ 2014 Dated: 21/ 06 / 2014.
2) An application received by M/s. AJAY WADE & ASSOCIATES, Architects, Engineers & Surveyors Dated:16/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/CC/BP-3497/W/354 DATE: 19/05/2010
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate No.BMC Lic No. W/36/LS/VVCMC/ENGR/03 OF M/s. AJAY WADE & ASSOCIATES, Architects, Engineers & Surveyors Dated:16/06/214
6) Structure Stability certificate No. Reg No. STR/T/29 of M/s. UMESH D. TAYSHETYE , Structural Engineers Dated:10/06/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **CFC Building.** Building at above mentioned address. As per c.c issued by **CIDCO/VVSR/CC/BP-3497/W/354 DATE: 19/05/2010.** The party has constructed **"CFC Building " , Gr/st +3 Floors** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 12/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1000 LPM 60mtr head 15HP main submersible pump
2. Control panel for pump
3. S S Single hydrant valve
4. hose box
5. 2way breeching
6. RRL canvas pipe 15 mtr long 63 mm dai with male female coupling with branch pipe
7. Thermpolast hose reel pipe 20 mtr long 20 mm bore with hose drum and shut up nozzle
8. ABC type fire extinguisher 4.5 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having **Construction area** admeasuring **to 808.82 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 80,000 /- vide Receipt No.153434, Dated 07/09/2013, DD.bearing No.000934 Issued by Saraswat Bank in Favour of VVCMC, Fire Brigade fees for the total **Construction area** admeasuring **to 808.82 Sq.Mtrs** as per the letter given by the party Dated 07/09/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 084/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.8 Wing A In Sector-v, phase-I On Land Bearing S. No./ H.No. 180, 181/2, 185/1 to12, 186, 187B, 188/pt, 190, 191, 197, 192, 193, 194, 196, 199, 201, 202, 203, 204/3pt, 204/4, 205/1, 2, 3 pt, 6, 7, 206/pt, 206/pt, 208/1, 2,4 to 8, 209/pt, 211/1, 2,3,6,7pt, 212/3, 213/1, 214/3, 215/pt, 215/pt, 216/1,2,4, 220/pt, 221/1,2, 223/1,2, 250/pt, 251/8, 254, 255/1 to 4, 4/1, 257/1, 259/1, 260pt, 206pt, 261 & 263 at village: Nilemore ,Tal- Vasai, Dist-Thane.

Ref:- 1. **A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1630 / 2014, Dated:- 03/07/2014.**
2. **An application received by M/s. Vijay & Associates, Dated: 02/07/2014.**
3. **Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0022/287/,Dated: 22/03/2012.**
4. **Certificate from License Agency M/s, Fire worx Engineering ,Dated: 25/12/2013.(Form A)**
5. **Building Completion certificate of M/s. Sanat Mehta & Associates Consultants , Dated:-02/08/2014.**
6. **Built up area certificate M/s. Sanat Mehta & Associates, Dated: 02/07/2014.**
7. **Structure Stability certificate of M/s. Vijay & Associates, Dated: 02/07/2014.**
8. **License to work the Lift From Govt. of Maharashtra Industries, License, No. 140751 Dated:- 29/03/2014.**
9. **This office Provisional No objection Certificate No. VVCMC / FIRE / 28E/ 2012-13, Dated:12/10/2012.**

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building No.8 Wing A In Sector-v, phase-I (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 25/12/2013. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2431.97 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Approved plan

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 085/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residincial Bilding No.1 Wing C & D on Plot No.1 to 5 , S.No. 265, H.No. 2, at village: Nilemore ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1179 / 2014, Dated:- 10/06/2014.
2. An application received by M/s. Sanat Mehta & Associates, Dated: 02/12/2013.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / CC / VP-0132/1918/, Dated: 28/12/2011.
4. Certificate from License Agency M/s, Fire worx Engineering , Dated: 12/11/2013.(Form A)
5. Building Completion certificate of M/s. Sanat Mehta & Associates Consultants , Dated:-29/11/2013.
6. Built up area certificate M/s. Sanat Mehta & Associates, Dated: 29/11/2013.
7. Structure Stability certificate of M/s. A-Cube Consultant, Dated: 15/10/2013.
8. License to work the Lift From Govt. of Maharashtra Industries, License, No. 136551, 136564 Dated:- 16/11/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 157/ 2012-13, Dated:03/11/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residincial Bilding No.1 Wing C & D on Plot No.1 to 5 , (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 12/11/2013. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3138.54 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/086/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERTIAL BUILDING Type A4a (748), A1 (747), A1 (746), In Sector F, on land bearing New S.No. 1,2,3,4, of village: Achole. S.No. 101, 103, 104, 106, 107 of village Manikpur S.No. 97B,105B,106B of village:Gokhiware, S.NO.254, H.No.3,6,7/1,7/2,13,14,15 &16 of village: Achole, S.NO.128, H.NO-6 ,S.NO.106, H.NO.8, S.NO.110, H.NO.8/1 of village: Gokhiware.Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1362/ 2014 Dated: 21 / 06 / 2014.
2) An application received by M/s. Shah Gatani Consultants, Dated:21/06/2014..
3) Revised c.c. Issued By CIDCO/,VVSR/RDP/BP/ZCC-20/E/124, Dated:-20/04/2010.
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:15/02/2014. (Form A)
5) Building Completion certificate of M/s . Shah Gatani Consultants, Dated: 01/07/2014
6) Built up area certificate of M/s . Shah Gatani Consultants, Dated: 19/06/2014.
7) Structure Stability certificate of M/s . Shah Gatani Consultants, Dated: 19/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 139362,139365 Dated:-07/02/2014.&138898 Dated:-25/09/2013

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERTIAL BUILDING Type A4a(748), A1(747), A1(746), In Sector F** Building at above mentioned address. As per c.c issued by **CIDCO/,VVSR/RDP/BP/ZCC-20/E/124, Dated:-20/04/2010.** The party has constructed **"RESIDENTIAL CUM COMMERTIAL BUILDING Type A4a(748), A1(747), A1(746) Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, dated 16/08/2013 issued by this office and has submitted Certificate of dated 15/02/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1400LPM 56 mtr. Head 20 HP main pump-1 Nos.
2. 5 Hp Booster pump-1 Nos.
3. S S Single hydrant Valves-9 Nos
4. Hose box-2 Nos
5. 2 Way Breeching-1 Nos
6. RRL Canvas pipe 15 mtr long 63 mm dia with male female coupling with branch pipe-20 Nos
7. Thermpolast hose reel pipe 20mtr long 20mm bore with hose drum and shut up nozzle-7 Nos.
8. ABC type fire extinguisher 4kg capacity-9 Nos

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 4743.80 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained,

retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.6,00,000 /- vide Receipt No. 187144, Dated 21/06/2014 & .DD.bearing No. 118939, Issued by Bank of India .in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **4743.80 Sq.Mtrs.** as per the letter given by the party Dated 19/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

ICIPAL CORPORATION RE AED

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 087/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residincial Cum Commercial Bilding No.1 Wing A, & Residincial Wing B (G+7) on Plot bearing S.No. 10, ,H.No. 2/1 at village Nilemore ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1307 / 2014, Dated:- 19/06/2014.
2. An application received by M/s. Sanat Mehta & Associates, Dated: 08/05/2013.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / BP-4648/W/VP-0331/01/ 2011-12, Dated: 15/04/2011.
4. Certificate from License Agency M/s, Fire worx Engineering , Dated: 28/06/2014.(Form A) (Form A).
5. Building Completion certificate of M/s. Sanat Mehta & Associates Consultants , Dated:-28/05/2013.
6. Built up area certificate M/s. Sanat Mehta & Associates, Dated: 08/05/2013.
7. Structure Stability certificate of M/s. A-Cube Consultant, Dated:-10/05/2013.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 130397 & 130398, Dated:- 21/05/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 276/ 2012-13, Dated:19/03/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residincial Cum Commercial Bilding No.1 Wing A, & Residincial Wing B (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 28/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3090.25 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

2/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 088/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residincial Cum Commercial Bilding No.8 Wing D In Sector-V, Phase-I, on Land Bearing S.No. / H.No. 180, 185/1 to 12, 186, 187B, 188/pt,190,191,197,192,193,194,196,199,201,202,203,204/3pt,204/4,205/1,2,3pt,6,7,206 /pt,206/pt,208/1,2,4 to 8, 209/pt, 211/1,2,3,6,7pt, 212/3,213/1, 214/3,215/pt, 215/pt, 216/1,2,4,220/pt,221/1,2,250/pt,250/pt,251/8,254,255/1to4,4/1,257/1,259/1,260pt,260pt, 261&263 at village: Nilemore ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1627 / 2014, Dated:- 06/07/2014.
2. An application received by M/s. Vijay & Associates, Dated: 01/07/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0022/287/2011-12, Dated: 22/03/2012.
4. Certificate from License Agency M/s, Fire worx Engineering , Dated: 25/12/2013.(Form A)
5. Building Completion certificate of M/s. Sanat Mehta & Associates Consultants , Dated:-01/07/2014.
6. Built up area certificate M/s. Sanat Mehta & Associates, Dated: 01/07/2014.
7. Structure Stability certificate of M/s. Vijay & Associates, Dated: 01/07/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 135013, Dated:- 01/10/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 128H/ 2012-13, Dated:12/10/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residincial Cum Commercial Bilding No.8 Wing D In Sector-V, Phase-I, (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 25/12/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2514.52 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 089/2014-15 DATE: 02/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" For Residential Cum Commercial Building Type SR4A (Wing A & B) Known as ' Sai Prabhat Complex' on land bearing S.No. 1,2,3,4, of village: Achole, S.No. 101,103,104,106,107, of Village: Gokhiware, Tal: Vasai, Dist: Thane, S.No. 254, H.No. 3,6,7/1,7/2,13,14,15 & 16 Of village:Achole , S.No. 128, H.No. 8/1, of Village: Gokhiware, Tal: Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1500/2014 Dated:26/06/2014
2) An application received by M/s. Shah Gattani Consultant, Dated: 24/06/ 2014
3) Revised c.c. Issued By VVCMC No. VVCMC/TP/RDP/VP-0743/096/2012-13, Dated:11/07/2012.
4) Certificate from License Agency M/s. Fire worx Engineering , Dated: 28/06/2014.(Form A)
5) Building Completion certificate m/s. Shah Gattani Consultant, Dated: 24/06/ 2014.
6) Built up area certificate of M/s . Shah Gattani Consultant, Dated: 24/06/ 2014.
7) Structure Stability certificate of M/s. Shah Gattani Consultant, Dated: 24/06/ 2014
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. 141257,141256 Dated:- 29/04/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building Type SR4A (Wing A & B) Known as ' Sai Prabhat Complex'**at above mentioned address. As per c.c issued by **VVCMC No. VVCMC/TP/RDP/VP-0743/096/2012-13, Dated:11/07/2012.**The party has constructed **" Residential Cum Commercial Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s.Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 28/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1400LPM 56 mtr. Head 20 HP main pump-1 Nos.
2. 5 Hp Booster pump-1 Nos.
3. S S Single hydrant Valves-9 Nos
4. Hose box-2 Nos
5. 2 Way Breeching-1 Nos
6. RRL Canvas pipe 15 mtr long 63 mm dia with male female coupling with branch pipe-20 Nos
7. Thermpolast hose reel pipe 20mtr long 20mm bore with hose drum and shut up nozzle-7 Nos.
8. ABC type fire extinguisher 4kg capacity-9 Nos

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2672.58 Sq.Mtrs**. This certificate shall be treated valid **up**

to 31/12/2014. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupierwill be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the 187187 Dated 27/06/2014, DD No. 140173 Ratnakar Bank. for the total gross built up area **2672.58 Sq.Mtr**. as per the letter given by the party Dated 24/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 090/2014 -15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building Wing A On Land Bearing S. No.402A, Plot No. 241 & 255 at village: Virar,Tal- Vasai, Dist-Thane.

Ref :-
1. **A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1499 / 2014, Dated:-27/06/2014.**
2. **An application received by M/s. Shree Giridhar Enterprise,Dated: 23/06/2014.**
3. **Revised c.c. Issued By VVCMC No. VVCMC / TP / AMD / VP-0782/144/ 2011-12/,Dated: 30/11/2011.**
4. **Certificate from License Agency M/s, Fire worx Engineering ,Dated: 31/03/2014.(Form A)**
5. **Building Completion certificate of M/s. Shah Gattani Consultants,Dated:-18/05/2013.**
6. **Built up area certificate M/s. Shah Gattani Consultants,Dated:-18/05/2013.**
7. **Structure Stability certificate of M/s. Shah Gattani Consultants,Dated:-18/05/2013.**
8. **License to work the Lift From Govt. of Maharashtra Industries, License, No. 132043 Dated:- 03/08/2014.**
9. **This office Provisional No objection Certificate No. VVCMC / FIRE / 111/ 2012-13, Dated:27/09/2012.**

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building Wing A (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 31/03/2014. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1193.25 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 091/2014-15 DATE: 02/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential Building Type RSA2-6 (wing B) wing in Avenue- A1, known as GLOBAL CITY on Land bearing New S.No.5,5B,5F,5G,5D at village Dongre ,Virar (W),Tal- Vasai, Dist- Thane.

Ref :-
1. **A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1628/ 2014, Dated:- 03/07/2014.**
2. **An application received by Shri Mathuresh Enterprises, Dated: 23/06/2014.**
3. **Revised C.C. Issued By No. VVCMC / TP / RDP / VP-0453/296/2011-12 Dated- 31/03/2012**
4. **Certificate from License Agency M/s, Fire Worx Engineering, Dated: 31/03/2014 (Form A).**
5. **Building Completion certificate of M/s. Shah Gattani Consultants, Dated:25/6/2014**
6. **Built up area certificate of Shah Gattani Consultants, Dated: - 25/06/2014.**
7. **Structure Stability certificate of Shah Gattani Consultants, Dated: - 25/06/2014.**
8. **License to work the Lift From Govt. of Maharashtra Industries, licence, No. 139111 Dated-20/01/2014**
9. **This Office Provisional No Objection Certificate vvcmc/fire/110/2012-13 Dated- 27/09/2012**

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Building Type RSA2-6 (wing B) wing (part G+7) in Avenue- A1, known as GLOBAL CITY** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 31/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2344.65 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION * Dist. Thane. FIRE BRIGAED

Dattatray 2.7.2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 092/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for INDUSTRIAL building no.1 & 4 on Land bearing S.No. 36, H.No.12, Village: Waliv Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1497/ 2014 Dated: 27/ 06 / 2014.
2) An application received by M/s. EN CON Project Consultants Architectural & Structural works, Dated:25/04/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0009/0184/2012-13,Dated:- 08/02/2013
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Project Consultants Architectural & Structural works, Ref No. VP-0009/69, 70,72, 73{BP-4420} Dated:23/04/2014.
6) Structure Stability certificate of M/s. Sanjay Narang & Associates, Ref . No.VP-0009/71, 74 {BP-4420} Dated:23/04/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL building no.1 & 4'.** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0009/0184/2012-13,Dated:-08/02/2013.** The party has constructed **"INDUSTRIAL building no.1 & 4" , G +2 pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 31/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1200 LPM, 56 mtr. Head 20 HP Subersible pump
2. 450 LPM, 35Mtr. Head 5 HP Booster Pump
3. S.S. single Hydrant valve
4. Hose box
5. Branch pipe
6. RRL Canvas pipe 15 mtr long 63mm dia with male female coupling with branch pipe
7. Two way breeching
8. Thermoplast hose reel pipe 20 mtr long 20mm bore with hose drum and shut up nozzle
9. ABC Type fire Extinguisher 4 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to 744.12 Sq.Mtrs & 690.82 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Bldg No.1, Rs. 85,000 /- vide Receipt No. 187105, Dated 28/04/2014, DD.bearing No. 255832 Issued by Bank of India, Rs. 85,000 /- vide Receipt No. 187106, Dated 28/04/2014, DD.bearing No. 255831 Issued by Bank of Baroda & Bldg No.4, Rs. 40,000 /- vide Receipt No. 187107, Dated 28/04/2014, DD.bearing No. 255830 Issued by Bank of **Baroda**, Rs. 40,000 /- vide Receipt No. 187108, Dated 28/04/2014, DD.bearing No. 255829 Issued by Bank of Baroda in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to 744.12 Sq.Mtrs & 690.82 Sq.Mtrs** as per the letter given by the party Dated 28/04/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY ... CIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

ICIPAL CORPORATION ED

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 093/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Automobiles shops & Godown Unit no01,2 & 73 on Land bearing S.No. 72+75/1+75+277/1(p)+77/2+65+69/1+70+71(p)+78+213/2(p), at Village: Pelhar, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1632/ 2014 Dated: 03/ 07 / 2014.
2) An application received by M/s.HIMESH GUPTA & ASSOCIATES Urban Planners, Architectural & Structural consultant, Dated:01/07/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0898/0188/2013-14,Dated:-20/07/2013
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate Reg. No.VVCMC/ENGR/08 of M/s. HIMESH GUPTA & ASSOCIATES Date: 23/06/2013.
6) Structure Stability certificate of M/s. Swati Structure Solutions Pvt.Ltd. , Structural Consultants,Engineers & Estimators Dated:30/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Automobiles shops & Godown Unit no01,2 & 73 .** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0898/0188/2013-14,Dated:-20/07/2013.** The party has constructed **"Automobiles shops & Godown Unit no01,2 & 73" , G +2 p Floors** as per sanctioned Plan.

With reference to above on Dated: 07/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Mian pump: 1400 LPM 70mtr head 30HP
2. Jockey pump : 180 LPM 70Mtr head. 7.5 HP
3. Control panel to above pump
4. S S Single hydrant valve
5. Double door hose box
6. 2way breeching
7. RRL canvas pipe 15 mtr long 63 mm dai with male female coupling with branch pipe
8. Thermpolast hose reel pipe 20 mtr long 20 mm bore with hose drum and shut up nozzle
9. ABC type fire extinguisher 4.5 kg capacity
10. CO2 type fire extinguisher 4.5 kg capacity
11. M/foam type fire extinguisher 9 Ltr capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having **Construction area** admeasuring **to 1624.33 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed

form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 1,70,000 /- vide Receipt No. 226648, Dated 03/07/2014, DD.bearing No.005475 Issued by State Bank of India in Favour of VVCMC, Fire Brigade fees for the total **Construction area** admeasuring **to 1624.33 Sq.Mtrs** as per the letter given by the party Dated 03/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

7/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Rady

IPAL CORPORATION E AED Thane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 094/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for INDUSTRIAL building no.2 (Wing A) on Land bearing S.No. 36, H.No.10, Village: Waliv Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1629/ 2014 Dated: 03/ 07 / 2014.
2) An application received by M/s.EN CON Project Consultants Architectural & Structural works, Dated:30/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0785/124/2011-12,Dated:- 31/10/2011
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Project Consultants Architectural & Structural works, Ref No. VP-0785/43, 44 Dated:28/06/2014.
6) Structure Stability certificate of M/s. Sanjay Narang & Associates, Ref . No.VP-0785/46 Dated:28/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL building no.2 (Wing A) .** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0785/124/2011-12,Dated:-31/10/2011.** The party has constructed **"INDUSTRIAL building no.2 (Wing A) " , G +1 pt Floors** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 23/10/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1140 LPM,60 mtr. Head 20 HP Subersible pump Main pump
2. 450 LPM, 5 HP Booster Pump
3. Electronic motor starter control panel for pump
4. S.S. single Hydrant valve ISI marked
5. Branch pipe
6. Canvas hose pipe with male female coupling
7. Single door hose box
8. Two way breeching
9. Hose reel drum with thermoplast pipe with shut off nozzle
10. ABC Type fire Extinguisher 4 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to 792.93 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40,000 /- vide Receipt No. 153661, Dated 12/09/2013, Rs. 40,000 /- vide Receipt No. 153662, Dated 12/09/2013, DD.bearing No. 016943 Issued by in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to 792.93Sq.Mtrs** as per the letter given by the party Dated 12/09/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 095/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for INDUSTRIAL building no.5 on Land bearing S.No. 233/C 233/B&281, H.No.2, Village: Gokhivare Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1382/ 2014 Dated: 21/ 06 / 2014.
2) An application received by M/s. EN CON Project Consultants Architectural & Structural works, Dated:21/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0196/094/2013-14,Dated:- 12/06/2013
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Project Consultants Architectural & Structural works, Ref No. VP-196/112, 113, Dated:19/06/2014.
6) Structure Stability certificate of M/s. Sanjay Narang & Associates, Ref No. VP-196/114, Dated:19/06/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License No.143462 Dated:20/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL building no.5.** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0196/094/2013-14,Dated:-12/06/2013.** The party has constructed **"INDUSTRIAL building no.5" , G +2 pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 25 /06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 12/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1400 LPM, 70 mtr. Head 25 HP Subersible pump
2. 450 LPM, 35mtr. Head 5 HP Booster Pump
3. Control panel pump
4. S.S. single Hydrant valve
5. Hose box
6. RRL Canvas pipe 15 mtr long 63mm dia with male female coupling with branch pipe
7. Two way breeching
8. Thermoplast hose reel pipe 20 mtr long 20mm bore with hose drum and shut up nozzle
9. ABC Type fire Extinguisher 4 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to 3468.40 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 2,40,000 /- vide Receipt No. 187130, Dated 19/06/2014, DD.bearing No. 365518 Issued by Union Bank , Rs. 2,40,000 /- vide Receipt No. 187131, Dated 19/06/2014, DD.bearing No. 365519 Issued by Union Bank in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to 3468.40 Sq.Mtrs** as per the letter given by the party Dated 19/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 096/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Building Type SR5(Wing A,B,C) Known as ' Galaxy Apartment' on Land bearing S.No.1,2,3,3,4 Of Village: Achole S.No. 101,103,104,106,107 Of village: Gokhiware, Tel: Vasai, Dist: Thane, S.No. 254, H.No. 3,6,7/1,7/2,13,14,15 & 16 of Village: Achole, S.No. 128, H.No. 8/1, of Village: Gokhiware, Tel: Vasai, Dist: Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1679 / 2014, Dated:- 05/07/2014.
2. An application received by M/s. Shah Gattani Consultants & Orchid Consultants, Dated: 02/07/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP-0743 / 0200 / 2012-13. Dated: 22/02/2013.
4. Certificate from License Agency M/s, Fire Worx Engineering, Dated:30/06/2014 (Form A).
5. Building Completion certificate of M/s. Shah Gattani Consultants for, Dated: 01/07/2014.
6. Built up area certificate Shah Gattani Consultants for, Dated: 01/07/2014.
7. Structure Stability certificate of M/s. Shah Gattani Consultants for, Dated: 01/07/2014.
8. Lift Completion Undertaking by M/S. Orchid Consultants, Dated: 01/07/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 84 / 2013-14, Dated:15/05/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Building Type SR5(Wing A,B,C) Known as ' Galaxy Apartment'** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s.Fire Worx Engineering bearing License No. MFS-LA/F- 43A/2014, dated 16/08/2013 issued by this office and has submitted Certificate on 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **4054.14 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 097 /2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for INDUSTRIAL building no.3 and RG Structure on Land bearing S.No. 75, H.No.2, Village: Waliv Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1498/ 2014 Dated: 27/ 06 / 2014.
2) An application received by M/s. PRITHVI Arch Consultants Dated:04/10/2013.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0801/185/2011-12,Dated:- 18/01/2012
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. PRITHVI Arch Consultants Date:03/03/2014 & Date: 03/10/2013.
6) Structure Stability certificate of M/s. PRITHVI Arch Consultants Dated:03/10/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL building no.3 and RG Structure .** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0801/185/2011-12,Dated:- 18/01/2012.** The party has constructed **"INDUSTRIAL building no.3" , G +2 pt Floors and RG Structure Gr. Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 15/02/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1400 LPM, 70 mtr. Head 30 HP Subersible pump
2. 450 LPM, 5 HP Booster Pump
3. S.S. single Hydrant valve
4. Branch pipe
5. Canvas hose pipe with male female coupling
6. Single door hose box
7. Two way breeching
8. First air hose reel drum fitted with 20 mm dia. Thermoplast rubber hose with stop valve
9. ABC Type fire Extinguisher 5 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to 5620.927 & 198.006 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 4,50,640 /- vide Receipt No. 187157, Dated 24/06/2014, DD.bearing No. 010866 , Rs. 40,000 /- vide Receipt No. 187155, Dated 24/06/2014, DD.bearing No. 010865, Rs. 40,000 /- vide Receipt No. 187154, Dated 24/06/2014, DD.bearing No. 010864, Rs. 5,00,000 /- vide Receipt No. 187156, Dated 24/06/2014, DD.bearing No. 010867 & Rs. 49,360 /- vide Receipt No. 167581, Dated 16/01/2012, Issued by HDFC Bank in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to 5620.927 & 198.006 Sq.Mtrs** as per the letter given by the party Dated 24/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

7/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

CIPAL CORPORATION RE GAED Thane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 098/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of <u>Automobiles shops & Godowns Unit No.15 On land bearing S.No. 72+75/1+75/2+77/1(p)+65+69/1+70+71(p)+78+213/2(p)</u> of Villge: Pelhar, Tal: Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept. No. VVCM/NR/1610/2014 Dated: 16/09/2013.
2) An application received by M/s. Himesh Gupta & Associates, Dated:06/09/2013.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0898/018/2013-14, Dated: 15/04/2013.
4) Certificate from License Agency M/s.Fire Worx Engineering , Dated: 31/03/2014. (Form A)
5) Building Completion certificate of m/s Himesh Gupta & Associates, Dated:06/09/2013.
6) Construction area certificate of m/s. Himesh Gupta & Associates, Dated:06/09/2013.
7) Structure Stability certificate of M/s.. A- Cube Consultant , Dated:01/07/2014

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **<u>Automobiles shops & Godowns Unit No.15 On land bearing S. No. 72 + 75/1 + 75/2 + 77/1(p) + 65 + 69/1 + 70 + 71(p) + 78 + 213/2(p)</u>** Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP-0898/018/2013-14, Dated: 15/04/2013 The party has constructed **"<u>Automobiles shops & Godowns Unit No.15</u> G+1 (pt) Floors"** as per sanctioned Plan.

With reference to above on Dated: 11/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering, bearing License No. MFS-LA/F- 0227, Dated:16/08/2013 issued by this office and has submitted Certificate of Dated: 31/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1000 LPM, 44 Mtr. head, 10 HP Submersible pump :-1 nos
2. Control Panel for pump :- 01 nos
3. S S Single hydrant Valves:-3 nos.
4. Hose box :- 3 nos
5. 2 way Breeching:-1 nos.
6. RRL Canvas pipe 15mtr. Long 63mm dia with male female coupling with branch pipe :- 3 nos
7. Thermpolast hose reel pipe 20mtr. Long 20 mm bore with hose drum and shut up nozzle:- 3 nos
8. ABC type fire extinguisher 4kg cap:-4 nos

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring to **230.35 Sq.Mtrs.** This certificate shall be treated valid **<u>up to 31/12/2014.</u>** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **<u>sub-section (3) of section 3</u>** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.80,000/- vide Receipt No. 90828, Dated: 16/04/2013, DD No. 270101, DCB Bank. for the total gross Construction area **230.35 Sq.Mtrs.** as per the letter given by the party Dated:- 06/09/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 099/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for INDUSTRIAL building on Land bearing S.No. 103, H.No.4, Village: Sativali, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1631/ 2014 Dated: 03/ 07 / 2014.
2) An application received by M/s.EN CON Project Consultants Architectural & Structural works, Dated:27/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0497/0164/2012-13,Dated:- 08/01/2013
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:16/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Project Consultants Architectural & Structural works, Ref No. VP-0497/15, 16 Dated:24/06/2014.
6) Structure Stability certificate of M/s. Sanjay Narang & Associates, Ref . No.VP-0497/18 Dated:26/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL building.** Building at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-0497/0164/2012-13,Dated:-08/01/2013.** The party has constructed **"INDUSTRIAL building " , G +2 pt Floors** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS/LA/F0227, Dated- 16/08/2013 issued by this office and has submitted Certificate on dated 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 1200 LPM,50 mtr. Head 20 HP Subersible pump
2. 450 LPM, 5 HP Booster Pump
3. S.S. single Hydrant valve
4. Branch pipe
5. Canvas hose pipe with male female coupling
6. Single door hose box
7. Two way breeching
8. First air Hose reel drum fitted with 20 mm dia. thermoplast rubber hose with stop valve

This office is issuing a **"Final No Objection Certificate"** for your following building having **Built up area** admeasuring **to 601.94 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection

system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40,000 /- vide Receipt No. 226610, Dated 01/07/2014, DD.bearing No. 831737, Rs. 40,000 /- vide Receipt No. 226611, Dated 01/07/2014, DD.bearing No. 831738 Issued by Union Bank in Favour of VVCMC, Fire Brigade fees for the total **Built up area** admeasuring **to 601.94 Sq.Mtrs** as per the letter given by the party Dated 01/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

IPAL CORPORATION E AED

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 101/2014-15 DATE: 07/07/2014

TO,

M/s. Arihant Developers
Arihant Industrial Park, Shivaji Nagar, Opp.K.T.
Industrial Park, Waliv village, Vasai (E), Dist-Thane.

Sub:- "Renewal of Final No Objection Certificate" of Industrial Building on Land bearing S.No.9H, No. 1/1,1/2&1/3 H.No.4 at village: Waliv, Tal: Vasai, Dist: Thane.

Ref :- 1. An application received by M/s. Arihant Developers, Dated: 30/06/2014.
2. Certificate from License Agency M/s, Fire Worx Engineering , Dated:16/08/2013 (Form B).
3. This office final No objection Certificate No. VVCMC / FIRE /243/ 2012-13, Dated:20/02/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Industrial Building** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227 , issued by this office and has submitted Certificate on dated- 30/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per Final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.37,500 /- vide Receipt No. 226614, Dated 01/07/2014.DD.bearing No. `592570. Issued by Vijaya Bank renewal fees for the said building..

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 102/2014-15 DATE: 07/07/2014

TO,

M/s.Rajesh Harakchand Dedhia
Survey No.36/15, Bldg. No. 2 UniQue Ind. Complex,
Dhumal Nagar, Waliv, Vasai (W)] Dist-Thane.

Sub:- "Renewal of Final No Objection Certificate" of Industrial Building Plot No.2 Building No.2, on Land bearing S.No.36 H.No. 15, at village: Waliv, Tal: Vasai, Dist: Thane.

Ref :- 1. An application received by M/s.Rajesh Harakchand Dedhia, Dated: 15/04/2014.
2. Certificate from License Agency M/s, Fire Worx Engineering , Dated:16/08/2013 (Form B).
3. This office final No objection Certificate No. VVCMC / FIRE /27/ 2013-14, Dated:18/04/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Industrial Building Plot No.2, Building No.2** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227 , issued by this office and has submitted Certificate on dated-30/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per Final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.21,250 /- vide Receipt No. 226819, Dated 07/07/2014.DD.bearing No. 011336. Issued by HDFC Bank renewal fees for the said building..

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 103/2014-15 DATE: 07/07/2014

TO,

Mr. Yogesh S. Mishra
203 Indumati Apartment, near Celebrity Hotel,
Ambadi Road, Vasai (W)] Tal-Vasai,
Dist-Thane.

Sub:- "Renewal of Final No Objection Certificate" of Siddheshwar Industrial Building on Land bearing S.No.44 H.No. 3pt, at village: Waliv, Tal: Vasai, Dist: Thane.

Ref :- 1. An application received by Mr. Yogesh S. Mishra, Dated: 04/07/2014.
2. Certificate from License Agency M/s, Fire Worx Engineering , Dated:16/08/2013 (Form B).
3. This office final No objection Certificate No. VVCMC / FIRE /19/ 2012-13, Dated:23/05/2012.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Siddheshwar Industrial Building** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227 , issued by this office and has submitted Certificate on dated- 30/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per Final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.10,000 /- vide Receipt No. 226691, Dated 04/07/2014.DD.bearing No. `365696. Issued by Union Bank renewal fees for the said building..

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 104/2014-15 DATE: 07/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1, (Wing A,B,C) on Land bearing S.No.127, H.No.6, S.No. 129, H.No. 7/3, S.No.130, H. No.4(pt), 5,6,7,8,9,10,11,12,13,14,& 28, S.No. 131,H.No.1 Of Village: Virar, Tel: Vasai, Dist: Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1480 / 2014, Dated:- 27/06/2014.
2. An application received by M/s. En Con Consultants / Shree Ganesh Asociates, Dated: 10/02/2014.
3. Revised c.c. Issued By CIDCO/VVSR/CC/BP-4632/E/674, Dated: 22/02/2013.
4. Certificate from License Agency M/s, Noble Firetech Engineers, Dated: 07/02/2014 (Form A).
5. Building Completion certificate of M/s. En Con Consultants , Dated: 11/12/2013.
6. Built up area certificate M/S. En Con Consultants , Dated: 09/10/2013.
7. Structure Stability certificate of M/s. Sanjay Narang & Associates for, Dated: 11/12/2013.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 139144, 139146,139145 Dated:-20/01/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 197 / 2011-12, Dated:22/03/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building No.1, (Wing A,B,C)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Noble Firetech Engineers, bearing License No. MFS-LA/F- 0156-D dated 18/07/2012 issued by this office and has submitted Certificate on 07/02/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3675.55 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received
11.07.2014

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 105/2014-15 DATE: 07/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.2 (Wing A to D) on land bearing S.No. 191,197,190 & S.No. 251, H.No. 8, of village- Nilemore, Tal- Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1349/ 2014 Dated: 20/ 06 / 2014.
2) An application received by M/s. Himesh gupta & Associates, Dated: 26/02/2014.
3) Revised c.c. Issued by VVCMC/TP/RDP/VP-0605& VP-0096/125/2011-12, Dated:31/10/2011
4) Certificate from License Agency M/s. Alpha National Fire Safety Services Pvt. Ltd., Dated:22/06/2014. (Form A)
5) Building Completion certificate of M/s Himesh gupta & Associates, Dated: 24/05/2012.
6) Builtup area certificate M/s Himesh gupta & Associates, Dated: 07/04/2012.
7) Structure Stability certificate Reg.No. STR/T/29 of M/s. Umesh D. Tayshetye, Dated: 24/05/2012
8) License to work the Lift From Govt. of Maharashtra Industries, License No.119044,119045,119046,119047Dated:-06/03/2013.
9) CIDCO Provisional No objection Certificate No. CIDCO/ FIRE /KLM/506/2010 Dated:16/04/2010.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building No.2 (Wing A to D),** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Alpha National Fire Safety Services Pvt. Ltd. bearing License No. MFS-LA/RD-0017, License No. MFS-LA/RD-0020, issued by this office and has submitted Certificate on Date:22/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **30007.55** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 16,40,066 /- vide Capitation & Scrutiny fees for the total Construction area admeasuring **to 15336.42 Sq.Mtrs**. as per the letter given by Himesh Gupta & Associates Dated 23/01/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 106 /2014-15 DATE: 10/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING No.1, PH-1, Sector –IV, wing B & C Shreenath Nagar on land bearing S.No.180,181/2,185/1to12, 186, 187B,188/pt,190,191,197,192,193,194 &196,199, 201, 202,203, 204/3Pt, 204/4,205/1,2,3/Pt,6,7,206/Pt,208/1,2,4to8,209/Pt,211, 1,23, 6,7/pt, 212/3, 213/1,214/3, 215/pt &215/pt, 216/1,2,4, 220/pt,221/1&2, 223/1&2, 250/pt. &251/8, 254,255/1to4, 257/1, 259/1,260/pt.&260/pt.,261,263 at Village-Nilemore, Tal-Vasai, Dist-Thane.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/1693/2014 Dated: 07/07/2014.
2) An Application received by M/s. Shreenath Enterprises.Dated:-30/06/2014.
3) Revised c.c. Issued by VVVMC/TP/RDP/VP-0420/135/2011-12 Dated:-18/11/2011
4) Certificate from License Agency M/s Shree Sainath Enterprises, Dated:-01/08/2013 (Form A)
5) Building Completion certificate of M/s Sanat Mehta & Associates, Dated:-30/07/2013
6) Build up area certificate No. VVVMC/ TP/RDP/VP-0420 of of M/s Sanat Mehta & Associates , Dated:-30/07/2013
7) Structure Stability certificate of A-Cube Consultant.Dated:-30/06/2014.
8) License to work the Lift From Govt.of Maharashtra Industries, License No.132596 & 132594 Dated:- 23/07/2013

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.1, PH-1, Sector –IV, wing B & C** Building at above mentioned address. As per c.c issued by **VVVMC/TP/RDP/VP-0420/135/2011-12 Dated:-18/11/2011** The party has constructed **"RESIDENTIAL CUM COMMERCIAL BUILDING G +7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Shree Sainath Enterprises bearing License No. –MFS-LA/RF-0076 ,Dated- 11/09/2012 issued by this office and has submitted Certificate of dated -01/08/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

- Vertical riser cum down comer
1. Landing valve each floor
2. Courtyard Hydrant
3. Fire services inlet
4. Booster pump- 5HP
5. Main Electrical pump - 20HP
6. Fire extinguisher ABC – 5kg
7. Fire extinguisher Co2 – 3kg
8. Sprinkler system.

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring **to 2814.93 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 4,00,000 /- vide Receipt No. 226813, Dated 07/07/2014, DD.bearing No. 019390 Issued by Basin Catholic Bank fees for the total built up area admeasuring **to 2814.93 Sq.Mtrs.**

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan . of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

ICIPAL CORPORATION
RE
GAED
Thane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 107 /2014-15 DATE: 10/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING No.2, PH-1, Sector –IV, wing A, B & C Shreenath Nagar on land bearing S.No.180,181/2,185/1to12, 186, 187B,188/pt,190,191,197,192,193,194 &196,199, 201, 202,203, 204/3Pt, 204/4,205/1,2,3/Pt,6,7,206/Pt,208/1,2,4to8,209/Pt,211, 1,23, 6,7/pt, 212/3, 213/1,214/3, 215/pt &215/pt, 216/1,2,4, 220/pt,221/1&2, 223/1&2, 250/pt. &251/8, 254,255/1to4, 257/1, 259/1,260/pt.&260/pt.,261,263 at Village-Nilemore, Tal-Vasai, Dist-Thane.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/1692/2014 Dated: 07/07/2014.
2) An Application received by M/s. Shreenath Enterprises.Dated:-30/06/2014.
3) Revised c.c. Issued by VVVMC/TP/RDP/VP-0420/135/2011-12 Dated:-18/11/2011
4) Certificate from License Agency M/s Shree Sainath Enterprises, Dated:-01/08/2013 (Form A)
5) Building Completion certificate of M/s Sanat Mehta & Associates, Dated:-30/07/2013
6) Build up area certificate No. VVVMC/ TP/RDP/VP-0420 of of M/s Sanat Mehta & Associates , Dated:-30/07/2013
7) Structure Stability certificate of A-Cube Consultant.Dated:-30/06/2014.
8) License to work the Lift From Govt.of Maharashtra Industries, License No.132595, 132596 & 132597 Dated:- 23/07/2013

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.2, PH-1, Sector –IV, wing A, B & C** Building at above mentioned address. As per c.c issued by **VVVMC/TP/RDP/VP-0420/135/2011-12 Dated:-18/11/2011** The party has constructed **"RESIDENTIAL CUM COMMERCIAL BUILDING G +7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Shree Sainath Enterprises bearing License No. –MFS-LA/RF-0076 ,Dated- 11/09/2012 issued by this office and has submitted Certificate of dated -01/08/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

- Vertical riser cum down comer

1.Landing valve each floor
2.Courtyard Hydrant
3.Fire services inlet
4.Booster pump- 5HP
5.Main Electrical pump - 20HP
6.Fire extinguisher ABC – 5kg
7.Fire extinguisher Co2 – 3kg

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring **to 6260.58 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

Received

The Fire Fighting System provided by you in the premises ,shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.6,00,000 /- vide Receipt No. 226814, Dated 07/07/2014, DD.bearing No. 019389 Issued by Basin Catholic Bank fees for the total built up area admeasuring **to 6260.58 Sq.Mtrs.**

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan . of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 108/2014-15 DATE: 10/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Industrial Building located On Plot No.7, S.No. 7+8/1+8/2+8/3+11+12/1/2+67(pt), at Village: Sativali, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 1496/ 2014 Dated: 27/06/2014
2) An application received by M/s. EN CON Consultants, Dated:13/05/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0624/0197/2012-13, Dated:21/02/2013.
4) Certificate from License Agency M/S. Neo Enterprises, Dated:25/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-18/01/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, date-18/01/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Industrial Building located On Plot No.7,** Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP-0624/0197/2012-13, Dated:21/02/2013. The party has constructed **"Industrial Building located On Plot No.7, Gr+ 1 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s. Neo Enterprises, bearing License No. MFS-LA/F- 220, & MFS-LA/D- 185, dated 01/05/2013 issued by this office and has submitted Certificate on 25/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) 4" Raiser
2) Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) main Electrical pump

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1013.02 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.85,000/- vide Receipt No. 187110, Dated 13/05/2014, DD No.000928 , Saraswat Bank & Rs.72,700/- vide Receipt No. 187111, Dated 13/05/2014 DD No.000927, Saraswat Bank for the total gross built up area **1013.02** Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

10/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 108/2014-15 DATE: 10/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Industrial Building On Land Bearing Plot No.13 S.No. 94, H.No. 17/2, Of Village: Waliv, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 1689/ 2014 Dated: 05/07/2014
2) An application received by M/s. EN CON Consultants/ Rakesh Agarwal, Dated: 28/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP-0755/072/2014-15, Dated:26/06/2014.
4) Certificate from License Agency M/S. Neo Enterprises, Dated:26/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-28/06/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, date-28/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Industrial Building On Land Bearing Plot No.13** Building at above mentioned address. As per c.c issued by VVCMC/TP/RDP/VP-0755/072/2014-15,Dated:26/06/2014. The party has constructed **"Industrial Building on Plot No.13, Gr+ 1(pt) Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s. Neo Enterprises, bearing License No. MFS-LA/F- 220, & MFS-LA/D- 185, dated 01/05/2013 issued by this office and has submitted Certificate on 26/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) 4" Raiser G+1st Floor
2) Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) main Electrical pump

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **641.33 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40,000/- vide Receipt No. 187195, & Rs. 40,000/- vide Receipt No. 187194, Dated 30/06/2014, DD No.540166, & DD No. 540165, Alahabad Bank for the total gross built up area **641.33 Sq.Mtrs** as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

10/7/14

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

10/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 110/2014-15 DATE: 10/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Industrial Building No. 1, (Plot C), On Land Bearing S.No. 23, H.No. 2(pt); S.No.24, H.No.1(pt) & S.No. 24, H.No.2 Of Village: Sativali, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 1690/ 2014 Dated: 05/07/2014
2) An application received by M/s. EN CON Consultants, Dated:10/06/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP-0401/1779, Dated:09/12/2011.
4) Certificate from License Agency M/S. Neo Enterprises, Dated:25/04/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-10/06/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, date-10/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Industrial Building No. 1, (Plot C),** Building at above mentioned address. As per c.c issued by VVCMC/TP/CC/VP-0401/1779, Dated:09/12/2011. The party has constructed **"Industrial Building No. 1, (Plot C), Gr+ 2 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s. Neo Enterprises, bearing License No. MFS-LA/F- 220, & MFS-LA/D- 185, dated 01/05/2013 issued by this office and has submitted Certificate on 25/04/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) 4",Raiser G+2nd Floor
2) Landing valves on each floor
3) Courtyard hydrant
4) Hose box set with canvas hose
5) Hose reel drum sets with shut up nozzle on each floor
6) Booster pump
7) main Electrical pump

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2076.16 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 1,50,000/- vide Receipt No. 187192, Dated 30/06/2014, DD No.018072 , & Rs. 1,50,000/- vide Receipt No. 187193, Dated 30/06/2014, DD No.018073,Basin Catholic Bank for the total gross built up area **2076.16** Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

10/7/14

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 111 /2014-15 DATE: 14/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial Building Type S3-08, S3-09,T1-12,T1-14,T1-15, Y1-23, Y1-24, Y1-25, Y1-26,S1-41 in Avenue 'H' & Type R1-08 in Avenue 'G' Known as 'GLOBAL CITY', of Group Housing Scheme on Land bearing new S.No.5, 5B, 5F, 5G,5D at Village- Dongre, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1418/ 2014 Dated: 24/ 06 / 2014.
2) An application received by M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:21/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-3519/W/5057,Dated:- 08/10/2009.
4) Certificate from License Agency M/s. Masani Engineering Co.Pvt.Ltd. Dated:08/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:17/10/2013.
6) Structure Stability certificate No. TCN/08-1012/2012-2013/2191,2192, 2195, 2196,2315,2205,2206,2207,2208,2223,2175 of M/s. J+W CONSULTANTS LLP, Dated:08/03/2013
7) License to work the Lift From Govt. of Maharashtra Industries, License No.136536, 136541, 136545, 136537, 136531, 136525, 136533, 136542 Dated:08/11/2013., 137486, 137499, Dated:26/12/2013.,135489 Dated:08/10/2013
8) This office Provisional No objection Certificate No. CIDCO/ FIRE /KLM/247/2010 Dated:24/02/2010.& CIDCO/ FIRE /KLM/307/2010 Dated:08/03/2010.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential / Residential Cum Commercial Building Type S3-08, S3-09,T1-12,T1-14,T1-15, Y1-23, Y1-24, Y1-25, Y1-26,S1-41 in Avenue 'H' & Type R1-08 in Avenue 'G' Known as 'GLOBAL CITY', of Group Housing Scheme** , at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Masani Engineering Co.Pvt.Ltd. bearing License No. MFS-LA/RF/0090 RD/0129, issued by this office and has submitted Certificate on Date:17/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **Avenue 'H' Commercial Built up Area 1107.19** Sq.Mtrs., **Avenue 'H' & Avenue 'G' Residential Built up Area 14699.61** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

14/7/14

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 112/2014-15 DATE: 14/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial Building Type S3-06, S3-07, Y1-28, Y1-29, Y1-30, Y1-27 in Avenue 'H' & Type R1-05, R1-06, R1-07 in Avenue 'G' Known as 'GLOBAL CITY', of Group Housing Scheme on Land bearing new S.No.5, 5B, 5F, 5G,5D at Village- Dongre, Tal- Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1419/ 2014 Dated: 24/ 06 / 2014.
2) An application received by M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:21/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-3519/W/5057,Dated:- 08/10/2009.
4) Certificate from License Agency M/s. Masani Engineering Co.Pvt.Ltd. Dated:08/08/2013. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:10/10/2013.
6) Structure Stability certificate No. TCN/08-1012/2012-2013/2172,2173,2174,2188,2189,2209,2210,2211,2212 of M/s. J+W CONSULTANTS LLP, Dated:08/03/2013
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 132391 Dated:15/07/2013., 134462,134463 Dated:31/08/2013., 132396 Dated:15/07/2013., 132392,132390 Dated:15/07/2013., 135484 Dated:24/09/2013., 132387,132388 Dated:15/07/2013.,
8) This office Provisional No objection Certificate No. CIDCO/ FIRE /KLM/247/2010 Dated:24/02/2010.& CIDCO/ FIRE /KLM/307/2010 Dated:08/03/2010.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential / Residential Cum Commercial Building Type S3-06, S3-07, Y1-28, Y1-29, Y1-30, Y1-27 in Avenue 'H' & Type R1-05,R1-06, R1-07 in Avenue 'G' Known as 'GLOBAL CITY', of Group Housing Scheme** , at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Masani Engineering Co.Pvt.Ltd. bearing License No. MFS-LA/RF/0090 RD/0129, issued by this office and has submitted Certificate on Date:17/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **Avenue 'H' Commercial Built up Area 740.74** Sq.Mtrs., **Avenue 'H' & Avenue 'G' Residential Built up Area 11548.82** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

14/07/14

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 113/2014-15 DATE: 14/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Building No.3, Wing B & C on Land bearing S.No. 73A, S.No.73B, S.No.112, H.NO. 4&5, at village Achole, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/1678/2014 Dated:05/072014
2) An application received by M/s. En Con Project Consultant, of Dated:04/07/2014
3) Revised c.c. Issued By VVCMC / TP / RDP / VP-0121 & 3051 / 012 / 2013-14, Dated: 09/04/2013.
4) Certificate from License Agency M/s .Sadanand Fire Controls, Dated:01/05/2013. (Form A)
5) Building Completion certificate of M/s. En Con Project Consultant, of Dated:01/06/2014.
6) Built up area certificate of M/s. En Con Project Consultant, of Dated:01/06/2014.
7) Structure Stability certificate M/S.Umesh D. Tayshetye, Dated: 06/07/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No. 137497, 137496 ,Dated:26/12/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Building No.3, Wing B & C** Building at above mentioned address. As per c.c issued by VVCMC / TP / RDP / VP-0121 & 3051 / 012 / 2013-14, Dated: 09/04/2013 The party has constructed **"Residential Building No.3, Wing B & C Building G + 7 Floors"** as per sanctioned Plan.

With reference to above on Dated:02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. M/s **Sadanand Fire Controls bearing License No. MFS-LA/F- 0216, dated 01/05/2014, issued by this office and has submitted Certificate On 25/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3697.28 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.2,40,000/- vide Receipt No. 226698 Dated 05/07/2014 & DD No. 140178 Ratnakar Bank. for the total gross built up area **3697.28 Sq.Mtrs.** as per the letter given by the party Dated :04/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of

the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/114/2014-15 DATE: 14/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential Building Type A on Land bearing S.No.325,H.No-3,4,5,7,9,10& ,House.No-531,531A at village -Virar ,Tal- Vasai, Dist-Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1445 / 2014, Dated:-25/06/2014.
2. An application received by M/s. Sameer R.Desai Architects, Dated: 24/06/2014.
3. Revised c.c. Issued By No. VVCMC / TP / CC / VP-0661/1442 Dated-25/10/2011.
4. Certificate from License Agency M/s, Sadanand fire controls, Dated: 24/06/2014 (Form A).
5. Building Completion certificate of M/s. M/s. Sameer R.Desai Architects, Dated: 11/03/2014.
6. construction area certificate of M/S M/s. Sameer R.Desai Architects, Dated: 20/06/2014.
7. Structure Stability certificate of Ms.krupa Mehta Consulting Engineers, Dated:-15/04/2013.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. -139141 Dated:- 20/01/2014
9. This Office Provisional No Objection Certificate vvcmc/fire/113 /2011-12 Dated-03/10/2011.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Building Type A (G +6)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Sadanand Fire Controls bearing License No. MFS-LA/F- 0216, dated 01/05/2014, issued by this office and has submitted Certificate On 24/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring to **2014.25 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

Dattatray Jadhav

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received copies

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 115/2014-15 DATE: 14/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential / Residential Cum Commercial Building Type T1-10,T1-11,Y3-19,Y1-20,Y1-21,Y1-22,S1-37,S1-38,S1-39,S1-40,S1-42,S1-43,S1-44 in Avenue 'H' , Type R1-09, in Avenue 'G'& Type Y1-11 in Avenue 'J' Known as 'GLOBAL CITY', of Group Housing Scheme on Land bearing new S.No.5, 5B, 5F, 5G,5D at Village- Dongre, Tal- Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1676/ 2014 Dated: 05/ 07 / 2014.
2) An application received by M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:25/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/RDP/BP-3519/W/5057,Dated:- 08/10/2009.& Revised assessment order no. VVCMC/TP/AM/VP-453/09/2011-12 Dated-10/05/2011.
4) Certificate from License Agency M/s. Masani Engineering Co.Pvt.Ltd. Dated:08/08/2013. & M/s. Sadananad Fire Controls.Dated: 13/12/2013. (Form A)
5) Building Completion certificate M/s. SHAH GATTANI CONSULTANTS, Dated:25/06/2014 & 17/12/2013. & Built up area certificate of M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:24/06/2014 & 17/12/2013.
6) Structure Stability certificate No. TCN / 08-1012 / 2012- 2013 / 2176, 2193,,2194,, 2201 to 2204, 22019 to 2226, 210 of M/s. J+W CONSULTANTS LLP, Dated:08/03/2013
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 136523, 141382,136543,136530,136532,141377,1471378,141376,136526, 136535, 141383,141384,141375,136534, Dated:05/05/2014 & 08/11/2013. & 141344, Dated: 05/05/2014.
8) This office Provisional No objection Certificate No. CIDCO/ FIRE /KLM/247/2010, Dated:24/02/2010. & CIDCO/ FIRE /KLM / 307 / 2010 Dated: 08/03/2010.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential / Residential Cum Commercial Building Type T1-10,T1-11,Y3-19,Y1-20,Y1-21,Y1-22,S1-37,S1-38,S1-39,S1-40,S1-42,S1-43,S1-44 in Avenue 'H' , Type R1-09, in Avenue 'G'& Type Y1-11 in Avenue 'J' Known as 'GLOBAL CITY', of Group Housing Scheme on Land bearing new S.No.5, 5B, 5F, 5G,5D** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Masani Engineering Co.Pvt.Ltd. bearing License No. MFS-LA/RF/0090 RD/0129, & issued by this office and has submitted Certificate on Date: 08/08/2013 & M/s. Sadanand Fire Controls bearing License No. MFS-LA/F- 0216, dated 01/05/2014, issued by this office and has submitted Certificate On 13/12/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **Residential Cum Commercial Built up Area 20019.01Sq.Mtrs.& 1701.01 Sq.Mtrs.&** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice

14/07/14

& the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

ICIPAL CORPORATION ★ RE AED ★ hane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 116/2014-15 DATE: 14/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Commercial Building Type J Known as ' Sandeep House' on Land bearing S.No.370, H.No. 1,2,3/1,3,/3,4 to 16,18 to 30 Of village: Village: Bolinj,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1538 / 2014, Dated:- 30/06/2014.
2. An application received by M/s. Shah Gattani Consultants, Dated: 28/06/2014.
3. Revised c.c. Issued By CIDCO/VVSR/CC/BP-3867/W/219,Dated: 30/04/2010.
4. Certificate from License Agency M/s, Sadanand fire controls, Dated: 26/06/2014 (Form A).
5. Building Completion certificate & Carpet area certificate of M/s. Shah Gattani Consultants, Dated: 10/05/2014.
6. Structure Stability certificate of M/s. Nimisha Structural Design Academy, Dated: 30/06/2014.
7. License to work the Lift From Govt. of Maharashtra Industries, License, No. 132257, Dated: 13/07/2013.
8. This office Provisional No objection Certificate No. VVCMC/ FIRE /69/2012-13, Dated: 21/07/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Commercial Building Type J Known as ' Sandeep House' Stilt+7 Floor** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. M/s. Sadanand Fire Controls bearing License No. MFS-LA/F- 0216, dated 01/05/2014, issued by this office and has submitted Certificate On 26/06/2014 "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having carpet area admeasuring to **1713.25 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 117/2014-15 DATE: 14/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential Cum Commercial Building Type G,H,I&G1 Known as 'TIRUPATI GRANDE' on Land bearing S.No.370, H.No. 1,2, 3/1, 3/3, 4 to 16, 18 to 30 of village: Bolinj (old) & S.No. 101 of Village- Kharodi (New), Tal-Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1539/ 2014 Dated: 30/ 06 / 2014.
2) An application received by M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:28/06/2014.
3) Revised c.c. Issued By CIDCO/VVSR/CC/BP-3867/W/216,217,218 Dated:- 30/04/2010
4) Certificate from License Agency M/s, Sadanand fire controls, Dated: 26/06/2014 (Form A)
5) Building Completion certificate & Built up area certificate of M/s. SHAH GATTANI CONSULTANTS, architects & engineers Dated:14/05/2013.
6) Structure Stability certificate of M/s SHAH GATTANI CONSULTANTS, architects & engineers , Dated:14/05/2013
7) License to work the Lift From Govt. of Maharashtra Industries, License No.117425, 117426 Dated:07/01/2013., 118980,118979 Dated:05/03/2013
8) This office Provisional No objection Certificate No. VVCMC/FIRE/168/2011-12 Dated:27/01/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building Type G,H,I&G1 Known as 'TIRUPATI GRANDE' ,** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. License Agency M/s. Sadanand Fire Controls bearing License No. MFS-LA/F- 0216, dated 01/05/2014, issued by this office and has submitted Certificate On 26/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to Bldg. Type '**G**' Residential Built up area 2097.83 Sq.Mtrs. & Commercial Built up area 194.39 Sq. Mtrs., Bldg. Type 'H' Residential Built up area 1837.08 Sq.Mtrs. & Commercial Built up area 189.89 Sq. Mtrs. Bldg. Type 'I' Residential Built up area 1142.96 Sq.Mtrs. & Commercial Built up area 142.07 Sq. Mtrs., Bldg. Type '**G1**' Residential Built up area 2097.83 Sq.Mtrs. & Commercial Built up area 194.39 Sq. Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 118/2014-15 DATE: 16/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.2, Wing-A, Located on Land bearing S.No.69, H.No. 12 & 13 Of village: Manickpur and S.No. 197-B Of Village: Chulne,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1501 / 2014, Dated:- 24/06/2014.
2. An application received by M/s. En Con Consultants, Dated: 24/06/2014.
3. Revised c.c. Issued By VVCMC/TP/RDP/VP-0554/008/2013-14,Dated: 06/04/2013.
4. Certificate from License Agency M/s. Sadanand Fire Systems , Dated: 20/06/2014 (Form A).
5. Building Completion certificate & Built up area certificate of M/s. En Con Consultants, Dated: 30/06/2014.
6. Structure Stability certificate of M/s. Sanjay Narang & Associates,Dated: 30/06/2014.
7. License to work the Lift From Govt. of Maharashtra Industries, License, No. 132570, Dated: 23/07/2013.
8. This office Provisional No objection Certificate No. VVCMC/ FIRE /173/2011-12, Dated: 03/02/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Residential Cum Commercial Building No.2, Wing-A, G+7 Floor** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, issued by this office and has submitted Certificate for Dated: 20/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **1521.367 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

16/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 119/2014-15 DATE: 16/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building (Wing A & B) known as ' Goldcreast 369' on Land bearing New S.No.369B, H.No. 1 & 2 at village: Bolinj, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept. No. VVCM/NR/1444/2014 Dated: 25/06/2014
2) An application received by M/s. Shah Gattani Consuntants, Dated: 23/6/2014
3) Revised c.c. Issued By VVCMC No. VVCMC/TP/RDP/VP-0381/0216/2012-13, Dated:07/03/2013.
4) Certificate from License Agency M/s. Sadanand Fire Systems , Dated: 20/06/2014. (Form A)
5) Building Completion certificate of m/s. Shah Gattani Consuntants, Dated: 20/6/2014
6) Built up area certificate of m/s. Shah Gattani Consuntants, Dated: 20/6/2014.
7) Structure Stability certificate of M/s.. Shah Gattani Consuntants, Dated: 20/6/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License, No. 140520, Dated:25/03/2014.& 137387, Dated:09/01/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building (Wing A & B)** Building at above mentioned address. As per c.c issued by VVCMC No. VVCMC/TP/RDP/ VP-0381/0216/2012-13, Dated:07/03/2013. The party has constructed **"Residential Cum Commercial Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, issued by this office and has submitted Certificate for Dated: 20/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical Riser :- 2 no's
2. ISI Landing valves on each floor :- 01 no's
3. Courtyard Hydrant :- 04 no's
4. Hose box set with canvas hose:- 2 no's
5. Hose reel drum sets with shut up nozzle on each floor :- 1 no's
6. Booster pump:- 2 no's
7. Hydrant main pump:-1 no's
8. Siamese Connection at main gate :- 1 nos.

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **5424.05 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Before use of commercial area of the building the Owner or the Occupier must be provided sprinkler & smoke detector system & also the proper fire extinguishers in that area as per the

law. If the Owner or the Occupier used that area without providing installing fire fighting system they will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 80,000/- vide Receipt No. 187166 Dated 24/6/2014, DD No. 039075, & Rs. 80,000/- vide Receipt No. 187169, Dated 24/6/2014, DD No. 039676, Rs. 1,20,000/- vide Receipt No. 187170, Dated 24/6/2014, DD No. 039677, Rs. 1,20,000/- vide Receipt No. 187171, Dated 24/6/2014, DD No. 039678, Axis Bank.ltd for the total gross built up area **5424.05 Sq.Mtrs.** as per the letter given by the party Dated:- 20/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

16/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

IPAL CORPORATION
E
AED
hane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 120/2014-15 DATE: 16/07/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of INDUSTRIAL BUILDING No-2 located on land bearing S.No.150, H.No.(p), S.No.151, H.No.1/4, at village-Pelhar, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1668/ 2014 Dated: 05 / 07 / 2014.
2) An application received by M/s.Ajay Wade & Associates. Dated:04/07/2014.
3) Revised c.c. Issued By CIDCO/VVSR/CC/BP/4613/E/450 DATE-28/05/2010
4) Certificate from License Agency M/s. **M/s, Fire Worx Engineering, Dated: 30/06/2014 (Form A).**
5) Building Completion certificate M/s.Ajay Wade & Associates. Dated:04/07/2014.
6) Construction area certificate by M/s.Ajay Wade & Associates. Dated:04/07/2014.
7) Structure Stability certificate of Suresh Kumar M. Panicker Dated- 01/07/2014

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL BUILDING No-2 (G+1)** Building at above mentioned address. As per c.c issued by By CIDCO/VVSR/CC/BP/4613/E/450 DATE-28/05/2010 The party has constructed **"INDUSTRIAL BUILDING No-2 (G+1)"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump- 30 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring to **BUILDING No-2 – 3578.51 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-2,40,000 /- vide Receipt No.-226696.& Rs-1,86,300 /- vide Receipt No.-226697. Dated -04/07/2014 .DD.bearing No. -076235 & 076234. Issued by – HDFC Bank, in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **BUILDING No-2 – 3578.51 Sq.Mtrs**.. as per the letter given by the party Dated-04/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

16/7/2019

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

ICIPAL CORPORATION ★ RE AED Thane.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 121/2014-15 DATE: 16/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential cum commercial Building Type EG3- (wing A-B)& Residential Building Type EG4 (wing C-D) wing in Avenue- 6,known as GLOBAL CITY on Land bearing New S.No.5,5B,5F,5G,5D at village Dongre ,Virar (W),Tal- Vasai, Dist- Thane.

Ref :-
1. **A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1479/ 2014, Dated:- 27/06/2014.**
2. **An application received by M/s. Shah Gattani Consultants, Dated: 27/06/2014.**
3. **Revised c.c. Issued By No. VVCMC / TP / AM / VP-0453/296/2011-12 dated- 31/03/2012**
4. **Certificate from License Agency M/s, Fire Worx Engineering, Dated: 30/06/2014 (Form A).**
5. **Building Completion certificate of M/s. Shah Gattani Consultants, Dated:25/6/2014**
6. **Built up area certificate of Shah Gattani Consultants, Dated: - 25/06/2014.**
7. **Structure Stability certificate of of J.W.cosultant-Date- 07/07/2014.**
8. **License to work the Lift From Govt. of Maharashtra Industries, licence, No. 139909 & 139910 Dated:- 01/04/2014,140991&140992 Dated-17/04/2014, 141797,141793 Dated-28/05/2014 & 143466,143465 dated-20/06/2014.**
9. **This Office Provisional No Objection Certificate vvcmc/fire/206 D /2011-12 Dated- 30/03/2012**

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential cum commercial Building Type EG3- (wing A-B)& Residential Building Type EG4 (wing C-D) wing in Avenue- 6 (part G+7),known as GLOBAL CITY** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 28/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **8078.99 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGAED

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 122/2014-15 DATE: 16/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL BUILDING No.8 ,Ph-I,section-v, wing- C on proposed Group housing scheme on S.No.255/1,2,3,4,5,S.No-257,S.No-259/1,S.No-260pt & S.No-261. at village Nilemore, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1663 / 2014 Dated: 05 / 07 / 2014.
2) An application received by M/s. Sanat Mehta & Associates, Dated:02/07/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP- 0022/287/2011-12,Dated:-22/03/2012.
4) Certificate from License Agency M/s. M/s, Fire Worx Engineering, Dated: 25/12/2013 (Form A).
5) Building Completion certificate OF M/s. Sanat Mehta & Associates, Dated:02/07/2014
6) Built up area certificate OF M/s. Sanat Mehta & Associates, Dated:02/07/2014
7) Structure Stability certificate No. Vijay S. Gurav & Associates,Dated:31/12/2013.
8) License to work the Lift From Govt. of Maharashtra Industries, licence, No. - 140568.dated-25/03/2014.
9) This Office Provisional No Objection Certificate vvcmc/fire/128 G /2012-13 Dated-12/10/2012

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **RESIDENTIAL BUILDING No.8 ,Ph-I,section-v, wing- C (G+7)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 25/12/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2476.22 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION ★ FIRE BRIGAED ★ Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 123/2014-15 DATE: 16/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential cum commercial Building Type EG5- wing D &_Residential Building Type EG5- wing A,B&C in Avenue- A3a,known as GLOBAL CITY _on Land bearing New S.No.5,5B,5F,5G,5D at village Dongre ,Virar (W),Tal- Vasai, Dist- Thane.

Ref :-
1. **A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1478/ 2014, Dated:- 27/06/2014.**
2. **An application received by M/s. Shah Gattani Consultants, Dated: 25/06/2014.**
3. **Revised c.c. Issued By No. VVCMC / TP / AM / VP-0453/296/2011-12 dated- 31/03/2012**
4. **Certificate from License Agency M/s, Fire Worx Engineering, Dated: 30/06/2014 (Form A).**
5. **Building Completion certificate of M/s. Shah Gattani Consultants, Dated:25/6/2014**
6. **Built up area certificate of Shah Gattani Consultants, Dated: - 25/06/2014.**
7. **Structure Stability certificate of J.W.cosultant-Date- 07/07/2014**
8. **Lift completion undertaking by Omax Elevators company. Dated- 28 th june 2014.**
9. **This Office Provisional No Objection Certificate vvcmc/fire/206 E /2011-12 Dated- 30/03/2012**

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential cum commercial Building Type EG5- wing D &_Residential Building Type EG5- wing A,B&C in Avenue- A3a,(part G+7) known as GLOBAL CITY** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **6289.31 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane

Gattani 16/7/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Body

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 125/2014-15 DATE: 17/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING No.2,wing-A&B known as WONDER RESIDENCY on land bearing S.No-256,H.No.3&8,S.No-257 (pt), S.No. 18, H.No.1,2 at village Gokhiware, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1642 / 2014 Dated: 04 / 07 / 2014.
2) An application received by M/s. Galaxy Enterprises, Dated:22/06/2014.
3) Revised c.c. Issued By VVCMC/TP/CC/VP- 0416/0148/2012-13,Dated:-14/12/2012.
4) Certificate from License Agency M/s. **M/s, VIVA ENTERPRISES, Dated: 01/07/2014 (Form A).**
5) Building Completion certificate OF M/s. S.C.ARCHITECTS, Dated:01/07/2014.
6) Built up area certificate OF M/s. S.C.ARCHITECTS, Dated:01/07/2014.
7) Structure Stability certificate OF SATISH M. GHANEKAR,Dated:28/06/2014.
8) Lift completion undertaking by mr.umesh H Kasmani.Dated-02/07/2014

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.2,wing-A&B known as WONDER RESIDENCY** Building at above mentioned address. As per c.c issued by By VVCMC/TP/CC/VP- 0416/0148/2012-13,Dated:-14/12/2012The party has constructed **"RESIDENTIAL CUM COMMERCIAL Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.M/s. viva Enterprises bearing License No. MFS-LA/F- 0139, issued by this office and has submitted Certificate On 01/07/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump- 20 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **4487.61 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-4,00,000 /- vide Receipt No. -226646 Dated -03/07/2014.DD.bearing No. -018082 Issued by Basin Catholic Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **4487.61 Sq.Mtr**. as per the letter given by the party Dated -018082

Received two Copy

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGAED
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2521101/02/03/04/05/06

VVCMC/FIRE/ 131/2014-15 DATE: 24/07/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1, Wing (A, B & C) on Land bearing S.No.41, H.No. B,C,& D, S.No.51, H.No. A & B, at village: Malonde, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept. No. VVCM/NR/1440/2014 Dated: 25/06/2014
2) An application received by M/s. Ajay Wade & Associaltes, Dated: 16/06/2014
3) Revised D.P. Issued By VVCMC No. VVCMC/TP/RDP/VP-0033/052/2014-15, Dated:07/06/2014.
4) Certificate from License Agency M/s. Sadanand Fire Systems , Dated: 14/06/2014. (Form A)
5) Building Completion certificate of m/s. Ajay Wade & Associaltes, Dated: 30/06/2014.
6) Construction area certificate of m/s. Ajay Wade & Associaltes, Dated: 30/06/2014.
7) Structure Stability certificate of M/s.Umesh D. Tayshetye, Dated: 30/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License, No.112465, 112466, Dated:30/02/2012 .& License, No.113948, Dated:28/09/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 Wing (A, B & C)** Building at above mentioned address. As per D.P issued by VVCMC No. VVCMC/TP/RDP/ VP-0033/052/2014-15, Dated:07/06/2014.The party has constructed **"Residential Cum Commercial Building No.1, Wing (A, B & C) G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, issued by this office and has submitted Certificate for Dated: 14/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical Riser :- 3 nos
2. ISI Landing valves on each floor :- 01 nos
3. Courtyard Hydrant :- 06 nos
4. Hose box set with canvas hose:- 3 nos
5. Hose reel drum sets with shut up nozzle on each floor :- 1 nos
6. Booster pump:- 3 nos
7. Hydrant main pump:-1 nos
8. Siamese Connection at main gate :- 1 nos.

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring to **7226.00 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 5,52,000/- vide Receipt No. 187174, Dated 25/06/2014, DD No. 095103, for the total gross construction area **7226.00 Sq.Mtrs.** as per the letter given by the party Dated:- 20/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 132/2014-15 DATE: 24/7/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Building No.4 wing A & B on Land bearing S.No.55, H.No.14, S.No.60, H.No.1,2A,2B,3A,3B,4,5,6,7, S.No.61, H.No.1(pt)& S.No.62, H.No.2,3&5, at village-Chulne ,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1702 / 2014, Dated:- 07/07/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 28/06/2014.
3. Revised D.P. Issued By VVCMC No. VVCMC / TP / RDP / VP-0102 / 117 / 2011-12. Dated: 21/10/2011.
4. Certificate from License Agency M/s, Sadanand Fire Systems, Dated:28/06/2014 (Form A).
5. Building Completion certificate No. VP-0102/219 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:28/06/2014.
6. Built up area certificate No. VP-0102/221 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:28/06/2014.
7. Structure Stability certificate No. VP-0102/220 of M/s SANJAY NARANG & ASSOCITES DATED- 28/06/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 143777 & 143778 Dated:- 03/07/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE /283/ 2012-13, Dated:25/03/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Building No.4 wing A & B** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s.Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, dated 15/10/2013 issued by this office and has submitted Certificate on 28/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2723.95** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGAED Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 144/2014-15 DATE: 01/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial Building No.16 Known as ' HDIL INDUSTRIAL PARK' on Land bearing S.No. 123(325), H.No.1 To 4, S.No. 127 (258),H.No.1A/20,1A/22, 1A/28, 1A/29, 1A/32, 1A/36, 1A/26, 1A/15, 1A/9, 1A/25, 1A/34, 1A/17, 1A/21, 1A/30(pt), 1A/38(pt,) 1A/30(pt),1A/38(pt), 1A/18, 1A/19, 1A/38(pt), S.No.130(324), S.No.137(252), S.No.138(251), H.No.4 (pt), 4(pt), 15,3(pt) 13 (pt), 13 (pt), 3 (pt0, S.No.139 (274), H.No. 1,4,5,2 (pt), S.No. 136(322), H.No. 3(pt), 2,1,3(pt), S.No.122(259),H.No.3,6/1,9,2,5(pt),7(pt),S.No.134(254),H.No.8,Of village: Chandansar ,Tal:Vasai, Dist:Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1995/ 2014, Dated:- 31/07/2014.
2. An application received by M/s. Shah Gattani Consultants, Dated: 31/07/2014.
3. Revised D.P.Issued By CIDCO/VVSR/RDP/BP-4502/E/5875, Dated: 18/02/2010.
4. Certificate from License Agency M/s, Aayush Fire and Safety Services, Dated: 30/07/2014. (Form A).
5.Building Completion certificate of M/s. Shah Gattani Consultants, Dated: 17/07/2014.
6. Built up area certificate M/S. Shah Gattani Consultants, Dated: 17/07/2014.
7. Structure Stability certificate of M/s. Shah Gattani Consultants, Dated: 17/07/2014.
8.License to work the Lift From Govt. of Maharashtra Industries, licence, No. 137311,137310, Dated:- 19/12/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE /52/ 2013-14, Dated:08/05/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Industrial Building No.16 Known as ' HDIL INDUSTRIAL PARK' G+2 Floor** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Aayush Fire and Safety Services bearing License No. MFS-LA/RF- 0132,& MFS-LA/D- 191, issued by this office and has submitted Certificate on dated: 30/07/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **7292.65 Sq.Mtrs**. This certificate shall be treated valid ~~up to 31/12/2014~~ It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 153/2014-15 DATE: 05/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of INDUSTRIAL BUILDING No.1, on land bearing S.No- 36,H.No.6B. at village Waliv, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1683 / 2014 Dated: 05 / 07 / 2014.
2) An application received by M/s. EN CON Project Consultant, Dated:25/06/2014.
3) Revised D.P ISSUSED BY CIDCO/VVSR/RDP/BP-4405B/E/306 Issued DATED- 14/05/2010 .
4) Certificate from License Agency M/s, Ronak fire Industries, Dated: 25/06/2014 (Form A).
5) Building Completion certificate OF M/s. EN CON Project Consultant, Dated:24/07/2012.
6) Built up area certificate OF M/s. EN CON Project Consultant, Dated:24/07/2012.
7) Structure Stability certificate OF Sanjay Narang & Associates,Dated:24/07/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL BUILDING No.1** Building at above mentioned address. As per c.c issued by By **CIDCO/VVSR/RDP/BP-4405B/E/306 Issued DATED- 14/05/2010 .**The party has constructed **"INDUSTRIAL BUILDING No.1 G+1 Floors"** as per sanctioned Plan.

With reference to above on Dated: - 16/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Ronak fire Industries bearing License No. MFS-LA/RF- 0157,Dated-18/07/2013. issued by this office and has submitted Certificate On 25/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2094.08 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-1,50,000 /- vide Receipt No. -187183 Dated -27/06/2014.& Rs-1,50,000 /- vide Receipt No. -187184 Dated -27/06/2014 DD.bearing No.- 657726 & 657727 Issued by Corporation Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **2094.08 Sq.Mtr**.

Received
05/08/14

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE BRIGADE
Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 154/2014-15 DATE: 05/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Hotel Building on plot no.1,S.No.7,H.No.2(pt) at village –Chandansar,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 1680 / 2014, Dated:- 05/07/2014.
2. An application received by M/s. Sameer R.Desai Architects, Dated: 05/07/2014.
3. Revised c.c. Issued By No. CIDCO/VVSR/CC/BP-4517/E/5562 Dated-23/12/2009.
4. Certificate from License Agency M/s, Ronak fire Industries, Dated: - 05/07/2014 (Form A).
5. Building Completion certificate of M/s. M/s. Sameer R.Desai Architects, Dated: 02/07/2014
6. Built up area certificate of M/S M/s. Sameer R.Desai Architects, Dated: 02/07/2014.
7. Structure Stability certificate of Ms.Nimisha Structural Design Academy, Dated:- 30/06/2014.
8. Undertaking of Mrs.Kanta Jaishankar Joshi.obout side margine & lift completion. Dated- 01/08/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Hotel BUILDING** Building at above mentioned address. As per c.c issued by By **CIDCO/VVSR/CC/BP-4517/E/5562 Dated-23/12/2009** The party has constructed **"Hotel BUILDING G+4 Floors"** as per sanctioned Plan.

With reference to above on Dated: ---------- representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Ronak fire Industries bearing License No. MFS-LA/RF- 0157,Dated-18/07/2013. issued by this office and has submitted Certificate On ---------- ----------n "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1133.07 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-1,51,200/- vide Receipt No. -226672 Dated - 04/07/2014 DD.bearing No.- 014252 Issued by HDFC Bank in favour of VVCMC & Rs-18,800 /- vide

Received
05/08/14

challan No. -24546 Dated -21/12/2009 additional Capitation & Scrutiny fees for the total Built up area **1133.07 Sq.Mtr**.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 155/2014-15 DATE: 05/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING, known as "SAI HEIGHT" Type ZD,(wing A,B&C) on land bearing S.No- 1,2,3,4 of village- Achole.S.No.101,102,103,104,106,107 of Manikpur, S.No.97B,105B,106B of Village Gokhiware, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1549 / 2014 Dated: 30 / 06 / 2014.
2) An application received by M/s. Shree Sai Panchshil, Dated:24/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/ZCC-20/E/VP-0743/109/2011-12. Dated-15/10/2011
4) Certificate from License Agency M/s. M/s, Ronak fire Industries, Dated: 23/06/2014 (Form A).
5) Building Completion certificate OF M/s. Shah Gattani Consultant, Dated:20/06/2014.
6) Built up area certificate OF M/s. Shah Gattani Consultant, Dated:20/06/2014.
7) Structure Stability certificate OF M/s. Shah Gattani Consultant, Dated:20/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, Licence no.144350,144345, & 144349 Dated- 28/07/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING, known as "SAI HEIGHT" Type ZD,(wing A,B&C)** Building at above mentioned address. As per c.c issued by By **VVCMC/TP/RDP/ZCC-20/E/VP-0743/109/2011-12. Dated-15/10/2011.**The party has constructed **"RESIDENTIAL CUM COMMERCIAL BUILDING, Type ZD,(wing A,B&C) G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: - 16/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Ronak fire Industries bearing License No. MFS-LA/RF- 0157,Dated-18/07/2013. issued by this office and has submitted Certificate On 23/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
- a) on every floor hose reel hose & landing valve / Hydrant valve
- b) Booster pump on terrace- 5 HP
- c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
- d) Main Pump- 15 HP

B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 3400.52 **Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-4,00,000 /- vide Receipt No. -187185 Dated - 27/06/2014.& Rs-1,20,000 /- vide Receipt No. -187186 Dated -27/06/2014 DD.bearing No.- 000677 &

Received

000983 Issued byHDFC Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **3400.52 Sq.Mtr**.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 163/2014-15 DATE: 05/09/2014

TO,
M/s Privilege Power & Infrastructure Pvt. Ltd,
HDIL Towers, 3rd Floor,Anant Kaneker Marg,
Bandra (E).Mumbai 400 051.

Sub:- Renewal of "Final No Objection Certificate" for Industrial Building known as HDIL Industrial Park in Building No- 23,24,25,26,27,28,29,30,59,63,64&68 G+2. at village Chansar virar (w) ,Tal- Vasai, Dist- Thane.

Ref :- 1. An application received by Privilege Power & Infrastructure Pvt. Ltd. Dated: 30/07/2014.
2. Certificate from License Agency M/s, Aayush fire & Safety Services , Dated:30/07/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/54 / 2013-14, Dated: 08/05/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for **for Industrial Building known as HDIL Industrial Park in Building No- 23,24,25,26,27,28,29,30,59,63,64&68 G+2.**at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Aayush fire & Safety Services bearing License No. MFS-LAF-0132 , MFS-LA/D - 191 issued by this office and has submitted Certificate on dated- 30/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.311192/- vide Receipt No.-226868 Dated- 6/8/2014 .DD.bearing No. -231315 Issued by -Ratnakar Bank., renewal fees for the said building. & Rs. 38770/- vide Receipt No. 226858, Dated 01/08/2014, DD No. 231305

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you,

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 164/2014-15 DATE: 05/08/2014

TO,
M/s Privilege Power & Infrastructure Pvt. Ltd,
HDIL Towers, 3rd Floor,Anant Kaneker Marg,
Bandra (E).Mumbai 400 051.

Sub:- Renewal of "Final No Objection Certificate" for Industrial Building known as HDIL Industrial Park in Building No- 7,8,9,10,11,12,14,15,17,18 & 19 G+2. at village Chansar virar (w) ,Tal- Vasai, Dist- Thane.

Ref :- 1. An application received by Privilege Power & Infrastructure Pvt. Ltd. Dated: 30/07/2014.
2. Certificate from License Agency M/s, Aayush fire & Safety Services , Dated:30/07/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/86 / 2013-14, Dated: 11/08/2011.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for **for Industrial Building known as HDIL Industrial Park in Building No- 7,8,9,10,11,12,14,15,17,18 & 19 G+2.**at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Aayush fire & Safety Services bearing License No. MFS-LAF-0132 , MFS-LA/D - 191 issued by this office and has submitted Certificate on dated- 30/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.29480/- vide Receipt No.-226869 Dated- 6/8/2014 .DD.bearing No. - 231314 Issued by -Ratnakar Bank., renewal fees for the said building.& Rs. 40058/- vide Receipt No. 226859 Dated 01/08/2014 DD No. 231306

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 165 /2014-15 DATE: 05/08/2014

TO,

M/s Housing Development & Infrastructure Ltd,
9-01,HDIL Towers,Anant Kaneker Marg,
Bandra (E).Mumbai 400 051.

Sub:- Renewal of "Final No Objection Certificate" of Residential cum Commercial Building known as HDIL Residential Park Building No- A-16,20,B1-8,14,D2-7,18,E1-17,19,E1a-15,J-6,J1-22,N1-2,E3-E3 Part stilt+7 & Residential Building NO.B-9,10,11,12,D-1,2,3,4,E-13,F-5, stilt+7 . at village Dongre. ,Tal- Vasai, Dist- Thane.

Ref :- 1. An application received by Housing Development & Infrastructure Ltd,, Dated: 30/07/2014.
2. Certificate from License Agency M/s, Aayush fire & Safety Services , Dated:30/07/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/05 / 2013-14, Dated: 06/04/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Residential cum Commercial Building known as HDIL Residential Park in Building No- A-16,20,B1-8,14,D2-7,18,E1-17,19,E1a-15,J-6,J1-22,N1-2,E3-E3 Part stilt+7 & Residential Building NO.B-9,10,11,12,D-1,2,3,4,E-13,F-5,** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Aayush fire & Safety Services bearing License No. MFS-LAF-0132 , MFS-LA/D - 191 issued by this office and has submitted Certificate on dated-30/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 390327/- vide Receipt No.- 226867 Dated- 6 /8 /2014 .DD.bearing No. -231316 Issued by - Ratnakar Bank., renewal fees for the said building. & Rs. 45674/- vide Receipt No. 226860 Dated 01/08/2014 DD No. 231307

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE THANE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 166/2014-15 DATE: 05/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building Known as "PAM TOWER"on Land bearing S.No. 228, H.No.1/3B & 1/3C, & S.No. 228A, H.No. 2 at village: Virar, Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1697 / 2014, Dated:- 07/07/2014.
2. An application received by M/s. Pam Enterprises / Prithvi arch Consultants for Dated: 08/07/2014.
3. Revised D.P. Issued By CIDCO/VVSR/RDP/BP-3266/E/177, Dated: 23/04/2010.
4. Certificate from License Agency M/s, Fire Worx Engineering, Dated:07/07/2014. (Form A).
5. Building Completion certificate M/S. Prithvi arch Consultants, Dated:08/07/2014.
6. Built up area certificate Prithvi arch Consultants, Dated:08/07/2014.
7. Structure Stability certificate Prithvi arch Consultants, Dated:08/07/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 135492 Dated:- 24/10/2010.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building Known as "PAM TOWER"** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013 issued by this office and has submitted Certificate on 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1613.488 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

5/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 167/2014-15 DATE: 05/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial Building No.1 (Wing A) on Land bearing S.No. 36, H.No.13, at village: Waliv,Tal:Vasai, Dist:Thane.

Ref :-
1. **A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1945/ 2014, Dated:- 24/07/2014.**
2. **An application received by M/s. EN CON Architectural Structural Consultants, Dated: 24/07/2014.**
3. **Revised D.P.Issued By VVCMC No. VVCMC / TP/RDP / VP-4947 / 0145 / 2012-13 Dated: 13/12/2012.**
4. **Certificate from License Agency M/s, Fire Worx Engineering, Dated:30/06/2014. (Form A).**
5. **Building Completion certificate of M/s. EN CON Architectural Structural Consultants, Dated: 22/07/2014.**
6. **Built up area certificate M/S. EN CON Architectural Structural Consultants, Dated: 24/07/2014.**
7. **Structure Stability certificate of M/s Sanjay Narang & Associates Engineers, Dated: 22/07/2014.**

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Industrial Building No.1 (Wing A) G+2pt Floor** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013 issued by this office and has submitted Certificate on Dated:30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **793.54 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 168/2014-15 DATE: 05/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.3, Wing A & B In Sector-IV, phase-I on Land bearing S.No. / H.No. 180, 181/2, 185/1 to 12, 186,187B,188/pt,190,191,197,192,193,194,196,199,201,202,203,204/3pt,204/4,205/1,2,3 pt,6,7,206/pt,206/pt,208/1,2,4 to 8,209/pt, 211/1,2,3,6,7pt, 212/3, 231/1,214/3,215/pt, 215/pt,216/1,2,4 & 263, at village: Nilemore, Tal:Vasai, Dist:Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1727 / 2014, Dated:- 07/07/2014.
2. An application received by M/s. Sanat Mehta & Associates Consultants for Dated: 05/07/2014
3. Revised D.P. Issued By VVCMC/RDP/VP-0420/135/2011-12, Dated: 18/11/2011.
4. Certificate from License Agency M/s, Fire Worx Engineering, Dated:30/06/2014. (Form A).
5. Building Completion certificate M/S. Sanat Mehta & Associates Consultants for Dated: 05/07/2014.
6. Built up area certificate M/S. Sanat Mehta & Associates Consultants for Dated: 05/07/2014.
7. Structure Stability certificate M/S. A-CUBE Consultants, Dated:06/07/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 132420, Dated:- 05/07/2013.
9. This office Provisional No objection Certificate No. VVCMC / FIRE /154/ 2012-13, Dated:03/11/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building No.3, Wing A & B, G+7 Floor** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013 issued by this office and has submitted Certificate on 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3508.36 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

5/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 173/2014-15 DATE: 05/08/2014

TO,

M/s. Elite Food Specialites (P) Ltd.,
36/15/13, Unique Industrial Complex,
Dhumal Nagar, Village: Waliv, Tel: Vasai (E),
Dist: Thane.

Sub:- Renewal of "Final No Objection Certificate" for " Industrial Building No. 3" On Land Bearing S.No.36 H.No. 15 at village: Walive ,Tal- Vasai, Dist- Thane.
BUILDING KNOWN AS " LITTLELACY INDIA PVT. LTD"

Ref :- 1. An application received by M/s Elite Food specialities (p) ltd,Dated: 01/07/2014.
2. Certificate from License Agency M/s, Fire Worx Engineering,Dated: 01/07/2014 (Form B).
3.This office final No objection Certificate No. VVCMC/FIRE/02/ 2013-14, Dated: 02/04/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Industrial Building No. 3" known as " LITTLELACY INDIA PVT. LTD" G+2 part Floors"** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. No. MFS-LA/F- 0227, dated 16/08/2013 issued by this office and has submitted Certificate on dated- 30/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the **Rs.21,250/- vide Receipt No.-226838, Dated 16/07/2014 DD.bearing No. 657375 Issued by South Indian Bank, & Rs.3000/- vide Receipt No.-226842, Dated 17/07/2014** renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 174/2014-15 DATE: 05/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building Known As YASHWANT DARSHAN on land bearing S.No. 154,155 & 156 S.No. 402/A of village- Virar, Tal- Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1728/ 2014 Dated: 07/07 / 2014.
2) An application received by M/s. KeshavKumar Enterprises, Dated: 07/07/2014.
3) Revised D.P Issued by VVCMC/TP/RDP/VP-0166 /076/2014-15 Dated:01/07/2014
4) Certificate from License Agency M/s. M/s, Fire Worx Engineering, Dated: 07/07/2014. (Form A).
5) Building Completion certificate of M/s Abhay Raut, Dated: 01/07/2014
6) construction area certificate M/s Abhay Raut, Dated: 01/07/2014
7) Structure Stability certificate of Nimisha Structural Design Academy Dated: 25/11/2013.
8) License to work the Lift From Govt. of Maharashtra Industries, License No.- 119052 Dated-06/03/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building Known As YASHWANT DARSHAN** at above mentioned address. As per R.D.P issued by By **VVCMC/TP/RDP/VP-0166 /076/2014-15 Dated:01/07/2014 .**The party has constructed **"Residential Cum Commercial Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: **16/07/2014** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 07/07/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1755.64 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs- 2,00,000/- vide Receipt No. -226828 Dated -07/07/2014. DD.bearing No.- 107069 Issued by Vasai vikas co. Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **1755.64 Sq.Mtr**.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 175/2014-15 DATE: 05/08/2014

TO,

M/s. Anika Apparels Pvt Ltd.,
Shubh Industrial Estate, Gala No. 119,
First Floor, Opp. Chinchpada Busstop,
Waliv Road, Village: Gokhivare, Tel: Vasai,
Dist: Thane.

Sub:- Renewal of "Final No Objection Certificate" for " Anika Apparels Pvt. Ltd., Shubh Industrial Estate, Gala No. 119, First Floor, Opp. Chinchpada Busstop, Waliv Road, Village: Gokhivare, Tel: Vasai, Dist: Thane

Ref :- 1. An application received by M/s. Anika Apparels Pvt Ltd.Dated: 17/07/2014.
2. Certificate from License Agency M/s, Fire Worx Engineering,Dated: 30/06/2014 (Form B).
3.This office final No objection Certificate No. VVCMC/FIRE/241/ 2012-13, Dated: 06/02/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Anika Apparels Pvt. Ltd.,** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. No. MFS-LA/F-0227, dated 16/08/2013 issued by this office and has submitted Certificate on dated- 30/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the **Rs. 3000/- vide Receipt No.-226842, Dated 17/07/2014 Issued by Cash** renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 179/2014-15 DATE: 13/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Building No.2 (Wing E & F) Known as'Shiv Shrushti Complex' located on S.No. 73A; S.No.73B;S.No.112, H.No.4 & 5 at village: Achole, Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2064 / 2014, Dated:- 05/08/2014.
2. An application received by M/s. En Con Consultants for Dated: 31/07/2014.
3. Revised D.P. Issued By VVCMC/TP/RDP/VP-00121 & 3051/012/2013-14, Dated: 09/04/2013.
4. Certificate from License Agency M/s, Sadanand Fire Contorls, Dated:15/05/2013. (Form A).
5. Building Completion certificate M/S. En Con Consultants for Dated: 01/06/2014.
6. Built up area certificate M/S. En Con Consultants for Dated: 01/06/2014.
7. Structure Stability certificate M/S.Umesh D. Tryshetye, Dated:06/07/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 108392, Dated:- 04/02/2012 & licence, No. 101713, Dated:- 01/07/2011.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Building No.2 (Wing E & F) (G+7 Floors) Known as'Shiv Shrushti Complex** at above mentioned address. As per c.c issued by **VVCMC/TP/RDP/VP-00121 & 3051/012/2013-14, Dated: 09/04/2013.** The party has constructed **Residential Building No.2 (Wing E & F) (G+7 Floors) Known as'Shiv Shrushti Complex'** as per sanctioned Plan.

With reference to above on Dated: /2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s Sadanand Fire Controls bearing License No. MFS-LA/RF216,Date- 01/05/2014 issued by this office and has submitted Certificate of dated 15/05/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical wet riser down comer hydrant system
2. Courtyard single hydrant valve
3. Internal single landing valve
4. Hose reel drum set
5. Hose box set
6. Siamese connection
7. Booster pump on terrace level
8. Hydrant main pump
9. ABC Type fire Extinguishers 5 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to Residential Building No.2 (Wing E & F) (G+7 Floors) Known as'Shiv Shrushti Complex 3248.05 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the **Residential Building No.2 (Wing E & F)** Rs. 80,000 /- vide Receipt No. 226699, & Rs. 3,20,000 /- vide Receipt No. 226700,Dated 05/07/2014., DD.bearing No. 140182 & 140181, Ratnakar Bank, Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to 3248.05 Sq.Mtrs**. as per the letter given by the party Dated 04/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane

13/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 180/2014-15 DATE: 13/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.4 (Wing A & B) located on land bearing S.No. 69,H.No. 1,2,3; S.No.70. H.No. 1,2,3,4, at village: Chulne & S.No. 79A, H.No.3; S.No.84A of Village:Barampur, S.No.203A, H.No.1; S.No.208A, H.No.3 of Village:Sandor, Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2065 / 2014, Dated:- 05/08/2014.
2. An application received by M/s. En Con Consultants for Dated: 31/07/2014.
3. Revised D.P. Issued By VVCMC/TP/RDP/VP-0667/0255/2013-14, Dated: 01/10/2013.
4. Certificate from License Agency M/s, Sadanand Fire Controls, Dated:05/05/2013. (Form A).
5. Building Completion certificate M/S. En Con Consultants for Dated: 23/07/2014.
6. Built up area certificate M/S. En Con Consultants for Dated: 23/07/2014.
7. Structure Stability certificate M/S.Sanjay Narang & Associates, Dated:23/07/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 69954, Dated:- 23/05/2007 & licence, No. 88897, Dated:- 11/02/2010.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.4 (Wing A & B)** at above mentioned address. As per D.P. issued by **VVCMC/TP/RDP/VP-0667/0255/2013-14, Dated: 01/10/2013.** The party has constructed **Residential Cum Commercial Building No.4** as per sanctioned Plan.

With reference to above on Dated:05/08/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s Sadanand Fire Controls bearing License No. MFS-LA/RF216,Date- 01/05/2014 issued by this office and has submitted Certificate of dated 05/05/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Vertical wet riser down comer hydrant system
2. Courtyard single hydrant valve
3. Internal single landing valve
4. Hose reel drum set
5. Hose box set
6. Siamese connection
7. Booster pump on terrace level
8. Hydrant main pump
9. ABC Type fire Extinguishers 5 kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having Builtup area admeasuring **to Residential Cum Commercial Building No.4, Built up Area 3094.71 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 3,20,000 /- vide Receipt No. 226683, & Rs. 80,000 /- vide Receipt No. 226684, Dated 04/07/2014., DD.bearing No. 540176 & 540177, Elahabad Bank, Issued by in favour of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to 3094.31 Sq.Mtrs**. as per the letter given by the party Dated 30/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 184/2014-15 DATE: 13/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of RESIDENTIAL BUILDING Type A5a(725,726), A6(723), A7(724),on land bearing New S.No. 1,2,3,4, of village Achole. S.No. 101,103,104,106,107 of village Manikpur S.No. 97B,105B,106B of village Gokhiware, S.NO.254, H.No.3,6,7/1,7/2,13,14,15 &16 of village Achole, S.NO.128, H.NO-6 , S.NO.106, H.NO.8, S.NO.110, H.NO.8/1 of village Gokhiware.Tal. Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2010/ 2014 Dated: 01 / 08 / 2014.
2) An application received by M/s. Shah Gatani Consultants, Dated:02/07/2014..
3) Revised RDP Issued By CIDCO/,VVSR/RDP/BP/ZCC-20/E/124, Dated:-20/04/2010.
4) Certificate from License Agency M/s. Fire Works Engineering, Dated:01/08/2014. (Form A)
5) Building Completion certificate of M/s . Shah Gatani Consultants, Dated: 02/07/2014.
6) Built up area certificate of M/s . Shah Gatani Consultants, Dated: 02/07/2014.
7) Structure Stability certificate of M/s . Shah Gatani Consultants, Dated: 02/07/2014.
8) Lift completion undertaking by the Lakozy Builders Dated:-12/08/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL BUILDING Type A5a(725,726), A6(723), A7(724),** Building at above mentioned address. As per c.c issued by **CIDCO/,VVSR/RDP/BP/ZCC-20/E/124, Dated:-20/04/2010.** The party has constructed **"RESIDENTIAL BUILDING Type A5a(725,726), A6(723), A7(724)) Building G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 25/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Works Engineering bearing License No. MFS-LA/F-0227, dated 16/08/2013 issued by this office and has submitted Certificate of dated 01/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe

B) Fire Extinguishers ABC Type.

This office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring **to 4743.80 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.4,50,000 /- vide Receipt No. 226861, Dated 01/08/2014 & .DD.bearing No. 119061, & Rs.30,000 /- vide Receipt No. 226862, Dated 01/08/2014 & .DD.bearing No. 196227 Issued by Bank of India .in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **4743.80 Sq.Mtrs.** as per the letter given by the party Dated 21/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 185/2014-15 DATE: 13/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of CFC Building on land bearing S.No. 97/1/2 + 4/6/2 +4/7/3 + 4/12/2 + 4/13/2 + 4/15 (P),S.NO. 97,H.NO.2&5 of village- WALIV, Tal- Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1682/ 2014 Dated: 05/07 / 2014.
2) An application received by M/s. Himesh gupta & Associates, Dated: 27/06/2014.
3) Revised c.c. Issued by VVCMC/TP/CC/VP-0800/1462.Dated:25/10/2011.& Revised D.P Issued by VVCMC/TP/RDP/VP-0800/233/2012-13 .Dated:16/03/2013.
4) Certificate from License Agency M/s. – Fire worx Engineering Dated- 01/08/2014 (Form A)
5) Building Completion certificate of M/s Himesh gupta & Associates, Dated: 27/06/2014.
6) construction area certificate M/s Himesh gupta & Associates,Dated: 27/06/2014.
7) Structure Stability certificate of A-cube Cosultant, Dated: 15/04/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **CFC** Building at above mentioned address. As per **Revised C.C. Issued by VVCMC/TP/CC/VP-0800/1462. Dated:25/10/2011 & Revised D.P Issued by VVCMC/TP/RDP/VP-0800/233/2012-13 .Dated:16/03/2013.**The party has constructed **"CFC BUILDING G+2 Floors"** as per sanctioned Plan.

With reference to above on Dated: 05/08/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Fire worx Engineering bearing License No. MFS-LA/RF- 227Dated-16/08/2013 issued by this office and has submitted Certificate On Dated-01/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
- a) on every floor hose reel hose & landing valve / Hydrant valve
- b) Booster pump on terrace- 5 HP
- c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
- d) Main Pump- 10 HP

B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **471.99 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-80,000/- vide Receipt No. -76245 Dated -13/03/2013. DD.bearing No.- 028564 Issued by Vasai Vikas Bank in favors of VVCMC additional Capitation & Scrutiny fees for the total Built up area **471.99 Sq.Mtr**.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

13/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 186/2014-15 DATE: 13/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building on Land bearing S.No. 70, H.No.3, at village: Waliv,Tal:Vasai, Dist:Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1235/ 2014, Dated:- 12/08/2014.
2. An application received by M/s. EN CON Architectural Structural Consultants, Dated: 11/08/2014.
3. Revised D.P.Issued By CIDCO /VVSR/RDP/BP-4496/E/0263, Dated: 06/05/2010.
4. Certificate from License Agency M/s, Fire worx Engineering-, Dated:01/08/2014. (Form A).
5. Building Completion certificate of M/s. EN CON Architectural Structural Consultants, Dated: 07/08/2014.
6. Built up area certificate M/S. EN CON Architectural Structural Consultants, Dated: 07/08/2014.
7. Structure Stability certificate of M/s Sanjay Narang & Associates Engineers, Dated: 07/08/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 136514, Dated:- 08/11/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building** at above mentioned address. As per R.D.P. issued by **CIDCO /VVSR/RDP/BP-4496/E/0263, Dated: 06/05/2010.**. The party has constructed **"Industrial Building G+2 pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 05 /08 /2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s.Fire Worx Engineering bearing License No.MFS-LA/F-0227- Dated 16/08/2013, issued by this office and has submitted Certificate on Date 01/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. 15HP submersible pump
2. 5 HP Booster pump
3. S.S. single hydrant valves
4. Hose box
5. 2 way breeching
6. RRL Canvas pipe 15mtr long 63mm dia with male female coupling with branch
7. Thermpolast hose reel pipe 20mtr long 20mm bore with hose drum and shut up nozzle
8. ABC type fire extinguishe 4kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 383.65 **Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & you will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40,000/- vide Receipt No. 226855 Dated 30/07/2014, DD No. 008935, & Rs. 31,700/- vide Receipt No. 226856, Dated 30/07/2014, DD No. 008936, Union Bank.ltd for the total built up area 383.65 **Sq.Mtrs.** as per the letter given by the party Dated:- 30/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

13/8/2019

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 187/2014-15 DATE: 13/08/2014

TO,

M/s V R Construction Co.
Shop no.7, Swaran Hans Tower, Building No.1, Sector No. VI, Shreeprastha,
Nallasopara (W), Palghar.

Sub:- Renewal of "Final No Objection Certificate" for Residential Cum Commercial Building No.1, Sector VI, wing A & B, Known as SWARNHANS TOWER, on plot no. 1 to 8, 14 to 205, 214 to 218, 228 to 232, 240,241 on land bearing S. No- 56 to 58, 90, 91(p), 92 to 95, 98, 100, 102,103,104, 136, 137, , 148 to 157, 165 to 171, 173, 178 at village Nilemore, Tal- Vasai, Dist- Palghar.

Ref :- 1. An application received by M/s V R Construction Co. Dated:13/08/2014.
2. Certificate from License Agency M/s,Fire Worx engineering Dated:30/07/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/71/ 2012-13, Dated: 24/07/2012.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for **for Residential Cum Commercial Building No.1, Sector VI, wing A & B, Known as SWARNHANS TOWER.** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Fire Worx engineering bearing License No. MFS-LA/F-0227 dated 16/08/2013 issued by this office and has submitted Certificate on dated- 30/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 64000/- vide Receipt No.- 226820, Dated- 07/07/2014 .DD.bearing No.675743 Issued by City Union Bank.Ltd, renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you,

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

13/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 188/2014-15 DATE: 13/08/2014

TO,

M/s Kartikya Constructions,
Kartikya Paradise, shop no.31, shri Prastha complex, Nallasopara (W), Palghar.

Sub:- Renewal of "Final No Objection Certificate" for Residential Cum Commercial Building No.1, Sector VI, wing C & D, Known as KARTIKYA PARADISE, on plot no.89,90,101 &102 on land bearing S. No- 150 at village Nilemore, Tal- Vasai, Dist- Palghar.

Ref :- 1. An application received by M/s Kartikya Constructions, Dated: 13 /08 /2014.
2. Certificate from License Agency M/s,Fire Worx engineering Dated:30/07/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/72/ 2012-13, Dated: 24/07/2012.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for **for Residential Cum Commercial Building No.1, Sector VI, wing C & D, Known as KARTIKYA PARADISE** . at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Fire Worx engineering bearing License No. MFS-LA/F-0227 dated 16/08/2013 issued by this office and has submitted Certificate on dated- 30/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 64000/- vide Receipt No.- 226821, Dated- 07/07/2014 .DD.bearing No.675742 Issued by City Union Bank.Ltd, renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you,

FIRE BRIGADE

13/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 189/2014-15 DATE: 13/08/2014

TO,

M/s Manoj Expo International,
Bhanu Industrial Estate No.5, Bldg No.3, Dhumal nagar, Plot no.36/14,
Near Jivdani Industrial Estate No.2, waliv, Vasai (E), Palghar.

Sub:- Renewal of "Final No Objection Certificate" for Industrial Building called Manoj Expo International, Bhanu Industrial Estate No.5, Bldg No.3 on land bearing S. No- 36, H.No.14 at village Waliv, Tal- Vasai, Dist- Palghar.

Ref :- 1. An application received by M/s Manoj Expo International, Dated: 02/08/2014.
2. Certificate from License Agency M/s,Fire Worx engineering Dated:01/07/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/148 / 2012-13, Dated: 25/10/2012.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for **for Industrial Building called Manoj Expo International, Bhanu Industrial Estate No.5, Bldg No.3** . at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Fire Worx engineering bearing License No. MFS-LA/F-0227 dated 16/08/2013 issued by this office and has submitted Certificate on dated- 01/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 21250 /- vide Receipt No.- 226865, Dated- 02/08/2014 .DD.bearing No.963003 Issued by Union Bank., renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you,

FIRE BRIGADE

13/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 190/2014-15 DATE: 13/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of RESIDENTIAL CUM COMMERCIAL BUILDING No.6,Ph-I,section-v,wing-B&C known as SATYAM TOWER on proposed Group housing scheme on S.No.255/1,2,3,4,5,S.No-257,S.No-259/1,S.No-260pt & S.No-261. at village Nilemore, Tal. Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1667 / 2014 Dated: 05 / 07 / 2014.
2) An application received by M/s. Sanat Mehta & Associates, Dated:30/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP- 0111/100/2012-13,Dated:-11/07/2012.
4) Certificate from License Agency M/s. **M/s, Fire Worx Engineering, Dated: 20/05/2014 (Form A).**
5) Building Completion certificate OF M/s. Sanat Mehta & Associates, Dated:30/06/2014.
6) Built up area certificate OF M/s. Sanat Mehta & Associates, Dated:30/06/2014
7) Structure Stability certificate No. Vijay S. Gurav,Dated:11/06/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, licence No. 144482 & 144479 Dated-02-08-2014
9) This Office Provisional No Objection Certificate vvcmc/fire/280/2012-13 Dated-12/10/2012

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your Residential cum commercial Building **No.6,Ph-I,section-v,wing-B&C known as SATYAM TOWER** Building at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 30/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Final No Objection Certificate" for your following building having built up area admeasuring to **4057.06 Sq.Mtrs**. This certificate shall be treated valid up to 31/12/2014 It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of " Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 191/2014-15 DATE: 20/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" For Commercial Building No.1 (Basement+ Ground+3) located on land bearing S.No. 69, H.No. 1,2,3, S.No.70, H.No.1,2,3,4, of village: Chulne, & S.No. 79A, H.No.3, S.No.84A of Village: Barampur, S.No. 203A, H.No.1, S.No.208A, H.No.3 of Village: Sandor, Tal: Vasai, Dist- Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/2133/2014 Dated:12/08/2014.
2) An application received by M/s. En Con Consultant, Dated: 08/08/ 2014
3) Revised RDP Issued By VVCMC No. VVCMC/TP/RDP/VP-0667/0225/2013-14, Dated:01/10/2013.
4) Certificate from License Agency M/s. Nishan Enterprises, Dated: 23/07/2014.(Form A)
5) Building Completion certificate m/s. En Con Consultant, Dated:23/07/ 2014
6) Built up area certificate of M/s . En Con Consultant, Dated:23/07/ 2014
7) Structure Stability certificate of M/s. Sanjay Narang & Associates Consultant, Dated: 23/07/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy, No. 140612, Dated:- 25/03/2014.
9) fire fighting installation completion undertaking by Homage Developers Dated-28/07/2014 & Hardcastle Restaurant pvt ltd. Dated – 19/08/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Commercial Building No.1 (Basement+ Ground+3)** at above mentioned address. As per RDP issued by **VVCMC No. VVCMC/TP/RDP/VP-0667/0225/2013- 14, Dated:01/10/2013.** The party has constructed **"Commercial Building No.1 (Basement+ Ground+3)"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s. Nishan Enterprises, bearing License No. MFS-LA/F-0276, & MFS-LA/D-0230, issued by this office and has submitted Certificate on dated 23/07/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) **Vertical Riser Cum Down Comer System**
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Control Panel for Pump-1 No.
   e) Main pump- 15 HP
B) **Fire Extinguishers ABC Type.**
C) **Court yard Hydrants**

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1499.38 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

Before Starting of use of basement sprinkler system must be provided by the Owner or the Occupier and also before used of commercial part all the shop/other business holders must be take NOC from our department. If the Owner or the Occupier not following these condition then they are fully responsible for any accident & they will be solely responsible to loss of life or property.

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 85000 /- vide Receipt No. 226682, & Rs. 85000 /- vide Receipt No. 226681, Dated 04/07/2014. DD. bearing No. 540174 & 540175, Issued by Alahabad Bank in favor of VVCMC additional Capitation & Scrutiny fees for the total Construction area admeasuring **to 1499.38 Sq.Mtrs** as per the letter given by the party Dated 30 /06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 192/2014-15 DATE: 22/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" for Residential Building on S.No.114,H.No.32,37,47,21/5,48 & S.No.114,H.No.43 at village –Kopari,Tal- Vasai, Dist- Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2207 / 2014, Dated:- 21/08/2014.
2. An application received by M/s. Ajay wade & Associates, Dated: 24/06/2014.
3. Revised RDP. Issued By No. VVCMC/TP/RDP/VP-0780 & VP-0771/118/2012-13 Dated-17/07/2012.
4. Certificate from License Agency M/s, Ronak fire Industries, Dated: - 23/06/2014 (Form A).
5. Building Completion certificate of M/s. Ajay wade & Associates, Dated: 27/06/2014
6. Built up area certificate of M/S M/s. M/s. Ajay wade & Associates, Dated: 27/06/2014.
7. Structure Stability certificate of Ms.SURESH Kumar m.panikar, Dated:- 25/07/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 120775 & 120777 Dated:- 26/04/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENCIAL** Building at above mentioned address. As per c.c issued by By **VVCMC/TP/RDP/VP-0780 & VP-0771/118/2012-13 Dated-17/07/2012.**The party has constructed **"RESIDENCIAL BUILDING G+7 Floors"** as per sanctioned Plan.

With reference to above on Dated: - 05/08/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Ronak fire Industries bearing License No. MFS-LA/RF- 0157,Dated-18/07/2013. issued by this office and has submitted Certificate On DATED-23/062014 "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2690.96 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-240000/- vide Receipt No. -154395 Dated - 10/12/2013 DD.bearing No.- 000330 Issued by VASAI VIKAS Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **2690.96 Sq.Mtrs**.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 193/2014-15 DATE: 22/08/2014

TO,
M/s. Metler-Toledo India Pvt. Ltd.,
Industrial Building No-3,S.no 44 &45,
Village: Mouje Satiwali, Tel: Vasai (E),
Dist: Thane.

Sub:- Renewal of "Final No Objection Certificate" for " Industrial Building No. 3" On Land Bearing S.No.44&45 Village: Mouje Satiwali,Tal- Vasai, Dist- Thane.

Ref :- 1. An application received by M/s. Metler-Toledo India Pvt. Ltd,Dated: 13/08/2014.
2. Certificate from License Agency M/s, Fire Ext Engineering,Dated: 01/07/2014 (Form B).
3.This office final No objection Certificate No. VVCMC/FIRE/105/ 2012-13, Dated: 24/09/2012.

Dear sir,

With reference to Sr.No.1 above, these office is in receipt of your application for your **Industrial Building No. 3** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Fire ext Engineering bearing License No. No. MFS-LA/0001/F- 0028, issued by this office and has submitted Certificate on dated- 01/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the **Rs.3000/- vide Receipt No.-226887, Dated 20/08/2014** renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 194/2014-15 DATE: 22/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of CFC Building on Land bearing S.No. 371, H.No. 1 (p) & 3, at village: juchandra,Tal:Vasai, Dist:Thane.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1726/ 2014, Dated:- 07/07/2014.
2. An application received by M/s. Himesh Gupta & Associates Architectural Structural Consultants, Dated: 28/06/2014.
3. Revised P.C.C.Issued By VVCMC No. VVCMC / PCC / VP-0123 / 50 / 2013-14. Dated: 18/05/2013.
4. Certificate from License Agency M/s, Fire Worx Engineering, Dated:31/03/2014. (Form A).
5. Building Completion certificate of M/s. Himesh Gupta & Associates Architectural Structural Consultants, Dated: 04/07/2012.
6. Built up area certificate Himesh Gupta & Associates Architectural Structural Consultants, Dated: 04/07/2014.
7. Structure Stability certificate of M/s Jay Shree Krishna consulting Engineer Dated: - 04/07/2014.
8. This office Provisional No objection Certificate No. VVCMC / FIRE /144/ 2011-12, Dated:05/10/2011.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **CFC Building** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013 issued by this office and has submitted Certificate on 31/03/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **971.08 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 200/2014-15 DATE: 27/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential building no.6 (wing C & D) on Land bearing S.No. 165, H.No. 1,2,3,4,5,6,7,8,9,10,11,12,13, S.No. 167, H.No 1,2, S.No. 168, H.No.1,2,S.No. 169, H.No. 1,2,3, S.No. 1,2. S.No.173 H.No.1,2, S.No.365 at Village- Bolinj, Tal- Vasai, Dist- Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCMC / NR / 2248 / 2014, Dated:- 22/08/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 12/06/2014.
3. Revised D.P. Issued By CIDCO / VVSR / RDP / BP-3647,4226& 4437/W/ 092 / 2011-12. Dated: 28/09/2011.
4. Certificate from License Agency M/s, Sadanand Fire Systems, Dated:12/06/2014 (Form A).
5. Building Completion certificate of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:12/07/2014.
6. Built up area certificate of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated:26/06/2014.
7. Structure Stability certificate of M/s. Hiren M.Tanna, Dated:22/02/2013.
8. Lift completion undertaking by Unique construction Pvt.Ltd Dated- 09/07/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential building no.6 Wing C&D** Building at above mentioned address. **Revised D.P. Issued By CIDCO / VVSR / RDP / BP-3647,4226& 4437/W/ 092 / 2011-12. Dated: 28/09/2011**The party has constructed **"Residential building no.6 Wing C&D,Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 05/08/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **License Agency i.e.M/s.Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, dated 12/06/2014 issued by this office and has submitted Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on 450 LPM.
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 2648.68 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.480000/- vide Receipt No. 226612 Dated - 01/07/2014for the total gross built up area -2648.68 Sq.Mtr. as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 201/2014-15 DATE: 27/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building, Building No-1 Wing B on Land bearing S.No. 73, H.No. 3, S.No.74, H.No.12, 13, 14/2 & 15, S.No.75, H.No.2 at village Chulne ,Tal- Vasai, Dist- Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 1703 / 2014, Dated:- 07/07/2014.
2. An application received by M/s. EN CON Project Consultants for Architectural Structural Works, Dated: 28/06/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP / VP- 598/099/ 2013-14. Dated: 14/06/2013.
4. Certificate from License Agency M/s, Sadanand Fire System, Dated:28/06/2014 (Form A).
5. Building Completion certificate No. VP-0598/78 of M/s. EN CON Project Consultants for Architectural & Structural Works, Dated: 28/06/2014.
6. Built up area certificate No. VP-0598/88 of M/s. Sanjay Narang & Associates, Dated: 28/08/2014.
7. Structure Stability certificate of M/s. Sanjay Narang & Associates, Dated: 22/04/2014.
8. Lift completion undertaking by prime construction Dated- 20/08/2014.
9. This office Provisional No objection Certificate No. VVCMC / FIRE / 199 / 2012-13, Dated: 10/01/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Residential Cum Commercial Building, Building No-1 Wing B** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Sadanand Fire Systems bearing License No. LA/F-0252 ,Dated- 15/10/2013 issued by this office and has submitted Certificate of dated 28/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009",** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to 1851.29 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 202/2014-15 DATE: 27/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1, Located on Land bearing S.No.69, H.No. 12 & 13 Of village: Manickpur and S.No. 197-B Of Village: Chulne,Tal- Vasai, Dist- Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2249 / 2014, Dated:- 22/08/2014.
2. An application received by M/s. En Con Consultants, Dated: 12/06/2014.
3. Revised RDP Issued By VVCMC/TP/RDP/VP-0554/008/2013-14,Dated: 06/04/2013.
4. Certificate from License Agency M/s. Sadanand Fire Systems , Dated: 12/06/2014 (Form A).
5. Building Completion certificate & Built up area certificate of M/s. En Con Consultants, Dated: 12/06/2014.
6. Structure Stability certificate of M/s. Sanjay Narang & Associates,Dated: 12/06/2014.
7. Lift completion undertaking of M/S Unique land reality Pvt.Ltd Dated- 09/07/2014.
8. This office Provisional No objection Certificate No. VVCMC/ FIRE /173/2011-12, Dated: 03/02/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1,G+7 Floor** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Sadanand Fire Systems bearing License No. MFS-LA/F- 0252, issued by this office and has submitted Certificate for Dated: 12/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **1534.95 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 203/2014-15 DATE: 27/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub:- "Final No Objection Certificate" of Industrial Building on land bearing S.No. 234/1, 2, 3/1, 3/2, 4, 236/1, 2 & 237/1, 2 Plot No. 24 & S.No. 235, of village- Gokhiware, Tal-Vasai, Dist-Thane.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1025/ 2013-2014 Dated: 03/ 07/ 2013.
2) An application received by M/s. Himesh gupta & Associates, Dated: 12/08/2013.
3) C.C Issued by CIDCO/VVSR/BP-1302/E/5927 Dated- 12/03/1996.
4) Certificate from License Agency M/s. Shubhada Engineering, Dated:- 19/08/2014. (Form A)
5) Building Completion certificate of M/s Hi mesh gupta & Associates, Dated: 07/08/2013.
6) Construction area certificate M/s Himesh gupta & Associates, Dated: 07/08/2013.
7) Structure Stability certificate of Mr. Arun Bhakri, Dated:-12/04/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building** at above mentioned address. As per **C.C Issued by CIDCO/VVSR/BP-1302/E/5927 Dated- 12/03/1996.**The party has constructed **"Industrial Building ,Basement+ Gr +1** Floors" as per sanctioned Plan.

With reference to above on Dated: 23/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e.**M/s Shubhada Engineering bearing License No. MFS-LA/RF-0036Date- 12/05/2014 issued by this office and has submitted Certificate of dated - 19/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. wet riser down comer hydrant system
2. Courtyard single hydrant valve
3. Internal single landing valve
4. Hose reel drum set
5. Hose box set
6. Siamese connection
7. Jockey pump
8. Diesel & Electric Hydrant main pump
9. ABC Type fire Extinguishers 5 kg capacity
10. Sprinkler system in Basement.

This office is issuing a **"Final No Objection Certificate"** for your following building having construction area admeasuring **to 5137.95 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 4,75,000 /- vide Receipt No. 142615, Dated 12/08/2013., DD bearing No. 022274.,& Rs. 4,75,000 /- vide Receipt No. 142614, Dated 12/08/2013., DD bearing No. 022275, Axis Bank Issued by in favour of VVCMC & Rs. 50,000 /- vide Receipt No. 153682, Dated 16/09/2013., DD bearing No. 2020. additional Capitation & Scrutiny fees for the total construction area admeasuring **to 5137.95 Sq.Mtrs.** as per the letter given by the party Dated 07/08/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

27/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

ICIPAL CORPORATION RE ADE

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 206/2014-15 DATE: 27/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Residential Cum Commercial building Type SG-1 & SG-2 (Wing 1,2,3,4,5,6,7,8) in Avenue 'A4' , Known as 'GLOBAL CITY' on Land bearing New S.No.5, 5B, 5F, 5G, 5D at Village- Dongre, Virar (W), Vasai, Dist-Palghar

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/2214/2014 Dated:21/08/2014
2) An application received by M/s. SHAH GATTANI CONSULTANTS, Dated:08/08/2014
3) Revised D.P. Issued By VVCMC/TP/AM/VP-0453/296/2011-12 . Dated:31/03 /2012.
4) Certificate from License Agency M/s RUSHIL FIRE PROTECTION SYSTEM Dated:-23/06/2014.(Form A)
5) Building Completion certificate & Built up area certificate of M/s. SHAH GATTANI CONSULTANTS, Dated:-08/08/2014.
6) Structure Stability certificate M/s. SHAH GATTANI CONSULTANTS Dated-08/08/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License no. 141010, 141011,141012, 141013, 141014, 141015 Dated 17/04/2014 & 143217,143221 Dated -14/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **for Residential Cum Commercial building Type SG- 1 & SG-2 (Wing 1,2,3,4,5,6,7,8) in Avenue 'A4' , Known as 'GLOBAL CITY'** Building at above mentioned address. As per **Revised D.P. Issued By VVCMC/TP/AM/VP-0453/296/2011-12 . Dated:31/03 /2012.** The party has constructed **Residential Cum Commercial building Type SG- 1 & SG-2 (Wing 1,2,3,4,5,6,7,8) in Avenue 'A4' , Known as 'GLOBAL CITY' Building S/Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 18/06/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. M/s **RUSHIL FIRE PROTECTION SYSTEM bearing License No. MFS-LA/RF-0206, Dated 01/03/2014. issued by this office and has submitted Certificate on dated 23/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1) Vertical Riser Down Comer Hydrant System
2) Courtyard single hydrant valve
3) Internal single landing valve
4) Hose reel drum set
5) Hose box set
6) Siamese connection
7) Booster main pump
8) Hydrant main pump
9) ABC type fire extinguishers 5kg capacity

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **Type SG- 1 & SG-2 (Wing 1,2,3,4,5,6,7,8) in Avenue 'A4' is, 14563.07** Sq.Mtrs**.** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.960000/- vide Receipt No. 211897 Dated - 30/03/2012 & DD No. 028137 of Basin Catholic - Bank & Rs.400000/- vide Receipt No. 211896 Dated - 30/03/2012 & DD No. 028138 of Basin Catholic - Bank the total gross built up area **14563.07** Sq.Mtrs.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

27/8/2012

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 207/2014-15 DATE: 27/08/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Residential cum commercial Building No-2 Wing-A&B In Sector VII on Land bearing S.No.209B,246 to 259,267 to 271 at village Juchandra , Tal- Vasai, Dist- Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2213/ 2014, Dated:- 21/08/2014.
2. An application received by M/s. Ajay Wade & Associates, Dated: 24/07/2014.
3. Revised D.P. Issued By No. VVCMC / TP / RDP / VP-0570/0294/2013-14 Dated- 20/11/2013.
4. Certificate from License Agency M/s, Flame Out Fire Services, Dated: 24/06/2014 (Form A).
5. Building Completion certificate of M/s. Ajay Wade & Associates, Dated: - 24/07/2014.
6. Built up area certificate of M/s. Ajay Wade & Associates, Dated: - 24/07/2014.
7. Structure Stability certificate of M/S Shah & Shah consulting Engineers . Dated- 02/05/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, licence, No. 080324 &080323 Dated:- 07/2014.
9. This Office Provisional No Objection Certificate VVCMC/FIRE/53 /2011-12 Dated- 31/05/2011.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential cum commercial Building No-2 Wing-A&B In Sector VII on Land bearing S.No.209B,246 to 259,267 to 271 (G+7),** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Flame Out Fire Services bearing License No. MFS-LA/F- 0154 & MFS-LA/F- 0117, issued by this office and has submitted Certificate On 24/07/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **5172.39 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 211 /2014-15 DATE: 27/08/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.4 PH-I, Sector –V, (Wing C& D) Known as "SHUBHANGAN" IN THE COMPLEX KNOWN AS "VINAY COMPLEX" on land bearing S.No. / H.No.180/181/2,185/1 to 12, 186, 187B,188/pt, 190,191,197,192,193,194,196,199,201,202,203,204/3pt,204/4,205/1,2,3pt,6,7,206/pt,208/1,2,4 to 8,209/pt,211/1,2,3,6,7pt,212/3,213/1,214/3,215/pt,215/pt216/1,260pt,260pt,261&263 village-Nilemore, Tal- Vasai, Dist-Palghar..

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1687/ 2014 Dated: 05/07/2014.
2) An application received by M/s.Sanat Mehata & Associates, Dated: 04/07/2014.
3) Revised D.P Issued by VVCMC/AMEND/BP-4473/VP-0022/076/2011-12.Dated:09/08/2011.
4) Certificate from License Agency M/s. Flame Out Fire Services, Dated:03/07/2014.(Form A)
5) Building Completion certificate of M/s Sanat Mehata & Associates, Dated: 04/07/2014.
6) Builtup area certificate M/s Sanat Mehata & Associates, Dated: 04/07/2014.
7) Structure Stability certificate of M/s. Shilplekha Consultant, Dated: 30/04/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, License No.117883,117878, Dated:-30/01/2013.
9) Provisional No objection Certificate No. VVCMC/FIRE/28B/2012-13, Dated:12/10/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.4 PH-I, Sector –V, (Wing C& D)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Flame Out Fire Services bearing License No. MFS-LA/F-0154, License No. MFS-LA/F-0117,issued by this office and has submitted Certificate on Date:03/07/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **4074.11** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 3,20,000 /- vide Capitation & Scrutiny fees for the total Construction area admeasuring **to 4074.11 Sq.Mtrs.**

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE Dist. Thane.

27/8/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

Rec'd 02/09/2014

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 220/2014-15 DATE: 10/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1 (Wing A& B) sector VII on land bearing S.No. 209B,246 To 259,267 To 271 at village- Juchandra, Tal-Vasai, Dist- Palghar..

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2347/ 2014 Dated: 03/09/2014.
2) An application received by M/s.Ajay Wade & Associates, Dated: 02/09/2014.
3) Revised D.P Issued by VVCMC/TP/RDP/VP-570/0294/2013-14.Dated:20/11/2013.
4) Certificate from License Agency M/s. Flame Out fire services, Dated: 23/08/2014.(Form A)
5) Building Completion certificate of M/s.Ajay Wade & Associates, Dated: 02/09/2014.
6) Built up area certificate M/s.Ajay Wade & Associates, Dated: 02/09/2014.
7) Structure Stability certificate of M/s. Shah & shah Consulting Engineers, Dated: 02/05/2014.
8) lift Completion undertaking by Sealink construction co. pvt. Ltd.
9) Provisional No objection Certificate No. VVCMC/FIRE/53/2011-12, Dated:-31/05/2011.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 (Wing A& B) sector VII** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Flame out fire Services bearing License No. MFS-LA/RF-154 RD-0117,issued by MFS office and has submitted Certificate on Date:23/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **5172.39** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 221/2014-15 DATE: 10/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.4 PH-I, Sector –V, (Wing A& B) Known as "Sai Niwas Tower" IN THE COMPLEX KNOWN AS "VINAY COMPLEX" on land bearing S.No. / H.No.180/181/2,185/1 to 12, 186, 187B,188/pt, 190,191,197,192,193,194,196,199,201,202,203,204/3pt,204/4,205/1,2,3pt,6,7,206/pt,208/1,2,4 to 8,209/pt,211/1,2,3,6,7pt,212/3,213/1,214/3,215/pt,215/pt216/1,260pt,260pt,261&263 village-Nilemore, Tal- Vasai, Dist- Palghar..

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2372/ 2014 Dated: 06/09/2014.
2) An application received by M/s.Sanat Mehata & Associates, Dated: 30/06/2014.
3) Revised D.P Issued by VVCMC/AMEND/BP-4473/VP-0022/076/2011-12.Dated:09/08/2011.
4) Certificate from License Agency M/s. Pona Corporation, Dated: 17/06/2014.(Form A)
5) Building Completion certificate of M/s Sanat Mehata & Associates, Dated: 30/06/2014.
6) Built up area certificate M/s Sanat Mehata & Associates, Dated: 30/06/2014.
7) Structure Stability certificate of M/s. Shilplekha Consultant, Dated: 30/04/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, Licence No. 079830 & 79831
9) Provisional No objection Certificate No. VVCMC/FIRE/-142/2012-13, Dated:-20/10/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.4 PH-I, Sector –V, (Wing A& B)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Pona Corporation bearing License No. MFS-LA/RF-0149,issued by MFS office and has submitted Certificate on Date:17/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **4019.32** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

10/9/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

Received Copy

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 222/2014-15 DATE: 10/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.4 PH-I, Sector –V, (Wing E&F) Known as "Sai Savli Tower" IN THE COMPLEX KNOWN AS "VINAY COMPLEX" on land bearing S.No. / H.No.180/181/2,185/1 to 12, 186, 187B,188/pt, 190,191,197,192,193,194,196,199,201,202,203,204/3pt,204/4,205/1,2,3pt,6,7,206/pt,208/1,2,4 to 8,209/pt,211/1,2,3,6,7pt,212/3,213/1,214/3,215/pt,215/pt216/1,260pt,260pt,261&263 village-Nilemore, Tal- Vasai, Dist- Palghar..

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2371/ 2014 Dated: 06/09/2014.
2) An application received by M/s.Sanat Mehata & Associates, Dated: 30/06/2014.
3) Revised D.P Issued by VVCMC/AMEND/BP-4473/VP-0022/076/2011-12.Dated:09/08/2011.
4) Certificate from License Agency M/s. Pona Corporation, Dated: 17/06/2014.(Form A)
5) Building Completion certificate of M/s Sanat Mehata & Associates, Dated: 30/06/2014.
6) Built up area certificate M/s Sanat Mehata & Associates, Dated: 30/06/2014.
7) Structure Stability certificate of M/s. Shilplekha Consultant, Dated: 30/04/2014.
8) License to work the Lift From Govt. of Maharashtra Industries, Licence No. 079828 & 79829.
9) Provisional No objection Certificate No. VVCMC/FIRE/-143/2012-13, Dated:-20/10/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.4 PH-I, Sector –V, (Wing E& F)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Pona Corporation bearing License No. MFS-LA/RF-0149,issued by MFS office and has submitted Certificate on Date:17/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **3500.45** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

10/9/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

Received Copy
Damini Religion
10/9/14

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 226/2014-15 DATE: 10/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of INDUSTRIAL BUILDING No-1 (wing A)located on land bearing S.No.36 H.No-10. at village Waliv, Tal. Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1662 / 2014 Dated:-05 / 07 / 2014.
2) An application received by M/s.EN CON,Project consultants. Dated:28/06/2014.
3) Revised c.c. Issued By VVCMC/TP/RDP/VP- 0785/0297//2013-14,Dated:-04/12/2013.
4) Certificate from License Agency M/s. M/s, Fire Worx Engineering, Dated: 23/08/2014 (Form A).
5) Building Completion certificate M/s.EN CON,Project consultants. Dated:28/06/2014.
6) Built up area certificate M/s.EN CON,Project consultants. Dated:28/06/2014.
7) Structure Stability certificate of Sanjay Narag & Associates ,Dated:28/06/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL BUILDING No-1 (wing A)** Building at above mentioned address. As per c.c issued by By VVCMC/TP/RDP/ VP- 0785/0297//2013-14,Dated:-04/12/2013. The party has constructed **"INDUSTRIAL BUILDING No-1 (wing A) Building G+2pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 23/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
- a) on every floor hose reel hose & landing valve / Hydrant valve
- b) Booster pump on terrace- 5 HP
- c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
- d) Main Pump- 20 HP

B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **BUILDING No-1 (wing A)- 569.86 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-40,000 /- vide Receipt No.-226652.& Rs-40,000 /- vide Receipt No.-226653. Dated -03/07/2014 .DD.bearing No. -211841& 211843. Issued by – Syndicate Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **BUILDING No-1 (wing A)- 569.86. Sq.Mtrs**..

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 227/2014-15 DATE: 10/09/2014

TO,

M/s. P.K. Hospitality services Pvt.Ltd.,
Garuda House,142, Upper Govindnagar,
Malad (E),Mumbai-400 097.

Sub:- Renewal of "Final No Objection Certificate" for " Hotel Building " On Land Bearing S.No./H.No.44/5/1,10/1 at village: Walive ,Tal- Vasai, Dist- Palghar.
BUILDING KNOWN AS " Hotel Golden Tulip"

Ref :- 1. An application received by M/s. P.K. Hospitality services Pvt.Ltd , Dated: 02/09/2014.
2. Certificate from License Agency M/s, Fire Worx Engineering,Dated: 30/07/2014 (Form B).
3.This office final No objection Certificate No. VVCMC/FIRE/79/ 2013-14, Dated: 29/07/2011.

Dear sir,

With reference to Sr.No.1 above, this office is in receipt of your application for your **Hotel Building known as " Hotel Golden Tulip" G+2 part Floors"** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. No. MFS-LA/F- 0227, dated 16/08/2013 issued by this office and has submitted Certificate on dated- 30/07/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the **Rs.1,80,000/- vide Receipt No.-265606, Dated 02/09/2014 DD.bearing No.430743 Issued by Panjab National Bank,** renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGADE

10/9/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 228/2014-15 DATE: 10/09/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1 (Wing D) sector V on land bearing S.No. 387B,22/4,13/1,13/2 at village- Bolinj, Tal- Vasai, Dist-Palghar..

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2209/ 2014 Dated: 21/08/2014.
2) An application received by M/s. Ajay Wade & Associates, Dated: 12/07/2014.
3) Revised D.P Issued by CIDCO/VVSR/RDP/BP-1087/W/6048.Dated:23/02/2010.
4) Certificate from License Agency M/s. Ronak fire Industries, Dated: 07/08/2014.(Form A)
5) Building Completion certificate of M/s.Ajay Wade & Associates, Dated: 12/07/2014.
6) Built up area certificate M/s. Ajay Wade & Associates, Dated: 12/07/2014.
7) Structure Stability certificate of M/s. Suresh Kumar M Panikar Consulting Stuctural Engineers, Dated: 14/03/2014
8) lift License to work the Lift From Govt. of Maharashtra Industries, Licence No. 141023 Dated-17/04/2014.
9) Provisional No objection Certificate No. CIDCO/FIRE/467/2010, Dated:-10/04/2010.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 (Wing A& B) sector VII** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Ronak fire Industries bearing License No. MFS-LA/RF-157 ,issued by MFS office and has submitted Certificate on Date:07/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **2515.48** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 239/2014-15 DATE: 16/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of INDUSTRIAL BUILDING No-1 Located on land Bearing S.No.36 H.No-09. at village Waliv, Tal. Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2212 / 2014 Dated: 21 / 08 / 2014.
2) An application received by M/s.EN CON,Project consultants. Dated:30/06/2014.
3) C.C. Issued By CIDCO/VVSR/CC//BP- 4427/E/4435,Dated:-15/06/2009.
4) Certificate from License Agency M/s. **M/s, Fire Worx Engineering, Dated: 23/08/2014 (Form A).**
5) Building Completion certificate BP-4427/60 M/s.EN CON,Project consultants. Dated:30/06/2014.
6) Built up area certificate BP-4427/59 M/s.EN CON,Project consultants. Dated:30/06/2014.
7) Structure Stability certificate BP-4427/56 of Sanjay Narag & Associates , Dated:18/01/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL BUILDING No-1** Building at above mentioned address. As per C.C. Issued By CIDCO/VVSR/CC//BP- 4427/E/4435,Dated:-15/06/2009.The party has constructed **"INDUSTRIAL BUILDING No-1 Building Gr+3 /pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 02/07/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On 23/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump- 20 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **BUILDING No-1 1319.19 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-23830 /- vide Challan No.-21597 Dated - 12/09/2009 Issued by – SBI Bank,& Rs-61,200 /- vide Receipt No.-226688.& Rs-85,000 /- vide Receipt No.-226630. Dated -04/07/2014 .DD.bearing No. - 818000 & 817999 Issued by – SBI Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **BUILDING No-1 1588.40 Sq.Mtrs**. as per the letter given by the party Dated-04/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

16/9/2019

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

CIPAL CORPORATION
RE
ADE
LGHAR.

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 240/2014-15 DATE: 16/09/2014

TO,
M/s. Vidyavardhini's Collage of Engineering & Techology,
K.T Marge, Vasai Road (W), Tel: Vasai,
Dist: Palghar.

Sub:- Renewal of "Final No Objection Certificate" for "Vidyavardhini's Collage of Engineering & Techology,K.T Marge,Vasai Road (W), Tel: Vasai,Dist: Palghar.

Ref :- 1. An application received by M/s. Vidyavardhini's Collage of Engineering & Techology.Dated: 26/08/2014.
2. Certificate from License Agency M/s, Ronak Fire Industries ,Dated: 23/08/2014 (Form B).
3.This office final No objection Certificate No. VVCMC/FIRE/258/ 2012-13, Dated: 02/03/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for **M/s. Vidyavardhini's Collage of Engineering & Techology,** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Ronak Fire Industries bearing License No. No. MFS-LA/RF- 0157, dated 18/07/2013issued by this office and has submitted Certificate on dated- 23/08/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the **Rs. 1,25,000/- vide Receipt No.-226899, Dated 21/08/2014 Issued by Cash** renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

16/9/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 241/2014-15 DATE: 16/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Primary School Building (St+2) on Plot bearing S.No. 52, ,H.No. 2 (pt) at village Barampur ,Tal- Vasai, Dist- Palghar.

Ref :- 1. A Letter of Dy. Director, Townplanning Dept. No. VVCM / NR / 2517 / 2014, Dated:- 16/09/2014.
2. An application received by M/s. J.M. Faroz Architect , Dated:24/07/2014.
3. Revised c.c. Issued By VVCMC No. VVCMC / TP / RDP /VP-0508/103/ 2011-12, Dated: 10/10/2011.
4. Certificate from License Agency M/s, Fire worx Engineering , Dated: 25/06/2013.(Form A) .
5. Building Completion certificate of M/s. J.M. Faroz Architect, Dated:-24/07/2014.
6. Built up area certificate M/s. J.M. Faroz Architect, Dated:-24/07/2014.
7. Structure Stability certificate of M/s. A-Cube Consultant, Dated:-28/05/2013.
8. This office Provisional No objection Certificate No. VVCMC / FIRE / 208/ 2011-12, Dated:30/03/2012.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Primary School Building (St+2) on Plot bearing S.No. 52, ,H.No.2 (pt)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, Dated 16/08/2013. issued by this office and has submitted Certificate on dated 25/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **570.42Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

16/9/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 246/2014-15 DATE: 20/09/2014

TO,

M/s. Rishubh Realty.,
221/223,Shripal Shoping Centre,
Near Petrol Pump,Agashi Raod,Virar (W)
Tel: Vasai ,Dist: Palghar.

Sub:- Renewal of "Final No Objection Certificate" for " Residential cum commercial Building No. 1 Wing A,B&C in Sector III & Residential cum commercial Building No. 1 Wing C in Sector V" On Land Bearing S.No.387B,22/4,13/1,13/2 Village: Virar,Tal- Vasai, Dist- Palghar.

Ref :- 1. An application received by M/s. M/s. Rishubh Realty Dated: 15/09/2014.
2.Certificate from License Agency M/s, Viva Enterprises ,Dated: 14/09/2014 (Form B).
3.This office final No objection Certificate No. VVCMC/FIRE/82/ 2013-14, Dated: 14/05/2013.

Dear sir,

With reference to Sr.No.1 above, these office is in receipt of your application for your **Industrial Building No. 3** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e.M/s. Viva Enterprises bearing License No. No. MFS-LA/RF- 0139, issued by MFS office and has submitted Certificate on dated- 14/09/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the **Rs.66000/- vide Receipt No.-226827,& Rs.22000/- vide Receipt No.-226826 Dated 07/07/2014 DD No 039863 & 039864 of Axis bank** renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2521101/02/03/04/05/06

VVCMC/FIRE/ 247/2014-15 DATE: 20/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1 (Wing A&B) Ph-I,sector IIA, on land bearing S.No. 193,194&196 Of village- Nillemore, Tal- Vasai, Dist-Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2544/ 2014 Dated: 19/09/2014.
2) An application received by Ref No-SMA/531/164D/14 M/s – Sanat Mehta & Associates . Dated -26/06/2014.
3) Revised D.P Issued by VVCMC/TP/RDP/VP-111/100/2012-13.Dated:11/07/2012.
4) Certificate from License Agency M/s. Ronak fire Industries, Dated: 23/06/2014.(Form A)
5) Building Completion certificate of M/s. Sanat Mehta & Associates, Dated: 19/05/2014.
6) Built up area certificate SMA/531/164D/14 M/s – Sanat Mehta & Associates . Dated -26/06/2014.
7) Structure Stability certificate of M/s. Shilplekha Consultant Stuctural Engineers, Dated: 22/04/2014.
8) lift License to work the Lift From Govt. of Maharashtra Industries, Licence No. 140648 & 140651 Dated-28/03/2014.
9) Provisional No objection Certificate No. CIDCO/FIRE/255/2010, Dated:-24/02/2010.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 (Wing A&B) Ph-I,sector IIA,** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Ronak fire Industries bearing License No. MFS-LA/RF-157 ,issued by MFS office and has submitted Certificate on Date:23/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **2910.43** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 250/2014-15 DATE: 26/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Residential Cum Commercial Building No.1 (Wings C) Located On Land Bearing S.No. 79, H.No.1; S.No.81, H.No.1, Of Village: Chulne, Tal- Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 1700/ 2014 Dated: 07/07/2014
2) An application received by M/s. EN CON Consultants, Dated:04/07/2014.
3) Revised C.C. Issued By VVCMC/TP/CC/VP-0099/1989, Dated:03/01/2012.
4) Certificate from License Agency M/S. Sadanand Fire Systems, Dated:28/06/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants, Dated:-28/06/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, dated-28/06/2014.
7) Lift completion undertaking by M/S.JRX Developers Dated-09/09/2014.
8) This Office Provisional No Objection Certificate VVCMC/FIRE/163/2012-13, Dated-09/11/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 (Wings -C)** Building at above mentioned address. As per C.C. issued by **VVCMC/TP/CC/VP-0099/1989, Dated:03/01/2012.** The party has constructed **" Residential Cum Commercial Building No.1 (Wings- C) Pt/Stilt/ Gr+ 7 pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 24/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire System bearing License No. MFS-LA/F- 0252, issued by this office and has submitted Certificate on 28/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **5241.53 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or Nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2321101/02/03/04/05/06

VVCMC/FIRE/ 251/2014-15 DATE: 26/09/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Residential Cum Commercial Building No.1 (Wings A & B) Located On Land Bearing S.No. 79, H.No.1; S.No.81, H.No.1, Of Village: Chulne, Tal- Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 1699 / 2014 Dated: 07/07/2014
2) An application received by M/s. EN CON Consultants, Dated:04/07/2014.
3) C.C. Issued By VVCMC/TP/CC/VP-0099/1989, Dated:03/01/2012.
4) Certificate from License Agency M/S. Sadanand Fire Systems, REF No.SFS/A/019 Dated:28/06/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants, Dated:-28/06/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, dated-28/06/2014.
7) Lift completion undertaking by M/S. Maryland developers Dated-05/09/2014.
8) This Office Provisional No Objection Certificate VVCMC/FIRE/163/2012-13, Dated-09/11/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 (Wings A & B) Building** at above mentioned address. As per C.C. issued by **VVCMC/TP/CC/VP-0099/1989, Dated: 03/01/2012.** The party has constructed **"Residential Cum Commercial Building No.1 (Wings A & B), Pt/Stilt/ Gr+ 7 pt Floors"** as per sanctioned Plan.

With reference to above on Dated: - 24/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire System bearing License No. MFS-LA/F- 0252, issued by MFS office and has submitted Certificate on 28/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **Wing A is 1566.00 Sq.Mtrs & Wing B is 1507.97 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or Nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2581101/02/03/04/05/06

VVCMC/FIRE/ 252/2014-15 DATE: 26/09/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Industrial Building (Plot 1) Located On Land Bearing S.No. 44, H.No. 2/A+2B+2C/1(P); S.No. 44, H.No. 2/A+2B+2C/2(P); S.No. 44, H.No.8/1(P) Of Village: Waliv, Tal- Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 2522/ 2014 Dated: 17/09/2014
2) An application received by M/s. EN CON Consultants, Dated:17/09/2014.
3) Revised R.D.P. Issued By VVCMC/TP/RDP/VP-0376/059/2012-13, Dated:05/06/2012.
4) Certificate from License Agency M/S. Sadanand Fire Systems, Dated:09/08/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants, Dated:-09/08/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, date-09/08/2014.
7) License to work the Lift From Govt. of Maharashtra Industries, License No. 143992,143990,143991, Dated:- 15/07/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building (Plot 1)** Building at above mentioned address. As per R.D.P. issued by CIDCO VVCMC/TP/RDP/VP-0376/059/2012-13, Dated:05/06/2012. The party has constructed **"Industrial Building (Plot 1) , Gr+ 2/pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 24/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Sadanand Fire System bearing License No. MFS-LA/F- 0252, issued by this office and has submitted Certificate on 09/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser System
   a) on every floor hose reel hose & landing valve / Hydrant valve.
   b) Booster pump on terrace
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Jockey Pump, Main Pump
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **2295.66 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or Nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by & the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 1,50,000/- vide Receipt No. 265608, & Rs. 1,50,000/- vide Receipt No. 265607, Dated 03/09/2014, DD No.001761 , &, DD No.001760, Saraswat Bank for the total gross built up area **2295.66** Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

26/9/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2321101/02/03/04/05/06

VVCMC/FIRE/ 262/2014-15 DATE: 29/09/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Shop for Automobiles/ Godowns Building No.3 on On Land Bearing S.No. 280, H.No. 1/B Of Village: Pelhar, Tal- Vasai, Dist-Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 2582/ 2014 Dated: 24/09/2014
2) An application received by M/s. EN CON Consultants, Dated:23/09/2014.
3) Revised c.c. Issued By CIDCO/VVSR/CC/BP-4178/E/503., Dated:03/06/2010.
4) Certificate from License Agency M/S. Fire Worx Engineering, Dated:23/08/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants Dated:-18/09/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, date-18/09/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Shop for Automobiles/ Godowns Building No.3** Building at above mentioned address. As per c.c issued by CIDCO/VVSR/CC/BP-4178/E/503,, Dated:03/06/2010. The party has constructed **"Shop for Automobiles/ Godowns Building No.3, Gr+ 1/pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 17/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, dated 16/08/2013, issued by this office and has submitted Certificate on 23/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) 1500 Lpm, 70 Mtr head Main Pump
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **370.16 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or Nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40,000/- vide Receipt No. 226832, & Rs. 40,000/- vide Receipt No. 226833, Dated 14/07/2014, DD No.018105 , &, DD No.018105,Basin Catholic Bank for the total gross built up area **370.16** Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

Rec 01/10/14

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 263/2014-15 DATE: 29/09/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Industrial Building No.5, Located On Land Bearing S.No.62, H.No. 4/2, 4/3, 4/4, 4/5, Of Village: Waliv & S. No.18, H.No. 2/1, Of Village: Sativali, Tal- Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 2584/ 2014 Dated: 24/09/2014
2) An application received by M/s. EN CON Consultants, Dated:23/08/2014.
3) Revised R.D.P Issued By VVCMC/TP/RDP/VP-0507/014/2014-15, Dated:22/04/2014.
4) Certificate from License Agency M/S. Fire Worx Engineering, Dated:-23/08/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. EN CON Consultants, Dated:-23/09/2014.
6) Structure Stability certificate M/S. Sanjay Narang & Associates, date-23/09/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building No.5,** Building at above mentioned address. As per R.D.P Issued By **VVCMC/TP/RDP/VP-0507/014/2014-15, Dated:22/04/2014.** The party has constructed **" Industrial Building No.5, Gr+1(pt) Floors"** as per sanctioned Plan.

With reference to above on Dated: 17/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s. Fire Worx Engineering bearing License No. MFS-LA/F-0227, dated 16/08/2013, issued by MFS office and has submitted Certificate on 23/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) 1500 Lpm, 70 Mtr head Main Submersible Pump
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **213.80 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or Nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by & the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 40000/- vide Receipt No. -265637 & Rs. 40000/- vide Receipt No. -265638 Dated-29/09/2014 Bank for the total gross built up area **213.80 Sq.Mtrs** as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 264/2014-15 DATE: 29/09/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of INDUSTRIAL BUILDING No-1 (wing B)located on land bearing S.No.36 H.No-13. at village Waliv, Tal. Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2541 / 2014 Dated:-19/09/2014.
2) An application received by Ref.No. VP-4947/43 M/s.EN CON,Project consultants. Dated:16/09/2014.
3) Revised DP Issued By VVCMC/TP/RDP/VP- 4947/0145/2012-13,Dated:-13/12/2012.
4) Certificate from License Agency M/s. M/s, Fire Worx Engineering, Dated: - 23/08/2014. (Form A).
5) Building Completion Ref.No. VP-4947/45 M/s.EN CON,Project consultants. Dated:16/09/2014.
6) Built up area certificate Ref.No. VP-4947/44 M/s.EN CON,Project consultants. Dated:16/09/2014.
7) Structure Stability certificate Ref.No. VP-4947/46 of Sanjay Narag & Associates ,Dated:16/09/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **INDUSTRIAL BUILDING No-1 (wing B)** Building at above mentioned address. As per **Revised DP Issued By VVCMC/TP/RDP/VP- 4947/0145/2012-13,Dated:-13/12/2012.**. The party has constructed **"INDUSTRIAL BUILDING No-1 (wing B) Building G+2pt Floors"** as per sanctioned Plan.

With reference to above on Dated: 17/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **License Agency i.e.M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate On -23/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Cum Down Comer System
- a) on every floor hose reel hose & landing valve / Hydrant valve
- b) Booster pump on terrace- 5 HP
- c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
- d) Main Pump- 20 HP

B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **BUILDING No-1 (wing B)- 752.04. Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs-40,000 /- vide Receipt No.-226629.& Rs-40,000 /- vide Receipt No.-226630. Dated -02/07/2014 .DD.bearing No. - 048067& 048068. Issued by – Axis Bank in favour of VVCMC additional Capitation & Scrutiny fees for the total Built up area **BUILDING No-1 (wing B)- 752.04. Sq.Mtrs**.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 271/2014-15 DATE: 01/10/2014

TO,

M/s. Relible Homemakers & Infrastructure Pvt.Ltd.
Shop No.101,Zanabiya Manzil,Opp.
Sai Dham Towar,Achole Road, Nallasopara.
Tal-Vasai.Dist Thane.

Sub:- Renewal of "Final No Objection Certificate" of Residential Building No.1 Wing A to G & Building No.2 Wing H to M On land bearing S.No. 371, H.No. 1(pt) & 3 at village : Juchandra ,Tal- Vasai (E), Dist- Palghar.

Ref :- 1. An application received by M/s. Relible Homemakers & Infrastructure Pvt.Ltd..
2.Certificate from License Agency M/s, Fire Worx Engineering Dated : 30/06/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/51 / 2013-14, Dated: 08/05/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Residential Building No.1 Wing A to G & Building No.2 Wing H to M On land bearing S.No. 371, H.No. 1(pt) & 3** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by MFS office and has submitted Certificate on 30/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,56,000/- vide Receipt No: 265656 , Dated:01/10/2014 Issued by Cash renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGADE

1/10/2014

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 272/2014-15 DATE: 01/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No.1 on Land bearing S.No. 104A at village: Dhowali, Tal:Vasai, Dist:Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2545/ 2014, Dated:- 19/09/2014.
2. An application received by M/s. J.M.Faroz Architect, Dated: 22/08/2014.
3. C.C. Issued By VVCMC No. VVCMC / TP/RDP / VP-0091/2628 Dated: 20/03/2012
4. Certificate from License Agency M/s, Neo Enterprises, Dated:-7/09/2014. (Form A).
5. Building Completion certificate of M/s. J.M.Faroz Architect, Dated: 22/08/2014.
6. Built up area certificate M/s. J.M.Faroz Architect, Dated: 22/08/2014
7. Structure Stability certificate of J.M.Faroz Associates Dated: 27/08/2014.
8. This office Provisional No objection Certificate No. VVCMC / FIRE / 260/ 2012-13, Dated:-05/03/2013.

Dear sir,

With reference to Sr.No.2 above, thise office is in receipt of your application for your **Industrial Building No.1 G+1pt Floor** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s, Neo Enterprises bearing License No. MFS-LA/RF- 220, dated - 01/05/2014 issued by MFS office and has submitted Certificate on Dated:-07/09/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **747.27 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 273/2014-15 DATE: 01/10/2014

TO,
M/s. Giriraj Realtors

Sub:- Renewal of "Final No Objection Certificate" of Industrial Building On land bearing S.No. 46, H.No. 3 & 4 at village : Gokhiware,Tal- Vasai (E), Dist- Palghar.

Ref :- 1. An application received by M/s. Giriraj Realtors, Dated: 30/07/2014.
2.Certificate from License Agency M/s, Fire Worx Engineering Dated : 30/06/2014 (Form B).
3. This office final No objection Certificate No. VVCMC/FIRE/246 / 2012-13, Dated: 25/02/2013.

Dear sir,

With reference to Sr.No.1 above, thise office is in receipt of your application for your **Industrial Building On land bearing S.No. 46, H.No. 3 & 4** at above mentioned address. Since the fire fighting arrangements Carried Out inspection by **License Agency i.e. M/s, Fire Worx Engineering bearing License No. MFS-LA/F- 0227, dated 16/08/2013, issued by this office and has submitted Certificate on 30/06/2014 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009**, this office is issuing a **" Renewal No Objection Certificate"** for your building .

This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by you in the premises as per final No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.10,000/- vide Receipt No: 187179 , Dated:25/06/2014 Issued by Cash renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the building. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 274/2014-15 DATE: 01/10/2014

TO,
M/S Jubilant FoodWorks Ltd.
National Highway NO-8,
Tungareshwar Phata,Satiwali,
Tal-Vasai,Dist-Palghar.

Sub:- "Final No Objection Certificate" for Mix Occupancy Building On land bearing S.No. 76, at village: Sativali,Tal- Vasai, Dist- Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2650/ 2014, Dated:- 26/09/2014.
2. An application received by M/s. Jubilant Food Works, Dated: 23/09/2014.
3. Certificate from License Agency M/s, Neo Enterprises, Dated: 27/09/2014 (Form A).
4. Agreement copy
5. This Office Provisional No Objection Certificate vvcmc /fire/98/2012-13 Dated- 10/01/2013.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Mix Occupancy Building (G+2 Floor)** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Neo Enterprises, bearing License No. MFS-LA/RF-0220, dated 01/05/2014 issued by this office and has submitted Certificate On 27/09/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3547.45 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nomited officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 276/2014-15 DATE: 01/10/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.1 (Wing D&E) Ph-I,sector IIA, on land bearing group housing Scheme Of village- Nillemore, Tal- Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2580/ 2014 Dated: 24/09/2014.
2) An application received by Ref No-SMA/531/164D/14 M/s – Sumati builders & developers . Dated -05/09/2014.
3) Revised D.P Issued by VVCMC/TP/RDP/VP-111/100/2012-13.Dated:11/07/2012.
4) Certificate from License Agency M/s. Ronak fire Industries, Ref/C/0183/2014-15 Dated: - 07/08/2014.(Form A)
5) Building Completion certificate of M/s. Sanat Mehta & Associates, Dated: 26/08/2014.
6) Built up area certificate SMA/531/164D/14 M/s – Sanat Mehta & Associates . Dated -26/08/2014.
7) Structure Stability certificate of M/s. A-CUBE CONSULTANT Stuctural Engineers, Dated: 12/02/2014.
8) lift License to work the Lift From Govt. of Maharashtra Industries, Licence No. 140648 & 140651 Dated-28/03/2014.
9) Provisional No objection Certificate No. VVCMC/FIRE/166/2012-13, Dated:-16/11/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 (Wing D&E) Ph-I,sector IIA,** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Ronak fire Industries bearing License No. MFS-LA/RF-157 ,issued by MFS office and has submitted Certificate on Dated:-07/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **2796.41** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 279/2014-15 DATE: 01/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of School Building on land bearing S.No.76 to 79,81 to 86,110 to 120,122/3pt &109 Of village- Nillemore, Tal- Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 1174/ 2014 Dated: 10/06/2014.
2) An application received by Shree Consultants Architects Dated -09/06/2014.
3) Revised D.P Issued by VVCMC/TP/RDP/VP-0263/0149/2012-13.Dated:14/12/2012.
4) Certificate from License Agency M/s. Ronak fire Industries, Ref/C/202/2014-15 Dated: - 30/09/2014.(Form A)
5) Built up area certificate Shree Consultants Architects . Dated -09/06/2014.
7) Structure Stability certificate of M/s. Suresh Kumar M.Panicker , Dated: 26/09/2014.
8) lift completion undertaking by Liberty Education So./Winsant Dated -01/10/2014.
9) Provisional No objection Certificate No. CIDCO/FIRE/957/2010, Dated:-23/06/2010.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **School Building,** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s. Ronak fire Industries bearing License No. MFS-LA/RF-157 ,issued by MFS office and has submitted Certificate on Dated:-09/06/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Built up area admeasuring to **7555.10** Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If **any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect
Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org .

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-2521101/02/03/04/05/06

VVCMC/FIRE/ 278/2014-15 DATE: 01/10/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Industrial Building Located On Land Bearing Plot No.16,S.no.104 H.No. 1(P) Of Village: Dhowali, Tal- Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM /NR/ 2634 / 2014 Dated: 26/09/2014
2) An application received by M/s. Fine airsys , Dated:25/09/2014.
3) C.C. Issued By VVCMC/TP/C.C/3391/2012-13, Dated:15/03/2013.
4) Certificate from License Agency M/s. Ronak fire Industries, Ref/C/205/2014-15 Dated: - 30/09/2014 (Form A)
5) Building Completion certificate & Built up area certificate of M/s.Shashank Vartak & Associates , Dated:-24/09/2014.
6) Structure Stability certificate M/S. H.J.Mathos & Associates, date-22/07/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building** Building at above mentioned address. As per **C.C. Issued By VVCMC/TP/C.C/3391/2012-13, Dated:15/03/2013** The party has constructed **"Industrial Building , Gr+ 3/pt Floors"** as per sanctioned Plan.

With reference to above on Dated: -24/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **M/s. Ronak fire Industries, bearing License No. MFS-LA/RF- 0157, issued by MFS office and has submitted Certificate on 30/09/2014. in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) vertical riser cum Down Comer System
   a) on every floor hose reel hose & landing valve / Hydrant valve
   b) Booster pump on terrace- 5 HP
   c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
   d) Main Pump-10 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **373.02 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or Nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 80,000/- vide Receipt No. 265647, , Dated 01/10/2014 , DD No.011508 , Bank of India Bank for the total gross built up area **373.02** Sq.Mtrs as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect:-

Please Note:- **The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org**

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 279/2014-15 DATE: 01/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING No.1, PH-2, Sector -III, wing C, D & E Known as 'Shree Sai Enclave' on land bearing Sr.No. 201 at Village-Nilemore, Tal-Vasai, Dist-Palghar.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/2636/2014 Dated: 26/09/2014.
2) An Application received by M/s. Shree Sai Bhumi Realtors.Dated:-24/09/2014.
3) Revised c.c. Issued by VVVMC/TP/RDP/VP-0111/0209/2013-14 Dated:-24/07/2013
4) Certificate from License Agency M/s Shree Sainath Enterprises, Dated:-01/08/2014 (Form A)
5) Building Completion certificate of M/s Sanat Mehta & Associates, Dated:-17/09/2014
6) Build up area certificate No. SMA/615/164D/14 of of M/s Sanat Mehta & Associates , Dated:-17/09/2014
7) Structure Stability certificate of Shilplekha Consultant.Dated:-21/04/2014.
8) Affidavit for Completion of Lift work by Mr.Animesh P.Purohit Dated:- 24/09/2014
9) This office Provisional NOC VVCMC/FIRE/147/2014-15 Dated-02/08/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.1, PH-2, Sector –III, wing C, D & E** at above mentioned address. Since the fire fighting arrangements provided is installed by **M/s. Shree Sainath Enterprises bearing License No. –MFS-LA/RF-0076 ,Dated- 08/08/2013 issued by this office and has submitted Certificate of dated- 01/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **8111.57 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Received

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 282/2014-15 DATE: 01/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No. 5 on Land bearing S.No.59, H.No.1, 2/1, 2/2, 2/3,3,4,5,6,7,9,10,11,12/1,12/2,13, 14,&15,S.No.62 H.No.4 at Village Chulne Tal. Vasai, Dist- Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM/NR/2649/2014 Dated:-26/09/1014.
2) An application received by M/s. En con Project consultants, Dated:18/07/2014.
3) Revised D.P. Issued By VVCMC/TP/RDP/VP-0277/058/2013-14, Dated:16/05/2013.
4) Certificate from License Agency M/s. Sadanand fire Controls. Dated:27/09/2014. (Form A)
5) Building Completion certificate & Built up area certificate of M/s. En con Project consultants, Dated:-18/07/2014.
6) Structure Stability certificate M/s. Sanjay Narang & Associates,Dated:-18/07/2014
7) Lift work completion undertaking By C.P.M. Associates ,Dated 20/09/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt application for your **Residential Cum Commercial Building No.05**Building at above mentioned address. As per Revised D.P. Issued By VVCMC/TP/RDP/VP-0277/058/2013-14, Dated:16/05/2013 .The party has constructed **"Residential Cum Commercial Building No. 05 . Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 24/09/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. M/s. M/s. Sadanand fire Controls **bearing License No. MFS-LA/RF-216, DT-01/05/2014 issued by MFS office and has submitted Certificate on dated 27/09/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on Terrace Level.-05 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Main Pump- 10 HP.
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants.

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to1887.38 Sq.Mtrs. This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,60,000/- vide Receipt No. 226801 Dated -05/07/2014.& Rs.-40000/- vide Receipt No. -226802 Dated -05/07/2014 for the total gross built up area -1887.38 Sq.Mtr. as per the letter given by the party .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 283/2014-15 DATE: 04/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING No.3 wing A&B , on land bearing Sr.No. 278 (pt), S.No.280, S.No.282,H.No.1,S.No.283 of Village-Nilemore, Tal-Vasai, Dist-Palghar.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/2637/2014 Dated: 26/09/2014.
2) An Application received by M/s. Alok construction Builders & Developers. Dated:-24/09/2014.
3) Revised D.P. Issued by VVVMC/TP/RDP/VP-0041/074/2014-15 Dated:-30/06/2014.
4) Certificate from License Agency M/s Viva Enterprise , Dated:-04/10/2014. (Form A)
5) Building Completion certificate of Abhay Raut Architect, Dated:-30/09/2014
6) Build up area certificate of Abhay Raut Architect , Dated:-30/09/2014
7) Structure Stability certificate of Haresh L.Patel.Dated:-02/10/2014.
8) Affidavit for Completion of Lift work by M/s. Alok construction Dated:- 29/09/2014
9) This office Provisional NOC VVCMC/FIRE/120/2012-13 Dated-12/10/2012.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.3 wing A&B** at above mentioned address. Since the fire fighting arrangements provided is installed by **M/s. Viva Enterprises bearing License No. – MFS-LA/F-0139 , issued by MFS office and has submitted Certificate of dated- 04/10/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **4310.77 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Pankesh Jha

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 284/2014-15 DATE: 04/10/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Thane.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING at Behind Sector – 6, wing A & B Known as 'White Hills' on land bearing S.No.128 Opp.- Vidya Vikas School, Evershine City, Vasai (E). Tal-Vasai, Dist-Thane.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/2600/2014 Dated: 24/09/2014.
2) An Application received by M/s. Crystal Construction. Dated:-24/09/2014.
3) Revised c.c. Issued by VVVMC/TP/RDP/VP-0208/1319/2013-14 Dated:-07/08/2013
4) Certificate from License Agency M/s Shree Sainath Enterprises, Dated:-01/08/2013 (Form A)
5) Building Completion certificate of M/s J. M. Faroz, Dated:-09/08/2014
6) Build up area certificate No. VVVMC/ TP/RDP/VP-0208 of of M/s J. M. Faroz, Dated:-07/10/2014
7) Structure Stability certificate of A-Cube Consultant.Dated:-07/10/2014.
8) Affidavit for Completion of Lift work by Mr. Salim Sayed. Dated:- 07/10/2014

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your RESIDENTIAL CUM COMMERCIAL BUILDING at Behind of Sector –6, wing A,& B Building at above mentioned address. As per c.c issued by VVVMC/TP/RDP/VP-0208/1319/2013-14 Dated:-07/08/2013 The party has constructed "RESIDENTIAL CUM COMMERCIAL BUILDING G +7 Floors" as per sanctioned Plan.

With reference to above on Dated: 01/10/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Shree Sainath Enterprises bearing License No. –MFS-LA/RF-0076 ,Dated- 11/09/2012 issued by this office and has submitted Certificate of dated -01/08/2013 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

- Vertical riser cum down comer
1.Landing valve each floor
2.Courtyard Hydrant
3.Fire services inlet
4.Booster pump- 5HP
5.Main Electrical pump - 15HP
6.Fire extinguisher ABC – 6kg
7.Fire extinguisher Co2 – 3kg

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring **to 2949.49 Sq.Mtrs** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice &

the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.4,00,000 /- vide Receipt No. 265663, Dated 07/10/2014, DD.bearing No. 025308 Issued by Basin Catholic Bank fees for the total built up area admeasuring **to 2949.49 Sq.Mtrs.**

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan . of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 285/2014-15 DATE: 04/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING No.4, PH-2, Sector -III, wing A & B Known as 'ORANGE HIGHT' on land bearing Sr.No. 201/206 at Village-Nilemore, Tal-Vasai, Dist-Palghar.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/2598/2014 Dated: 24/09/2014.
2) An Application received by M/s.Sai Crystal Builders & Developers. Dated:-24/09/2014.
3) Revised c.c. Issued by VVVMC/TP/RDP/VP-0111/0212/2013-14 Dated:-24/07/2013
4) Certificate from License Agency M/s Shree Sainath Enterprises, Dated:-01/08/2014 (Form A)
5) Building Completion certificate of M/s Sanat Mehta & Associates, Dated:-07/10/2014
6) Build up area certificate No. SMA/633/164D/14 of of M/s Sanat Mehta & Associates, Dated:-07/10/2014
7) Structure Stability certificate of A-Cube Consultant.Dated:-07/10/2014.
8) Affidavit for Completion of Lift work by Mr. Salim Sayed & Mr.Dayaram Pal. Dated:- 07/10/2014
9) This office Provisional NOC VVCMC/FIRE/150/2014-15 Dated-02/08/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **RESIDENTIAL CUM COMMERCIAL BUILDING No.4, PH-2, Sector –III, wing A & B** at above mentioned address. Since the fire fighting arrangements provided is installed by **M/s. Shree Sainath Enterprises bearing License No. –MFS-LA/RF-0076 ,Dated- 08/08/2013 issued by this office and has submitted Certificate of dated- 01/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **6204.35 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 286/2014-15 DATE: 04/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING No.2, PH-2, Sector -III, wing E Known as 'ORANGE HIGHT' on land bearing Sr.No. 201/206 at Village- Nilemore, Tal-Vasai, Dist-Palghar.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/2597/2014 Dated: 24/09/2014.
2) An Application received by M/s.Mira Dharti Realty. Dated:-24/09/2014.
3) Revised D.P Issued by VVVMC/TP/RDP/VP-0111/0211/2013-14 Dated:-24/07/2013
4) Certificate from License Agency M/s Shree Sainath Enterprises, Dated:-01/08/2014 (Form A)
5) Building Completion certificate of M/s Sanat Mehta & Associates, Dated:-07/10/2014
6) Build up area certificate No. SMA/636/164D/14 of of M/s Sanat Mehta & Associates , Dated:-07/10/2014
7) Structure Stability certificate of A-Cube Consultant.Dated:-07/10/2014.
8) Affidavit for Completion of Lift work by Mr. Sanjay Yadav. Dated:- 07/10/2014
9) This office Provisional NOC VVCMC/FIRE/149/2014-15 Dated-02/08/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your RESIDENTIAL CUM COMMERCIAL BUILDING No.2, PH-2, Sector –III, wing E at above mentioned address. Since the fire fighting arrangements provided is installed by **M/s. Shree Sainath Enterprises bearing License No. –MFS-LA/RF-0076 ,Dated- 08/08/2013 issued by this office and has submitted Certificate of dated- 01/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **3120.56 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 287/2014-15 DATE: 04/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub-"Final No Objection Certificate"of RESIDENTIAL CUM COMMERCIAL BUILDING No.2, PH-2, Sector -III, wing A, B, C, D & F Known as 'ORANGE HIGHT' on land bearing Sr.No. 201/206 at Village-Nilemore, Tal-Vasai, Dist-Palghar.

Ref:- 1) A Letter Of Dy.Director, Town Planning Dept.No.VVCM/NR/2599/2014 Dated: 24/09/2014.
2) An Application received by M/s. Sai Crystal Developers.Dated:-24/09/2014.
3) Revised c.c. Issued by VVVMC/TP/RDP/VP-0111/0203/2013-14 Dated:-24/07/2013
4) Certificate from License Agency M/s Shree Sainath Enterprises, Dated:-01/08/2014 (Form A)
5) Building Completion certificate of M/s Sanat Mehta & Associates, Dated:-07/10/2014
6) Build up area certificate No. SMA/632/164D/14 of of M/s Sanat Mehta & Associates , Dated:-07/10/2014
7) Structure Stability certificate of A-Cube Consultant.Dated:-07/10/2014.
8) Affidavit for Completion of Lift work by Mr. Salim Sayed Dated:- 07/10/2014
9) This office Provisional NOC VVCMC/FIRE/148/2014-15 Dated-02/08/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your RESIDENTIAL CUM COMMERCIAL BUILDING No.2, PH-2, Sector –III, wing A, B, C, D & F at above mentioned address. Since the fire fighting arrangements provided is installed by **M/s. Shree Sainath Enterprises bearing License No. –MFS-LA/RF-0076 ,Dated- 08/08/2013 issued by this office and has submitted Certificate of dated- 01/08/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** this office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **13296.56 Sq.Mtrs**. This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 293/2014-15 DATE: 04/10/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Residential cum commercial Building No.1 Wing A To O on Land bearing S.No.346 ,H.No-1 to 8,10to22,24 to 29,S.No.355,H.No-6&7,at village -Bolinj ,Tal- Vasai, Dist-Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2628 / 2014, Dated:-26/09/2014.
2. An application received by M/s. En Con project consultant, Dated: 24/06/2014.
3. Revised D.P. Issued By No. VVCMC / TP / RDP / VP-0663/0146/2014-15 Dated-25/09/2014.
4. Certificate from License Agency M/s, Sadanand fire controls, Dated: 27/09/2014 (Form A).
5. Building Completion certificate of M/s. En Con project consultant Ref.No. VP-663/110, Dated: 26/09/2014.
6. Construction area certificate of M/s. En Con project consultant Ref.No. VP-663/111, Dated: 26/09/2014.
7. Structure Stability certificate of M/S.Nimisha Structural Design Academy Consulting Structural Engineers, Dated:- 30/09/2014.
8. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, No. -139426,139427,139428& 139431 Dated-07/02/2014.,139428& 139431 Dated-07/02/2014. & other Lift completion undertaking given by Prieska Real Estates Pvt.Ltd.dated-25/09/2014.
9. This Office Provisional No Objection Certificate vvcmc/fire/282 /2012-13 Dated-25/03/2013.

Dear sir,

With reference to Sr.No.2 above, these office is in receipt of your application for your **Residential cum commercial Building No.1 Wing A To O** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e.M/s. Sadanand Fire Controls bearing License No. MFS-LA/F- 0216, dated 01/05/2014, issued by this office and has submitted Certificate On 27/09/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,** this office is issuing a **"Final No Objection Certificate"** for your following building having Construction area admeasuring to **21577.55 Sq.mtrs** . This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **" Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE BRIGADE DIST. PALGHAR.

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/300/2014-15 DATE: 07/10/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building Type SD-7 &SD-8 Known As "NIRAVANA" in P4 Pocket Situated At village- Achole, Tal- Vasai, Dist-Palghar.

Ref:-1) A Letter of Dy. Director, Town Planning Dept.No. VVCM / NR / 2716/ 2014 Dated: 04/10/ 2014.
2) An application received by M/s.Shah Gattani Consultants , Dated: 04/10/2014.
3) C.C Issued by CIDCO/VVSR/BP/ZCC-20/I/4382 Dated- 10/05/1995.
4) Certificate from License Agency M/s. Fire Worx Engineering, Dated:- 04/10/2014. (Form A)
5) Building Completion certificate of M/s.Shah Gattani Consultants , Dated: 04/10/2014
6) Built up area certificate M/s.Shah Gattani Consultants, Dated: 04/10/2014
7) Structure Stability certificate M/s.Shah Gattani Consultants, Dated:-04/10/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential Building Type SD-7 &SD-8 Known As "NIRAVANA" in P4 Pocket** at above mentioned address. As per **C.C Issued by CIDCO/VVSR/BP/ZCC-20/I/4382 Dated- 10/05/1995.**The party has constructed **" Residential Building ,G+7** Floors" as per sanctioned Plan.

With reference to above on Dated: 4/10/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e. **M/s. Fire Worx Engineering bearing License No. MFS-LA/F- 0227 issued by MFS office and has submitted Certificate of dated -04/10/2014 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

1. Down comer system
2. Booster Pump-2 Nos
3. Single Hydrant valve- 16 Nos
4. Hose box-02 Nos
5. Hose reel Drum-14 Nos
6. ABC type fire Extinguishers-16 Nos

This office is issuing a **"Final No Objection Certificate"** for your following building having construction area admeasuring **to 2113.72 Sq.Mtrs.** This certificate shall be treated valid **up to 31/12/2014** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs. 2,40,000 /- vide Receipt No. 265618, Dated 18/09/2014., DD bearing No. 944921 Of Kotak Bank Issued by in favor of VVCMC additional Capitation & Scrutiny fees for the total construction area admeasuring **to 2113.72 Sq.Mtrs.**

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st Jan/April. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 306/2014-15 DATE: 07/10/2014

TO,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Residential cum commercial Building No.1 Wing B on Land bearing plot No.4., on S.No.48 ,H.No-1A to 1D/2(pt)and 1A to 1D/3 to at village -Sativali ,Tal- Vasai, Dist-Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 2716 / 2014, Dated:- 04/10/2014.
2. An application received by M/s. En Con project consultant, Dated: 03/07/2014.
3. Revised D.P. Issued By No. VVCMC / TP / RDP / VP-0339/043/2013-14 Dated-08/05/2013.
4. Certificate from License Agency M/s, Neo Enterprises, Dated: 27/09/2014 (Form A).
5. Building Completion certificate of M/s. En Con project consultant Ref.No. VP-339/120, Dated: 03/07/2014.
6. Construction area certificate of M/s. En Con project consultant Ref.No. VP-339/119, Dated: 03/07/2014.
7. Lift completion undertaking given by Mr.Valerian Dias dated-27/09/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Residential cum commercial Building No.1 Wing B** Building at above mentioned address. As per **Revised D.P. Issued By No. VVCMC / TP / RDP / VP-0339/043/2013-14.Dated-08/05/2013.**The party has constructed **Revised D.P. Issued By No. VVCMC / TP / RDP / VP-0339/043/2013-14.Dated-08/05/2013.Building Gr+ 7 Floors"** as per sanctioned Plan.

With reference to above on Dated: 01/10/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **Neo Enterprises bearing License No. MFS-LA/RF-0220,RD-0185 Dated-01/05/2014, issued by MFS office and has submitted on dated 27/09/2014 Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition.

A) Vertical Riser with Down Comer System
a) on every floor hose reel hose & landing valve / Hydrant valve
b) Booster pump on terrace- 5 HP
c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
d) Main Pump- 15 HP
B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1079.50** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand canceled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.1,60,000/- vide Receipt No. 265664 Dated 07/10/2014 & DD No.021076 Bassine Catholic Bank & Rs.40,000/- vide Receipt No. 265665 Dated 07/10/2014 & DD No.021077 Bassine Catholic Bank for the total gross built up area **1079.50** Sq.Mtrs .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION.

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE DEPARTMENT

Tel. No. 0250-252101/02/03/04/05/06

VVCMC/FIRE/ 309/2014-15 DATE: 20/12/2014

TO,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist-Palghar.

Sub:- "Final No Objection Certificate" for Industrial Building No.2 Type B (first floor only) Located on S.No.95 ,H.No-5 at village -Waliv ,Tal- Vasai, Dist-Palghar.

Ref :- 1. A Letter of Dy. Director, Town planning Dept. No. VVCM / NR / 3347/ 2014, Dated:- 20/12/2014 .
2. An application received by M/s. En Con project consultant, Dated: 26/09/2014.
3. Revised D.P. Issued By No. CIDCO/VVSR/RDP/BP-460/E/60 Dated-15/06/2010.
4. Certificate from License Agency M/s, Neo Enterprises, Dated: 15/12/2014 (Form A).
5. Building Completion certificate of M/s. En Con project consultant Ref.No. BP-460/18, Dated: 26/09/2014.
6. Built up area certificate of M/s. En Con project consultant Ref.No. BP-460/17, Dated: 26/09/2014.
7. Structure Stability certificate of M/s. Sanjay Narang & Associates Ref.No. BP-460/16, Dated: 26/09/2014.

Dear sir,

With reference to Sr.No.2 above, this office is in receipt of your application for your **Industrial Building No.2 Type B (first floor only)** Building at above mentioned address. As per **Revised D.P. Issued By No. CIDCO/VVSR/RDP/BP-460/E/60 Dated-15/06/2010** The party has constructed **Building Gr+ 1 Floors"** as per sanctioned Plan.

With reference to above on Dated: - 20/12/2014 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by License Agency i.e **Neo Enterprises bearing License No. MFS-LA/RF-0220,RD-0185 Dated-01/05/2014, issued by MFS office and has submitted on dated -15/12/2014 Certificate in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009"** Following Fire Fighting Arrangements provided were found in satisfactory working condition

A) Vertical Riser with Down Comer System
- a) on every floor hose reel hose & landing valve / Hydrant valve
- b) Booster pump on terrace- 5 HP
- c) Fire Brigade inlet at ground floor, Hose Box, Cotton Hose & Branch Pipe.
- d) Main Pump- 15 HP

B) Fire Extinguishers ABC Type.
C) Court yard Hydrants

This office is issuing a **"Final No Objection Certificate"** for your following building having built up area admeasuring to **1741.29** Sq.Mtrs This certificate shall be treated valid **up to 31/12/2014.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by the Owner or the Occupier in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand canceled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid already paid the Rs.85,000/- vide Receipt No. 266689 Dated 04/07/2014 & DD No.018092 Bassine Catholic Bank & Rs.85,000/- vide Receipt No. 266689 Dated 04/07/2014 & DD No.018091 Bassine Catholic Bank for the total gross built up area **1741.29** Sq.Mtrs .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

FIRE BRIGADE

NOMINATED FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect

Please Note:- The Developer / Owner / Occupier have to renew the N.O.C. on 1st January. of every year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org