

मुख्यालय, विरार
विरार (पूर्व),
जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. [आग्नि]मुका/०२८
दिनांक : ०५/०४/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential With Shopline Building No. 3 (Wing-A) (Gr + 7 Floor) On S No.13, H.No.1A/1 to 5, 1B/1 & S.No.14 of Village:Sopara, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1162/2020-21, Dated:05/03/2021.
2) An application received by M/s- Sanat Mehta & Associates, Dated:03/03/2021.
3) Built up area certificate of M/s- Sanat Mehta & Associates, Dated:03/03/2021.
4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:05/04/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/838/2016-17, Dated:02/01/2017.
6) Certificate from License Agency M/s-Kinjal Enterprises, Dated:10/12/2020 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:14/01/2021.
10) Structure Stability Certificate for M/s- Shilplekha Consultant, Dated:25/08/2020.
11) Submitted Electric Certificate for M/s- Diamond Electric Works, Dated:03/03/2021.
12) RDP issued by VVCMC/TP/RDP/VP-0432/145/2019-20, Dated:16/10/2019
13) C.F.O. site visit Dated:05/04/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential With Shopline Building No. 3 (Wing-A) (Gr + 7 Floor) in height 23.90mtr. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Kinjal Enterprises, bearing License No. MFS-LA/2020/RF-214, MFS-LA/2020/RD-190 and has submitted Certificate on 10/12/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area 2169.51sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 4,00,000/- vide Receipt No. 499066, Book No. 4991, DD No. 073096 (Vasai Janta Sahakari Bank), Dated: 19/12/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next T... certificate of fire fighting system's only from Licensed... list of the License Agencies is available on...
agency appointed by Government of Maharashtra on 1st July of ex...
maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६


फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. / भागि / मुका / ०२९
दिनांक : ०५/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Residential With Shopline Building No. 1 (Basement + Gr + 7 Floor) On land Bearing S No.30A, H.No.1 & 2A & H.No.2B & 3 of Village:Sopara, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1311/2020-21, Dated:26/03/2021.
2) An application received by M/s- Sanat Mehta & Associates, Dated:23/03/2021.
3) Built up area certificate of M/s- Sanat Mehta & Associates, Dated:23/03/2021.
4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:05/04/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2096/2019-20, Dated:31/12/2019.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated:27/02/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/04/2021.
10) Structure Stability Certificate for M/s- Shilplekha Consultant, Dated:14/08/2020.
11) Submitted Electric Certificate for M/s- SMB Electricals, Dated:11/02/2021.
12) RDP issued by VVCMC/TP/RDP/VP-0916/348/2019-20, Dated:18/03/2020
13) Submitted Diesel Engine Test Certificate, Dated:23/12/2020.
14) C.F.O. site visit Dated:05/04/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential With Shopline Building No. 1 (Basement + Gr + 7 Floor) in height 23.95mtr. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-The Fire Protection Company , bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 27/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area 2362.03sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/- vide Receipt No. 425824, Book No. 42, DD No.021535 (Bassein Catholic Bank), Dated:20/02/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

By: Architect

Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed / appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on maharashtrafireservice.org or www.maharashtra.gov.in

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/०५६/२०२९
दिनांक : १७/०४/२०२९

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. 9 (Wing- R & W) (Stilt / Gr + 7 Floor) located on land bearing S No.52(Pt) & S.No.53, H.No.1/2(Pt) old, S.No.52, H.No.2, S.No.53, H.No.1/3(New) of Village: Sativali, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1165/2020-21, Dated:05/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:01/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:01/03/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:01/03/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/474/2019-20, Dated:23/08/2019.
6) Certificate from License Agency M/s-The Fire Protection Company, Dated:15/02/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/04/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:01/03/2021.
11) RDP issued by VVCMC/TP/RDP/VP-0730/215/2019-20, Dated:25/11/2019
12) Submitted M/s- Amar Electricals Certificate, Dated:03/04/2021.
13) C.F.O. site visit Dated:11/04/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential with Shopline Building No. 9 (Wing- R & W) (Stilt / Gr + 7 Floor) in height 24.65mtr. At above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 15/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area 3864.36sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 8,00,000/- vide Receipt No. 487485, DD No. 000029, Dated:27/08/2016 for Building No.9 Wing- P, Q, R & W).

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL COR

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting s Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License www.maharashtrafireservice.org or www.mfsindia.org


मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/०५७/२०२१
दिनांक : १७/०४/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No. 1 & 2 (Gr + 2 Floor) located on land bearing S No.51, H.No.2 & 3 of Village: Gokhivare, Tal: Vasai, Dist: Palghar.

- Ref:-** 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1283/2020-21, Dated:24/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:22/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:22/03/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:22/03/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/124/2019-20, Dated:14/05/2019
6) Certificate from License Agency M/s-The Fire Protection Company, Dated:17/03/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/03/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:22/03/2021.
11) RDP issued by VVCMC/TP/RDP/VP-6121/114/2020-21, Dated:09/12/2020
12) Submitted M/s- Choice Electricals Certificate, Dated:01/04/2021.
13) C.F.O. site visit Dated:11/04/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Industrial Building No. 1 & 2 (Gr + 2 Floor) in height 15.60mtr. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2020/RE-228, MFS-LA/2020/RD-202 and has submitted Certificate on 17/03/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area for Building No.1 - 1957.76sq.mtr, Building No.2 - 1980.76sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,70,000/- vide Receipt No. 779284, DD No. 007554 (IDBI Bank), Dated:09/05/2019 for Industrial Building No.1 & Rs.1,70,000/- vide Receipt No.779283, DD.No.007553 (IDBI Bank), Dated:09/05/2019 for Building No.2.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect.

Please Note:- The Developer / Owner / Occupier have to submit the Agency appointed by Government of Maharashtra on 1st
www.maharashtrafireservice.org or www.mfsindia.com

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/०५८/२०२७
दिनांक : १७/०४/२०२७

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No. 1 (Stilt / Gr + 8(Pt) located on land bearing S No.121, H.No.B of Village: Manikpur, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1282/2020-21, Dated:24/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:22/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:22/03/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:22/03/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2244/2019-20, Dated:17/02/2020
6) Certificate from License Agency M/s-The Fire Protection Company, Dated:22/03/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/03/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:22/03/2021.
11) RDP issued by VVCMC/TP/RDP/VP-5463/67/2020-21, Dated:23/11/2020
12) Submitted M/s- Shree Laxmi Electrical Works Certificate, Dated:27/03/2021.
13) C.F.O. site visit Dated:11/04/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential Cum Commercial Building No. 1 (Stilt / Gr + 8 (Pt) in height 28.95mtr.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 23/03/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area 2322.07sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/- vide Receipt No. 470141, DD No. 022012 (Bassein Catholic Bank), Dated:05/05/2016 & Rs. 90,000/- vide Receipt No.818860, DD.No.023758 (Bassein Catholic Bank), Dated:21/12/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/०५९/२०२१
दिनांक : १०/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prama Hikvision India Pvt Ltd,
Gokul Annexe,
Opp Muljibhai Mehta School,
Agarwal Gardens, Gokul Township,
Bolinj, Virar (W), Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Vaishnavi Industrial Estate at Prama Hikvision India Pvt Ltd S.No.14, H.No.1B, Unit No.1, Gala No.1, 101, 201, Unit No.2, Gala No.2, 102, 202, Unit No.3, Gala No.3, 103, 203, Unit No.4, Gala No.4, 104, 204, Unit No.5, Gala No.5, 105, 205 of Village: Pelhar, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s-Prama Hikvision India Pvt Ltd, Dated:13/01/2021.
2. This office Renewal No Objection Certificate No.VVCMC/FIRE/HQ/834/2019, Dated:22/10/2019.
3. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:01/01/2021.
4. Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/01/2021.
6. C.F.O site visit Dated:23/03/2021

With reference to Sr.No.1 above, this office is in received of your application for your Vaishnavi Industrial Estate at Prama Hikvision India Pvt Ltd, Industrial Building No.1 & 2 (Gr+2(Pt) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226 & MFS-LA/2020/RD-200 and has submitted Certificate On 01/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/12/2021** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 97,500/- vide Receipt No. 895387, Dated:06/04/2021, DD No.148152 Issued by Union Bank renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/६१/२०२१
दिनांक : १६/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prima Hikvision India Pvt Ltd,
Industrial Estate Building No. G,
Village: Pelhar,
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Mit Industrial Estate No. 2 at Prama Hikvision India Pvt Ltd S.No.151, H.No.1/2, Mit Industrial Estate No. 2, Gala No.1 to 15, 101 to 117, 201 to 203 of Village: Pelhar, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s-Prima Hikvision India Pvt Ltd, Dated:13/01/2021.
2. This office Renewal No Objection Certificate No.VVCMC/FIRE/HQ/1092/2019, Dated:19/12/2019.
3. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:01/01/2021.
4. Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:27/01/2021.
6. C.F.O site visit Dated:23/03/2021

With reference to Sr.No.1 above, this office is in received of your application for your Mit Industrial Estate No. 2 at Prama Hikvision India Pvt Ltd, Mit Industrial Estate No. F at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226 & MFS-LA/2020/RD-200 and has submitted Certificate On 01/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/12/2021** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 60,000/- vide Receipt No. 895388, Book No. 8954, DD No.148149 (Union Bank), Dated:06/04/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. |आग्नि|मुका |६२/२०२१
दिनांक : १७/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prima Hikvision India Pvt Ltd,
Lotus Building No. 2,
Hira Industrial Estate,
Village- Pelhar,
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Lotus at Prima Hikvision India Pvt Ltd S.No.151, H.No.1/5 Lotus Building No. 2, Hira Industrial Estate of Village: Pelhar, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s-Prima Hikvision India Pvt Ltd, Dated:13/01/2021.
2. This office Renewal No Objection Certificate No.VVCMC/FIRE/HQ/1064/2019, Dated:12/12/2019.
3. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:01/01/2021.
4. Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/01/2021.
6. C.F.O site visit Dated:23/03/2021

With reference to Sr.No.1 above, this office is in received of your application for your Lotus at Prima Hikvision India Pvt Ltd, Lotus Building No. 2 (Gr+1) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226 & MFS-LA/2020/RD-200 and has submitted Certificate On 01/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/12/2021** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 37,500/- vide Receipt No. 895386, Book No. 8954, DD .No.148150 (Union Bank), Dated:06/04/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्ने/मुफा/६३/२०२१
दिनांक : १७/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prima Hikvision India Pvt Ltd,
Cosmos Building No. 3B,
Hira Industrial Estate,
Village- Pelhar,
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Cosmos at Prima Hikvision India Pvt Ltd S.No.151, H.No.1/5 Cosmos, Hira Industrial Estate of Village: Pelhar, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s-Prima Hikvision India Pvt Ltd, Dated:13/01/2021.
2. This office Renewal No Objection Certificate No.VVCMC/FIRE/HQ/1063/2019, Dated:12/12/2019.
3. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:01/01/2021.
4. Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/01/2021.
6. C.F.O site visit Dated:23/04/2021

With reference to Sr.No.1 above, this office is in received of your application for your Cosmos at Prima Hikvision India Pvt Ltd, Cosmos at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226 & MFS-LA/2020/RD-200 and has submitted Certificate On 01/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/12/2021** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 37,500/- vide Receipt No. 895384, Book No. 8954, DD .No.148147 (Union Bank), Dated:13/04/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

9/4
R. B. M. H. G. N.
869148113

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/६४/२०२१
दिनांक : १७/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prama Hikvision India Pvt Ltd,
Hira Hall Mark, S.No.149, H.No.1,
Village-Pelhar, Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Hira Hall Mark at Prama Hikvision India Pvt Ltd, Hira Hall Mark, S.No.149, H.No.1, Hira Industrial Estate of Village: Pelhar, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s-Prama Hikvision India Pvt Ltd, Dated:13/01/2021.
2. This office Renewal No Objection Certificate No.VVCMC/FIRE/HQ/2021/2019, Dated:21/12/2019.
3. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:01/01/2021.
4. Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/01/2021.
6. C.F.O site visit Dated:23/03/2021

With reference to Sr.No.1 above, this office is in received of your application for your Hira Hall Mark at Prama Hikvision India Pvt Ltd, Hira Industrial Estate at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226 & MFS-LA/2020/RD-200 and has submitted Certificate On 01/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/12/2021** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 1,18,750/- vide Receipt No. 895385, Book No. 8954, DD.No. 148148 (Union Bank), Dated:06/04/2021. renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. | आग्नि | मुका | ६५ | २०२१
दिनांक : १८/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prma Hikvision India Pvt Ltd,
Kristal Building No. 2,
Hira Industrial Estate,
Village- Pelhar,
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Kristal at Prma Hikvision India Pvt Ltd S.No.150/151, H.No.1/4 Kristal Building No. 2/2A, Hira Industrial Estate of Village: Pelhar, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s-Prma Hikvision India Pvt Ltd, Dated:13/01/2021.
2. This office Renewal No Objection Certificate No.VVCMC/FIRE/HQ/1065/2019, Dated:12/12/2019.
3. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:01/01/2021.
4. Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/01/2021.
6. C.F.O site visit Dated:23/03/2021

With reference to Sr.No.1 above, this office is in received of your application for your Kristal at Prma Hikvision India Pvt Ltd, Kristal Building No. 2 (Gr+1 Floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226 & MFS-LA/2020/RD-200 and has submitted Certificate On 01/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/12/2021** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 60,000/- vide Receipt No. 895383, Book No. 8954, DD .No.148151 (Union Bank), Dated:06/04/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

o/c
F. B. Prma Hikvision
869048113

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/००३
दिनांक : २९/०४/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s.D.G.Land Developers Pvt.Ltd,
104,Raghnath Krupa Building,Walawalkar Wadi,
Aarey Road,Goregaon (East)

Sub:- "Renewal_Final No Objection Certificate" of Residential With Shopline Building No. 3, Wing G & H, Sheetal Height in Sector – VI S. No. 51 ,52,53,54,55,56 & 77 Village: Achole, Tal: Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s- D.G.Land Developers Pvt.Ltd, Dated: 09/03/2021.
2) This Office Final No Objection Certificate No. VVCMC/FIRE/187/2015, Dated:26/08/2015.
3) Certificate from license Agency M/s- FireBird Fire Services, Dated:12/02/2021.
(Form B)
4) Submitted Fire Fighting Installation Photographs Dated: 23/02/2021.
5) Site visit Dated :- 19/03/2021

With reference to Sr.No.2 above, this office is in received of your application for Residential With Shopline Building No. 3 , Wing G & H, (Stilt+14 Floor) Sheetal Height in Sector – VI S. No. 51 ,52,53,54,55,56 & 77, height 43.85 Mtrs. only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- FireBird Fire Services bearing License No. MFS-LA/RF-26, & MFS-LA/2021/RD-20 Dated:08/01/2021 on in "Form B" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Renewal No Objection Certificate" for your building

This certificate shall be treated valid upto 31/08/2021 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid Industrial Building Rs. 4,25,000/- vide Receipt No. 895244, DD No.796211, Dated - 09/03/2021, Issued by the Bharat Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you,



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मक/६४२
दिनांक : २६-०६-२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential With Shopline Building Wing-A, B, C, D & E (Gr+P1+P2+7Pt) on Plot No. 81 out of larger layout land bearing on Plot No. 1 to 4, 30, 31, 32, 35, 42, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 70, 71, 73, 74, 75, 76, 77, 78, 80, 81, 82, 83, S.No.7 to 11, 15 to 17, 19 to 25, H.No.Part, S.No.4, H.No.3 & 4, S.No.5, H.No.1, 2, 3A, 3B, 2/2/A, 5/1, 5/2, S.No.6, H.No.1/1, 1/2A, 2A, 2B, S.No.7/Pt & 8/Pt, S.No.26, H.No.2, 3 & 4, S.No.27, H.No.1, 2 & 3, S.No.28, H.No.1, 2 & 3, S.No.29, H.No.1 & A, S.No.30, H.No.3 & 5, S.No.31, S.No.33, H.No.2, S.No.14/1, S.No.15/Pt & S.No.15/Pt, S.No.17/Pt & S.No.18/Pt, Central Park, Village: More, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/330/2021-22, Dated:21/06/2021.
2) An application received by M/s- Sanat Mehta & Associates, Dated:21/06/2021.
3) An application received by M/s- Versatile Realtors Pvt Ltd, Dated:24/06/2021
4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:29/06/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/291/2014-15, Dated:04/10/2014.
6) Construction area certificate for M/s- Sanat Mehta & Associates, Dated:21/06/2021.
7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:19/06/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021.
9) AMC Certificate by M/s- Versatile Realtors Pvt Ltd, Dated:24/06/2021
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/06/2021.
12) Structure Stability Certificate for M/s- Seemu Consultancy, Dated:21/06/2021.
13) RDP issued by VVCMC/TP/RDP/VP-0273/111/2021-22, Dated:07/05/2021.
14) Submitted Electric Certificate M/s- Vimal Electical, Dated:20/02/2021.
15) Diesel Engine Test Certificate of M/s- Tata Cummins Pvt Ltd, Dated:24/11/2018
16) C.F.O. site visit Dated:25/06/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential With Shopline Building Wing-A, B, C, D & E (Gr+P1+P2+7Pt) in 29.70 mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/2021/RF-26, MFS-LA/2021/RD-20 and has submitted Certificate on 19/06/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 39183.34 sq.mtrs.

With reference to above on 25/06/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Versatile Realtors Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank.
- G) Jockey Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.

- I) Diesel Generator Set
- J) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 20,80,000/- vide Receipt No.265639, Dated- 29/09/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "Y. K. Kulkarni", written over a horizontal line.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Sanat Mehta & Associates

2) Developer- M/s- Versatile Realtors Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म।अ.प्र.।मु.क।।६४२
दिनांक : २६-०६-२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential With Shopline Building Wing-A, B, C, D & E (Gr+P1+P2+7Pt) on Plot No. 81 out of larger layout land bearing on Plot No. 1 to 4, 30, 31, 32, 35, 42, 52, 53, 54, 55, 56, 57, 58, 59, 60, 61, 70, 71, 73, 74, 75, 76, 77, 78, 80, 81, 82, 83, S.No.7 to 11, 15 to 17, 19 to 25, H.No.Part, S.No.4, H.No.3 & 4, S.No.5, H.No.1, 2, 3A, 3B, 2/2/A, 5/1, 5/2, S.No.6, H.No.1/1, 1/2A, 2A, 2B, S.No.7/Pt & 8/Pt, S.No.26, H.No.2, 3 & 4, S.No.27, H.No.1, 2 & 3, S.No.28, H.No.1, 2 & 3, S.No.29, H.No.1 & A, S.No.30, H.No.3 & 5, S.No.31, S.No.33, H.No.2, S.No.14/1, S.No.15/Pt & S.No.15/Pt, S.No.17/Pt & S.No.18/Pt, Central Park, Village: More, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/330/2021-22, Dated:21/06/2021.
2) An application received by M/s- Sanat Mehta & Associates, Dated:21/06/2021.
3) An application received by M/s- Versatile Realtors Pvt Ltd, Dated:24/06/2021
4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:29/06/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/291/2014-15, Dated:04/10/2014.
6) Construction area certificate for M/s- Sanat Mehta & Associates, Dated:21/06/2021.
7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:19/06/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021.
9) AMC Certificate by M/s- Versatile Realtors Pvt Ltd, Dated:24/06/2021
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/06/2021.
12) Structure Stability Certificate for M/s- Seemu Consultancy, Dated:21/06/2021.
13) RDP issued by VVCMC/TP/RDP/VP-0273/111/2021-22, Dated:07/05/2021.
14) Submitted Electric Certificate M/s- Vimal Electical, Dated:20/02/2021.
15) Diesel Engine Test Certificate of M/s- Tata Cummins Pvt Ltd, Dated:24/11/2018
16) C.F.O. site visit Dated:25/06/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential With Shopline Building Wing-A, B, C, D & E (Gr+P1+P2+7Pt) in 29.70 mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/2021/RF-26, MFS-LA/2021/RD-20 and has submitted Certificate on 19/06/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 39183.34 sq.mtrs.

With reference to above on 25/06/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Versatile Realtors Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
B) Hose Reel Hose has been installed in every floor
C) Hose Box has been installed in Alternate floor
D) Siamese Connection has been installed in entrance gate
E) Courtyard Hydrant has been installed in the building & prominent places.
F) Mian Pump on under ground water storage tank.
G) Jockey Pump on under ground water storage tank.
H) Booster Pump near over head water storage tank.

Komal Shetty
986060333

- I) Diesel Generator Set
- J) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 20,80,000/- vide Receipt No.265639, Dated- 29/09/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, written over the printed name.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Sanat Mehta & Associates
2) Developer- M/s- Versatile Realtors Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

विभागीय कार्यालय, वसई
वसई, जि. ठाणे, पिन ४०१ २०१.



दूरध्वनी : ०२५०-२३०९०२०/२३२२२५८/२३२३३४३

२३२२०२१, रूग्णालय : २३२२१२०

फॅक्स : ०२५०-२३०९८३५

जा. क्र. : व.वि.श.म./अग्नि/मुका/७८०/२०२०

दिनांक : ०५/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- D-Mart Avenue Supermarts Limited,
S.no. 396,H.no. 1/1/1,
Virar Nallasopara Link Road , Virar (E),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of D-Mart Avenue Supermarts Limited,
S.no. 396,H.no. 1/1/1, Virar Nallasopara link Road, Virar (E) , Tal- Vasai, Dist- Palghar.

- Ref: - 1. An application received by M/s- D-Mart Avenue Supermarts Limited, Dated: 02/12/2020
2. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated: 01/07/2020 (Form B).
3. License No. MFS-LA/2020/RF-226, & MFS-LA/2020/RD-200 Dated :16/10/2020
4. Renewal fire NOC Issued BY. VVCMC/FIRE/2110/2019, Dated: 06/01/2020
5. Site Visit on Dated : 05/01/2021

Dear Sir,

With reference to Sr.No.1 above, this office is in received of your application for your "**D-Mart Avenue Supermarts Limited**" at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/2020/RF-226, & MFS-LA/2020/RD-200 issued by this office and has submitted Certificate On 16/10/2020 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 2,40,000/- vide Receipt No. 819694 Dated: 02/01/2021, DD No.025141, Issued by HDFC Bank, renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

Santosh Chaudhary
Santosh Chaudhary
9820586484



[Signature]
CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/७८२/२०२१

दिनांक : १२/०७/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Jubilant FoodWorks Ltd,
National Highway No. 08,
Near Tungareshwar Phata,
Sativali, Vasai (E),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Jubilant FoodWorks Ltd, National Highway No. 08, Tungareshwar Phata, Sativali, Vasai (E), Tal-Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Jubilant FoodWorks Ltd, Dated:17/06/2021.
2. This office Renewal No Objection Certificate No.VVCMC/FIRE/HQ/147/2020, Dated:21/07/2020.
3. Certificate from License Agency M/s- Anushka Fire Services, Dated:01/06/2021.
4. Submitted License copy of Maharashtra Fire Services, Dated:06/01/2021.
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:15/06/2021.
6. C.F.O site visit Dated:19/06/2021
7. Submitted Electrical Certificate of Gov of Maharashtra, Dated:29/09/2019

With reference to Sr.No.1 above, this office is in received of your application for your Jubilant FoodWorks Ltd at above mention address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Anushka Fire Services bearing License No. MFS-LA/2021/RF-15 & MFS-LA/2021/RD-15 and has submitted Certificate On 01/06/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 1,20,000/- vide Receipt No. 895494, Book No. 8955, DD .No.033497 (ICICI Bank), Dated:17/06/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to M/s- Jubilant FoodWorks Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

विभागीय कार्यालय, वसई
वसई, जि. ठाणे, पिन ४०१ २०१.



दूरध्वनी : ०२५०-२३०९०२०/२३२२२५८/२३२३३४३
२३२२०२१, रूग्णालय : २३२२१२०
फॅक्स : ०२५०-२३०९८३५

जा. क्र. : व.वि.श.म./अग्नि/मुका/७८६/२०२०
दिनांक : ०६/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- V.R.Construction Co,
Shop no.7, Swarn Hans Tower, Buiding No.1
Sector no.VI, Shreeprasta, Nallasopara (W)

Sub:- Renewal of "Final No Objection Certificate" of Residential Cum Commercial Building No.1 Sector VI, (Wing A & B), Known as "SWARNANS TOWER" on Plot No.1 to 8, 14 to 205, 214 to 218, 228 to 232, 240, 241 on land bearing S.No.56 to 58, 90, 91(P), 92 to 95, 98, 100, 102, 103, 104, 136, 137, 148 to 157, 165 to 171, 173, 178 at village: Nilemore, Tal- Vasai, Dist-Palghar.

- Ref:-
1. An application received by M/s- V. R. Construction Co, Dated:11/12/2020 (BP-3145)
 2. Certificate from License Agency M/s.Firebird Fire Services, Dated:07/12/2020 (Form B)
 3. Submitted Fire Fighting Installation Photo Copy, Dated:07/12/2020
 4. Submitted License copy of Maharashtra Fire Services, Dated:24/12/2019
 5. This office Renewal of Final No Objection Certificate No. VVCMC/FIRE/HQ/815/2017-18, Dated:22/12/2017

Dear Sir,

With reference to Sr.No.1 above, this office is in received of your application for your **Residential Cum Commercial Building No.1 (Wing- A & B)** at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s.Firebird Fire Services bearing License No. MFS-LA/2019/RF-404, MFS-LA/2019/RD-376 issued by this office and has submitted Certificate On 24/12/2019 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,32,000/- vide Receipt No. 819647, Dated:15/12/2020, DD No. 000030 & Rs. 44,000/- vide Receipt No. 819676, Dated: 24/12/2020, DD.No.000034 Issued by City Union Bank Ltd renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुक/७२०/२०२१
दिनांक : १४/०७/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial with Shopline Building (Gr+2) located on land bearing S.No.45, H.No.1, S.No.47, H.No.2/6 of Village: Gokhiware, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/230/2021-22, Dated:31/05/2021.
- 2) An application received by M/s- Prithvi Arch Consultants, Dated:05/05/2021.
 - 3) An application received by M/s- Rajprabha Developers Pvt Ltd, Dated:16/06/2021
 - 3) Work Completion certificate of M/s- Prithvi Arch Consultants, Dated:05/05/2021.
 - 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/672/2019-20, Dated:24/09/2019.
 - 5) Construction area certificate for M/s- Prithvi Arch Consultants, Dated: 05/05/2021.
 - 6) Certificate from License Agency M/s- The Fire Protection Company, Dated:15/04/2021 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/06/2021.
 - 10) Structure Stability Certificate for M/s- Prithvi Arch Consultants, Dated:05/05/2021.
 - 11) RDP issued by VVCMC/TP/RDP/VP-6162/112/2020-21, Dated:09/12/2020.
 - 12) Submitted Electric Certificate M/s- Choice Electical, Dated:22/04/2021.
 - 13) C.F.O. site visit Dated:28/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial with Shopline Building (Gr+2) in 16.20mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company,** bearing License No. MFS-LA/2019/RF-228, MFS-LA/2019/RD-202 and has submitted Certificate on 15/04/2021 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 4542.830sq.mtrs.

With reference to above on 28/03/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Rajprabha Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Auto Matic Sprinkler system has been installed in every floor & prominent places
- D) Smoke Detector has been installed in prominent places
- E) Hose Box has been installed in ground floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building
- H) Wet Riser
- I) Mian Pump on under ground water storage tank.
- J) Stant by Pump on under ground water storage tank.
- K) Jockey Pump on under ground water storage tank.
- L) Sprinkler Pump on under ground water storage tank.
- M) Jocky Pump on under ground water storage tank.
- N) Booster Pump near over head water storage tank.
- O) Diesel Generator Set
- P) Manual Operated Electrical Fire Alarm System.

OC
B

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 9,50,000/- vide Receipt No. 818508, DD No. 123530 (Syndicate Bank) Dated- 24/09/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "D. Pawar", written over the printed name of the Chief Fire Officer.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/७२७/२०२१
दिनांक : १४/०७/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial with Shopline Building (Gr+2) located on land bearing S.No.45, H.No.1, S.No.47, H.No.2/6 of Village: Gokhiware, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/230/2021-22, Dated:31/05/2021.
2) An application received by M/s- Prithvi Arch Consultants, Dated:05/05/2021.
3) An application received by M/s- Rajprabha Developers Pvt Ltd, Dated:16/06/2021
3) Work Completion certificate of M/s- Prithvi Arch Consultants, Dated:05/05/2021.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/672/2019-20, Dated:24/09/2019.
5) Construction area certificate for M/s- Prithvi Arch Consultants, Dated: 05/05/2021.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated:15/04/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/06/2021.
10) Structure Stability Certificate for M/s- Prithvi Arch Consultants, Dated:05/05/2021.
11) RDP issued by VVCMC/TP/RDP/VP-6162/112/2020-21, Dated:09/12/2020.
12) Submitted Electric Certificate M/s- Choice Electical, Dated:22/04/2021.
13) C.F.O. site visit Dated:28/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial with Shopline Building (Gr+2) in 16.20mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company,** bearing License No. **MFS-LA/2019/RF-228, MFS-LA/2019/RD-202** and has submitted Certificate on **15/04/2021** in **"Form A"** Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to **4542.830sq.mtrs.**

With reference to above on **28/03/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Rajprabha Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Auto Matic Sprinkler system has been installed in every floor & prominent places
- D) Smoke Detector has been installed in prominent places
- E) Hose Box has been installed in ground floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building
- H) Wet Riser
- I) Mian Pump on under ground water storage tank.
- J) Stant by Pump on under ground water storage tank.
- K) Jockey Pump on under ground water storage tank.
- L) Sprinkler Pump on under ground water storage tank.
- M) Jocky Pump on under ground water storage tank.
- N) Booster Pump near over head water storage tank.
- O) Diesel Generator Set
- P) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 9,50,000/- vide Receipt No. 818508, DD No. 123530 (Syndicate Bank) Dated- 24/09/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "G. P. Chawla", written over a horizontal line.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-


Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ २०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/७००६/२०२१
दिनांक : १४/०७/२०२१



FIRE & EMERGENCY DEPARTMENT



To
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Automobile Shops & Godowns / Local Resource Based Industry Building (Unit No.35) (Stilt + Gr + 1 floor) on land bearing S.No.69, H.No.1(Pt), S.No.71, H.No.Pt & S.No.213, H.No.2(P) & S.No.72 + 75/1 + 75/2 + 77/1(P) + 77/2 + 65 + 69/1 + 70 + 71(P) + 78 + 213/2(P) of Village: Pelhar, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/332/2021-22, Dated:23/06/2021.
2) An application received by M/s- Himesh Gupta & Associates, Dated:08/06/2021.
3) An application received by M/s- Abdul Rehman Patel, Dated:01/06/2021
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/59/2018-19, Dated:16/04/2019.
5) Construction area certificate for M/s- Himesh Gupta & Associates, Dated:01/06/2021.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated:10/05/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) AMC Certificate by M/s- Abdul Rehman Patel, Dated:13/07/2021
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/07/2021.
10) Structure Stability Certificate for M/s- S.P.Associates, Dated:15/06/2021.
11) Submitted Electric Certificate M/s- S.S.Electricals & Engineers, Dated:21/05/2021.
12) C.F.O. site visit Dated:12/07/2021.

With reference to Sr.No. 2 above, this office is in received of your application for your **Automobile Shops & Godowns / Local Resource Based Industry Building (Unit No. 35) (Stilt + Gr + 1 floor)** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 10/05/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 296.79sq.mtrs.

With reference to above on 12/07/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Abdul Rehman Patel" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
B) Hose Reel Hose has been installed in every floor
C) Smoke Detector has been installed in Machine Room, Electrical Meter Room, Office area & prominent places
D) Hose Box has been installed in Alternate floor
E) Courtyard Hydrant has been installed in the building & prominent places.
F) Wet Riser
G) Booster Pump near over head water storage tank.
H) Diesel Generator Set
I) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.80,000/- vide Receipt No. 761305, DD.No.195005, Dated- 28/03/2019 & Rs.80,000/- vide Receipt No.779239, DD.No.012267, Dated:10/04/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "P. Patel", written over the printed name of the Chief Fire Officer.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Himesh Gupta & Associates
2) Developer- M/s- Abdul Rehman Patel

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/८००/२०२१-२२
दिनांक : १४/०६/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building No. 1 & 2 (Gr +2 floor) located on land bearing S.No.40, H.No.1 of Village: Sativali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/237/2021-22, Dated:02/06/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:20/05/2021.
 - 3) An application received by M/s- S.K.Developers, Dated:16/06/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:20/05/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1075/2019-20, Dated:01/01/2019.
 - 6) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/311/2019-20, Dated:09/07/2019
 - 7) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:20/05/2021.
 - 8) Certificate from License Agency M/s- The Fire Protection Company, Dated:08/02/2021 (Form A).
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 10) AMC Certificate by M/s-S.K.Developers, Dated:14/07/2021
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:25/06/2021.
 - 12) Structure Stability Certificate for M/s- S.S & Associates, Dated:10/06/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-6096/292/2019-20, Dated:05/02/2020.
 - 14) Submitted Electric Certificate M/s- Pradhan Electrical Works, Dated:24/06/2021.
 - 15) Diesel Engine Test Certificate of M/s-Pradhan Electrical Works, Dated:24/06/2021
 - 16) C.F.O. site visit Dated:25/06/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No. 1 & 2 (Gr + 2 floor) in 15.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company**, bearing License No. **MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on **08/02/2021** in **"Form A"** Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to Ind Bldg No.1 – 7355.15sq.mtrs & Ind Bldg No. 2 – 6836.11sq.mtrs.

With reference to above on **25/06/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- S.K. Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Automatic Sprinkler has been installed in every floor
- E) Automatic Smoke Detector has been installed in every floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Main Pump on under ground water storage tank.
- I) Stand by Pump on under ground water storage tank.
- J) Jockey Pump on under ground water storage tank.
- K) Booster Pump near over head water storage tank.

- L) Diesel Generator Set
- M) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 10,00,000/- vide Receipt No.727091, DD.No.014918, Dated- 01/01/2019 of HDFC Bank for Industrial Bldg No. 1.

The Party has all ready paid the Rs.10,00,000/- vide Receipt No.727092, DD.No.014918, Dated: 01/01/2019 of HDFC Bank for Industrial Bldg No. 2.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "V. Patil", written over the official stamp.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- S.K.Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

विभागीय कार्यालय, वसई
वसई, जि. ठाणे, पिन ४०१ २०१.



दूरध्वनी : ०२५०-२३०९०२०/२३२२२५८/२३२३३४३
२३२२०२१, रूग्णालय : २३२२१२०
फैक्स : ०२५०-२३०९८३५

जा. क्र. : व.वि.श.म/अग्नि/मुका/८०२/२०२०-२१
दिनांक : ११/०१/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Residential Building No. T3 Stilt+3 upper level Parking Podium Floor (Stilt+3 upper level Parking+19 floors) located on land bearing S.No. 296, 297, 298, 299, 303, 304, 324 & 390-B of Village: Bolinj, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/687/2020-21, Dated: 23/11/2020
2) An application received by M/s- En Con Project Consultants, Dated: 19/11/2020
3) Work Completion certificate of M/s- En Con Project Consultants, Dated: 19/11/2020
4) Built up area certificate of M/s- En Con Project Consultants, Dated: 19/11/2020
5) Certificate from License Agency M/s- Falcon Technoprojects India Pvt Ltd, Dated: 07/12/2019 (Form A)
6) Certificate from License Agency M/s- Bright Infra System Pvt Ltd, Dated: 09/11/2020 (Form A)
7) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 11/11/2020
8) RDP Issued by VVCMC/TP/RDP/VP-0059/097/2017-2018, Dated: 17/10/2017
9) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/535/2016-17, Dated: 30/09/2016
10) Submitted License copy of Maharashtra Fire Services, Dated: 25/11/2020, 24/08/2020
11) Diesel Engine Test Certificate of M/s- CG Power & Industrial Solutions Ltd, Dated: 23/03/2017
12) Certificate from M/s- Noor Electricals, Dated: 02/11/2020
13) C.F.O. site visit Dated :- 21/12/2020

Dear Sir,

With reference to Sr.No.2 above, this office is in received of your application for your of Residential Building No. T3 Stilt+3 upper level Parking Podium Floor (Stilt+3 upper level Parking+19 floors) in 68.20 Mtrs height. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- M/s- Falcon Technoprojects India Pvt Ltd bearing License No. MFS-LA/F-0693, MFS-LA/D-0590, MFS-LA/P-0093 & Ms-Bright Infra System Pvt Ltd bearing License No. MFS-LA/2020/RF-0166 issued by this office and has submitted Certificate on 05/11/2020 & 09/11/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9116.24 sq.mtrs.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Building No. T1 to T7 the Rs 33,00,000/- vide Receipt No. 487467, DD No.084307, & Rs.10,40,000/- vide Receipt No. 487424, DD No. 033221, Dated- 29/08/2016 of Standard Chartered Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



[Handwritten signature]

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to Architect-

Please Note:- The Developer / Owner / Occupier has to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT


Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 805 /2020-21

DATE: 14/01/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" for Commercial Building No 1 (Mall- Departmental Store, Banquet Hall, 5 Multiplexes, Restaurants, Games Zone) in Sector No. II 2 Basement + Lower Gr + Gr Floor + 4 Floor (Pt) Located on land bearing S.No. 49, 50,51,52,53,54,55,56,77 & S. No. 57 H.No. 1 of Village: Achole. Tal: Vasai, Dist: Palghar. (VP.No.0127)

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./NR/544/2020-21, Dated: 21/10/2020.
2) An application received by M/s-Encon Project Consultants, Dated: 19/10/2020.
3) Work Completion certificate of M/s- Encon Project Consultants, Dated: 07/12/2019.
4) Gross built up area certificate of M/s- Encon Project Consultants, Dated: 19/10/2020.
5) Structure Stability Certificate from M/s- JW Consultants LLP, Dated: 19/10/2020.
6) Certificate from License Agency M/s- Abhishek Millennium Contracts Pvt Ltd, Dated: 05/03/2020, (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated: 25/11/2021.
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 19/10/2020.
9) Part Final Fire NOC by VVCMC/FIRE/HQ/2048/2019-20, Dated: 26/12/2019.
10) RDP issued by VVCMC/RDP/VP-0127/231/19-20 dated 03/12/2019.
11) Provisional NOC Issued By VVCMC/FIRE/HQ/957/2017-18, Dated: 06/02/2018.
12) License to work the Lift From Govt. of Maharashtra Industries, Energy & License No. M.V.N./990/12022020/35438 to 35443 (6 Nos) Dated 15/02/20 and M.V.N/990/08122020/43973 to 43978 (6 Nos)
13) Fire Officer site visit, Dated: / /2021.

With reference to Sr.No.2 above, this office is in received of your application for Commercial Building No. 1 (2 Basement + Lower Gr + Gr + 4 (pt) Floor only) in height 25.20 Mtrs. only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Abhishek Millennium Contracts Pvt Ltd bearing License No. MFS-LA/2019/RF-254 & MFS-LA/2019/RD-330 , issued by this office and has submitted Certificate on 5/3/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having Gross built up area is 48040.77 sq. mtrs.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Party has paid Capitation and Scrutiny fees of Rs. 10,00,000/- vide Receipt No. 609556 Dated 22/01/20 DD No.000118 Of Bassien Catholic Co-Op Bank. & Rs. 28,43,262/- vide Receipt No. 895023, DD No.808447, 08/01/2021 Of HDFC Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building essential.

Thanking you,



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/807/2021

DATE: 14/01/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- Part "Final No Objection Certificate" of Residential With shop line Building No.2
(Out of Gr+3 part approval now for Ground+1upper Commercial portion only) on
land bearing S.No.234,H.No. 2 B of Village: Achole, Tal: Vasai, Dist: Palghar.

- Ref:- 1) A letter from Deputy Director Town Planning No.VVCMC/NR/ 801 /2020-21,
Dated: 22/12/2020. (VP- 2395)
2) An application received by Mr. Abhay Raut, Dated: 27/11/2020.
3) Built up area certificate of Mr. Abhay Raut , Dated: 27/11/2020.
4) Work Completion certificate M/s- Shree Consultants , Dated: 27/11/2020 .
5) Structure Stability certificate for – Mr.Suresh kumar panicker , Dated: 05/11/2020.
6) Certificate from license Agency M/s- Vision Fire & Safety Engineering, Dated:29/10/2020.
(Form A).
7) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 17/11/2020.
8) RDP Issued by VVCMC/TP/RDP/VP-0658/121/2018-19, Dated: 11/10/2018.
9) Provisional No objection Certificate No. VVCMC/FIRE/02/2017-18, Dated: 03/04/2017.
10) Submitted License copy of Maharashtra Fire Services, Dated: 06/10/2020.
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & License
No.990/41089, Dated: 12/11/2020.
12) Site Visit on Dated:- 28/12/2020.

With reference to Sr.No.1 above, this office is in receipt of your application for your of Residential With shop line Building No.2, (Out of Gr+3 part approval now for Ground+1upper Commercial portion only), 13.84 Mtrs. in height at above mentioned address. Since the fire fighting provided is installation by License Agency i. e M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226, MFS-LA/2020/RD-200 Issued by MFS office and has submitted certificate on 29/10/2020 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Final No Objection Certificate" for your building. Having built up area admeasuring to 1515.82 Sq.mtr.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.1,70,000/- vide Receipt No.470286, DD. No.017558, Dated: 20/03/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you.



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's along with 'B' form only from Licensed Agency appointed by Government of Maharashtra on 1st January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 811 /2020-21

DATE: 14/01/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of I.T. Industrial Building (Stilt/Gr + 1 Floor) Located on land bearing S.No.219, H.No. 1(Pt) & S No. 217 of Village: Pelhar, Tal: Vasai, Dist: Palghar. (VP.No.5225)

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/878/2020-21, Dated: 07/01/2021.
2) An application received by M/s-Himesh Gupta & Associates, Dated: 30/12/2020.
3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated: 30/12/2020.
4) Gross built up area certificate of M/s-Himesh Gupta & Associates, Dated: 30/12/2020.
5) Structure Stability Certificate from M/s- Pro-Tech Consultants, Dated: 12/12/2020.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated: 06/01/2021, (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated: 05/10/2021
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 05/01/2021.
9) RDP Issued by VVCMC/TP/RDP/VP- 5225/37/2019-20, Dated: 18/06/2019.
10) Provisional NOC Issued By VVCMC/FIRE/HQ/57/2018-19, Dated: 16/04/2019.
12) Fire Officer site visit, Dated: / /2021.

With reference to Sr.No.2 above, this office is in received of your application for **IT Industrial Building Stilt/Ground + 1 Floor only, in height 10.60 Mtrs.** only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/RD-259 & MFS-LA/RF-282, issued by this office and has submitted Certificate on 06/1/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having **Gross built up area is 478.97 sq. mtrs.**

This certificate shall be treated **valid upto one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Party has paid Capitation and Scrutiny fees of Rs. 80,000/- vide Receipt No. 646049, DD No.742606, Dated: 16/04/2018 Dated: 16/04/2018 Of Kotak Mahindra Bank. & Rs. 40,000/- vide Receipt No. 779240, DD No.598819, Dated: 10/04/2018 Of Kotak Mahindra Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building essential.

Thanking you,



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-Himesh Gupta & Associates

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

विभागीय कार्यालय, वसई
वसई, जि. ठाणे, पिन ४०१ २०१.



दूरध्वनी : ०२५०-२३०९०२०/२३२२२५८/२३२३३४३
२३२२०२१, रूग्णालय : २३२२१२०
फॅक्स : ०२५०-२३०९८३५

जा. क्र. : व.वि.श.म./अग्नि/मुका/८२०/२०२०
दिनांक : १८/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub: "Final No Objection Certificate" of Residential Building with Shops (Gr.+7 Floors) on land bearing S.No. 325,H.no.3,4,5,7,9,10 & House No.531.531A, of Village Virar , Tal - Vasai, Dist. Palghar.

- Ref: 1) A Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/754/2020, Dated: 15/12/2020. (VP-0661)
2) An Application received from M/s- Sameer R.Desai ,Dated: 07/12/2020
3) Gross Built up area certificate received from M/s- Sameer R.Desai, Dated: 18/02/2020.
4) Work Completion certificate received from M/s- Sameer R.Desai, Dated:05/01/2021.
5) Structure Stability certificate for M/s- Paresn Unnarkar , Dated:25/12/2019.
6) Certificate from License Agency M/s- Sadanand Fire Systems, Dated: 10/02/2020. (Form-A)
7) Submitted Affidavit & Fire Fighting Installation Photo copy, Dated: 17/02/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Licence, मु.वि.नि/41181/Dated 20/11/2020
9) Submitted License copy of Maharashtra Fire Services, Dated : 08/02/2020.
10) RDP Issued by VVCMC/TP/RDP/VP-0661/29/2018, Dated: 14/05/2018.
10) FIRE Provisional NOC ISSUED BY VVCMC/FIRE/HQ/711/2017, Dated: 14/11/2017.
11) Site Visit date: 12/01/2021

With reference to Sr. No.2 & 3 this office is in received of your application for your Residential with Shopline Gr.+07 floors located on land bearing S.No. 325,H.no.3,4,5,7,9,10 & House No.531.531A in 23.94 Mtrs. Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Controls bearing License No. MFS-LA/2020/RF-68 issued by this office and has submitted Certificate on 08/02/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1664.46 sq. mtrs.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C" will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life property if any, which may please be noted.

The Party has paid fees of Rs.2,00,000/- vide Receipt No. 150919, Dated - 28/09/2011 Of Bassein Catholic Bank.

The undersigned reserve right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to Architect-

PLEASE NOTE:- The Developer/Owner/Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the Licensed agencies is available on www.maharashtrafireservices.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/८२३/२०२०

दिनांक : २९/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- IASIS Hospital,
Evershine City,
Vasai (E),
Tal-Vasai, Dist-Palghar.

Sub: - Renewal of "Final No Objection Certificate" of Hospital Building, Evershine City, Vasai (E), village- Achole, Tal- Vasai, Dist-Palghar.

Ref :- 1. An application received by M/s- IASIS Hospital, Dated: 22/12/2020
2. Certificate from License Agency M/s- Ray Fire Protection Services, Dated: 01/12/2020 (Form B).
3. Submitted Fire Fighting Installation Photo Copy, Dated: 07/12/2020
4. This office Renewal of Final No objection Certificate No. VVCMC / FIRE / 973/2019, Dated: 18/11/2019.

Dear Sir,

With reference to Sr.No.1 above, this office is in received of your application for your **Hospital Building (Ground + 3 upper Floors)** at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Ray Fire Protection Services bearing License No. MFS-LA/2019/RF-59 issued by this office and has submitted Certificate On 02/05/2019 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal of Final No Objection Certificate" for your building.

This certificate shall be treated valid up to one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 21,250/- vide Receipt No. 895015, dated 11/01/2021 DD. No. 322217 of The south Indian Bank Ltd.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/८२३/२०२१
दिनांक : २२/०६/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Agro Based Industry (Gr+1 floor) located on land bearing S.No.82, H.No.1/1 of Village: Tokre, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/08/2021-22, Dated:01/04/2021 (SPA VP-20)
- 2) An application received by M/s- Umesh Kekre Architect, Dated:10/03/2021
 - 3) An application received by M/s- Mega Vision Developers, Dated:10/03/2021
 - 4) Work Completion certificate of M/s- Umesh Kekre Architect, Dated:10/03/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/242/2017-18, Dated:29/06/2017.
 - 6) Built up area certificate for M/s- Umesh Kekre Architect, Dated:10/03/2021.
 - 7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:08/07/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021.
 - 9) AMC Certificate by M/s- Mega Vision Developers, Dated:10/03/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/06/2021.
 - 12) Structure Stability Certificate for M/s- Shilplekha Consultant, Dated:17/08/2020.
 - 13) Submitted Electric Certificate M/s- Ishwar Electrical Works, Dated:13/02/2021.
 - 14) Diesel Engine Test Certificate of M/s- Ishwar Electrical Works, Dated:13/02/2021
 - 15) C.F.O. site visit Dated:22/06/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Agro Based Industry Gr + 1 floor in 10.00mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/2021/RF-26, MFS-LA/2021/RD-20** and has submitted **Certificate on 08/07/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 1213.66sq.mtrs.

With reference to above on **22/06/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Mega Vision Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank.
- G) Jockey Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.
- I) Sprinkler Pump on under ground water storage tank.
- J) Diesel Generator Set
- K) Manual Operated Electrical Fire Alarm System.

NK-Dohi
२२-०६-२०२१

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,50,000/- vide Receipt No.265626, DD.No.95510 (Vasai Vikas Sahakari Bank), Dated-22/09/2014 & Rs.60,000/- vide Receipt No.265625, DD.No.095511 (Vasai Vikas Sahakari Bank), Dated:22/09/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "P. S. Patil", written over the printed name of the Chief Fire Officer.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Umesh Kekre Architect
2) Developer- M/s- Mega Vision Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/८२४/२०२०
दिनांक : २९/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
Mr.Raakesh Agarwaal
Mixed Occupancy Building no.1 A
Rajprabha Landmark Ind.Estate,
Bldg.No.1First Floor,Bhoidapada,
Sativali Road,Vasai (E)
Dist. Palghar

Sub:- Renewal of "Final No Objection Certificate" of Mixed Occupancy Building no.1 A
On land bearing S.No./H.no.33,42/1,43/1 Village: Gokhivare, Tal: Vasai, Dist: Palghar.

Ref:- 1) An application received by Mr.Raakesh Agarwaal, Dated: 19/01/2021
2) Certificate from License Agency M/s- Ray Fire Protection Services, Dated: 06/01/2021, (Form B)
3) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 07/01/2021
4) This office Final No Objection Certificate No. VVMC/ FIRE/ 197/2012-13 Dated: 05/01/2013
5) Site Visit on Dated :-19/01/2021

With reference to Sr.No.1 above, this office is in received of your application for your Mixed Occupancy Building no.1, On land bearing S.No./H.no.33,42/1,43/1 A (Gr.+1 Floor), in at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Ray Fire Protection Services bearing License No. MFS-LA/2019/RF-59 issued by this office and has submitted Certificate On 02/05/2019 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party paid the Rs.1,70,000/- vide Receipt No.895060,DD .No.024408, Dated - 19/01/2021,Bassin catholic ltd. co.op.Bank

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०९
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/८२७/२०२१
दिनांक : २३/०७/२०२१



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.6 Wing-B (Gr + 10 floor) & Wing-C (Gr + 9 floor) located on land bearing S.No.242, S.No.246, H.No.1 & 2, S.No.247, 248, 249, 256 of Village: Nilemore, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/490/2021-22, Dated:19/07/2021.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:20/07/2021.
 - 3) An application received by M/s- Shakti Developers, Dated:20/07/2021
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:20/07/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/303/2014-15, Dated:07/10/2014.
 - 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:20/07/2021.
 - 7) Certificate from License Agency M/s- Shree Fire Guard Co, Dated:08/07/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
 - 9) AMC Certificate by M/s- Shakti Developers, Dated:15/06/2021.
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/07/2021.
 - 12) Structure Stability Certificate for M/s- Nimisha Structural Design Academy, Dated:18/04/2019
 - 13) RDP issued by VVCMC/TP/RDP/VP-0567/0106/2014-15, Dated:13/08/2014.
 - 14) Submitted Electric Certificate M/s-Gopal Electric Engineering Services, Dated:14/03/2021.
 - 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:15/04/2017
 - 16) C.F.O. site visit Dated:16/07/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building No. 6 (Wing-B) Gr + 10 floor in 32.15mtrS & (Wing- C) Gr + 9 floor in 29.30mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree Fire Guard Co, bearing License No. MFS-LA/2020/RF-270, MFS-LA/2020/RD-243 and has submitted Certificate on 08/07/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No. 6 (Wing-B) – 1643.22sq.mtrs & (Wing- C) – 1596.02sq.mtrs.

With reference to above on 31/03/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Shakti Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Automatic Sprinkler System has been installed in entire building including car parking areas, lift lobby & common corridor at each floor level.
- C) Hose Reel Hose has been installed in every floor
- D) Hose Box has been installed in Alternate floor
- E) Siamese Connection has been installed in entrance gate
- F) Courtyard Hydrant has been installed in the building & prominent places.
- G) Mian Pump on under ground water storage tank.

- H) Booster Pump near over head water storage tank.
- I) Sprinkler Pump on under ground water storage tank.
- J) Diesel Generator Set
- K) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,90,000/- vide Receipt No. 187146; Rs. 5,80,000/- vide Receipt No. 187148 & Rs.5,80,000/- vide Receipt No. 187149 Dated:21/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates

2) Developer- M/s- Shakti Developers


Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/८३२/२०२९
दिनांक : २३/०७/२०२९



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. A1, (Stilt / Gr + 16 floor) located on land bearing S.No.296, 297, 298, 299, 303, 304, 324 & 390-B of Viliage: Bolinj, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/233/2021-22,
Dated:31/05/2021.

- 2) An application received by M/s- En Con Project Consultants, Dated:11/05/2021.
- 3) An application received by M/s- Viva Winner Venture Realtors LLP, Dated:11/05/2021
- 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/06/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/535/2016-17, Dated:30/09/2016.
- 6) Construction area certificate for M/s- En Con Project Consultants, Dated:11/06/2021.
- 7) Certificate from License Agency M/s- Bright Infra System Pvt Ltd, Dated:12/04/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:24/08/2020.
- 9) AMC Certificate by M/s- Viva Winner Venture Realtors LLP, Dated:05/06/2021
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:15/07/2021.
- 12) Structure Stability Certificate for M/s- Nimisha Structural Design Academy, Dated:27/03/2021
- 13) RDP issued by VVCMC/TP/RDP/VP-0059/097/2017-18, Dated:17/10/2017.
- 14) Submitted Electric Certificate M/s-Aim Realty Engineering Pvt Ltd, Dated:14/03/2021.
- 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:09/03/2021
- 16) C.F.O. site visit Dated:15/07/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential with Shopline Building No. A1, Stilt / Gr + 16 floor** in 49.85 mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Bright Infra System Pvt Ltd**, bearing License No. MFS-LA/2020/RF-166, MFS-LA/2020/RD-148 and has submitted Certificate on 12/04/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No. A1-5754.34sq.mtrs.

With reference to above on 31/03/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Viva Winner Venture Realtors LLP" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Automatic Sprinkler System has been installed in entire building including Each habitable room, fitness center, stilted car parking areas, lift lobby & common corridor at each floor level.
- C) Automatic Smoke Detection System has been installed in main console panel at ground floor level, provided in Electric meter room & lift machine room.
- D) Hose Reel Hose has been installed in every floor
- E) Hose Box has been installed in Alternate floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Mian Pump on under ground water storage tank.

- I) Jockey Pump on under ground water storage tank.
- J) Booster Pump near over head water storage tank.
- K) Sprinkler Pump on under ground water storage tank.
- L) Diesel Generator Set
- M) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 5,25,000/-, 5,25,000/-, 5,25,000/-, 5,25,000/-, 5,25,000/-, 80,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/- vide Receipt No.487412, 487413, 487415, 487416, 487417, 487414, 487418, 487419, 487420, 487421, 487422, 487423 DD.No.111939, 111943, 111942, 111941, 111938, 111940, 111948, 111949, 111947, 111944, 111946, 111945 (Vasai Vikas Sahakari Bank), Dated-29/08/2016. & Building No. T1 to T7 Rs.33,00,000/- vide Receipt NO. 487467, DD.No.084307 & Scrutiny Fees Rs.10,40,000/- vide Receipt No.487424, DD.No.033221 (Standard Chartered Bank) Dated:29/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants

2) Developer- M/s- Viva Winner Venture Realtors LLP

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 845/2020-2021

DATE: 28/01/2021.

FIRE & EMERGENCY DEPARTMENT

To,
Space Associates,
102, Ambika Commercial Complex,
NAVGHAR, VASAI (E).
TAL-VASAI, DIST-PALGHAR.

Sub:- Renewal of "Final No Objection Certificate" of "Space Heights", Residential Cum Commercial Building (Stilt/Ground + 7 Floors), Located on Land Bearing S. No. 49, H No. 6,8 of Village – Waliv, Tal- Vasai, Dist- Palghar.

- Ref:-**
1. An application received by M/s- Space Associates, Dated: 20/01/2021.
 2. Certificate from License Agency M/s- The Fire Protection Company, Dated:21/01/2021. (Form B).
 3. Submitted Fire Fighting Installation Photo Copy and Affidavit, Dated:21/01/2021.
 4. This office Final No Objection Certificate No. VVCMC/FIRE/HO/502/2017-18, Dated: 22/09/2017.
 5. Fire Officer Site Visit, Dated: 28/01/2021.

Dear Sir,

With reference to Sr.No.1 above, this office is in received of your application for your **Residential Cum Commercial Building (Gr/Stilt +7 Floors) "Space Heights", Located on Land Bearing S. No. 49, H No. 6,8 of Village – Waliv, Tal- Vasai, Dist- Palghar.** at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/RD-202 issued by this office and has submitted Certificate On 20/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal of Final No Objection Certificate" for your building.

This certificate shall be treated valid upto 1 Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1). Install M.C.P On each floor & Pressure Gauge on pump.

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.88,000/- vide Receipt No.895063. Dated: 23/01/2021,DD No.125649 Issued by Bharat Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT


Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 846/2020-21

DATE: 28/01/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" for Industrial Building No 4 (Gr Floor + 2 Floor (Pt) Located on land bearing S.No. 204, H No. 4/A, 4/B, S. No. 205 S. No. 208 H. No. 5, S. No. 213 H. No. 1/A, 1/B, 2 S. No. 214, H. No. 2,3, S. No. 215, H. No. 1 of Village: Gokhivare, Tal: Vasai, Dist: Palghar. (VP.No.6079)

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/128/2020-21, Dated:18/01/2021.
2) An application received by M/s-Ajay Wade And Associates, Dated: 13/01/2021.
3) Work Completion certificate of M/s- Ajay Wade And Associates, Dated: 13/01/2021.
4) Gross built up area certificate of M/s- Ajay Wade And Associates, Dated: 13/01/2021.
5) Structure Stability Certificate from M/s- Sameer Mohile And Associates, Dated: 14/01/2021.
6) Certificate from License Agency M/s- The Fire Protection Co., Dated: 06/01/2021, (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated: 05/10/2021
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 13/01/2021.
9) RDP issued by VVCMC/RDP/VP-6079/116/19-20 dated 25/09/2019.
10) Provisional NOC Issued By VVCMC/FIRE/HQ/844/2018-19, Dated: 22/10/2018.
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & License No. M.V.N./990/19012021/44840 to 44842 (3 Nos) Dated 22/01/21
12) Fire Officer site visit, Dated: 28/01/2021.

With reference to Sr.No.2 above, this office is in received of your application for **Industrial Building No. 4 Gr + 2 (pt) Floor only, in height 15.60 Mtrs.** only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2020/RF-228 & MFS-LA/2020/RD-202, has submitted Certificate on 6/1/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having **Gross built up area is 9424.12 sq. mtrs.**

This certificate shall be treated **valid upto one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Party has paid Capitation and Scrutiny fees of Rs. 10,00,000/- vide Receipt No. 714224 Dated 22/10/18 DD No.030270 Of Axis Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building essential.

Thanking you,



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

विभागीय कार्यालय, वसई
वसई, जि. ठाणे, पिन ४०१ २०१.



दूरध्वनी : ०२५०-२३०९०२०/२३२२२५८/२३२३३४३
२३२२०२१, रूग्णालय : २३२२१२०
फैक्स : ०२५०-२३०९८३५

जा. क्र. : व.वि.श.म/अग्नि/मुका/८५४/२०२०
दिनांक : २६/०७/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" Residential With Shopline Building No. 1, as Gr.+7) on land bearing S. No. 32A H.no.1A 1B Village: Sopara, Tal: Vasai, Dist: Palghar.(VP-5862)

Ref:-

- 1) A letter from Deputy Director Town Planning No.VVCMC/NR/922/2020-21, Dated:14/01/2021.
- 2) An application received by M/s- Ajay Wade & Associates, Dated: 01/01/2021.
- 3) Built up area certificate of M/s- Ajay Wade & Associates, Dated: 01/01/2021.
- 4) Work Completion certificate M/s- Ajay Wade & Associates, Dated: 01/01/2021.
- 5) Structure Stability certificate for M/s- Paresh Unnarkar, Dated :26/12/2020.
- 6) Certificate from license Agency M/s- Kinjal Enterprise, Dated:10/12/2020. (Form A)
- 7) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:01/01/2021.
- 8) Fire Provisional Noc VVCMC/FIRE/113/2017-18, Dated: 18/05/2017.
- 9) Issued by VVCMC/TP/RDP/VP-5862/52/2018-19 Dated 22/06/2018.
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & License No.990/33484, Dated:30/12/2019.
- 11) Site Visit date: 18/01/2021

With reference to Sr.No.1 above, this office is in receipt of your application for your Residential With Shopline Building No. 1, as Gr.+7) on land bearing S. No. 32A H.no.1A 1B, 24.00 Mtrs. at above mentioned address. Since the fire fighting Provided is installation by License Agency i. e M/s- Kinjal Enterprise bearing License No. MFS-LA/2020/RF-214/ MFS-LA/2020/RD-190 Dated:06/10/2020 Issued by MFS office and has submitted certificate on 10/12/2020 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Final No Objection Certificate" for your building. having built up area Building 2673.87 Sq.mtr.

This certificate shall be treated valid up to one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid Rs.2,00,000/- vide Receipt No.548176,DD.No. 313927, Dated 18/05/2017

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you.



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT


Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 855 /2020-21

DATE: 29/01/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub: "Final No Objection Certificate" of Industrial Building Basement+Gr.+2 (Pt) floors on land bearing bearing S.No.19, H.No.1/C Village Sativali Tal.Vasai, Dist.Palghar.

- Ref:** 1) A Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/141/2020-21
Dated:13/06/2020. (VP-3030)
2) An Application received from M/s- En Con Project Consultants,Dated:13/06/2020.
3) Gross Built up area certificate received from M/s- En Con Project Consultants, Dated:13/06/2020.
4) Work Completion certificate received from M/s- En Con Project Consultants,Dated:13/06/2020.
5) Structure Stability certificate for M/s- S.S. & ASSOCIATES, Dated:11/06/2020.
6) Certificate from License Agency M/s- RONAK FIRE INDUSTRIES Dated: 19/01/2021. (Form-A)
7) Submitted Affidavit & Fire Fighting Installation Photo copy, Dated: 28/12/2020.
8) Submitted License copy of Maharashtra Fire Services, Dated : 24/12/2020.
9) RDP Issued by VVCMC/TP/CC/VP-3030/88/2018-19 Dated: -17/07/2018.
10) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/899/2017-18
Dated:17/01/2018.
12) Fire officer Visit date:- 05/01/2021.

With reference to Sr. No.1 & 2 above, this office is in received of your application for Industrial Building Basement + Gr.+2 (Pt) Floors in 16.20 Mtrs. Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-RONAK FIRE INDUSTRIES bearing License No. MFS-LA/2020/RD-354 & MFS-LA/2020/RF-393 issued by this office and has submitted Certificate on 19/01/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 554.14 sq.mtrs.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C" will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life property if any, which may please be noted.

The Party has paid For Capitation & Scrutiny fees of Rs.1,70,000/- vide Receipt No.609543, D.D. No.028272 dated 16/01/2018.

The undersigned reserve right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from office is essential.**

Thanking you.



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to Architect-

PLEASE NOTE:- The Developer/Owner/Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the Licensed agencies is available on www.maharashtrafireservices.org or www.mfsindia.org.

विभागीय कार्यालय, वसई
वसई, जि. ठाणे, पिन ४०१ २०१.



दूरध्वनी : ०२५०-२३०९०२०/२३२२५८/२३२३३४३
२३२२०२१, रूग्णालय : २३२२१२०
फैक्स : ०२५०-२३०९८३५

जा. क्र. : व.वि.श.म/अग्नि/मुका/८५६/२०२०
दिनांक : २८/०९/२०२०

वसाई-विरार शहर महानगरपालिका
वसाई-विरार शहर महानगरपालिका
क. २९/११/२०२०

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential With Shopline Building No. 3, Wing .F (Gr/Stilt+14 Floor) in Sector – VI located on land bearing S. No. 49, 50,51,52,53,54,55,56, 57,77 & S.No.57, H.No. 1 of Village: Achole, Tal: Vasai, Dist: Palghar. (VP-0127)

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/586/2020, Dated: 27/10/2020.
2) An application received by M/s- EN Con Project Consultants, Dated: 17/10/2020 .
3) Work Completion certificate of M/s- EN Con Project Consultants, Dated: 17/10/2020.
4) Gross built up area certificate of M/s- EN Con Project Consultants, Dated: 17/10/2020.
5) Structure Stability Certificate for M/s-Jay Shree Krishna, Dated: 30/11/2016.
6) Certificate from License Agency M/s- Ronak Fire Industries, Dated : 28/08/2020, (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated: 24/12/2020 .
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 31/08/2020 .
9) RDP Issued by VVCMC/TP/RDP/VP-0127/344/2019-20, Dated: 17/03/2020 .
10) FIRE NOC Issued By VVCMC/FIRE/HQ/236/2014-15, Dated - 10/09/2014.
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & License मु.वि.नि.९९२५/२०१६ Dated: 06/02/2016 & मु.वि.नि.९८४६/२०१६ Dated: 06/02/2016
12) Site visit Dated :- 23/12/2020

With reference to Sr.No.2 above, this office is in received of your application for Residential With Shopline No. 3, Wing .F Gr/Stilt+14 Floor in Sector – VI located on land bearing S. No. 49, 50,51,52,53,54,55,56, 57,77 & S.No.57, H.No. 1, in height 43.85 Mtrs. only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Ronak Fire Industries bearing License No. MFS-LA/2020/RF- 393, MFS-LA/2020/RD- 354, MFS-LA/2020/RP- 84 issued by this office and has submitted Certificate on 24/12/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having Groos built up area for Industrial Building admeasuring to 5585.95 sq. mtrs.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid Rs. 2,00,750/- vide Receipt No. 226870 & Rs. 88,000/- vide Receipt No. 226871, Rs. 1,64,250/- vide Receipt No. 226872, Rs. 72,000/- vide Receipt No. 226873 Dated - 06/08/2014 .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage with inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building. If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you,



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect- En-Con Project Consultants
Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/८५५/२०२०

दिनांक : २६/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Lodging & boarding with shoplevel cum Commercial Building on land bearing S. No. 122, Ho6, of Village: Achole, Tal: Vasai, Dist: Palghar. (VP- 4035)

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/755/2020, Dated: 15/12/2020.
2) An application received by M/s- Shilplekha Consultant, Dated: 02/12/2020 .
3) Work Completion certificate of M/s- Shilplekha Consultant, Dated: 21/12/2019 .
4) Gross built up area certificate of M/s- Shilplekha Consultant, Dated: 02/12/2020.
5) Structure Stability Certificate for M/s- Shilplekha Consultant, Dated: 14/08/2020.
6) Certificate from License Agency M/s- Sadanand Fire Controls, Dated: 21/12/2020, (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated: 08/02/2020 .
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 16/01/2021.
9) Revised Provisional NOC Issued By VVCMC/Fire/HQ/650/2019, Dated-20/09/2019.
11) Site visit Dated :- 23/12/2020

With reference to Sr.No.2 above, this office is in received of your application for of Lodging & boarding with shoplevel cum Commercial Building on land bearing S. No. 122, Ho6, Gr.+4 Floor, in height 19.20 Mtrs. only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems bearing License No. MFS-LA/2020/RF- 68, issued by this office and has submitted Certificate on 08/02/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having Groos built up area for Industrial Building admeasuring to 737.77 sq. mtrs.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid Rs.80,000/- vide Receipt No. 818498, DD No.001241, Dated - 18/09/2019, of Bassein Catholic Co-op Bank .

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you,



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect- En-Con Project Consultants

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./ग्रामि/मुका/८७७/२०२०

दिनांक : ०४/०२/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub: "Final No Objection Certificate" of Residential with Shopline Building No.12, Wing A & B, (Gr./Stilt+12) floors located on land bearing S.No. 110,H.no.4,S.No.111,H.No.3,9,13 & 14, S.no.127,H.no.2,S.no.128 H.no.13 & S.no.352 of Village Virar , Tal - Vasai, Dist. Palghar.

- Ref: 1) A Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/690/2020-21, Dated: 23/11/2020. (VP-0002)
- 2) An Application received from M/s- En Con Project Consultants, Dated: 09/11/2020
 - 3) Gross Built up area certificate received from M/s- En Con Project Consultants, Dated: 9/11/2020.
 - 4) Work Completion certificate received from M/s- En Con Project Consultants, Dated: 9/11/2020.
 - 5) Structure Stability certificate for M/s- Pro-tech consultants , Dated: 10/11/2020.
 - 6) Certificate from License Agency M/s- Sadanand Fire Controls, Dated: 21/12/2020. (Form-A)
 - 7) Submitted Affidavit & Fire Fighting Installation Photo copy, Dated: 16/01/2021.
 - 8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Licence, मु.वि.नि/06858/Dated 1/2/2018 & मु.वि.नि/06848/Dated 1/2/2018
 - 9) Submitted License copy of Maharashtra Fire Services, Dated : 08/02/2020.
 - 10) FIRE Provisional NOC ISSUED BY VVCMC/FIRE/HQ/2099/2019, Dated: 31/12/2019.
 - 11) Site Visit date: 23/12/2020.

With reference to Sr. No.2 & 3 above, this office is in received of your application for your Residential with Shopline No.12, Wing A & B, Gr./Stilt+12 floors located on land bearing S.No. 110,H.no.4,S.No.111,H.No.3,9,13 & 14, S.no.127,H.no.2,S.no.128 H.no.13 & S.no.352 in 38.55 Mtrs. Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Controls bearing License No. MFS-LA/2020/RF-68 issued by this office and has submitted Certificate on 08/02/2020 in "From A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 7516.45 sq. mtrs.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C" will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life property if any, which may please be noted.

The Party has paid Fees of Rs.6,80,000/- vide Receipt No. 818767, Dated - 30/11/2019 & Paid Fees Of Rs.26,000/- vide Receipt No. 895085, D.D No. 205888 Of RBL Bank Dated - 01/02/2021

The undersigned reserve right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

PLEASE NOTE:- The Developer/Owner/Occupier have to Renew the N.O.C. after every one year & submit Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra. The list of the Licensed agencies is available on www.maharashtrafireservices.org or www.mfsindia.org.

the next testing
July of every year.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-

2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/883/2020-2021

DATE: 08/02/2021.

FIRE & EMERGENCY DEPARTMENT

To,
Desai Plastics Private Limited.
Plot No.50A, Survey No.104A
Vasai Municipal Ind Area, Umela Road,
Vasai (West), Dist-Palghar,
Maharashtra-401207,

Sub:-Renewal of "Final No Objection Certificate" Of Industrial Building On Plot No.50A, S.No.104A Of Village Dhowali, Tal- Vasai, Dist- Palghar.

Ref:- 1. An application received by M/s- Desai Plastics Private Limited, Dated: 25/01/2021.
2. Certificate from License Agency M/s- The Fire Protection Company, Dated: 14/01/2021.

(Form B).

3. Submitted Fire Fighting Installation Photo Copy and Affidavit, Dated: 07/01/2021
4. This office Final No Objection Certificate No.VVCMC/FIRE/HO/950/2019-20, Dated:15/11/2019.
5. Fire Officer Site Visit, Dated: 04/02/2021.

Dear Sir,

With reference to Sr.No.1 above, this office is in received of your application for your Industrial Building On Plot No.50A, S.No.104A Of Village:Dhowali, Tal- Vasai, Dist- Palghar. (Gr+1Floors) in height 10.60 Mtr at above mentioned address. Since the fire fighting maintenance provided by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/RF-228MFS-LA/RD-202 issued by this office and has submitted Certificate On 14/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal of Final No Objection Certificate" for your building. Its valid upto 31st December 2021

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Renewal fees of Rs 10,000/- DD No vide.023960, Receipt No.895083, Dated- 01/02/2021 of Bassien Catholic Co-Op Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फॅक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : व.वि.श.म./अग्नि/मुका/९०६/२०२१

दिनांक : ३१/०७/२०२१.



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Industrial / Commercial Building located on land bearing S.No.74, H.No.1, S.No.2 & 3 of Village: Bapane, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/374/2021-22, Dated: 29/06/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated: 22/06/2021.
 - 3) An application received by Developer Mrs. Manjula M. Sangoi, Dated: 22/06/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated: 22/06/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1139/2020-21, Dated: 31/03/2021.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated: 23/03/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated: 22/06/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated: 06/10/2020.
 - 9) AMC Certificate by Developer Mrs. Manjula M. Sangoi, Dated: 22/06/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 07/10/2021.
 - 12) Structure Stability Certificate for M/s- S. S & Associates, Dated: 06/07/2020
 - 13) RDP issued by VVCMC/TP/RDP/VP-5907/34/2021-22, Dated: 15/04/2021.
 - 14) Submitted Electric Certificate, Dated: 28/07/2021.
 - 15) Diesel Engine Test Certificate of M/s- Stamford, Dated: 15/01/2017.
 - 16) C.F.O. site visit Dated: 31/07/2021.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your 2nd Floor (Part) & 3rd Floor (Part) Industrial / Commercial Building (Gr + 3 floor) in 19.50mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 22/06/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9036.55sq.mtrs.

With reference to above on 31/07/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mrs. Manjula M. Sangoi" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in Lift machine room, Electric meter room, Pump room, every floor & prominent places.
- B) Hose Reel Hose has been installed in every floor – 10 Nos.
- C) Hose Box has been installed in Alternate floor – 9 Nos.
- D) Siamese Connection has been installed in entrance gate
- E) Down Comer
- F) Courtyard Hydrant has been installed in the building & prominent places.
- G) Mian Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.
- I) Smoke Detectors – 154 Nos.
- J) Diesel Generator Set
- K) Manual Operated Electrical Fire Alarm System.

THAN
ENION

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 10,00,000/- vide Receipt No.601193, DD.No.650852 (Bank of Maharashtra), Dated-24/10/2017.

The Party has paid Rs. 5,00,000/- vide Receipt No. 601193, DD.No.650852 (Bank of Maharashtra).

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants

2) Developer- Mrs. Manjula M. Sangoi

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 912 /2020-21

DATE: 10/02/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" for Residential Building with Shopline No 1 Wing A in Sector No. I (Gr/Stilt Floor + 14 Floors) Located on land bearing S.No. 49, 50,51,52,53,54,55,56,77 & S. No. 57 H.No. 1 of Village: Achole. Tal: Vasai, Dist: Palghar. (VP.No.0127)**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./NR/970/2020-21, Dated: 02/02/2021.
2) An application received by M/s-Encon Project Consultants, Dated: 14/01/2021.
3) Work Completion certificate of M/s- Encon Project Consultants, Dated: 14/01/2021.
4) Gross built up area certificate of M/s- Encon Project Consultants, Dated: 14/01/2021.
5) Structure Stability Certificate from M/s- ProTech Consultants, Dated: 18/09/2020.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated: 24/09/2020, (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated: 05/11/2021
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 03/02/2021.
9) RDP issued by VVCMC/RDP/VP-0127/067/15-16 dated 09/06/2015.
10) Provisional NOC Issued By VVCMC/FIRE/HQ/729/2018-19, Dated: 06/10/2018.
11) Fire Officer site visit, Dated: 04/02/2021.

With reference to Sr.No.2 above, this office is in received of your application for **Residential Building with Shopline No. 1 (Gr/Stilt + 14 Floors), in height 43.85 Mtrs.** only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2019/RF-282 & MFS-LA/2019/RD-259 , issued by this office and has submitted Certificate on 24/9/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having **Gross built up area is 7055.41 sq. mtrs.**

This certificate shall be treated **valid upto one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Party has paid Capitation and Scrutiny fees of Rs. 5,25,000/- vide Receipt No. 487316 Dated 21/06/16 DD No.011824 Of Corporation Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building essential.

Thanking you,



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org





VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT


Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 914 /2020-21

DATE: 10/02/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Automobile Shops & Godowns (Unit No. 69) (Stilt + Gr + 1 Floor) Located on land bearing S.No.69, H.No. 1 (pt) S No. 71 H. No. Pt &S. No. 213, H. No. 2(p) & S. No. 72 + 75/1 + 75/2 + 77/1 (P) + 77/2 + 65 + 69/1 + 70 + 71 (P) of Village: Pelhar, Tal: Vasai, Dist: Palghar. (VP.No.898 & 5224)

- Ref:-** 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/757/2020-21, Dated: 01/02/2021.
2) An application received by M/s-Himesh Gupta & Associates, Dated: 27/01/2021.
3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated: 22/01/2020.
4) Gross built up area certificate of M/s-Himesh Gupta & Associates, Dated: 22/01/2021.
5) Structure Stability Certificate from M/s- S & S Associates, Dated: 15/01/2021.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated: 11/01/2021, (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated: 05/10/2021
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 19/01/2021.
9) CC Issued by VVCMC/TP/RDP/VP-0898/52/2018-19, Dated: 19/05/2018.
10) Provisional NOC Issued By VVCMC/FIRE/HQ/254/2017-18, Dated: 01/07/2017.
12) Fire Officer site visit, Dated: 28/01/2021.

With reference to Sr.No.2 above, this office is in received of your application for Automobile Shops & Godowns (Unit No. 69) (Stilt + Gr + 1 Floor), in height 12.55 Mtrs. only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/RD-259 & MFS-LA/RF-282 , issued by this office and has submitted Certificate on 11/01/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having Gross built up area is 458.57 sq. mtrs.

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Party has paid Capitation and Scrutiny fees of Rs. 80,000/- vide Receipt No. 572109, Dated: 07/06/2017 DD No. 153521.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building essential.

Thanking you,



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect--Himesh Gupta & Associates.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/२२५/२०२१

दिनांक : ११/०२/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Vidya Vikas Education Trust,
Filka Building, Daftary Road,
Opp Railway Station,
Malad (E), Mumbai-400 097.

Sub:-Renewal of "Final No Objection Certificate" of Technical Campus Faculty of Engineering, Faculty of Management & Architecture phase-1 Collage (Gr+5pt Storey) on land bearing S.No.146(PT), of Village:Kaman, Tal- Vasai, Dist- Palghar.

- Ref:- 1) An application received by M/s-Vidya Vikas Education Trust, Dated:27/01/2021
2) This office Provisional No Objection Certificate No.VVCMC/FIRE/HQ/865/2016-17, Dated:11/01/2017
3) This office Final No Objection Certificate No. VVCMC / FIRE / HQ / 1095 / 2019, Dated:19/12/2019
4) Occupancy Certificate issued by VVCMC / TP / OC / VP-0205 / 135 / 2019 - 20, Dated:18/01/2020
5) Certificate from License Agency M/s- Win Fire Services, Dated:13/01/2021 (Form B)
6) Submitted License copy of Maharashtra Fire Services, Dated:29/06/2019.
7) Submitted Fire Fighting Installation Photo Copy, Dated:27/01/2021
8) Fire Officer site visit Dated:02/02/2021

With reference to Sr.No.1 above, this office is in received of your application for your Technical Campus Faculty of Engineering, Faculty of Management & Architecture phase-1 Collage at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Win Fire Services bearing License No. MFS-LA/2020/RD-192 & MFS-LA/2020/RF-216 issued by this office and has submitted Certificate On 13/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 1,25,000/-, vide Receipt No. 895101, Book No. 8952, Dated:08/02/2021, DD No. 503447, Issued by Indian Overseas Bank, renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 937 /2020-21

DATE: 18/02/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Transit Godowns, Building NO. 2 (Gr + 1 (Pt) Floor), Building No. 3 – Ground Floor Located on land bearing S.No.1, H.No. 2, 1/3 of Village: Kaman, Tal: Vasai, Dist: Palghar. (VP.No.5979)**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/967/2020-21, Dated: 01/02/2021.
2) An application received by M/s-Himesh Gupta & Associates, Dated: 22/01/2021.
3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated: 22/01/2020.
4) Gross built up area certificate of M/s-Himesh Gupta & Associates, Dated: 22/01/2021.
5) Structure Stability Certificate from M/s- S & S Associates, Dated: 29/01/2021.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated: 11/01/2021, (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated: 05/10/2021
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 12/01/2021.
9) RDP Issued by VVCMC/TP/RDP/VP-5979/217/2018-19, Dated: 12/02/2019.
10) Provisional NOC Issued By VVCMC/FIRE/HQ/930/2017-18, Dated: 29/01/2018.
12) Fire Officer site visit, Dated: 28/01/2021.

With reference to Sr.No.2 above, this office is in received of your application for **Transit Godowns, Building NO. 2 (Gr + 1 (Pt) Floor- 10.60 mtr), Building No. 3 – Ground Floor, in height 5.60 Mtrs.** only at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/RD-259 & MFS-LA/RF-282, issued by this office and has submitted Certificate on 11/01/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building no. 2 having **Gross built up area is 2784.80 sq. mtrs and** building no. 3 having **Gross built up area is 108.62 sq. mtrs**

This certificate shall be treated **valid upto one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

Party has paid Capitation and Scrutiny fees of Rs. 3,00,000/- vide Receipt No. 609561, DD No. 158531, Dated 23/01/2018 (for building no 2), Rs. 80,000/- vide Receipt No. 609562, DD No. 158528, Dated 23/01/2018 (for building no 3) of Syndicate Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building essential.

Thanking you,



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to Architect--Himesh Gupta & Associates.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT


Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 938 /2020-21

DATE: 18/02/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Godown Building No6 Ground+2(Pt) Floors located on land bearing S No. 129 H. No.2 S. No. 130A, H. No. 2 (Pt.) & 3 (Pt.) of Village: Rajivali, Tal: Vasai, Dist: Palghar.(Vp.No-5478)

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/768/2020-21, Dated: 02/12/2021.
2) An application received by M/s- En Con Project Consultants, Dated: 14/01/2021.
3) Work Completion certificate of M/s- En Con Project Consultants, Dated: 14/01/2021.
4) Gross built up area certificate of M/s- En Con Project Consultants, Dated: 14/01/2021.
5) Structure Stability Certificate for M/s- SS & Associates, Dated: 20/01/2021.
6) Certificate from License Agency M/s-The Fire Protection Company, Dated: 07/12/2020 (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated: 05/10/2021.
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: / /2021.
9) RDP Issued by VVCMC/TP/RDP/VP-5478/195/2018-19, Dated: 22/01/2019.
10) Provisional Fire Noc Issued By VVCMC/FIRE/HQ/196/2016-17, Dated: 17/06/2016
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated: 08/12/2020.
12) Fire officer site visit, Dated : 04/02/2021.

Dear Sir,

With reference to Sr.No.2 above, this office is in received of your application for your **Godown Building No6 Ground+2(Pt) Floors in 12.85 Mtrs. Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/RF-228, MFS-LA/RD-202 issued by this office and has submitted Certificate on 11/11/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to **467.39 sq. mtrs.**

This certificate shall be treated **valid upto one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid Capitation And Scrutiny Rs. 80,000/- Vide Receipt No. 425812, DD No.015362 dated 15/02/2016 of Shamrao Vitthal Co-op Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you.



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to Architect- En Con Project Consultants.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.प./अग्नि/मुका/१६५/२०२१
दिनांक : २३/०२/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Cardinal gracias memorial Hospital trust,
Bangli, Sandor, P.O. Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub: - Renewal of "Final No Objection Certificate" of Hospital Building, Located at Bangli naka, sandor, Vasai (W), Tal- Vasai, Dist-Palghar.

- Ref :-** 1. An application received by M/s- Cardinal gracias memorial Hospital trust,
Dated: 06/02/2021
2. Certificate from License Agency M/s- FIREBIRD FIRE SERVICES, Dated: 06/02/2021 (Form B).
3. Submitted Fire Fighting Installation Photo Copy, Dated: 06/02/2021
4. This office Renewal No objection Certificate No. VVCMC / FIRE/2237/2020,
Dated: 05/03/2020

Dear Sir,

With reference to Sr.No.1 above, this office is in received of your application for your **Hospital Building Located at Bangli Naka, Sandor, Vasai (W) Tal- Vasai, Dist – Palghar**. The Hospiat Building Gr+3 Floor is completed fully occupied at site. License Agency i.e. M/s- FIREBIRD FIRE SERVICES bearing License No. MFS-LA/2021/RF-26, MFS-RD/2021/RD-20 issued by this office and has submitted Certificate On 08/01/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal of Final No Objection Certificate" for your building.

This certificate shall be treated valid up to One year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 60,000/- vide Receipt No. 895143, dated 18/02/2021 ssued by Bank of India renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1014/2020-21

DATE: 05/03/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Industrial Building No 1 (Wing B&C), Industrial Building No. 2 (Wing A & B) Ground+2 Floors located on land bearing S No. 72 H. No.1 & 2 of Village: Bapane, Tal: Vasai, Dist: Palghar.(Vp.No-2840)

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/1081/2020-21, Dated: 22/02/2021.
2) An application received by M/s- En Con Project Consultants, Dated: 05/02/2021.
3) Work Completion certificate of M/s- En Con Project Consultants, Dated: 05/02/2021.
4) Gross built up area certificate of M/s- En Con Project Consultants, Dated: 05/02/2021.
5) Structure Stability Certificate for M/s- SS & Associates, Dated: 13/02/2021.
6) Certificate from License Agency M/s-The Fire Protection Company, Dated: 01/02/2021 (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated: 05/10/2021.
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/02/2021.
9) CC Issued by VVCMC/TP/CC/VP-2840/169/2018-19, Dated: 26/10/2018.
10) Provisional Fire Noc Issued By VVCMC/FIRE/HQ/206/2018-19, Dated: 09/06/2018
11) Electrical Contractor Certificate of ISI Standard by M/s Khodiyar Electricals dated 06/02/2021
12) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated: 04/02/2021.
13) Fire officer site visit, Dated :-04/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Industrial Building No 1 (Wing B&C) Building No 2 Wing (Wing A&C) Ground+2 Floors in 15.60 Mtrs. Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/RF-228, MFS-LA/RD-202 issued by this office and has submitted Certificate on 01/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009 This office is issuing a "Final No Objection Certificate" for your building no 1 (Wing B&C) having built up area admeasuring to 2456.71 sq. mtrs, building no 2 (Wing A&B) having built up area admeasuring to 1272.68 sq. mtrs

This certificate shall be treated valid upto one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid Capitation And Scrutiny Rs. 8,30,000/- Vide Receipt No. 672733, DD No.541211 dated 24/05/2018 for Industrial Building No 1 (Wing A, B & C), Building No 2 (Wing A & B) & Building No 3 (Wing A & B)

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you.



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect- En Con Project Consultants.

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मु.का/१०१५/२१-२२
दिनांक : ०६-०६-२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Cosmos Prime Projects Ltd,
Cosmos Group, First Floor,
Poonam Arena Building,
Poonam Nagar, Near New Viva Collage,
Virar (W), Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Residential Building Known as "COSMOS REGENCY" Wing-J, Building No.2, Sector-3, H.D.I.L Layout, of Village:Chikhal Dongare Virar (W), Tal- Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s-Cosmos Prime Projects Ltd,
Dated:18/06/2021.
2) Certificate from License Agency M/s- Viva Enterprises, Dated:21/06/2021 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy,
Dated: 20/07/2021.
4) Submitted Final No Objection Certificate No. VVCMC/FIRE/HQ/871/2019,
Dated:24/10/2019.
5) Submitted Provisional No Objection Certificate No. VVCMC/FIRE/266/2012 /13, Dated:11/03/2013.
6) Submitted License copy of Maharashtra Fire Services, Dated:15/01/2021.
7) C.F.O site visit Dated: 20/07/2021.

With reference to Sr.No.1 above, this office is in received of your application for your Residential Building No. 2 (Wing-J) (Gr/Stilt + 12 Floors) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Viva Enterprises. bearing License No. MFS-LA/2021/RF-43, MFS-LA/2021/RD-34 and has submitted Certificate On 21/06/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 78,000/- vide Receipt No. 895530, Book No. 8956, DD No.491681 (Axis Bank) Dated:09/07/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

7/8/2021
9324279771



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect / Developer-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मका/१०१६/२१-२२
दिनांक : ०६-०६-२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Cosmos Prime Projects Ltd,
Cosmos Group, First Floor,
Poonam Arena Building,
Poonam Nagar, Near New Viva Collage,
Virar (W), Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Residential with Shopline Building Known as "COSMOS SOLITAIRE" Wing-E, Building No.3, Sector-2, H.D.I.L Layout, of Village:Chikhal Dongare Virar (W), Tal- Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s-Cosmos Prime Projects Ltd,
Dated:18/06/2021.
2) Certificate from License Agency M/s- Shree Fire Guard Co.,
Dated:11/06/2021 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy,
Dated: 20/07/2021.
4) Submitted Final No Objection Certificate No. VVCMC/FIRE/HQ/994/2019,
Dated:09/12/2011.
5) Submitted Provisional No Objection Certificate No. VVCMC/FIRE/147/2011
/12, Dated:09/12/2011.
6) Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
7) C.F.O site visit Dated: 20/07/2021.

With reference to Sr.No.1 above, this office is in received of your application for your Residential with Shopline Building No.3 (Wing-E) (Gr/Stilt + 12 Floors) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree Fire Guard Co. bearing License No. MFS-LA/2020/RF-270, MFS-LA/2020/RD-243 and has submitted Certificate On 11/06/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 2,52,000/- vide Receipt No. 895531, Book No. 8956, DD No.491680 (Axis Bank) Dated:09/07/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **if any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect / Developer-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

7/8/2021
9324279771

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/१४६६/१०१६/२१-२२
दिनांक : ०६-०६-२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Cosmos Associates,
Cosmos Square,
Chikhal Dongre Road,
Near Mc Donalds, Global City,
Virar (W), Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Residential with Shopline Building Known as "COSMOS LEGEND" Wing-A & B, Building No.1, Sector-7, H.D.I.L Layout, of Village:Chikhal Dongare Virar (W), Tal- Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s-Cosmos Associates,
Dated:18/06/2021.
2) Certificate from License Agency M/s- Shree Fire Guard Co,
Dated:11/06/2021 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy,
Dated: 20/07/2021.
4) Submitted Final No Objection Certificate No. VVCMC/FIRE/HQ/3069/2018,
Dated:15/02/2019.
5) Submitted Provisional No Objection Certificate No. VVCMC/FIRE/266A/
2012-13, Dated:11/03/2013.
6) Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
7) C.F.O site visit Dated: 20/07/2021.

With reference to Sr.No.1 above, this office is in received of your application for your Residential with Shopline Building No. 1 (Wing-A & B) (Gr/Stilt + 15 Floors) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree Fire Guard Co. bearing License No. MFS-LA/2020/RF-270, MFS-LA/2020/RD-243 and has submitted Certificate On 11/06/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 4,01,400/- vide Receipt No. 895529, Book No. 8956, DD No.019548 (Axis Bank) Dated:09/07/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

9/8/2021
9324279771

Copy to Architect / Developer-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



[Signature]

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७


ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१०६५/

दिनांक : १६/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" for Residential With Shopline Building No. 1, Wing – F, Plot-A (Part Stilt+Part Gr.+7) bearing S.No.278, Part, S.no.280, S.No. 282, H.No. 1, S.No. 283
Village: Nilemore, Tal: Vasai, Dist: Palghar.

Ref:-

- 1) A letter from Deputy Director Town Planning No. VVCMC/NR/1061/2020, Dated:17/02/2021.
- 2) An application received by M/s-Abhay Raut , Dated: 06/12/2020.
- 3) Built up area certificate of -Abhay Raut , Dated: 06/12/2020, Dated: 06/12/2020.
- 4) Work Completion certificate M/s-Haresh L.patel , Dated: 14/12/2020.
- 5) Structure Stability certificate for Haresh L.patel Engineers, Dated: 14/12/2020.
- 6) Certificate from license Agency – M/s.Kinjal Enterprise, Dated: 22/10/2020. (Form A)
- 7) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 18/12/2020.
- 8) License to work the Lift From Govt. of Maharashtra Industries, Energy & License, Dated: 17/11/2020.
- 9) Govt. Approval Electric Licensed – M/s.SMB Electricals, Dated – 17/12/2020.
- 10) Fire Provisional Noc. VVCMC/FIRE/730/2017-18, Dated: 18/11/2019.
- 11) RDP Issued by VVCMC/TP/RDP/VP-0041, Dated- 10/12/2018.
- 12) C.F.O. site visit Dated :- 09/03/2021.

With reference to Sr.No.1 above, this office is in receipt of your application for your Residential With Shopline Building No. 1, Wing – F, Plot-A (Part Stilt+Part Gr.+7), 23.92 Mtrs. in height at above mentioned address. Since the fire fighting Provided is installation by License Agency i. e M/s.Kinjal Enterprise bearing License No. MFS/RF-214, MFS- RD-190 Dated: 06/10/2020 Issued by MFS office and has submitted certificate on 22/10/2020 in "Form A" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Final No Objection Certificate" for your building. having built up area admeasuring to 1313.79 Sq.mtr.

This certificate shall be treated valid up to one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer or nominated officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by you in the premises shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid Rs.200000/- vide Receipt No.590365 Dated – 06/09/2017, DD no.021446 Of Axis Bank

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the company. **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१०६६/२०२१
दिनांक : १६/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No.1 Wing-B (Stilt/Gr+7 Floors located on land bearing CTS No.2626, 2628-B, 2646-A, 2684-B, 2685 & 2686-A(Old), 2626-A, 2626-B, 2628-B, 2646-A/1, 2646-A/2, 2684-B, 2685-A, 2685-B, 2686-A/1, 2686-A/2, 2686-A/3(New) of Village:Dhivali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1132/2020-21, Dated:25/02/2021.
2) An application received by M/s- En Con Project Consultants, Dated:22/02/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:22/02/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:22/02/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/095/2015-16, Dated:20/07/2015
6) Certificate from License Agency M/s-The Fire Protection Company, Dated:15/02/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:15/02/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:22/02/2021.
11) RDP issued by VVCMC/TP/RDP/VP-5157/088/2015-16, Dated:02/07/2015
12) Submitted M/s-Dishant Electrical Service, Dated:17/03/2021
13) C.F.O. site visit Dated:15/02/2020.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building (Wing-B) (Stilt/Gr.+ 7) in 24.00Mtrs. Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2019/RD-202, MFS-LA/2019/RF-228 and has submitted Certificate on 15/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 1537.16 sq.mtrs.

This certificate shall be treated **valid upto one Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/- vide Receipt No. 265652, DD No. 780457 (ING Vysya Bank Ltd) Dated- 01/10/2014, Rs. 1,20,000/- vide Receipt No. 265653, DD.No. 009217(Bassein Catholic Bank) Dated- 01/10/2014 & Rs. 4,00,000/-, vide Receipt No. 265655, DD.No.009216 (Bassein Catholic Bank) Dated:01/10/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.प./अग्नि/मुका/१०७६/२०२१
दिनांक : १०/०८/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No. 18, (Wing-A & B) (Gr+7 floor) located in Sector II of Village: Dongare, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/442/2021-22, Dated:13/07/2021.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:26/07/2021.
 - 3) An application received by M/s- Shubh Shwet Developers, Dated:26/07/2021
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:26/07/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/915/2019-20, Dated:05/10/2019.
 - 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:26/07/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated:15/04/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 9) AMC Certificate by M/s- Shubh Shwet Developers, Dated:26/07/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:02/08/2021.
 - 12) Structure Stability Certificate for M/s- Shilplekha Consultants, Dated:31/03/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0880/037/2014-15, Dated:15/05/2014.
 - 14) Submitted Electric Certificate M/s-Jignesh vidyut Service & Electrical Contractor, Dated:10/05/2021.
 - 15) Diesel Engine Test Certificate of M/s- Mahindra Powerol, Dated:23/02/2021
 - 16) C.F.O. site visit Dated:02/08/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building No. 18 (Wing-A & B) Gr + 7 floor** in 23.60 mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-220** and has submitted Certificate on 15/04/2021 in "Form A" Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 5242.32sq.mtrs.

With reference to above on **02/08/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Shubh Shwet Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Down Commer has been installed in every floor
- G) Mian Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.
- I) Diesel Generator Set
- J) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 4,00,000/- vide Receipt No.187161, Dated-24/06/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates

2) Developer- M/s- Shubh Shwet Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१०८५/२०२१

दिनांक : २३/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Ameya Builders & Property Developers,
M.Baria Business House,
P.P.Marg, Virat Nagar,
Virar (W),
Tal-Vasai, Dist-Palghar,

Sub:- Renewal of "Final No Objection Certificate" of Residential with Shopline Building No.1 (Wing A & B) (Stilt / Gr + 7 floor) on Plot bearing S.No.4, H.No.5 (CTS No.328), S.No.5, H.No.1, (CTS.No.329) & S.No.34, H.No.2 (CTS No.331B), 41/7 & 41/8) situated at Village-Malonde, Tal-Vasai, Dist-Palghar.

Ref:-1) An application Received by M/s- Ameya Builders & Property Developers, Dated:20/10/2020.

2) This Office Renewal of Final No Objection Certificate No. VVCMC/FIRE/HQ/832, Dated:03/01/2017.

3) This Office Provisional No Objection Certificate No.VVCMC/FIRE/051/2015-16, Dated:08/07/2015.

4) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:27/10/2020

5) Submitted Affidavit & Fire Fighting Installation photo copy, Dated:27/10/2020

6) Submitted License copy of Maharashtra Fire Services, Dated:08/07/2020

7) Part Occupancy Certificate No.VVCMC/TP/POC/CP-0530/146/2015-16, Dated:01/10/2015.

8) C.F.O. site visit, Dated: 22/03/2021

With reference to Sr.No.1 above, this office is in received of your application for your Residential with Shopline Building No.1 (Wing- A & B) (Stilt / Gr + 7 Floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services bearing License No. MFS/LA/2019/RF-404 & MFS/RD/2019/RD-376 and has submitted Certificate On 27/10/2020 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal of Final No Objection Certificate" for your building.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1). Install Sprinkler, Smoke Detector & M.C.P On each floor & Pressure Gauge on pump.

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid fire cess fees Rs. 1,36,000/- vide Receipt No.895269, Book No.8953, DD.No. 118109 (Vasai Vikas Sahakari Bank) Dated:23/03/2021 renewal fees for the said building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आम/मुका/1096
दिनांक : 25/03/2021

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Local Resource Based Industry (Ice Factory) Building No.1, 2, 3, 4 (Gr + 1Pt Floor) & CFC Building (Gr Floor) located on land bearing S No.31, H.No.6 of Village: Bilalpada, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1201/2020-21, Dated:08/03/2021.
2) An application received by M/s- Himesh Gupta & Associates, Dated:02/02/2021.
3) Gross Built up area certificate of M/s- Himesh Gupta & Associates, Dated:02/02/2021.
4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated:02/02/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/449/2018-19, Dated:21/08/2018
6) Certificate from License Agency M/s-The Fire Protection Company, Dated:05/03/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/03/2021.
10) Structure Stability Certificate for M/s- Finite Consultants, Dated:18/02/2021.
11) RDP issued by VVCMC/TP/RDP/VP-5344/142/2018-19, Dated:01/11/2018
12) Submitted M/s- S.S.Electricals & Engineers, Dated:13/03/2021.
13) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Local Resource Based Industry (Ice Factory) Building No. 1, 2, 3, 4 (Gr + 1 Floor) in height 10.60mtr & CFC (Ground Floor) in height 2.55mtr. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 05/03/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area for Building No.1 - 372.19sq.mtr, Building No.2 - 413.08sq.mtr, Building No.3 - 446.33sq.mtr, Building No.4 - 518.82sq.mtr & CFC Building 73.47sq.mtr.

This certificate shall be treated **valid upto one Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 572192, DD No. 014836, Rs.80,000/- vide Receipt No.572193, DD.No.014837, Rs.80,000/- vide Receipt No.572194, DD.No.014838, Rs.80,000/- vide Receipt No.572195, DD.No.014839, Rs.80,000/- vide Receipt No.572196, DD.No.973892, Dated:18/07/2017 of Kotak Mahindra Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org


मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/१११२
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential Building No. 1 (Wing- A) as (Gr + 7 Floor) on land bearing S No.286 (Old), S.No.4 (New), H.No.3 of Village: Chandansar, Tal: Vasai, Dist: Palghar.

- Ref:-** 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1106/2020-21, Dated:23/02/2021.
2) An application received by M/s- Ajay Wade & Associates, Dated:13/01/2021.
3) Built up area certificate of M/s- Ajay Wade & Associates, Dated:13/01/2021.
4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:13/01/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/238/2016-17, Dated:29/06/2016.
6) This Office Provisional No Objection Certificate No.VVCMC/FIRE/HQ/834/2017-18, Dated:29/12/2017
7) Certificate from License Agency M/s-Fire Protection Company, Dated:24/11/2020 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/11/2020.
11) Structure Stability Certificate for M/s- S. S & Associates, Dated:02/11/2020.
12) RDP issued by VVCMC/TP/RDP/VP-5168/235/2019-20, Dated:04/12/2019
13) Submitted Electric Certificate M/s- R.R. Electricals, Dated:17/09/2020.
14) C.F.O. site visit Dated:08/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential Building No. 1 (Wing- A) (Gr.+ 7 Floor) in 23.40mtr Height.** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on 24/11/2020 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 2006.33sq.mtrs.

This certificate shall be treated **valid upto one Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.


Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No. 425856, DD.No. 110895, Dated: 03/03/2016 & Rs.1,20,000/- vide Receipt No. 425857, DD.No. 110893, Dated: 03/03/2016 of Vasai Viakas Sahakari Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org


मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आम/मुका/१११३
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No.2 on land bearing S No.46, H.No.2/7, (Old), S.No.46F, H.No.1, 2 & 3 (New) of Village: Bilalpada, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1142/2020-21, Dated:02/03/2021.
2) An application received by M/s- Ajay Wade & Associates, Dated:16/02/2021.
3) Built up area certificate of M/s- Ajay Wade & Associates, Dated:16/02/2021.
4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:16/02/2021.
5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/272/2019-20, Dated:26/08/2019.
6) Certificate from License Agency M/s-Fire Protection Company, Dated:26/12/2020 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/02/2021.
10) Structure Stability Certificate for M/s- Paresch Unnarkar, Dated:06/02/2021.
11) RDP issued by VVCMC/TP/RDP/VP-5315/359/2019-20, Dated:18/03/2020
12) Submitted Electric Certificate M/s- Zip Engineers, Dated:08/03/2021.
13) C.F.O. site visit Dated:08/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No. 2 (Gr.+ 2 Floor) in 15.60Mtrs** Height. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 26/12/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 6969.87sq.mtrs.

This certificate shall be treated **valid upto one Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 5,00,000/- vide Receipt No. 609540, DD No. 124006, (Bharat Bank) Dated- 16/01/2018 & Rs.5,00,000/- vide Receipt No.609541, DD.No.124007 (Bharat Bank), Dated:16/01/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१११६/२०२
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Agro Based Industrial Building No.1 & 2 (Stilt / Gr + 1 Floor)
On land bearing S No.215, H.No.7Pt, S.No.216, H.No.1/1Pt, 1/2Pt & 2Pt of Village: Pelhar, Tal:
Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1216/2020-21,
Dated:15/03/2021.
2) An application received by M/s- Himesh Gupta & Associates, Dated:10/03/2021.
3) Gross Built up area certificate of M/s- Himesh Gupta & Associates, Dated:10/03/2021.
4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated:10/03/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/738/2019-20,
Dated:15/10/2019
6) Certificate from License Agency M/s-The Fire Protection Company, Dated:08/02/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:25/03/2021.
10) Structure Stability Certificate for M/s- Seemu Consultants, Dated:08/03/2021.
11) CC issued by VVCMC/TP/CC/VP-6144/304/2019-20, Dated:21/11/2019
12) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Agro Based Industrial Building No. 1 & 2 (Stilt / Gr + 1 Floor) in height 10.60mtr. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 08/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area 415.57sq.mtr & Building No.2 having built up area 415.57sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 818533, DD No. 001044, Dated: 30/09/2019 & Rs.80,000/- vide Receipt No.818534, DD.No.001045, Dated:30/09/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१११०/२०२१
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Agro Based Industrial Building No.1 (Stilt / Gr + 2Pt) On land bearing S No.214, H.No.1Pt & 2Pt of Village: Pelhar, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1217/2020-21, Dated:15/03/2021.
2) An application received by M/s- Himesh Gupta & Associates, Dated:10/03/2021.
3) Gross Built up area certificate of M/s- Himesh Gupta & Associates, Dated:10/03/2021.
4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated:10/03/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1017/2019-20, Dated:04/12/2019
6) Certificate from License Agency M/s-The Fire Protection Company, Dated:08/02/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:25/03/2021.
10) Structure Stability Certificate for M/s- Seemu Consultants, Dated:08/03/2021.
11) CC issued by VVCMC/TP/CC/VP-6188/421/2019-20, Dated:13/02/2020
12) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Agro Based Industrial Building No. 1 & 2 (Stilt / Gr + 2Pt) in height 15.60mtr. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 08/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area 359.33sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 818770, DD No.154906, Dated: 30/11/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on mahatrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/११९
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

प्रतमिळाली

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

[Signature]
लिपिक (न.र.)
वसई-विरार शहर महानगरपालिका
दिनांक ३०/०५/२०२१

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.2 (Wing-D) (Stilt/Gr+7 Floors) located on land bearing S No.345(Pt), S.No.346, H.No.1, S.No.347, S.No.348, H.No.2, S.No.350, S.No.349, S.No.339, H.No.1, S.No.352, H.No.3, S.No.351, H.No.4A, 4B & 6, S.No.331, H.No.1, 2, 3, 4 & 5, S.No.317, H.No.6A, 6B, 6C & 6D, S.No.332, H.No.9, S.No.352, H.No.4 of Village:Juchandra, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1240/2020-21, Dated:17/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:09/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:09/03/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:09/03/2021.
5) This office Provisional No Objection Certificate No. VVCMC/FIRE/161/2015-16, Dated:26/08/20
6) Certificate from License Agency M/s-Jai Jivdani Fire Service, Dated:26/03/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/01/2021.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:04/01/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:09/03/2021.
11) RDP issued by VVCMC/TP/RDP/VP-0429/0259/2014-15, Dated:24/12/2014
12) Submitted M/s- Singh Electrical Works, Dated:20/01/2020.
13) Submitted Disel Engine Test Certificate, Dated:12/01/2021.
14) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential with Shopline Building No.2 (Wing-D) (Stilt/Gr+ 7) in 23.90Mtrs. Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Jai Jivdani Fire Services, bearing License No. MFS-LA/2021/RF-04, MFS-LA/2021/RD-04 and has submitted Certificate on 26/03/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1843.74sq.mtrs.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/- vide Receipt No. 351037, DD No. 000619, Dated- 26/08/2015 of HDFC Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



[Signature]
CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१११९८/२०२१
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.1 (Wing-A, B & C) (Stilt/Gr+7 Floors) located on land bearing S No.345(Pt), S.No.346, H.No.1, S.No.347, S.No.348, H.No.2, S.No.350, S.No.349, S.No.339, H.No.1, S.No.352, H.No.3, S.No.351, H.No.4A, 4B & 6, S.No.331, H.No.1, 2, 3, 4 & 5, S.No.317, H.No.6A, 6B, 6C & 6D, S.No.332, H.No.9, S.No.352, H.No.4 of Village:Juchandra, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1242/2020-21, Dated:17/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:09/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:09/03/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:09/03/2021.
5) This office Provisional No Objection Certificate No. VVCMC/FIRE/162/2015-16, Dated:26/08/2015
6) Certificate from License Agency M/s-Bright Infra Syatem Pvt Ltd, Dated:12/01/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:04/08/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:15/03/2021.
10) Structure Stability Certificate for M/s- Seemu Consultancy, Dated:31/03/2021.
11) RDP issued by VVCMC/TP/RDP/VP-0429/0259/2014-15, Dated:24/12/2014
12) Submitted M/s- Sai Electric Works, Dated:26/03/2021.
13) Submitted Disel Engine Test Certificate, Dated:12/01/2021.
14) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building No.1 (Wing-A, B & C) (Stilt/Gr.+ 7) in 23.90Mtrs. Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Bright Infra System Pvt Ltd, bearing License No. MFS-LA/2020/RF-166, MFS-LA/2020/RD-148 and has submitted Certificate on 12/01/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 2920.54sq.mtrs.

This certificate shall be treated **valid upto one Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No. , DD No. 072167, Dated- 10/08/2015 & Rs.4,80,000/- vide Receipt No.351009, DD.No.072168, Dated:10/08/2015 of Vasai Janta Co. Op. Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org


मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/११२०/२०२१
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.2 (Wing-C) (Stilt/Gr+7 Floors) located on land bearing S No.345(Pt), S.No.346, H.No.1, S.No.347, S.No.348, H.No.2, S.No.350, S.No.349, S.No.339, H.No.1, S.No.352, H.No.3, S.No.351, H.No.4A, 4B & 6, S.No.331, H.No.1, 2, 3, 4 & 5, S.No.317, H.No.6A, 6B, 6C & 6D, S.No.332, H.No.9, S.No.352, H.No.4 of Village:Juchandra, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1241/2020-21, Dated:17/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:09/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:09/03/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:09/03/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1038/2019-20, Dated:05/12/2019
6) Certificate from License Agency M/s-Shree Fire Guard Co, Dated:05/03/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/03/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:09/03/2021.
11) RDP issued by VVCMC/TP/RDP/VP-0429/0259/2014-15, Dated:24/12/2014
12) Submitted M/s- Sap Enterprises, Dated:26/03/2021.
13) Submitted Disel Engine Test Certificate, Dated:12/01/2021.
14) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential with Shopline Building No.2 (Wing-C) (Stilt/Gr.+ 7) in 23.90Mtrs. Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree Fire Guard Co, bearing License No. MFS-LA/2020/RF-270, MFS-LA/2020/RD-243 and has submitted Certificate on 05/03/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1475.50sq.mtrs.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/- vide Receipt No. 818779, DD No. 001012 (Bassein Catholic Bank) Dated- 04/12/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/११२४/२०२१
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building No. 1 (Wing-A) (Gr + 2 Floor) on land bearing S No.72, H.No.1 & 2 of Village:Bapane, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1112/2020-21, Dated:24/02/2021.
2) An application received by M/s- En Con Project Consultants, Dated:13/02/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:13/02/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:13/02/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/206/2018-19, Dated:09/06/2018.
6) Certificate from License Agency M/s- Ray Fire Protection Services, Dated:05/02/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:02/05/2019.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/03/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:13/02/2021.
11) CC Issued by VVCMC/TP/CC/VP-2840/169/2018-19, Dated:26/10/2018.
12) C.F.O. site visit Dated:23/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No. 1 (Wing-A) (Gr + 2 Floor) in 15.60Mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Ray Fire Protection Services,** bearing **License No. MFS-LA/2019/RF-59, MFS-LA/2019/RD-64** and has submitted **Certificate on 05/02/2021 in "Form A"** Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 1089.20sq.mtrs.

This certificate shall be treated **valid upto one Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 8,30,000/- vide Receipt No.672733, DD.No.541211, Dated:24/05/2018 for Industrial Building No.1 (Wing- A, B & C), Industrial Building No.2 (Wing- A & B) & Industrial Building No.3 (Wing- A & B).

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received
5/4/21
Mhate

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/११२८/२०२१
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Educational Building (Stilt/Gr+2 Floors) located on land bearing C.T.S. No.2245A, 2246, 2247(A,B,C), 2248(A,B), 2249, 2250, 2251, 2252, 2253, 2254, 2255, 2256, 2257 of Village: Dhovali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1239/2020-21, Dated:17/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:11/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:11/03/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/03/2021.
5) This office Provisional No Objection Certificate No. VVCMC/FIRE/689/2016-17, Dated:28/10/2016
6) Certificate from License Agency M/s-Fire Protection Company, Dated:02/03/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/01/2021.
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/04/2021.
9) Structure Stability Certificate for M/s- S.S & Associates, Dated:11/03/2021.
10) RDP issued by VVCMC/TP/RDP/VP-5618/123/2019-20, Dated:01/10/2019
11) Submitted Electric certificate M/s- Zip Engineers, Dated:11/03/2021.
12) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Educational Building (Stilt / Gr.+ 2 Floor) in 11.40Mtrs.** Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s- Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on **02/03/2021** in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 4277.64sq.mtrs.

This certificate shall be treated **valid upto one Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Capitation Fees of Rs. 2,40,000/- vide Receipt No. 487486, DD No. 214160 & Scrutiny Fees Rs.2,40,000/- vide Receipt No. 487487, Dated- DD.No.214161, Dated:20/10/2016 of Bank of Baroda.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/११२८/२०२१
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No. 1 & 2 (Gr+2 Floor) located on land bearing S.No. 45, H.No.6, 7A, 7B, S.No.47, H.No.3/1/3 & 4/B of Village: Gokhiware, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1284/2020-21, Dated:24/03/2021.
2) An application received by M/s- En Con Project Consultants, Dated:22/03/2021.
3) Gross Built up area certificate of M/s- En Con Project Consultants, Dated:20/04/2021.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:20/04/2021.
5) This office Provisional No Objection Certificate No. VVCMC/FIRE/HQ/734/2019-20, Dated:15/10/2019
6) Certificate from License Agency M/s-Fire Protection Company, Dated:05/04/2021 (Form A)
7) Certificate from License Agency M/s-Fire Protection Company, Dated:17/03/2021 (Form A)
8) Submitted License copy of Maharashtra Fire Services, Dated:06/01/2021.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/04/2021.
10) Structure Stability Certificate for M/s- S.S & Associates, Dated:20/04/2021.
11) RDP issued by VVCMC/TP/RDP/VP-5838/241/2021-22, Dated:06/04/2021
12) CC issued by VVCMC/TP/CC/VP-5838/259/2019-20, Dated:25/10/2019
13) Submitted Electric certificate M/s- Choice Electricals, Dated:01/04/2021.
14) C.F.O. site visit Dated:09/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No. 1 & 2 (Gr.+ 2 Floor) in 15.60Mtrs.** Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 05/04/2021 & 17/03/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3017.70sq.mtrs.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Capitation & Scrutiny Fees of Rs. 4,80,000/- vide Receipt No. 818529, DD No. 023837, Dated:28/09/2019 of Bassein Catholic Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from License Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/प्रग्नि/मुका/११३०/२०२१

दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential With Shopline Building (Wing- D) (Shop / Stilt / Gr + 12 Floor) On land Bearing S No.188B, H.No.1 to 8, S.No.189, H.No.12 of Village:Sandor, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1286/2020-21, Dated:24/03/2021.
2) An application received by M/s- Shape Consultants, Dated:23/03/2021
3) Built up area certificate of M/s- Shape Consultants, Dated:23/03/2021.
4) Work Completion certificate of M/s- Shape Consultants, Dated:23/03/2021.
5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/2399/2020, Dated:17/03/2020.
6) Certificate from License Agency M/s- The Fire Protection Company, Dated:27/02/2021 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:02/04/2021.
10) Structure Stability Certificate for M/s- Jay Shree Krishna Consulting, Dated:23/03/2021.
11) Submitted Electric Certificate for M/s- Sneha Enterprises, Dated:23/03/2021.
12) RDP issued by VVCMC/TP/RDP/VP-5793/146/2018-19, Dated:03/11/2018.
13) C.F.O. site visit Dated:25/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential With Shopline Building (Wing-A) (Shop / Stilt / Gr + 12 Floor) in height 38.20mtr.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s-The Fire Protection Company**, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 27/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your buildings having built up area 2581.63sq.mtr.

This certificate shall be treated valid upto one Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 4,80,000/- vide Receipt No. 425454, DD No.033015 (Vasai Vikas Sahakari Bank), Dated:27/01/2016, Rs.90,000/- vide Receipt No.609432, DD.No.034747 (Vasai Vikas Sahakari Bank), Dated:09/11/2017, Rs.90,000/- vide Receipt No.609433, DD.No.034743 (Vasai Vikas Sahakari Bank) Dated:09/11/2017, Rs.3,25,000/- vide Receipt No.609430, DD.No.011867 & Rs.80,000/- vide Receipt No.609431, (Bassein catholic Bank) Dated:09/11/2017, Rs.3,25,000/- vide Receipt No.609428, DD.No.011865 & Rs.80,000/- vide Receipt No.609429,

DD.No.011866 (Bassein Catholic Bank) Dated:09/11/2017, Rs.80,000/- vide Receipt No. 609427, DD.No. 000493 Rs.3,25,000/- vide Receipt No.609426 (Bassein Catholic Bank) Dated:09/11/2017, Rs.4,45,000/- vide Receipt No.609425, DD.No.034746 (Vasai Vikas Sahakari Bank) Dated:09/11/2017, Rs.1,05,000/- vide Receipt No.819127, DD.No.067972 (Bassein Catholic Bank) Dated:18/03/2020, Rs.20,000/- vide Receipt No.819128, DD.No.067983, Dated:17/03/2020 of (Bassein Catholic Bank), Rs.50,000/- vide Receipt No. 819129, DD.No.067982, Dated:17/03/2020 of (Bassein Catholic Bank), Rs.14,500/- vide Receipt No.819130, DD.No.067984, Dated:17/03/2020 (Bassein Catholic Bank), Rs.13,500/- vide Receipt No.819131, DD.No.000727, Dated:17/03/2020 (Bassein Catholic Bank), Rs.2,000/- vide Receipt NO.819132, DD.No.033415, Dated: 17/03/2020 (Bassein Catholic Bank).

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



A handwritten signature in blue ink, appearing to be "Gale", written over the official title.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. १३३१/४८४/१९३४
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No.1 (Shop / Stilt / Gr+7 Floors) located on land bearing Pardi No.152 & Chalta No.3 to 11 (House No.301 & 301A) & Chalta No.12 to 16 (House No.304) of Village:Agashi, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/917/2020-21, Dated:13/01/2021.
2) An application received by M/s- Abhay Raut Architect, Dated:02/01/2021.
3) An application received by M/s-Sadguru Builders & Developers, Dated:30/03/2021
4) Gross Built up area certificate of M/s- Abhay Raut Architect, Dated:02/01/2021.
5) Work Completion certificate of M/s- Abhay Raut Architect, Dated:02/01/2021.
6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/752/2018-19, Dated:08/10/2018
7) RDP issued by VVCMC/TP/RDP/VP-5200/062/2016-17, Dated:09/12/2016
8) CC issued by VVCMC/TP/CC/VP-5200/548/2014-15, Dated:30/04/2014.
9) Certificate from License Agency M/s-Bright Infra System Pvt Ltd, Dated:05/12/2020 (Form A).
10) Submitted License copy of Maharashtra Fire Services, Dated:24/08/2020.
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/12/2020.
13) Structure Stability Certificate for M/s- Nimisha Structural Design Academy, Dated:04/03/2021.
14) Submitted M/s-Jay Vagheshvari Electricals, Dated:18/03/2021
15) C.F.O. site visit Dated:13/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building No.1 (Shop/ Stilt / Gr.+ 7 Floor) in 23.95Mtrs.** Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Bright Infra System Pvt Ltd, bearing License No. MFS-LA/2020/RD-0148, MFS-LA/2020/RF-0166** and has submitted **Certificate on 05/12/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 1730.31sq.mtrs.

This certificate shall be treated **Valid upto One Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/- vide Receipt No. 694536, DD No. 11469 (New India Co.Op. Bank) Dated- 06/09/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to Architect- 1) M/s- Abhay Raut Architect
Copy to Developer-2) M/s-Sadguru Builders & Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received
31/03/2021


मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/११५०/२०२१
दिनांक : ३१/०३/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential Building No. T3 (Stilt +3 Podium floor + 19 floor) located on land bearing S.No.296, 297, 298, 303, 304, 324 & 390-B of Village: Bolinj, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1164/2020-21, Dated:05/03/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:01/03/2021.
 - 3) An application received by M/s- Joyville by Shapoorji Pallonji, Dated:01/03/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:01/03/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/535/2016-17, Dated:30/09/2016.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:01/03/2021.
 - 7) Certificate from License Agency M/s- Bright Infra System Pvt Ltd, Dated:15/02/2021 (Form A). & Submitted License copy of Maharashtra Fire Services, Dated:24/08/2020.
 - 8) Certificate from License Agency M/s- Falcon Technoprojects India Pvt Ltd, Dated:08/02/2021 (Form A). & Submitted License copy of Maharashtra Fire Services, Dated:25/11/2020.
 - 9) Certificate from License Agency M/s- Tejfire Safety Indai Pvt Ltd, Dated:03/02/2021 (Form A). & Submitted License copy of Maharashtra Fire Services, Dated:30/07/2020.
 - 10) AMC Certificate by M/s- Falcon Technoproject India Pvt Ltd, Dated:08/02/2021
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/03/2021.
 - 13) Structure Stability Certificate for M/s- Epicons Consultants Pvt Ltd, Dated:21/10/2020.
 - 14) RDP issued by VVCMC/TP/RDP/VP-0059/097/2017-18, Dated:17/10/2017.
 - 15) Submitted Electric Certificate M/s-Noor Electrical, Dated:08/02/2021.
 - 16) Diesel Engine Test Certificate of M/s- Perkins, Dated:08/08/2019
 - 17) C.F.O. site visit Dated:16/03/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential Building No. T3, Stilt + 3 upper level Parking Podium floors + 19 floor in 68.20 mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. (1) M/s- Bright Infra System Pvt Ltd, bearing License No. MFS-LA/2020/RF-166, MFS-LA/2020/RD-148 and has submitted Certificate on 15/02/2021 in "Form A"; (2) M/s- Falcon Technoprojects India Pvt Ltd, bearing License No. MFS-LA/2020/RF-318, MFS-LA/2020/RD-283, MFS-LA/2020RP-64 and has submitted Certificate on 25/11/2020 in "Form A"; (3) M/s- Tejfire Safety India Ptv Ltd, bearing License No. MFS-LA/2020/RF-149, MFS-LA/2020/RD-133 and has submitted Certificate on 03/02/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 19707.90sq.mtrs.

With reference to above on 16/03/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Joyville by Shapoorji Pallonji" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.

- F) Mian Pump on under ground water storage tank.
- G) Jockey Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.
- I) Sprinkler Pump on under ground water storage tank.
- J) Diesel Generator Set
- K) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Building No.A1 to A11 the Rs. 5,25,000/-, 5,25,000/-, 5,25,000/-, 5,25,000/-, 5,25,000/-, 80,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/- vide Receipt No.487412, 487413, 487415, 487416, 487417, 487414, 487418, 487419, 487420, 487421, 487422, 487423, DD.No.111939, 111943, 111942, 111941, 111938, 111940 (Vasai Vikas Sahakari Bank), Dated-29/08/2016; Rs.33,00,000/- vide Receipt No.487467, DD.No.084307 & Rs.33,00,000/- vide Receipt No.487467, DD.No.084307 & Rs.10,40,000/- vide Receipt No.487424, DD.No.033221 Dated:29/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Joyville by Shapoorji Pallonji

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/१२९८/२०२१
दिनांक : २६/०८/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Ebco Pvt Ltd,
Survey No.53, Hissa No.7/3, 7/4, 7/2A & 7/2B,
Gaurai Pada, Vasai (E),
Tal-Vasai, Dist-Palghar.

Sub:- Renewal of "Final No Objection Certificate" of Industrial Building Known as "EBCO PVT LTD" (Gr + 1st floor), located on land bearing S.No.53, H.No.7/2/B of Village: Bilalpada, Tal- Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s-Ebco Pvt Ltd, Dated:27/07/2021.
2) Certificate from License Agency M/s- The Fire Protection Company, Dated: 19/01/2021 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 04/08/2021.
4) Submitted Final No Objection Certificate No. VVCMC/FIRE/HQ/710/2019, Dated:09/10/2019.
5) CC issued by VVCMC/TP/CC/VP-6033/117/2018-19, Dated:31/08/2018
6) OC issued by VVCMC/TP/OC/VP-6033/111/2019-20, Dated:22/11/2019
7) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
7) C.F.O site visit Dated:04/08/2021.

With reference to Sr.No.1 above, this office is in received of your application for your Industrial Building, (Gr + 1st Floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company. bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate On 06/10/2020 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 21,250/- vide Receipt No. 895591, Book No. 8956, DD No.502483 & Rs.21,250/- vide Receipt No. 895592, Book No.8956, DD.No.502499 (Kotak Mahindra Bank) Dated:10/01/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect / Developer-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१२२०/२०२१
दिनांक : २६/०८/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Ebco Pvt Ltd,
Survey No.53, Hissa No.7/3, 7/4, 7/2A & 7/2B,
Gaurai Pada, Vasai (E),
Tal-Vasai, Dist-Palghar.

Sub:- Renewal of "Final No Objection Certificate" of Existing Industrial Building Known as "EBCO PVT LTD" (Basement Gr + Mezzanine + 1st floor), located on land bearing S.No.53, H.No.7/3, 7/4 of Village: Bilalpada, Tal- Vasai, Dist- Palghar.

- Ref:- 1) An Application received by M/s-Ebco Pvt Ltd, Dated:27/07/2021.
2) Certificate from License Agency M/s- The Fire Protection Company, Dated: 13/07/2021 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 04/08/2021.
4) Submitted Final No Objection Certificate No. VVCMC/FIRE/HQ/354/2019, Dated:27/07/2018.
5) CC issued by VVCMC/TP/CC/VP-6033/117/2018-19, Dated:31/08/2018
6) OC issued by VVCMC/TP/OC/VP-6033/111/2019-20, Dated:22/11/2019
6) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
7) C.F.O site visit Dated:04/08/2021.

With reference to Sr.No.1 above, this office is in received of your application for your Existing Industrial Building, (Basement + Gr + Mezzanine + 1st Floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company. bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate On 06/10/2020 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 1,20,000/- vide Receipt No. 895584, Book No. 8956, DD No.502482 & Rs.60,000/- vide Receipt No. 895585, Book No.8956, DD.No.502584 (Kotak Mahindra Bank) Dated:05/08/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect / Developer-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasavirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१२३७/२०२१
दिनांक : २७/०८/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Vijay Associates,
3rd Floor, Meghdoot Apt,
Virar (W),
Tal-Vasai, Dist-Palghar.

Sub:- Renewal of "Final No Objection Certificate" of Commercial Building Known as "Ladkoo Plaza" (Basement + Gr + 1st floor) at Ladkoo Plaza, Olanda Naka, Agashi, Virar (W), Tal- Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s- Vijay Associates, Dated:27/01/2021.
2) Certificate from License Agency M/s- Shree Fire Guard Co, Dated: 15/02/2021 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 17/08/2021.
4) Submitted Renewal of Final No Objection Certificate No. VVCMC/ FIRE/ HQ/2192/2019, Dated:03/02/2020.
5) CC issued by CIDCO/VVSR/CC/BP-4636/W/593, Dated:14/06/2010
6) POC issued by VVCMC/TP/POC/VP-0797/78/2018-19, Dated:03/01/2019
7) Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
8) Electric Certificate received from M/s-Hind Electric & Engineering Corporation, Dated:08/08/2021
9) C.F.O site visit Dated: 17/08/2021.

With reference to Sr.No.1 above, this office is in received of your application for your Commercial Building, (Basement + Gr + 1st Floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree fire Guard Co. bearing License No. MFS-LA/2020/RF-270, MFS-LA/2020/RD-243 and has submitted Certificate On 15/02/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 21,250/- vide Receipt No. 895184, Book No. 8952, DD No.118040 (Vasai Vikas Sahakari Bank) Dated: 25/02/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect / Developer-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

भावक क्र. : व.वि.श.म./आग्नि/मुका/११५५/२०२१
दिनांक : ०४/०८/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Industrial Building No. C located on land bearing Plot No.6/1, 6/2, 6/3 H.No.1+5 of Village: Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/571/2021-22, Dated:06/08/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:30/07/2021.
 - 3) An application received by M/s- D Vora and Co, Dated:26/08/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:30/07/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/269/2019-20, Dated:25/06/2019.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:30/07/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated:30/07/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 10) AMC Certificate by M/s- D Vora and Co, Dated:26/08/2021
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:30/08/2021.
 - 12) Structure Stability Certificate for M/s- S.S & Associates, Dated:30/07/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-6142/79/2019-20, Dated:11/07/2019.
 - 14) Submitted Electric Certificate M/s- Rudra Power Solutions, Dated:02/08/2021.
 - 15) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:07/05/2021
 - 16) C.F.O. site visit Dated:30/08/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Industrial Buildings No. C (Gr + 3Pt floor) in 18.00mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on 30/07/2021 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 3135.49sq.mtrs.

With reference to above on **30/08/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- D. Vora and Co"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Automatic Sprinkler has been installed in every floor
- E) Automatic Smoke Detector has been installed in every floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Main Pump on under ground water storage tank.
- I) Sprinkler Pump on under ground water storage tank.
- J) Stand by Pump on under ground water storage tank.
- K) Jockey Pump on under ground water storage tank.
- L) Booster Pump near over head water storage tank.

M) Diesel Generator Set

N) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 24,00,000/- vide Receipt No.779394, DD.No.067024, Dated- 25/06/2019 of Bassein Catholic Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- D. Vora and Co.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/१४५६/२०२१
दिनांक : ०४/०८/२०२१



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building (Gr + 2Pt floor) located on land bearing Plot.No.27, S.No. 66 of Village: Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/306/2021-22, Dated:15/06/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:08/06/2021.
 - 3) An application received by Developer Ms.Meeta Kirit Nagda, Dated:26/08/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:08/06/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/125/2019-20, Dated:14/05/2019.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:08/06/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated:08/06/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated: 06/10/2020.
 - 10) AMC Certificate by Ms.Meeta Kirit Nagda, Dated:26/08/2021
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:30/08/2021.
 - 12) Structure Stability Certificate for M/s- Framic Structural Architectural, Dated:10/08/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-6112/47/2019-20, Dated: 28/05/2019.
 - 14) Submitted Electric Certificate M/s- Pradhan Electrical Works, Dated:04/08/2021.
 - 15) Diesel Engine Test Certificate of M/s- Advance Power, Dated: 18/08/2021
 - 16) C.F.O. site visit Dated:30/08/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Industrial Building (Gr + 2Pt floor) in 15.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company**, bearing License No. **MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on 08/06/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 526.55sq.mtrs.

With reference to above on **30/08/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Ms. Meeta Kirit Nagda"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Booster Pump near over head water storage tank.
- G) Diesel Generator Set
- H) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 80,000/- vide Receipt No.779280, DD.No.591726, Dated- 09/05/2019 of Kotak Mahindra Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you





CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- Ms. Meeta Kirit Nagda.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१५१२/१२१
दिनांक : ०८/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building Type- F (Wing- C) (Gr+7 floor), Residential with SHopline Building Type- G (Wing-B) (Gr+7 floor) & Type- H, (Wing- A) (Gr+7 floor) on land bearing S.No.126, H.No.9, 10, S.No.123, H.No.1, 4, 5, 7, S.No.217, H.No.3 & 4 of Village: Achole, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/441/2021-22,
Dated:13/07/2021.

- 2) An application received by M/s- Shah Gattani Consultants, Dated:08/06/2021.
- 3) An application received by Developer M/s-Dhule Construction Co, Dated:21/08/2021
- 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:09/06/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/980/2020-21,
Dated:25/02/2021.
- 6) Gross Built up area certificate for M/s- Shah Gattani Consultants, Dated:08/06/2021.
- 7) Certificate from License Agency M/s- Vision Fire & Safety Engineering,
Dated:22/01/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
- 9) AMC Certificate by M/s-Dhule Construction Co, Dated:21/08/2021
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:14/08/2021.
- 12) Structure Stability Certificate for M/s- Shah Gattani Consultants,
Dated:08/06/2021.
- 13) RDP issued by VVCMC/TP/RDP/VP-0694/106/2021-22, Dated:07/05/2021.
- 14) Submitted Electric Certificate M/s- Prashant Electrical Enterprises,
Dated:21/08/2021.
- 15) Diesel Engine Test Certificate of M/s- Mahindra Powerol, Dated:29/08/2015
- 16) C.F.O. site visit Dated:14/08/2021.

With reference to Sr.No.2 & 3 above, this office is in received of your application for your Residential Building No. Type-F (Wing- C) Gr + 7 floor in 23.80 mtrs height & Residential with Shopline Building Type-G (Wing-B) & Type-H (Wing-A) Gr+7 floor in 23.80 height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/2020/RF-226, MFS-LA/2020/RD-200 and has submitted Certificate on 22/01/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Type-F (Wing-C) 1002.34sq.mtrs, Type-G (Wing-B) 2135.34sq.mtrs & Type-H (Wing-A) 1181.08sq.mtrs.

With reference to above on 14/08/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Dhule Construction Co" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Down Commer has been installed in every floor
- F) Booster Pump near over head water storage tank.
- G) Diesel Generator Set

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 3,60,000/- vide Receipt No.819541, DD.No.068175 (Bassein Catholic Bank), Dated-11/11/2020 & 80,000/- vide Receipt No.895176, DD.No.068512 (Bassein Catholic Bank), Dated: 24/02/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s- Dhule Construction Co

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१५२२/२०२१
दिनांक : ०६/०६/२०२१



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building located on land bearing S.No.188B, H.No.1 to 8, S.No.189, H.No.12 of Village: Sandor, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/265/2021-22, Dated:04/06/2021.
- 2) An application received by M/s- Shape Consultants, Dated:24/06/2021.
 - 3) An application received by Developer M/s- Ghanshyam Enterprises, Dated:24/06/2021
 - 4) Work Completion certificate of M/s- Shape Consultants, Dated:24/06/2021.
 - 5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/2399/2020-21, Dated:17/03/2020.
 - 6) Construction area certificate for M/s- Shape Consultants, Dated:24/06/2021.
 - 7) Certificate from License Agency M/s- Ronak Fire Industries, Dated:23/03/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:24/12/2020.
 - 9) AMC Certificate by Developer M/s- Ghanshyam Enterprises, Dated:23/06/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/06/2021.
 - 12) Structure Stability Certificate for M/s- Jay Shree Krishna, Dated:24/06/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-5793/188/2019-20, Dated:13/11/2019.
 - 14) Submitted Electric Certificate M/s-Zip Engineers, Dated:15/03/2021.
 - 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:02/02/2021
 - 16) O. site visit Dated:24/06/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential with Shopline Building (Wing- E) Stilt / Gr + 14 floor in 43.90 mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s- Ronak Fire Industries**, bearing License No. **MFS-LA/2020/RF-393, MFS-LA/2020/RD-354 & MFS-LA/2020/RP-84** and has submitted Certificate on 23/03/2021 in "Form A" Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 4468.60sq.mtrs.

With reference to above on **24/06/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "**M/s- Ghanshyam Enterprises**" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank.
- G) Jockey Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.
- I) Sprinkler Pump on under ground water storage tank.
- J) Diesel Generator Set
- K) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 4,80,000/- vide Receipt No.425454, DD.No.033015 (Vasai Vikas Sahakari Bank), Dated: 27/01/2016; Rs. 4,45,000/- vide Receipt No.609432, DD.No.034743 (Vasai Vikas Sahakari Bank), Dated:09/11/2017; Rs.90,000/- vide Receipt No.609433, DD.No.034743 (Vasai Vikas Sahakari Bank), Dated:09/11/2017; Rs.3,25,000/- vide Receipt No.609430, DD.No.011867 (Bassein Catholic Bank), Dated:09/11/2017; Rs.80,000/- vide Receipt No.609431, Bassein Catholic Bank, Dated:09/11/2017; Rs. 3,25,000/- vide Receipt No.609428, DD.No.011865 (Bassein Catholic Bank) Dated: 09/11/2017; Rs.80,000/- vide Receipt No.609429, DD.No.011866 (Bassein Catholic Bank), Dated:09/11/2017, Rs.80,000/- vide Receipt No.609427, DD.No.000493 (Bassein Catholic Bank), Dated: 09/11/2017; Rs. 3,25,000/- vide Receipt No. 609428, DD.No.609426 (Bassein Catholic Bank), Dated:09/11/2017; Rs.4,45,000/- vide Receipt No.609425, DD.No.034746 (Vasai Vikas Sahakari Bank), Dated: 09/11/2017; Rs. 1,05,000/- vide Receipt No.819127, DD.No.067972 (Bassein Catholic Bank), Dated:18/03/2020; Rs. 20,000/- vide Receipt No.819128, DD.No.067983 (Bassein Catholic Bank), Dated: 17/03/2020; Rs. 50,000/- vide Receipt No.819129, DD.No.067982 (Bassein Catholic Bank), Dated:17/03/2020, Rs.14,500/- vide Receipt No. 819130, DD.No.067984 (Bassein Catholic Bank), Dated: 17/03/2020; Rs.13,500/- vide Receipt No.819131, DD.No.000727 (Bassein Catholic Bank), Dated:17/03/2020; Rs. 2,000/- vide Receipt No.819132, DD.No.033415 (Axis Bank), Dated-17/03/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shape Consultants
2) Developer- M/s- Ghanshyam Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/प्रति/मुका/१०७०१/२०२१
दिनांक : १४/०७/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential Building No.2 (Wing-B) in Sector No.III (Stilt + 7 floor) located on land bearing S.No.49, 50, 51, 52, 53, 54, 55, 56, 77 & S.No.57, H.No.1 Village: Achole, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/445/2021-22, Dated:13/07/2021.
2) An application received by M/s- En Con Project Consultants, Dated:27/05/2021.
3) An application received by M/s- Shree JI Realtors, Dated:01/07/2021
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:27/05/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/1115/2020-21, Dated:31/03/2021.
6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:27/05/2021.
7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:08/10/2020 (Form A).
8) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:01/07/2021 (Form B).
9) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
10) AMC Certificate by M/s- Shree JI Realtors, Dated:01/07/2021
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:15/06/2021.
13) Structure Stability Certificate for M/s- Hansal Parikh and Associates, Dated:14/01/2014.
14) RDP issued by VVCMC/TP/RDP/VP-0127/344/2019-20, Dated:17/03/2020.
15) Submitted Electric Certificate M/s- Shree Swami Samarth Power Works, Dated:26/05/2021.
16) Power Inverter Certificate of M/s- Shree Swami Samarth Power Works, Dated: 20/12/2021
17) C.F.O. site visit Dated:01/07/2021.

With reference to Sr.No.2 above, this office is in received of your application for your Residential Building No. 2 (Wing- B) in 23.90mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Services, bearing License No. MFS-LA/2021/RF-332 and has submitted Certificate on 08/10/2020 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1121.40sq.mtrs.

With reference to above on 01/07/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Shree JI Realtors" following Fire Fighting arrangements provided were found in satisfactory working condition.

- Portable Fire Extinguishers has been installed
- Hose Reel Hose has been installed in every floor
- Hose Box has been installed in Alternate floor
- Siamese Connection has been installed in entrance gate
- Courtyard Hydrant has been installed in the building & prominent places.
- Booster Pump near over head water storage tank.
- Power Inverter

Nimish Shah

N D Shah

93231/8604

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No.895215, Book No. 8953, DD. No. 000623, Dated- 04/03/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Shree JI Realtors

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. | अग्नि | मुका | १६०८/२०२१-२२
दिनांक : २२/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Shree Vimalnath Reality
Builders & Developers,
232, Satyam Shivam Shopping Centre,
2nd Floor, Nalasopara (W),
Tal-Vasai, Dist-Palghar.



Sub:-Renewal of "Final No Objection Certificate" of Residential with Shopline Building Type-MD (Wing-A) (Stilt / Gr + 15Pt) on land bearing S.No.70, 90, 91, 96, 98, 106, 108, 110, 111, 112, 113 of Village: Chulne / Diwanman, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Shree Vimalnath Reality Builders & Developers, Dated:30/07/2021.
2. This office Final No Objection Certificate No.VVCMC/FIRE/HQ/560/2020, Dated:05/11/2020.
3. This office Provisional No Objection Certificate No.VVCMC/FIRE/HQ/416/2016-17, Dated:01/09/2016
4. Certificate from License Agency M/s- Fire Bird Fire Services, Dated: 01/07/2021. (Form- B)
5. AMC Certificate by Developer M/s- Shree Vimalnath Reality Builders & Developers, Dated:01/07/2021
6. Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:20/09/2021.
8. C.F.O site visit Dated:20/09/2021

With reference to Sr.No.1 above, this office is in received of your application for your Residential with Shopline Building Type-MD (Wing-A) (Stilt / Gr + 15Pt Floor) in 47.00mtrs Height at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services bearing License No. MFS-LA/2021/RF-26 & MFS-LA/2021/RD-20 and has submitted Certificate On 01/07/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 42,500/- vide Receipt No. 895660, Book No. 8957, DD .No.001951 (Bassein Catholic Bank), Dated:21/09/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **if any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

24/09/21

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्निमुक्ता/१८०९/२०२१-२२
दिनांक : २२/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. A2, (Stilt / Gr + 16 floor) located on land bearing S.No.296, 297, 298, 299, 303, 304, 324 & 390-B of Village: Bolinj, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/792/2021-22, Dated:08/09/2021.
2) An application received by M/s- En Con Project Consultants, Dated:07/09/2021.
3) An application received by M/s- Viva Winner Venture Realtors LLP, Dated:07/09/2021
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:07/09/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/535/2016-17, Dated:30/09/2016.
6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:07/09/2021.
7) Certificate from License Agency M/s- Bright Infra System Pvt Ltd, Dated:20/08/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:24/08/2020.
9) AMC Certificate by M/s- Viva Winner Venture Realtors LLP, Dated:07/09/2021
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/09/2021.
12) Structure Stability Certificate for M/s- Nimisha Structural Design Academy, Dated:27/03/2021
13) RDP issued by VVCMC/TP/RDP/VP-0059/097/2017-18, Dated:17/10/2017.
14) Submitted Electric Certificate M/s-Aim Realty Engineering Pvt Ltd, Dated:02/09/2021.
15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:09/03/2021
16) C.F.O. site visit Dated:17/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building No. A2, Stilt / Gr + 16 floor in 49.85 mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Bright Infra System Pvt Ltd, bearing License No. MFS-LA/2020/RF-166, MFS-LA/2020/RD-148 and has submitted Certificate on 20/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No. A2 - 5727.58sq.mtrs.

With reference to above on 17/09/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Viva Winner Venture Realtors LLP" following Fire Fighting arrangements provided were found in satisfactory working condition.

- Portable Fire Extinguishers has been installed in every floor & prominent places
- Automatic Sprinkler System has been installed in entire building including Each habitable room, fitness center, stilted car parking areas, lift lobby & common corridor at each floor level.
- Automatic Smoke Detection System has been installed in main console panel at ground floor level, provided in Electric meter room & lift machine room.
- Hose Reel Hose has been installed in every floor
- Hose Box has been installed in Alternate floor
- Siamese Connection has been installed in entrance gate
- Courtyard Hydrant has been installed in the building & prominent places.
- Mian Pump on under ground water storage tank.

- I) Jockey Pump on under ground water storage tank.
- J) Booster Pump near over head water storage tank.
- K) Sprinkler Pump on under ground water storage tank.
- L) Diesel Generator Set
- M) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 5,25,000/-, 5,25,000/-, 5,25,000/-, 5,25,000/-, 5,25,000/-, 80,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/-, 4,45,000/- vide Receipt No.487412, 487413, 487415, 487416, 487417, 487414, 487418, 487419, 487420, 487421, 487422, 487423 DD.No.111939, 111943, 111942, 111941, 111938, 111940, 111948, 111949, 111947, 111944, 111946, 111945 (Vasai Vikas Sahakari Bank), Dated-29/08/2016. & Building No. T1 to T7 Rs.33,00,000/- vide Receipt NO. 487467, DD.No.084307 & Scrutiny Fees Rs.10,40,000/- vide Receipt No.487424, DD.No.033221 (Standard Chartered Bank) Dated:29/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants

2) Developer- M/s- Viva Winner Venture Realtors LLP

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/१८११
दिनांक : २२/०८/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Ruchi Technoplast
Ruchi House,
Building No. 1A,
Opp Force House,
K.T.Industrial Park No.2,
Waliv Road, Golani, Vasai (E),
Tal-Vasai, Dist-Palghar.



Sub:-Renewal of "Final No Objection Certificate" of Ruchi Technoplast, Ruchi House, Building No. 1A, Opp Force House, K.T. Industrial Park No. 2, Waliv Road, Golani, Vasai (E) of Village: Waliv, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Ruchi Technoplast, Dated:20/08/2021.
2. This office Renewal of Final No Objection Certificate No.VVCMC/ FIRE/ HQ/ 37/ 2020-2021, Dated:27/08/2020.
3. Occupancy Certificate Received by VVCMC/TP/OC/VP-0490/276, Dated:15/09/2011
4. Certificate from License Agency M/s- The Fire Protection Company, Dated:24/08/2021. (Form- B)
5. AMC Certificate by Developer M/s- Ruchi Technoplast, Dated:20/08/2021
6. Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/09/2021.
8. C.F.O site visit Dated:09/09/2021

With reference to Sr.No.1 above, this office is in received of your application for your Industrial Building, M/s-Ruchi Technoplast, Ruchi House, Building No.1A, K.T Industrial Park No. 2, Waliv Road, Golani, Vasai (E), (Gr + 2 floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228 & MFS-LA/2020/RD-202 and has submitted Certificate On 24/08/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 21,250/- vide Receipt No. 895651, Book No. 8957, DD .No.753935 (Bank of Baroda), Dated:08/09/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. /आफी/मुका/१८१२
दिनांक : २२/०८/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No.1 (Wing- A to G) Building No. 2 (Wing- A, E, F) & Residential Building No.2 (Wing-B,C,D) in Avenue Q on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village: Dongre, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/661/2021-22, Dated:23/08/2021.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:16/08/2021.
 - 3) An application received by Developer M/S- Agarwal Realtors, Dated:16/08/2021
 - 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:16/08/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/351/2017-18, Dated:28/07/2017.
 - 6) Gross Built up area certificate for M/s- Shah Gattani Consultants, Dated:16/08/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated: 05/08/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 10) AMC Certificate by Developer M/s- Agarwal Realtors, Dated:16/08/2021
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:18/09/2021.
 - 12) Structure Stability Certificate for M/s- Shah Gattani Consultants, Dated:16/08/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-453/091/2017-18, Dated:13/10/2017.
 - 14) Submitted Electric Certificate M/s- Eshwari Electricals & Jignesh Vidyut Sercice, Dated:15/05/2021 & 10/05/2021.
 - 15) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:02/07/2021
 - 16) C.F.O. site visit Dated:18/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building No. 1 (Wing- A to F) (Stilt / Gr + 14) & Building No.2 (Wing- A, E, F) (Stilt / Gr + 14) a total height of 44.70mtrs & Residential Building No. 2 (Wing- B, C, D) (Stilt +14) in Avenue "Q" a total height of 44.85mtrs, at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 24/07/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building on the Gross built up area Building No.1 - 25853.88sq.mtrs & Building No. 2 - 21570.73sq.mtrs.

With reference to above on 18/09/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Agarwal Realtors" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Automatic Sprinkler has been installed in every floor
- E) Automatic Smoke Detector has been installed in every floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Main Pump on under ground water storage tank.
- I) Sprinkler Pump on under ground water storage tank.
- J) Stand by Pump on under ground water storage tank.

- K) Jockey Pump on under ground water storage tank.
- L) Booster Pump near over head water storage tank.
- M) Diesel Generator Set
- N) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 65,85,000/- vide Receipt No.590301, DD.No.021425, Dated- 25/07/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s- Agarwal Realtors.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. /आग्नि/मुका/१८४५/२०२१-२२
दिनांक : २४/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building located on land bearing S.No.28, H.No.2 of Village: Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/704/2021-22, Dated:26/08/2021.
- 2) An application received by Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 3) An application received by M/s- BLF Realtors Pvt Ltd, Dated:24/08/2021
 - 4) Work Completion certificate of Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/371/2016-17, Dated:23/08/2016.
 - 6) Gross built up area certificate for Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated:07/08/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 9) AMC Certificate by M/s- BLF Realtors Pvt Ltd, Dated:24/08/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/09/2021.
 - 12) Structure Stability Certificate for M/s- Finite Consultants, Dated:09/08/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-0454/0410/2017-18, Dated:25/01/2018.
 - 14) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated:10/08/2021.
 - 15) Diesel Engine Test Certificate of M/s-Arn timer Engineers & Fabricators, Dated:12/08/2021
 - 16) C.F.O. site visit Dated:09/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential Building No. 1, (Gr + 7 floor) in 23.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company**, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 07/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 2482.07sq.mtrs.

With reference to above on **09/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- BLF Realtors Pvt Ltd"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Automatic Sprinkler System has been installed in every floor.
- C) Automatic Smoke Detection System has been installed in every floor.
- D) Hose Reel Hose has been installed in every floor
- E) Hose Box has been installed in Alternate floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Mian Pump on under ground water storage tank.
- I) Jocket Pump on under ground water storage tank.
- J) Booster Pump near over head water storage tank.
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No.487398, DD.No.002117 (PMC Bank), Dated-11/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "D. K. Kulkarni".

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – Mr. Umesh Gala Architect
2) Developer- M/s- BLF Realtors Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./माहि/मुका/१८४५/२०२१-२२
दिनांक : २४/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential Building located on land bearing S.No.28, H.No.2 of Village: Waliv, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/704/2021-22, Dated:26/08/2021.
- 2) An application received by Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 3) An application received by M/s- BLF Realtors Pvt Ltd, Dated:24/08/2021
 - 4) Work Completion certificate of Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/371/2016-17, Dated:23/08/2016.
 - 6) Gross built up area certificate for Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated:07/08/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 9) AMC Certificate by M/s- BLF Realtors Pvt Ltd , Dated:24/08/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/09/2021.
 - 12) Structure Stability Certificate for M/s- Finite Consultants, Dated:09/08/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-0454/0410/2017-18, Dated:25/01/2018.
 - 14) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated:10/08/2021.
 - 15) Diesel Engine Test Certificate of M/s-Arn timer Engineers & Fabricators, Dated:12/08/2021
 - 16) C.F.O. site visit Dated:09/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential Building No. 1, (Gr + 7 floor) in 23.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company**, bearing **License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on 07/08/2021 in "Form A" Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2482.07sq.mtrs.

With reference to above on **09/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- BLF Realtors Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Automatic Sprinkler System has been installed in every floor.
- C) Automatic Smoke Detection System has been installed in every floor.
- D) Hose Reel Hose has been installed in every floor
- E) Hose Box has been installed in Alternate floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Mian Pump on under ground water storage tank.
- I) Jocket Pump on under ground water storage tank.
- J) Booster Pump near over head water storage tank.
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No.487398, DD.No.002117 (PMC Bank), Dated-11/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – Mr. Umesh Gala Architect
2) Developer- M/s- BLF Realtors Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./उगनि/मुका/१८४५/२०२१-२२
दिनांक : २४/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building located on land bearing S.No.28, H.No.2 of Village: Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/704/2021-22, Dated:26/08/2021.
- 2) An application received by Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 3) An application received by M/s- BLF Realtors Pvt Ltd, Dated:24/08/2021
 - 4) Work Completion certificate of Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/371/2016-17, Dated:23/08/2016.
 - 6) Gross built up area certificate for Mr. Umesh Gala Architect, Dated:24/08/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated:07/08/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
 - 9) AMC Certificate by M/s- BLF Realtors Pvt Ltd , Dated:24/08/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/09/2021.
 - 12) Structure Stability Certificate for M/s- Finite Consultants, Dated:09/08/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-0454/0410/2017-18, Dated:25/01/2018.
 - 14) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated:10/08/2021.
 - 15) Diesel Engine Test Certificate of M/s-Arn timer Engineers & Fabricators, Dated:12/08/2021
 - 16) C.F.O. site visit Dated:09/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential Building No. 1, (Gr + 7 floor) in 23.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company**, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 07/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 2482.07sq.mtrs.

With reference to above on **09/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- BLF Realtors Pvt Ltd"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Automatic Sprinkler System has been installed in every floor.
- C) Automatic Smoke Detection System has been installed in every floor.
- D) Hose Reel Hose has been installed in every floor
- E) Hose Box has been installed in Alternate floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Mian Pump on under ground water storage tank.
- I) Jocket Pump on under ground water storage tank.
- J) Booster Pump near over head water storage tank.
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No.487398, DD.No.002117 (PMC Bank), Dated-11/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, written over the printed name.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect – Mr. Umesh Gala Architect
2) Developer- M/s- BLF Realtors Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/१८४५/२०२१-२२
दिनांक : २४/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building located on land bearing S.No.28, H.No.2 of Village: Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/704/2021-22, Dated:26/08/2021.
2) An application received by Mr. Umesh Gala Architect, Dated:24/08/2021.
3) An application received by M/s- BLF Realtors Pvt Ltd, Dated:24/08/2021
4) Work Completion certificate of Mr. Umesh Gala Architect, Dated:24/08/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/371/2016-17, Dated:23/08/2016.
6) Gross built up area certificate for Mr. Umesh Gala Architect, Dated:24/08/2021.
7) Certificate from License Agency M/s- The Fire Protection Company, Dated:07/08/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
9) AMC Certificate by M/s- BLF Realtors Pvt Ltd , Dated:24/08/2021
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/09/2021.
12) Structure Stability Certificate for M/s- Finite Consultants, Dated:09/08/2021
13) RDP issued by VVCMC/TP/RDP/VP-0454/0410/2017-18, Dated:25/01/2018.
14) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated:10/08/2021.
15) Diesel Engine Test Certificate of M/s-Arn timer Engineers & Fabricators, Dated:12/08/2021
16) C.F.O. site visit Dated:09/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential Building No. 1, (Gr + 7 floor) in 23.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company**, bearing License No. **MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on 07/08/2021 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 2482.07sq.mtrs.

With reference to above on **09/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- BLF Realtors Pvt Ltd"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Automatic Sprinkler System has been installed in every floor.
- C) Automatic Smoke Detection System has been installed in every floor.
- D) Hose Reel Hose has been installed in every floor
- E) Hose Box has been installed in Alternate floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Mian Pump on under ground water storage tank.
- I) Jocket Pump on under ground water storage tank.
- J) Booster Pump near over head water storage tank.
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No.487398, DD.No.002117 (PMC Bank), Dated-11/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – Mr. Umesh Gala Architect
2) Developer- M/s- BLF Realtors Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
त. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०९
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.प्र.म. | आग्निमुका | १४७ | २०२१
दिनांक : २४/०९/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Agro Based Industrial Building located on land bearing S.No.34, H.No.3, S.No.35 & S.No.41, H.No.1 of Village: Chinchoti, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/795/2021-22, Dated:09/09/2021.
2) An application received by M/s- Sanjay Maloo & Associates, Dated:24/08/2021.
3) An application received by M/s- Hriday Construction, Dated:18/09/2021
4) Work Completion certificate of M/s- Sanjay Maloo & Associates, Dated:24/08/2021
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/727/2019-20, Dated:14/10/2019.
6) Built up area certificate for M/s- Sanjay Maloo & Associates, Dated:01/09/2021.
7) Certificate from License Agency M/s- The Fire Protection Company, Dated:03/09/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
10) AMC Certificate by M/s- Hriday Construction, Dated:18/09/2021
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/09/2021.
12) Structure Stability Certificate for M/s- GR Consultants, Dated:30/08/2021
13) CC issued by VVCMC/TP/CC/VP-6153/227/2019-20, Dated:25/10/2019.
14) CC issued by VVCMC/TP/CC/VP-6153/96/2021-22, Dated:25/06/2021.
14) Submitted Electric Certificate M/s- Rudra Power Solutions, Dated:03/09/2021.
15) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:08/06/2021
16) C.F.O. site visit Dated:22/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Agro Based Industrial Buildings No. 2 to 8 (Grond floor) in 5.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- The Fire Protection Company**, bearing License No. **MFS-LA/2020/RF-228, MFS-LA/2020/RD-202** and has submitted Certificate on 03/09/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to Bldg No. 2 – 1285.24sq.mtrs, Bldg No. 3 – 1753.60sq.mtrs, Bldg No.4 – 2287.69sq.mtrs, Bldg No.5 – 1065.30sq.mtrs, Bldg No.6 – 1252.26sq.mtrs, Bldg No.7 – 1232.14sq.mtrs & Bldg No.8 – 2465.39sq.mtrs

With reference to above on **22/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Hriday Construction"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in electric meter room, Pump room & prominent places
- B) Hose Reel Hose has been installed in Ground floor
- C) Hose Box has been installed in Ground floor
- D) Siamese Connection has been installed in entrance gate
- E) Main Pump on under ground water storage tank.
- F) Jockey Pump on under ground water storage tank.
- G) Diesel Generator Set
- H) Manual Operated Electrical Fire Alarm System.



This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 1,70,000/-, DD.No.501833, Dated- 07/10/2019, Rs. 80,000/-, DD.No.501828, Dated- 07/10/2019, Rs. 1,70,000/-, DD.No.501834, Dated- 07/10/2019, Rs. 3,00,000/-, DD.No.501830, Dated- 07/10/2019, Rs. 1,70,000/-, DD.No.501835, Dated- 07/10/2019, Rs. 1,70,000/-, DD.No.501836, Dated- 07/10/2019, Rs. 1,70,000/-, DD.No.501837, Dated- 07/10/2019, Rs. 3,00,000/-, DD.No.501831, Dated- 07/10/2019 of The Catholic Syrian Bank Ltd.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**


Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Sanjay Maloo & Associates
2) Developer- M/s- Hriday Construction.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on our www.mfsindia.org.



मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१८६१/२०२१
दिनांक : २०/०६/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Restaurant Building located on land bearing S.No.5, & S.No.B of Village: Tarkhad, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1442/2021-22,
Dated: 24/12/2021.

- 2) An application received by M/s- Ar. Umesh Kekre, Dated: 29/12/2021.
- 3) An application received by Developer Mr. Prakash Patil, Dated: 08/06/2021
- 4) Work Completion certificate of M/s- Ar. Umesh Kekre, Dated: 05/01/2022
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/745/2020-21,
Dated:24/12/2020.
- 6) Gross Built up area certificate for M/s- Ar. Umesh Kekre, Dated:22/04/2021.
- 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:05/08/2021
(Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
- 9) AMC Certificate by Developer Mr. Prakash Patil, Dated:08/06/2021
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/06/2021.
- 11) Structure Stability Certificate for M/s- S.S & Associates, Dated:29/12/2021.
- 12) CC issued by VVCMC/TP/CC/VP-SPA-VP-0090/043/2020-21, Dated:19/01/2021.
- 13) Submitted Electric Certificate M/s- Max Electricals, Dated: 29/12/2021.
- 14) C.F.O. site visit Dated: 08/06/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Restaurant Building (Gr + 1 floor) in 6.50mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sadanand Fire Services, bearing License No. MFS-LA/RF-332, MFS-LA/RD-305** and has submitted Certificate on **05/08/2021** in **"Form A"** Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring 1692.73sq.mtrs.

With reference to above on **08/06/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr. Prakash Patil"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places – 17 Nos.
- B) Hose Reel Hose has been installed in every floor – 01 Nos.
- C) Hose Box has been installed in Alternate floor – 03 Nos.
- D) Siamese Connection has been installed in entrance gate – 01 Nos.
- E) Courtyard Hydrant has been installed in the building & prominent places. – 02 Nos.
- F) Main Pump on under ground water storage tank – 01 Nos.
- G) Fire Alarm System – 01 Nos.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.


Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 80,000/- vide Receipt No.819658, DD.No.099356,, Dated- 25/11/2020 of Vasai Vikas Sahakari Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Ar.Umesh Kekre
2) Developer- Mr. Prakash Patil

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/१८४६/२०२१-२२
दिनांक : २४/०९/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Industrial Building on land bearing S.No.46, H.No.2/9 (Old), S.No.1 & 2 (New) of Village: Bilalpada, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/816/2021-22, Dated:17/09/2021.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:22/09/2021.
 - 3) An application received by Mr. Deepak B. Vora, Dated:22/09/2021
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:22/09/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/271/2019-20, Dated:26/06/2019.
 - 6) Gross built up area certificate for M/s- Ajay Wade & Associates, Dated:22/09/2021.
 - 7) Certificate from License Agency M/s- The Fire Protection Company, Dated:17/05/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2021.
 - 9) AMC Certificate by Mr. Deepak B. Vora, Dated:22/09/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/09/2021.
 - 12) Structure Stability Certificate for M/s- Unnarkar's Group of Companies, Dated:06/09/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-5318/631/2020-21, Dated:12/11/2020.
 - 14) Submitted Electric Certificate M/s- Zip Engineers, Dated:08/06/2021.
 - 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:11/12/2015
 - 16) O.F.O. site visit Dated:22/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Industrial Building No. 2, (Gr + 2 floor) in 15.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- The Fire Protection Company, bearing License No. MFS-LA/2020/RF-228, MFS-LA/2020/RD-202 and has submitted Certificate on 17/05/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3990.13sq.mtrs.

With reference to above on 22/09/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by " Mr. Deepak B. Vora " following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in Electric meter room, Pump room & prominent places
- B) Automatic Sprinkler System has been installed in lift lobby & common corridor at each floor level.
- C) Automatic Smoke Detection System has been installed in prominent places
- D) Hose Reel Hose has been installed in every floor
- E) Hose Box has been installed in Alternate floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Mian Pump on under ground water storage tank.



०८
B
24/9/21
7049095950

- I) Jockey Pump on under ground water storage tank.
- J) Sprinkler Pump on under ground water storage tank.
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 5,00,000/- vide Receipt No.609540, DD.No.124006 (Bharat Bank), Dated-16/01/2018 & Rs. 5,00,000/- vide Receipt NO. 609541, DD.No.124007 (Bharat Bank), Dated-16/01/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely belonging to the Chief Fire Officer.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- Mr.Deepak B. Vora

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from License Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म.अग्नि/मुका/१९२२/२०२१
दिनांक : २७/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Godown / Ware house Building & CFC Building Plot No.4, located on S.No.20, H.No.C/2 & S.No.22, H.No.1 (Old), S.No.20/C/2/4 (New) of Village: Sativali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/632/2021-22, Dated:17/08/2021.
2) An application received by M/s- En Con Project Consultants, Dated:12/08/2021.
3) An application received by Developer Mr. Harakchand P. Shah, Dated:19/07/2021
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:12/08/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/113/2019-20, Dated:10/05/2019.
6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:12/08/2021.
7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:12/08/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
9) AMC Certificate by Mr. Harakchand P. Shah, Dated:19/07/2021
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:02/09/2021.
12) Structure Stability Certificate for M/s- S.S & Associates, Dated:12/08/2021
13) RDP issued by VVCMC/TP/RDP/VP-5419B/53/2019-20, Dated:18/07/2019.
14) Submitted Electric Certificate M/s-Pradhan Electrical Works, Dated:25/08/2021.
15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:07/12/2021
16) C.F.O. site visit Dated:02/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Godown /Ware House Building No.1 (Gr + 1Pt floor) in 10.90mtrs Height & CFC Building Gr + 1Pt floor) in 9.30mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305 and has submitted Certificate on 12/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Godown / Wear house Bldg No. 1 – 1338.40sq.mtrs. & CFC Bldg – 108.45sq.mtrs

With reference to above on 02/09/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr. Harakchand P. Shah" following Fire Fighting arrangements provided were found in satisfactory working condition.

- Portable Fire Extinguishers has been installed in Lift machine room, Electric meter room & prominent places
- Hose Reel Hose has been installed in every floor
- Hose Box has been installed in Alternate floor
- Siamese Connection has been installed in entrance gate
- Courtyard Hydrant has been installed in the building & prominent places.
- Mian Pump on under ground water storage tank.
- Booster Pump near over head water storage tank.
- Diesel Generator Set
- Manual Operated Electrical Fire Alarm System.

Handwritten signature and initials in blue ink.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,50,000/- vide Receipt No.779292, DD.No.709593 (Bank of India), Dated-10/05/2019; Rs. 2,50,000/- vide Receipt No.779290, DD.No.709595 (Bank of India), Dated-10/05/2019; Rs. 2,40,000/- vide Receipt No.779289, DD.No.709594 (Bank of India), Dated-10/05/2019 & Rs. 2,50,000/- vide Receipt No.779291, DD.No.709596 (Bank of India), Dated-10/05/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- Mr. Harakchand P. Shah.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०९
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१९४५/२०२१
दिनांक : २०/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Godown / Ware house Building & CFC Building Plot No.1, located on S.No.20, H.No.C/2 & S.No.22, H.No.1 (Old), S.No.20/C/2/1 (New) of Village: Sativali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/630/2021-22, Dated:17/08/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:12/08/2021.
 - 3) An application received by Developer Mr. Satish R. Prasad, Dated:19/07/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:12/08/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/113/2019-20, Dated:10/05/2019.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:12/08/2021.
 - 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:12/08/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate by Mr. Satish R. Prasad, Dated:19/07/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:02/09/2021.
 - 12) Structure Stability Certificate for M/s- S.S & Associates, Dated:12/08/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-5419B/53/2019-20, Dated:18/07/2019.
 - 14) Submitted Electric Certificate M/s-Pradhan Electrical Works, Dated:25/08/2021.
 - 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:07/12/2021
 - 16) C.F.O. site visit Dated:02/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Godown /Ware House Building (Gr + 1Pt floor) in 11.00mtrs Height & CFC Building Gr + 1Pt floor) in 9.40mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305** and has submitted Certificate on 12/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to Godown / Wear house Bldg – 1369.25sq.mtrs. & CFC Bldg – 107.30sq.mtrs

With reference to above on **02/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr.Satish R. Prasad"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in Lift machine room, Electric meter room & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank.
- G) Booster Pump near over head water storage tank.
- H) Diesel Generator Set
- I) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,50,000/- vide Receipt No.779292, DD.No.709593 (Bank of India), Dated-10/05/2019; Rs. 2,50,000/- vide Receipt No.779290, DD.No.709595 (Bank of India), Dated-10/05/2019; Rs. 2,40,000/- vide Receipt No.779289, DD.No.709594 (Bank of India), Dated-10/05/2019 & Rs. 2,50,000/- vide Receipt No.779291, DD.No.709596 (Bank of India), Dated-10/05/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, positioned above the official title.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- Mr. Satish R. Prasad.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/१८४६/२०२१
दिनांक : २७/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Godown / Ware house Building & CFC Building Plot No.2, located on S.No.20, H.No.C/2 & S.No.22, H.No.1 (Old), S.No.20/C/2/2 (New) of Village: Sativali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/631/2021-22, Dated:17/08/2021.
2) An application received by M/s- En Con Project Consultants, Dated:12/08/2021.
3) An application received by Developer Mr. Kantilal P. Shah, Dated:19/07/2021
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:12/08/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/113/2019-20, Dated:10/05/2019.
6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:12/08/2021.
7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:12/08/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
9) AMC Certificate by Mr. Kantilal P. Shah, Dated:19/07/2021
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:02/09/2021.
12) Structure Stability Certificate for M/s- S.S & Associates, Dated:12/08/2021
13) RDP issued by VVCMC/TP/RDP/VP-5419B/53/2019-20, Dated:18/07/2019.
14) Submitted Electric Certificate M/s-Pradhan Electrical Works, Dated:25/08/2021.
15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:07/12/2021
16) C.F.O. site visit Dated:02/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Godown /Ware House Building (Gr + 1Pt floor) in 10.95mtrs Height & CFC Building Gr + 1Pt floor) in 9.35mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305 and has submitted Certificate on 12/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to Godown / Wear house Bldg – 1370.85sq.mtrs. & CFC Bldg – 107.65sq.mtrs

With reference to above on **02/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr. Kantilal P. Shah"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- Portable Fire Extinguishers has been installed in Lift machine room, Electric meter room & prominent places
- Hose Reel Hose has been installed in every floor
- Hose Box has been installed in Alternate floor
- Siamese Connection has been installed in entrance gate
- Courtyard Hydrant has been installed in the building & prominent places.
- Mian Pump on under ground water storage tank.
- Booster Pump near over head water storage tank.
- Diesel Generator Set
- Manual Operated Electrical Fire Alarm System.

EN CON

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,50,000/- vide Receipt No.779292, DD.No.709593 (Bank of India), Dated-10/05/2019; Rs. 2,50,000/- vide Receipt No.779290, DD.No.709595 (Bank of India), Dated-10/05/2019; Rs. 2,40,000/- vide Receipt No.779289, DD.No.709594 (Bank of India), Dated-10/05/2019 & Rs. 2,50,000/- vide Receipt No.779291, DD.No.709596 (Bank of India), Dated-10/05/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- Mr. Kantilal P. Shah

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from License Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१२४०/२०२१
दिनांक : २७/०८/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Godown / Ware house Building No.1, Building No.2 & CFC Building Plot No. 3, located on S.No.20, H.No.C/2 & S.No.22, H.No.1 (Old), S.No.20/C/2/3 (New) of Village: Sativali, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/633/2021-22,
Dated:17/08/2021.

- 2) An application received by M/s- En Con Project Consultants, Dated:12/08/2021.
- 3) An application received by Developer Mr. Sanjay V. Savla, Dated:16/07/2021
- 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:12/08/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/113/2019-20, Dated:10/05/2019.
- 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:12/08/2021.
- 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:12/08/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
- 9) AMC Certificate by Mr. Sanjay V. Savla, Dated:16/07/2021
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:02/09/2021.
- 12) Structure Stability Certificate for M/s- S.S & Associates, Dated:12/08/2021
- 13) RDP issued by VVCMC/TP/RDP/VP-5419B/53/2019-20, Dated:18/07/2019.
- 14) Submitted Electric Certificate M/s-Pradhan Electrical Works, Dated:25/08/2021.
- 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:07/12/2021
- 16) C.F.O. site visit Dated:02/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Godown /Ware House Building No. 1 (Gr + 1Pt floor) in 11.00mtrs Height; Building No. 2 (Ground floor) in 5.90mtrs Height & CFC Building Gr + 1Pt floor) in 9.40mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305 and has submitted Certificate on 12/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Godown / Wear house Bldg No.1 - 729.34sq.mtrs; Bldg No.2 - 669.74sq.mtrs & CFC Bldg - 94.82sq.mtrs

With reference to above on 02/09/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr. Sanjay V. Savla" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in Lift machine room, Electric meter room & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank.
- G) Booster Pump near over head water storage tank.
- H) Diesel Generator Set
- I) Manual Operated Electrical Fire Alarm System.

Ther
ENCON

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,50,000/- vide Receipt No.779292, DD.No.709593 (Bank of India), Dated-10/05/2019; Rs. 2,50,000/- vide Receipt No.779290, DD.No.709595 (Bank of India), Dated-10/05/2019; Rs. 2,40,000/- vide Receipt No.779289, DD.No.709594 (Bank of India), Dated-10/05/2019 & Rs. 2,50,000/- vide Receipt No.779291, DD.No.709596 (Bank of India), Dated-10/05/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants

2) Developer- Mr. Sanjay V. Savla

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/१९५९/२०२९
दिनांक : २०/०९/२०२९



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Part Final No Objection Certificate" of Residential Building located on S.No.38, H.No.1/1, 1/2, 1/3, 1/4, & 1/5 (Old), S.No.38/B, Plot No.1, 2, 3, 4, 5, 6, 7 (New) of Village: Waliv, Tal: Vasai, Dist:Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/779/2021-22, Dated:03/09/2021.

- 2) An application received by M/s- En Con Project Consultants, Dated:01/09/2021.
- 3) An application received by M/s- Zar Builders & Developers, Dated:22/07/2021
- 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:01/09/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2281/2019-20, Dated:24/02/2020.
- 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:01/09/2021.
- 7) Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:03/08/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:06/10/2020.
- 9) AMC Certificate by Developer M/s- Zar Builders & Developers, Dated:23/08/2021.
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:29/09/2021.
- 12) Structure Stability Certificate for M/s- Jay Shree Krishna Consulting Engineer, Dated:29/09/2021
- 13) RDP issued by VVCMC/TP/RDP/VP-5391/122/2021-22, Dated:07/05/2021.
- 14) CC issued by VVCMCR/TP/CC/VP-5391/1776/2013-14, Dated:05/10/2013.
- 15) Submitted Electric Certificate M/s- Shrinath Enterprises, Dated:16/08/2021.
- 16) Diesel Engine Test Certificate of M/s- Ashok Leyland, Dated:31/03/2021.
- 17) C.F.O. site visit Dated:24/09/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential Building No. 1 (Wing- A to E) (Stilt + Stilt / Gr + 7th floor) in 20.30mtr Height; (43.50mtr total building Height) at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/2020/RF-226, MFS-LA/2020/RD-200 and has submitted Certificate on 03/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing- A to E - 16622.24sq.mtrs.

With reference to above on 24/09/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Zar Builders & Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places - 45 Nos.
- B) Hose Reel Hose has been installed in every floor - 38 Nos.
- C) Hose Box has been installed in Alternate floor - 30 Nos.
- D) Siamese Connection has been installed in entrance gate - 1 Nos.
- E) Courtyard Hydrant has been installed in the building & prominent places - 48 Nos.
- F) Mian Pump on under ground water storage tank (75hp) - 1 Nos.
- G) Sprinkler Pump on under ground water storage tank (75hp) - 1 Nos.
- H) Stand by Pump on under ground water storage tank (75hp) - 1 Nos.
- I) Jockey Pump on under ground water storage tank (10hp) - 2 Nos.
- J) Booster Pump near over head water storage tank (10hp) - 5 Nos.

Hon
ENCM

- K) 2 way Siamese Connection – 1 Nos.
- L) Sprinkler Bulb installed in car parking & lobbies every floor – 292 Nos.
- M) Smoke Detectors – 10 Nos.
- N) Hooter- 45 Nos.
- O) Manual Operated Electrical Fire Alarm System.- 45 Nos.
- P) Diesel Generator Set

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 15,75,000/-, vide Receipt No.818861 (Bassein Catholic Bank), Dated:21/12/2019 & Rs.15,000/- vide Receipt No. 819048 (Syndicate Bank), Dated:24/02/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s-Zar Builders & Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/१९६७/२०२९
दिनांक : ०९/१०/२०२९

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential With Shopline Building Wing- F & G & Residential with Shopline Building & 1st Floor Party Office Wing-H in Avenue "L5" & Wing- I in Avenue "L6" & Garden Podium on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village: Dongre, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/540/2021-22, Dated:29/07/2021.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:24/07/2021.
 - 3) An application received by M/s- Poonam Developers, Dated:10/07/2021
 - 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:24/07/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/878/2017-18, Dated:10/01/2018.
 - 6) Gross Built up area certificate for M/s- Shah Gattani Consultants, Dated:24/07/2021.
 - 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated: 08/10/2020 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate by M/s- Poonam Developers, Dated:10/07/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/08/2021.
 - 12) Structure Stability Certificate for M/s- JW Consultants LLP, Dated:27/03/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0453/0025/2018-19, Dated:14/08/2018.
 - 14) Submitted Electric Certificate M/s- Jay Vagheshvari Electricals; Aim Realty Engineering Pvt Ltd & Jignesh Vidyut Service, Dated:13/05/2021 & 06/05/2021.
 - 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:02/04/2021
 - 16) C.F.O. site visit Dated:07/08/2021.

With reference to Sr.No.2 & 3 above, this office is in received of your application for your **Residential With Shopline Building Wing- F & G(Stilt / Gr + 14 Pt) in 44.95mtrs Height, Wing- H (Stilt / Gr + 14 floor) in 44.95mtrs Height & Wing-I (Stilt / Gr + 14 Pt) in 44.95mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/RF-332, MFS-LA/RD-305** and has submitted Certificate on 08/10/2020 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"**.

With reference to above on **07/08/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Poonam Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank.
- G) Jockey Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.

- I) Diesel Generator Set
- J) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 24,65,000/- vide Receipt No.609502, DD.No.845049 (Vasai Vikas Sahakari Bank), Dated: 26/12/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s-Poonam Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./प्रग्नि/मुका/२६७०/२०२१
दिनांक : ०९/१०/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No. 6A, (Wing-C & D) (Stilt / Gr + 16 floor) located on land bearing S.No.345(Pt), S.No.346, H.No.1, S.No.347, S.No.348, H.No.2, S.No.350, S.No.349, S.No.339, H.No.1, S.No.352, H.No.3, S.No.351, H.No.4A, 4B & 6, S.No.331, H.No.1, 2, 3, 4 & 5, S.No.317, H.No.6A, 6B, 6C & 6D, S.No.332, H.No.9, S.No.352, H.No.4 of Village: Juchandra, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1255/2020-21, Dated:18/03/2021.

- 2) An application received by M/s- Ajay Wade & Associates, Dated:15/03/2021.
- 3) An application received by M/s- Raj Maitry & Eskon Developers, Dated:15/03/2021
- 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:15/03/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/045/2015-16, Dated:03/07/2015.
- 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:15/03/2021.
- 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:31/07/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
- 9) AMC Certificate by M/s- Raj Maitry & Eskon Developers, Dated:15/03/2021
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/03/2021.
- 12) Structure Stability Certificate for M/s- Haresh L. Patel, Dated:15/01/2020.
- 13) RDP issued by VVCMC/TP/RDP/VP-0880/095/2014-15, Dated:31/07/2014.
- 14) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated:09/03/2021.
- 15) Diesel Engine Test Certificate of M/s- VE Commercial Vehicles, Dated:31/03/2014
- 16) C.F.O. site visit Dated:28/03/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential with Shopline Building No. 6A, (Wing- C & D) (Stilt / Gr + 16 floor) in 49.95mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305 and has submitted Certificate on 31/07/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to (Wing-C) 2345.48sq.mtrs & (Wing- D) 3194.05sq.mtrs.

With reference to above on **28/03/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Raj Maitry & Eskon Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Automatic Sprinkler System has been installed in lift lobby / common passage at each floor
- C) Smoke Detector System has been installed in Lift machine room & Electrical meter room
- D) Hose Reel Hose has been installed in every floor
- E) Hose Box has been installed in Alternate floor
- F) Siamese Connection has been installed in entrance gate
- G) Courtyard Hydrant has been installed in the building & prominent places.
- H) Mian Pump on under ground water storage tank.
- I) Jockey Pump on under ground water storage tank.

- J) Booster Pump near over head water storage tank.
- K) Sprinkler Pump on under ground water storage tank.
- L) Diesel Generator Set
- M) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 36,15,000/- vide Receipt No.187160, DD.No 019436 (Indian Bank), Dated-24/06/2015.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, written over the official stamp.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s- Raj Maitry & Eskon Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१२७२/२०२१
दिनांक : ०९/१०/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building located on land bearing S.No.101B, H.No.1 & 2 of Village: Tulinj, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/798/2021-22, Dated:09/09/2021.
2) An application received by M/s- Sanat Mehta & Associates, Dated:30/08/2021.
3) An application received by Developer M/s- Shree Sadguru Enterprises, Dated:28/08/2021
4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:30/08/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/874/2018-19, Dated:24/10/2018.
6) Construction area certificate for M/s- Sanat Mehta & Associates, Dated:30/08/2021.
7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:12/08/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
9) AMC Certificate by Developer M/s- Shree Sadguru Enterprises, Dated:28/08/2021
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/09/2021.
12) Structure Stability Certificate for M/s- Shilplekha Consultants, Dated:03/09/2021
13) RDP issued by VVCMC/TP/RDP/VP-0759/176/2019-20, Dated:25/10/2019.
14) Submitted Electric Certificate M/s-Amar Electrical, Dated:30/08/2021.
15) Diesel Engine Test Certificate of M/s- Nidec Industrial Automation India Pvt Ltd, Dated:12/04/2021.
16) C.F.O. site visit Dated:28/09/2021.

With reference to Sr.No.2 & 3 above, this office is in received of your application for your **Residential Building (Stilt / Gr + 9th floor) in 29.15mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305** and has submitted **Certificate on 12/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 5699.88sq.mtrs.

With reference to above on **28/09/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-Shree Sadguru Enterprises"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in Lift machine room, Electric meter room, Pump room, every floor & prominent places – 4 Nos.
- B) Hose Reel Hose has been installed in every floor – 1 No.
- C) Hose Box has been installed in Alternate floor – 14 Nos.
- D) Siamese Connection has been installed in entrance gate
- E) Down Comer – 2 Nos.
- F) Courtyard Hydrant has been installed in the building & prominent places – 4 Nos.
- G) Mian Pump on under ground water storage tank.
- H) Booster Pump near over head water storage tank.
- I) Smoke Detectors – 2 Nos.
- J) Diesel Generator Set
- K) Manual Operated Electrical Fire Alarm System.- 18 Nos.

o/c
Shivar J.
04/10/21

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No.470138, DD.No.026517, Dated-29/04/2016 & Rs.90,000/- vide Receipt No. 705536, DD.No.027998 (Bassein Catholic Bank), Dated-08/10/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Sanat Mehta & Associates
2) Developer- M/s-Shree Sadguru Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फॅक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : व.वि.श.म./अग्नि/मुका/४३३८/२०२१

दिनांक : ०९/१२/२०२१.



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential With Shopline Building on Plot Bearing S.No.224, H.No. 2 of Village: Nilemore, Tal: Vasai, Dist:Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1135/2021-22, Dated: 10/11/2021.
- 2) An application received by M/s- Abhay Raut, Dated: 01/11/2021.
 - 3) An application received by Developer Mr. Ashok Mehta & Mr. Manik Mehta, Dated: 28/10/2021
 - 4) Work Completion certificate of M/s- Abhay Raut, Dated: 01/11/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1125/2020-21, Dated: 31/03/2021.
 - 6) Gross built up area certificate for M/s- Abhay Raut, Dated:01/11/2021.
 - 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:29/10/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate by Developer Mr. Ashok Mehta & Mr. Manik Mehta, Dated:29/10/2021.
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/11/2021.
 - 12) Structure Stability Certificate for Mr. Paresh Unnarkar, Dated: 30/10/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-5894/120/2021-22, Dated: 07/05/2021.
 - 14) Submitted Electric Certificate M/s- R.R. Electricals, Dated: 30/10/2021.
 - 15) Diesel Engine Test Certificate of M/s- Stamford, Dated: 07/01/2021.
 - 16) C.F.O. site visit, Dated:17/11/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building No. 1 (Part Stilt + Part Gr + 12th floor) in 39.00mtr Height, at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305 and has submitted Certificate on 29/10/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2381.82sq.mtrs.

With reference to above on 17/11/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr. Ashok Mehta & Mr. Manik Mehta" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 16 Nos.
- B) Hose Reel Hose has been installed in every floor – 12 Nos.
- C) Hose Box has been installed in Alternate floor – 10 Nos.
- D) Siamese Connection has been installed in entrance gate – 1 Nos.
- E) Courtyard Hydrant has been installed in the building & prominent places – 04 Nos.
- F) Mian Pump on under ground water storage tank - 01 Nos.
- G) Sprinkler Pump on under ground water storage tank – 01 Nos.
- H) Stand by Pump on under ground water storage tank – 01 Nos.
- I) Jockey Pump on under ground water storage tank – 01 Nos.
- J) Booster Pump near over head water storage tank – 01 Nos.

Received
11/12/2021

- K) Siamese Connection – 1 Nos.
- L) Smoke Detectors in Lift Room, Lobby & Meter Room.
- M) Heat Detectors in Kitchen Area.
- N) Diesel Generator Set

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,22,500/-, vide Receipt No.636022, DD.No. 022307, Dated:19/03/2018 & Rs.2,22,500/- vide Receipt No. 636023, DD.No. 845152, Dated: 19/03/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, written over the official stamp.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect – Mr.Abhay Raut
2) Developer- Mr. Ashok Mehta & Mr. Manik Mehta

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४३४७/२०२९
दिनांक : २२/१०/२०२९

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Agarwal Builders,
Shop No. 9,
Gokul Annexe,
Opp Muljibhai Mehta School,
Agarwal Gardens, Gokul Township,
Bolinj, Virar (W),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Residential Building Known as "AGARWAL SOLITAIRE" in Sector II, on land bearing S.No.9, H.No.1, 2, 3/1, 3/2, 4, S.No.70, H.No.4, 5/1 of Village: Dongare, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Agarwal Builders, Dated:09/04/2021.
2. This office Renewal of Final No Objection Certificate No. VVCMC/ FIRE/ HQ/ 2442/2019, Dated:31/03/2020.
3. This office Final No Objection Certificate No. VVCMC/FIRE/116/2015-16, Dated:05/08/2015
4. Certificate from License Agency M/s- Shree FIREGUARD Co, Dated:28/04/2021 (Form- B)
5. AMC Certificate by Developer M/s- Agarwal Builders, Dated: 19/08/2021
6. Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2021.
8. Electric Certificate M/s- Jignesh Vidyut Service, Dated:06/08/2021
9. C.F.O site visit Dated:23/09/2021

With reference to Sr.No.1 above, this office is in received of your application for your Residential Building No. 2 (Wing- A to E) (Gr + 12 floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree FIREGUARD Co. bearing License No. MFS-LA/2020/RF-270 & MFS-LA/2020/RD-243 and has submitted Certificate On 28/04/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 1,00,000/- vide Receipt No. 895480, Book No. 8955, DD .No.026576 (Axis Bank), Dated:01/06/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **Any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/२३४८/२०२१
दिनांक : २२/१०/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Viva Gokul Builders,
Shop No. 9,
Gokul Annexe,
Opp Muljibhai Mehta School,
Agarwal Gardens, Gokul Township,
Bolinj, Virar (W),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Commercial Building Known as "VIVA GOKUL ARCADE" Type- J in Viva Gokul Complex on land bearing S.No.334, H.No.1 to 33, 6/2 of Village: Bolinj, Virar (W), Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Viva Gokul Builders, Dated:09/04/2021.
2. This office Renewal of Final No Objection Certificate No. VVCMC/ FIRE/ HQ/ 2314, Dated:02/03/2020.
3. This office No Objection Certificate No. VVCMC/FIRE/21/2011-12, Dated:25/04/2011
4. Certificate from License Agency M/s- Shree FIREGUARD Co, Dated:28/04/2021 (Form- B)
5. AMC Certificate by Developer M/s- Viva Gokul Builders, Dated:19/08/2021
6. Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2021.
8. Electric Certificate M/s- Jignesh Vidyut Service, Dated:06/08/2021
9. C.F.O site visit Dated:23/09/2021

With reference to Sr.No.1 above, this office is in received of your application for your Commercial Building Type-J (Gr + 4floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree FIREGUARD Co. bearing License No. MFS-LA/2020/RF-270 & MFS-LA/2020/RD-243 and has submitted Certificate On 28/04/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 37,500/- vide Receipt No. 895478, Book No. 8955, DD .No.026577 (Axis Bank), Dated:01/06/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४३४८/२०२१
दिनांक : २२/१०/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Surbhi Developers,
Shop No. 9,
Gokul Annexe,
Opp Muljibhai Mehta School,
Agarwal Gardens, Gokul Township,
Bolinj, Virar (W),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Community Hall Building, Type CFC-3, Known as "COMMUNITY HALL" on land bearing Sr.No.164 at Gokul Township of Village: Bolinj, Virar (W), Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Surbhi Developers, Dated:09/04/2021.
2. This office Renewal of Final No Objection Certificate No. VVCMC/ FIRE/ HQ/ 2315, Dated:02/03/2020.
3. This office No Objection Certificate No. VVCMC/FIRE/390/2014-15, Dated:27/01/2015
4. Certificate from License Agency M/s- Shree FIREGUARD Co, Dated:28/04/2021 (Form- B)
5. AMC Certificate by Developer M/s- Surbhi Developers, Dated: 19/08/2021
6. Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2021.
8. Electric Certificate M/s- Jignesh Vidyut Service, Dated:06/08/2021
9. C.F.O site visit Dated:23/09/2021

With reference to Sr.No.1 above, this office is in received of your application for your Community Hall Building, Type CFC - 3 (Stilt / Gr + 3 floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree FIREGUARD Co. bearing License No. MFS-LA/2020/RF-270 & MFS-LA/2020/RD-243 and has submitted Certificate On 28/04/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 10,000/- vide Receipt No. 895477, Book No. 8955, DD .No.026578 (Axis Bank), Dated:01/06/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४३५०/२०२१
दिनांक : २२/१०/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Surbhi Developers,
Shop No. 9,
Gokul Annexe,
Opp Muljibhai Mehta School,
Agarwal Gardens, Gokul Township,
Bolinj, Virar (W),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Assembly Building, Situated near Gokul Solitaire Building on land bearing Sr.No.164 at Gokul Township Village: Bolinj, Virar (W), Tal- Vasai, Dist-Palghar.

- Ref: -
1. An application received by M/s- Surbhi Developers, Dated:09/04/2021.
 2. This office Renewal of Final No Objection Certificate No. VVCMC/ FIRE/ HQ/ 2319, Dated:02/03/2020.
 3. This office No Objection Certificate No. VVCMC/FIRE/128/2011-12, Dated:25/10/2011
 4. Certificate from License Agency M/s- Shree FIREGUARD Co, Dated:28/04/2021 (Form- B)
 5. AMC Certificate by Developer M/s- Surbhi Developers, Dated: 19/08/2021
 6. Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
 7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2021.
 8. Electric Certificate M/s- Jignesh Vidyut Service, Dated:06/08/2021
 9. C.F.O site visit Dated:23/09/2021

With reference to Sr.No.1 above, this office is in received of your application for your Assembly Building (Gr + 3Pt floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree FIREGUARD Co. bearing License No. MFS-LA/2020/RF-270 & MFS-LA/2020/RD-243 and has submitted Certificate On 28/04/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 21,250/- vide Receipt No. 895479, Book No. 8955, DD .No.026583 (Axis Bank), Dated:01/06/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. / अ.वि. / म.क. / ४२६६ / २९-२२
दिनांक : २२-१०-२०२१



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of School Building on land bearing S.No.22, H.No.1,
Plot No. A & B of Village: Waliv, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/881/2021-22,
Dated: 23/09/2021.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:08/09/2021.
 - 3) An application received by Developer M/s- Karuna Welfare, Dated:05/08/2021
 - 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:20/08/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/2152/2019-20,
Dated: 17/01/2020.
 - 6) Gross built up area certificate for M/s- Shah Gattani Consultants, Dated:08/09/2021.
 - 7) Certificate from License Agency M/s- Bright Infra System Pvt Ltd, Dated:09/06/2021
(Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:04/09/2021.
 - 9) AMC Certificate by Developer M/s- Karuna Welfare, Dated:05/08/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/10/2021.
 - 12) Structure Stability Certificate for M/s- Shah Gattani Consultants,
Dated:08/09/2021
 - 13) CC issued by CIDCO/VVSR/CC/BP-2496/E/992, Dated: 31/12/2004.
 - 14) Submitted Electric Certificate M/s- Rumao Electrical, Dated:13/07/2021.
 - 15) Diesel Engine Test Certificate of M/s- East West Energy System Pvt Ltd.
 - 16) C.F.O. site visit Dated:12/10/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your School Building (Gr + 3 floor) in 17.40mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Bright Infra System Pvt Ltd, bearing License No. MFS-LA/RF-350, MFS-LA/RD-324 and has submitted Certificate on 09/06/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3496.92sq.mtrs.

With reference to above on 12/10/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Karuna Welfare" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places - 12 Nos.
- B) Wet Riser - 2 Nos
- C) Hose Reel Hose has been installed in every floor - 8 Nos.
- D) Hose Box has been installed in Alternate floor - 13 Nos.
- E) Courtyard Hydrant has been installed in the building & prominent places - 5 Nos.
- F) Mian Pump on under ground water storage tank (30hp) - 1 Nos.
- G) Stand by Pump on under ground water storage tank (30hp) - 1 Nos.
- H) Jockey Pump on under ground water storage tank (5.5hp) - 1
- I) Manual Call point cum Hotter - 8 Nos.
- J) Diesel Generator Set
- K) Manual Operated Electrical Fire Alarm System.- 2 Nos.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 46,000/- vide Receipt No. 9630, DD. No. 010012, (Uti Bank), Dated: 30/12/2004 & Rs.4,34,000/- vide Receipt No. 714271, DD.No.029800 (Axis Bank), Dated: 29/10/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s- Karuna Welfare

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.

प्रतमिकाली

लिपिक (न.र.)
ई-विरार शहर महानगरपालिका
फ. २३/११/२०२१



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०९
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अभि/मुळ/५३७७/२०२२
दिनांक : २२-१०-२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Hostel Building on land bearing S.No.22, H.No.1, Plot No. A & B of Village: Waliv, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/882/2021-22, Dated: 23/09/2021.

- 2) An application received by M/s- Shah Gattani Consultants, Dated:08/09/2021.
- 3) An application received by Developer M/s- Karuna Welfare, Dated:05/08/2021
- 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:20/08/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/2151/2019-20, Dated: 17/01/2020.
- 6) Gross built up area certificate for M/s- Shah Gattani Consultants, Dated:08/09/2021.
- 7) Certificate from License Agency M/s- Bright Infra System Pvt Ltd, Dated:09/06/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:04/09/2021.
- 9) AMC Certificate by Developer M/s- Karuna Welfare, Dated:05/08/2021
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/10/2021.
- 12) Structure Stability Certificate for M/s- Shah Gattani Consultants, Dated:08/09/2021
- 13) CC issued by CIDCO/VVSR/AM/BP-2496/E/546, Dated: 11/01/2009.
- 14) Submitted Electric Certificate M/s- Rumao Electrical, Dated:13/07/2021.
- 15) Diesel Engine Test Certificate of M/s- East West Energy System Pvt Ltd.
- 16) C.F.O. site visit Dated:12/10/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Hostel Building (Gr + 2 floor) in 9.90mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Bright Infra System Pvt Ltd, bearing License No. MFS-LA/RF-350, MFS-LA/RD-324** and has submitted Certificate on 09/06/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1923.43sq.mtrs.

With reference to above on 12/10/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Karuna Welfare" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 8 Nos.
- B) Wet Riser – 2 Nos
- C) Hose Reel Hose has been installed in every floor – 6 Nos.
- D) Hose Box has been installed in Alternate floor – 10 Nos.
- E) Siamese Connection has been installed in entrance gate
- F) Courtyard Hydrant has been installed in the building & prominent places – 4 Nos.
- G) Mian Pump on under ground water storage tank (30hp) - 1 Nos.
- H) Stand by Pump on under ground water storage tank (30hp) – 1 Nos.
- I) Jockey Pump on under ground water storage tank (5.5hp) – 1
- J) Manual Call point cum Hotter – 6 Nos.
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.- 2 Nos.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,70,000/- vide Receipt No. 714272, DD. No. 029949, (Axis Bank), Date:27/10/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s- Karuna Welfare

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुठा/४४०२/२०२१
दिनांक : २०/१०/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building No. 7 (Wing-A) in Sector – II of HDIL lay out of Village: Bolinj, Dongre & Chikhal Dongari , Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/490/2020-21, Dated: 30/09/2020.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:24/09/2020
 - 3) An application received by Developer M/s- Labh Associates, Dated: 01/09/2021.
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:24/09/2020.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/75/2012-13, Dated: 27/07/2012.
 - 6) Gross built up area certificate for M/s- Ajay Wade & Associates, Dated:24/09/2020.
 - 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:15/02/2020 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate Developer by M/s- Labh Associates , Dated:01/09/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/01/2020.
 - 12) Structure Stability Certificate for M/s- Shah Gattani Consultats, Dated:07/09/2020.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0880/037/2014-15, Dated:15/05/2014.
 - 14) Submitted Electric Certificate M/s- Jignesh Electicals, Dated: 21/10/2020
 - 15) Diesel Engine Test Certificate M/s- Stamford, Dated: 02/01/2020.
 - 16) C.F.O. site visit Dated:01/09/2021.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Residential Building No. 7 (Wing- A) as (Stilt / Gr + 12) in 37.85mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/RF-332 & MFS-LA/RD-305** and has submitted Certificate on 15/02/2020 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 3953.14sq.mtrs.

With reference to above on **21/10/2020** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Labh Associates"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (4 kg) – 02 Nos.
- B) Hose Reel Hose has been installed in every floor – 12 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Court Yard Hydrant – 03 Nos.
- E) Main Hydrant Pump (30 Hp) – 01 Nos.
- F) Jockey Pump (7.5 Hp) – 01 Nos.
- G) Booster Pump near over head water storage tank (5 Hp) 01 Nos.
- H) Fire Alarm System with P. A – 01 Nos.
- I) Smoke Detector – 01 Nos.
- J) Automatic Sprinkler System – 60 Nos.
- K) Diesel Generator Set

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 36,050/-, Rs. 91,975/-, Rs.1,92,700/-, Rs.64,450/-, Rs.1,88,100/-, Rs.56,350/-, Rs.1,23,500/-, Rs.13,57,080/- vide Receipt No.255132, Rs.1,98,110/- vide Receipt No.255133, Rs.74,850/- vide Receipt No.255134, Rs.63,440/- vide Receipt No.255135, Rs.1,98,110/- vide Receipt No.255136, Rs.1,29,990/- vide Receipt No.255137, Rs.63,850/- vide Receipt No.255138, Rs.1,24,550/- vide Receipt No.255139, Rs.2,72,600/- vide Receipt No.255140, Rs.63,400/- vide Receipt No.255141, Rs.63,400/- vide Receipt No.255142, Rs.2,72,600/- vide Receipt No.255143, Rs.2,97,200/- vide Receipt No.255144, Rs.60,700/- vide Receipt No.255145, Rs.2,64,300/- vide Receipt No.255146, Rs.63,850/- vide Receipt No.255147, Rs.3,28,100/- vide Receipt No.255148, Rs.3,61,900/- vide Receipt No.255149, Rs.3,52,550/- vide Receipt No.255150, Rs.3,42,050/- vide Receipt No.255151, Rs.1,98,500/- vide Receipt No.255152, Rs.74,950/- vide Receipt No.255153, Rs.66,400/- vide Receipt No.255154, Rs.5,29,900/- vide Receipt No.255155, Rs.2,64,950/- vide Receipt No.255156, Rs.63,700/- vide Receipt No.255157, Rs.2,97,450/- vide Receipt No.255159, Rs.60,900/- vide Receipt No.255160, Rs.2,73,450/- vide Receipt No.255161, Rs.63,400/- vide Receipt No.255162, Rs.3,36,850/- vide Receipt No.255163, Rs.3,58,350/- vide Receipt No.255164, Rs.9,40,888/- vide Receipt No.255165, Rs.5,85,850/- vide Receipt No.255166, Rs.3,55,460/- vide Receipt No.255167, Rs.29,140/- vide Receipt No.255168, Rs.2,43,000/- vide Receipt No.255169, Rs.27,300/- vide Receipt No.255170, Rs.6,13,200/- vide Receipt No.255171, Rs.2,66,700/- vide Receipt No.255172, Rs.2,66,700/- vide Receipt No.255173, Rs.6,84,000/- vide Receipt No.255174, Rs.2,38,550/- vide Receipt No.255180, Rs.5,61,450/- vide Receipt No.227647, Rs.2,64,250/- vide Receipt No.227648, Rs.3,28,630/- vide Receipt No.254551, Rs.3,28,630/- vide Receipt No.254544, Rs.3,28,100/- vide Receipt No.254541, Rs.1,27,400/- vide Receipt No.255191.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Ajay Wade & Associates

2) Developer- M/s- Labh Associates

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०३
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/२५२१/२०२१
दिनांक : ०९/११/२०२१



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building located on land bearing S.No.35/5, & 36/6 of Village: Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/885/2021-22, Dated: 23/09/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:11/09/2021.
 - 3) An application received by M/s- Jasraj Developers, Dated: 27/10/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/09/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/87/2020-21, Dated: 19/06/2020.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:11/09/2021.
 - 7) Certificate from License Agency M/s- Krees Enterprises, Dated:21/10/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated: 21/10/2021.
 - 10) AMC Certificate by M/s- Jasraj Developers, Dated:18/10/2021
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:27/10/2021.
 - 12) Structure Stability Certificate for M/s- S.S & Associates, Dated:11/09/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-6211/18/2021-22, Dated:06/04/2021.
 - 14) Submitted Electric Certificate M/s- Shree Hari Electricals Sales & Services, Dated: 25/10/2021.
 - 15) Diesel Engine Test Certificate of M/s-Ashok Leyland, Dated: 25/08/2021
 - 16) C.F.O. site visit Dated: 27/10/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Industrial Building (Gr + 2 floor) in 15.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Kress Enterprises, bearing License No. MFS-LA/2020/RF-328, MFS-LA/2020/RD-293 & MFS-LA/2020/RP-67 and has submitted Certificate on 21/10/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring 1692.73sq.mtrs.

With reference to above on **27/10/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Jasraj Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Main Pump on under ground water storage tank (20 HP).
- G) Diesel Generator Set
- H) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Thom
ENCON

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 1,70,000/- vide Receipt No.819247, DD.No.009706, Dated- 19/06/2020 of ICICI Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "D. K. W.", written over the printed name of the Chief Fire Officer.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Jasraj Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व. वि. श. म. / अग्नि / मुका / १५४६ / २०२१
दिनांक : ०२/११/२०२१



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline & Commercial Building Wing-C, S.No.123 of Village: Kopri, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/363/2021-22,
Dated: 24/06/2021.

- 2) An application received by M/s- Kuldeep Patil Architect, Dated:05/10/2021.
- 3) An application received by M/s- Lotus Lakshminarayan Homes, Dated:05/10/2021
- 4) Work Completion certificate of M/s- Vijay Gurav & Associates, Dated:22/02/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/297/2019-20,
Dated:08/08/2019.
- 6) Construction area certificate for M/s- Vijay Gurav & Associates, Dated:05/08/2021.
- 7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:17/07/2021
(Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated: 08/01/2021.
- 9) AMC Certificate by M/s- Lotus Laxminarayan Homes, Dated:05/10/2021
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:29/10/2021.
- 12) Structure Stability Certificate for M/s- Jay Shree Krishna Consulting
Engineering, Dated: 06/03/2021.
- 13) RDP issued by VVCMC/TP/RDP/VP-5841/40/2021-22, Dated:20/04/2021.
- 14) Submitted Electric Certificate M/s- Siddhi Electrical, Dated:20/06/2021.
- 15) C.F.O. site visit Dated: 29/10/2021.

With reference to Sr.No. 2 above, this office is in received of your application for your **Residential With Shopline & Commercial Building Wing- C** in 23.55mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s- Fire Bird Fire Services**, bearing License No. **MFS-LA/2021/RF-26, MFS-LA/2021/RD-20** and has submitted Certificate on 17/07/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2675.29sq.mtrs.

With reference to above on 29/10/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Laxminarayan Homes" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places – 09 Nos.
- B) Hose Reel Hose has been installed in every floor – 07 Nos.
- C) Hose Box has been installed in Alternate floor – 02 Nos.
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Booster Pump near over head water storage tank. (5HP) – 01 Nos.
- G) Diesel Generator Set
- H) Manual Operated Electrical Fire Alarm System.- 07 Nos.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/- vide Receipt No.818208, DD. No. 814579, Dated- 27/06/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Vijay G. G. & Associates / Kuldeep Patil Architect
2) Developer- M/s- Lotus Lakshminarayan Homes

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. [अभि/मु.का./१५५१/१९]
दिनांक : ०४/११/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Roop-Navval Developers,
4, Plot No. 3,
Shri Nagar Society,
1st Floor,
M.G.Road, Goregaon (W),

Sub:-Renewal of "Final No Objection Certificate" of Industrial Building on land bearing S.No.16, H.No.4 of Village: Sativali, Tal- Vasai, Dist-Palghar.

- Ref:-
1. An application received by M/s- Roop-Navval Developers, Dated:27/09/2021
 2. This office Renewal of Final No Objection Certificate No.VVCMC /FIRE/ HQ/ 577/2019, Dated: 31/08/2019.
 3. This office Renewal of Final No Objection Certificate No.VVCMC/FIRE/HQ/ 387/2018-19, Dated: 04/08/2018
 4. Certificate from License Agency M/s- Fire Bird Fire Services, Dated: 01/07/2021. (Form- B)
 5. AMC Certificate by Developer M/s- Roop-Navval Developers , Dated: 27/09/2021
 6. Submitted License copy of Maharashtra Fire Services, Dated: 08/01/2021.
 7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 30/10/2021
 8. Submitted Electric Certificate M/s-V.S.Electricals, Dated:27/09/2021
 8. C.F.O site visit Dated:31/10/2021

With reference to Sr.No.1 above, this office is in received of your application for your Industrial Building No. 2, (Gr + 2 Floor) in 15.45mtrs Height at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services bearing License No. MFS-LA/2021/RF-26 & MFS-LA/2021/RD-20 and has submitted Certificate On 01/07/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 75,000/- vide Receipt No. 895909, Book No. 8960, DD .No. 267945 (Bank Of India), Dated:29/10/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Received
[Signature]

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुफा/४५८८/२०२१
दिनांक : १८/११/२०२१



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building located on S.No.118, H.No.4, S.No.231, H.No.8 of Village: Virar, Tal: Vasai, Dist:Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1118/2021-22, Dated:29/10/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:16/10/2021.
 - 3) An application received by M/s- Chetana Realtors, Dated:16/10/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:16/10/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/652/2019-20, Dated:20/09/2019.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:16/10/2021.
 - 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:06/10/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate by Developer M/s- Chetana Realtors, Dated:16/10/2021.
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:10/11/2021.
 - 12) Structure Stability Certificate for M/s- Shilplekha Consultants, Dated:16/10/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-5937/137/2019-20, Dated:10/10/2019.
 - 14) Submitted Electric Certificate M/s- Deepak Electricals, Dated:04/10/2021.
 - 15) Diesel Engine Test Certificate of M/s- G.K Power, Dated:12/10/2021.
 - 16) C.F.O. site visit Dated:10/11/2021.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Residential Building No. 1 (Wing- A & B) (Stilt / Gr + 7th floor) in 24.65mtr Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305 and has submitted Certificate on 06/10/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5479.10sq.mtrs.

With reference to above on 10/11/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Chetana Realtors" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 04 Nos.
- B) Hose Reel Hose has been installed in every floor – 01 Nos.
- C) Hose Box has been installed in Alternate floor – 08 Nos.
- D) Siamese Connection has been installed in entrance gate – 02 Nos.
- E) Courtyard Hydrant has been installed in the building & prominent places – 04 Nos.
- F) Booster Pump near over head water storage tank (5hp) – 02 Nos.
- G) Smoke Detectors – 04 Nos.
- H) Manual Operated Electrical Fire Alarm System.- 02 Nos.
- I) Diesel Generator Set

ENCON

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/- vide Receipt No. 590375, DD. No. 878284 (RBL Bank), Dated: 08/09/2017 & Rs.1,20,000/- vide Receipt No. 818478, DD.No.142758 (RBL Bank), Dated:11/09/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely belonging to the Chief Fire Officer, positioned above the official title.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s-Chetana Realtors

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आजिने/मुका/२५००/२०२१
दिनांक : १८/११/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Local Resource Based Industry located on land bearing New S.No.21, H.No. B/3 Plot A, (Old S.No. 21, H.No.5, Plot A) of Village: Bilalpada, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/897/2021-22, Dated: 27/09/2021.
- 2) An application received by M/s- Himesh Gupta & Associates, Dated: 16/08/2021.
 - 3) An application received by Developer Mr. Devendra R. Ladhani, Dated: 24/08/2021.
 - 4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated: 16/08/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/834/2017-18, Dated: 17/10/2017.
 - 6) Gross built up area certificate for M/s- Himesh Gupta & Associates, Dated: 16/08/2021.
 - 7) Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated: 24/08/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated: 06/10/2020.
 - 9) AMC Certificate by Developer Mr. Devendra R. Ladhani, Dated: 16/08/2021.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 08/10/2021.
 - 11) Structure Stability Certificate for M/s- Seemu Consultancy, Dated: 16/08/2021
 - 12) CC issued by VVCMC/TP/CC/VP-5446/13/2019-20, Dated: 22/05/2019.
 - 13) Submitted Electric Certificate M/s- Shree Hari Electricals, Dated: 30/10/2021.
 - 14) Diesel Engine Test Certificate of M/s- Koel Greel, Dated: 12/11/2021.
 - 15) C.F.O. site visit Dated: 08/10/2021.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Local Resource Based Industry (Unit No.1) Building (Gr + 1pt floor) in 10.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Vision Fire Safety Engineering, bearing License No. MFS-LA/2020/RF-226, MFS-LA/2020/RD-200** and has submitted Certificate on 24/08/2021 in **"Form A"** Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 608.69sq.mtrs.

With reference to above on **08/10/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr. Devendra R. Ladhani"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places. – 04 Nos.
- B) Hose Reel Hose has been installed in every floor – 02 Nos.
- C) Hose Box has been installed in Alternate floor – 02 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places. – 04 Nos
- E) Booster Pump near over head water storage tank (7.5hp) – 01 Nos.
- F) Smoke Detectors – 02 Nos.
- G) Diesel Generator Set
- H) Manual Operated Electrical Fire Alarm System. 01 Nos

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 590384, DD. No. 500748 (The Satara Sahakari Bank), Dated- 14/09/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, written over the official stamp.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Himesh Gupta & Associates
2) Developer- Mr. Devendra R. Ladhani

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.

प्रतमिका

लिपिक (न.र.)

विरार शहर महानगरपालिका

FIRE & EMERGENCY DEPARTMENT

स्थापना : ३ जुलै २००९

दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४६००/२०२१

दिनांक : १८/११/२०२१



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of CFC- 8 Building located on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village: Dongre, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/983/2021-22, Dated: 11/10/2021.
2) An application received by M/s- Shah Gattani Consultants, Dated: 23/09/2021.
3) An application received by Developer M/s- Red Bricks Landmark LLP, Dated: 23/09/2021.
4) Work Completion certificate of M/s- M/s- Shah Gattani Consultants, Dated: 23/09/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/700/2016-17, Dated: 08/11/2016.
6) Gross built up area certificate for M/s- Shah Gattani Consultants, Dated: 23/09/2021.
7) Certificate from License Agency M/s- Crash Fire Services, Dated: 28/08/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated: 25/01/2021.
9) AMC Certificate by Developer M/s-Red Bricks Landmark LLP, Dated: 23/09/2021.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 01/11/2021.
11) Structure Stability Certificate for M/s- Raje Structural Consultants, Dated: 30/08/2021
12) CC issued by VVCMC/TP/CC/VP-0453/5523/2017-18, Dated: 10/10/2017.
13) Submitted Electric Certificate M/s- Santosh Electric Works, Dated: 08/07/2021.
14) Diesel Engine Test Certificate of M/s- Greaves Cotton Limited, Dated: 18/08/2021.
15) C.F.O. site visit Dated: 01/11/2021.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your CFC - 8 Building (Basement + Gr + 2pt floor) in 12.75mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Crash Fire Services, bearing License No. MFS-LA/2021/RF-82, MFS-LA/2021/RD-67 and has submitted Certificate on 28/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 7499.04sq.mtrs.

With reference to above on 01/11/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s. Red Bricks Landmark LLP" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places. – 22 Nos.
- B) Hose Reel Hose has been installed in every floor – 03 Nos.
- C) Courtyard Hydrant has been installed in the building & prominent places. – 12 Nos
- D) Main Pump (75hp) – 01 Nos.
- E) Booster Pump near over head water storage tank (7.5hp) – 01 Nos.
- F) Sprinkler Pump - (75hp) – 01 Nos.
- G) Jockey Pump - (75hp) – 01 Nos.
- H) Smoke Detectors – 304 Nos.
- I) Diesel Generator Set
- J) Manual Operated Electrical Fire Alarm System. 01 Nos

Received
Comau
20/11/2021
7972995801

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 5,00,000/- vide Receipt No. 499003, DD. No. 626505 & Rs. 5,00,000/- vide Receipt No. 499004, DD. No. 626506, (Dena Bank), Dated- 08/11/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s- Red Bricks Landmark LLP

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : व.वि.श.म./अग्नि/मुका/४६३७/२०२१
दिनांक : ३० /११ /२०२१.



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Agro Based Industrial Building on land bearing S.No.215, H.No.7Pt, S.No.216, H.No.2Pt of Village: Pelhar, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/945/2021-22, Dated: 05/10/2021.
- 2) An application received by M/s- Himesh Gupta & Associates, Dated: 18/09/2021.
 - 3) An application received by Developer M/s- PNR Enterprises, Dated: 18/10/2021
 - 4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated: 18/09/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/739/2019-20, Dated: 15/10/2019.
 - 6) Gross built up area certificate for M/s- Himesh Gupta & Associates, Dated: 18/09/2021.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated: 27/11/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated: 15/10/2021.
 - 9) AMC Certificate by Developer M/s- PNR Enterprises, Dated: 18/10/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 23/11/2021.
 - 12) Structure Stability Certificate for M/s- Seemu Consultancy, Dated: 18/09/2021
 - 13) CC issued by VVCMC/TP/CC/VP-6145/302/2019-20, Dated: 21/11/2019.
 - 14) Submitted Electric Certificate M/s-Powertech Electricals, Dated: 18/10/2021.
 - 15) Diesel Engine Test Certificate of M/s- Kirloskar oil Engines Ltd, Dated: 01/07/2021.
 - 16) C.F.O. site visit Dated: 23/11/2021.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Agro Based Industrial Building (Gr + 1 floor) in 10.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- TFPC Infra LLP**, bearing License No. **MFS-LA/2021/RF-384, MFS-LA/2021/RD-359** and has submitted **Certificate on 27/11/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 492.48sq.mtrs.

With reference to above on **23/11/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- PNR Enterprises"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in Lift machine room, Electric meter room, Pump room, every floor & prominent places – (4 kg) - 02 Nos
- B) Hose Reel Hose has been installed in every floor – 01 Nos.
- C) Hose Box has been installed in Alternate floor – 01 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places.- 02 Nos
- E) Booster Pump near over head water storage tank – (5 Hp) – 01 Nos
- F) Sprinkler Systems – 10 Nos.
- G) Diesel Generator Set
- H) Manual Operated Electrical Fire Alarm System – 01 Nos

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 818537, DD.No.285890, Dated- 03/10/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Himesh Gupta & Associates
2) Developer- M/s- PNR Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४६५६/२०२२
दिनांक : ०८/०२/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential Building in Sector - II on land bearing S.No.37, H.No. 1 to 8, S.No.38, H.No. 1,2(pt),2(pt), 3, S.No.39, H.No. 1, 2(pt), S.No.40, S.No. 41,H.No. 1 to 24, S.No.42, H.No. 1 to 6, S.No.43, H.No. 1A,1B, S.No.44, S.No. 45, H.No. 1 to 9, S.No.46, H.No. 1 to 6, S.No.51, H.No. 1, 2, 3pt, S.No.52, H.No. 1 to 9, S.No.53, H.No. 1 to 5, S.No.54, H.No. 1 to 6. 7pt,8 to 12, S.No.55, H.No. 1 to 20, S.No.56, H.No. 1 to 9, S.No.57, H.No. 1 to 23, S.No.58, H.No. 1 to 16, S.No.59, H.No. 1 to 22, S.No.60, H.No. 1 to 13, S.No.61, H.No. 1 to 28, S.No.62, H.No. 1 to 20, S.No.63, H.No. 1 to 24, S.No.64, H.No. 1 to 20, S.No.65, H.No. 1 to 32, 33/1,2,34 to 37, S.No.66, H.No. 1 to 16, S.No.67, H.No. 1 to 14, S.No.98, H.No. 100, S.No.99, H.No. 1 to 26, S.No.100, H.No. 1 to 20, S.No.101, H.No. 1 to 4, S.No.102, H.No. 1 to 7, S.No.103, H.No. 1 to 5, S.No.104, H.No. 1 to 29, S.No.105, H.No. 1 to 5, S.No.106, H.No. 1 to 10, S.No.107, H.No. 1 to 10, S.No.108, H.No. 1 to 8, S.No.109, H.No. 1 to 12, S.No.110, H.No. 1 to 12, S.No.111, H.No. 1 to 10, S.No.112, H.No. 1pt, 1/2, 2, 3pt, 4,5,6pt,6A,7, S.No.113, H.No. 1 to 4, S.No.114, H.No. 1 to 3, S.No.115, H.No. 1,2,3pt,4,5,6,7pt, 8,9pt, S.No.116, H.No. 1 to 5,6/2,6/3,6/1,7, S.No.117, H.No. 1 to 3, S.No.118, H.No. 1 to 5, S.No.119, H.No. 1 to 22, S.No.120, H.No. 1 to 39, S.No.121, H.No. 1 to 8, S.No.124, H.No. 1 to 6, S.No.145, S.No. 146, H.No. 1 to 11, 12A, 12B, S.No.147, H.No. 1 to 3, 4A, 4B, 5 to 7, 8A, 8B, S.No.368, H.No. A & B, S.No.374, H.No. 1 to 9, S.No.375, H.No. 1 to 5, S.No.376, S.No. 384, S.No.416, H.No. 2, S.No.420, H.No. 1/1, 1/2, 2 to 8, at Village: Bolinj, S.No.31, H.No. 4, 5, 6, 15, 21, 23, 25, S.No.34, H.No. 14 to 25, S.No.38, H.No. 1 to 11, S.No.39, H.No. 1 to 13, S.No.40, H.No. 1 to 7, S.No.41, H.No. 1, 2, S.No.42, H.No. 1, 2, 3/1, 3/2, 4, 5, 6/1, 6/2, 17, S.No.43, H.No. 1, 2, 3, 4/1, 4/2, 5, 6, 7/1, 7/2, 8 to 12, 13/1, 13/2, 14, S.No.44, H.No. 1 to 5, S.No.45, H.No. 1 to 4, S.No.299, H.No. 1 to 8, 9pt, 10 of Village: Chikhal Dongre, S.No.9(175), H.No. 1,2,3/1, 3/2, 4, S.No.14(438), H.No. 31, 1, 32, 4, S.No.17(490), H.No. 1, S.No. 18 (124), H.No. 1 to 9, S.No.19(125), H.No. 1 to 11, S.No.20(123), H.No. 1 to 13, 14A, 14B, 15, to 25, 26/1, 26/2, 27, 28, S.No.21(122), H.No. 1 to 12, S.No.22(126), H.No. 1 to 3, S.No.23(127), H.No. 1 to 5, S.No.24(128), H.No. 1 to 21, S.No.25(129), H.No. 1 to 21, S.No.26(130), H.No. 1 to 7, S.No.27(131), H.No. 1 to 21, S.No.28(132), H.No. 1 to 22, S.No.29(133), H.No. 1 to 20, S.No.30(134), H.No. 1 to 17, S.No.31 (135), H.No. 1,2,3A, 3B, 4, 5A, 5B, 6 to 10, S.No.32(136), H.No. 1 to 13, S.No.33(138), H.No. 1/1, 1/2, 1/3, 1/4, 1/5, 1/6, 1/7, 1/8, 1/9, 2, S.No.34(139), H.No. 1, 2A, 2B, 2C, 3 to 8, 9A, 9B, 10, to 13, 14pt, S.No.35(140), H.No. 1, S.No.36(141), H.No. 1 to 7, S.No.37(142), H.No. 1 to 5, S.No.38(143), H.No. 1pt, 2 to 6, S.No.39(144), H.No. 1 to 4, 5A, 5B, C, 6pt, 7, 8, S.No.40(145), H.No. 1 to 19, S.No.41(146), H.No. 1 to 10, 11pt, 12 to 14, S.No.42(147), H.No. 1pt, S.No.43(137), H.No. 1 to 7, S.No.44(149), H.No. 1, S.No.45(150), H.No. 1 to 7, S.No.46(491), H.No. 1, S.No.47, H.No. 1 to 5, S.No.48(152), H.No. 1, 2/1,2/2, 2/3, 3 to 10, 11/1, 11/2, S.No.49(153), H.No. 1, S.No.50(154), H.No. 1, S.No.51(155), H.No. 1 to 3, S.No.52(156), H.No. 1pt, S.No.53(157), H.No. 1pt, S.No.54(158), H.No. 1, S.No.56(159), H.No. 1 to 14, 14pt, 15 to 34, S.No.57(160), H.No. 1 to 6, S.No.58(161), H.No. 1 to 6, S.No.60(162), H.No. 1 to 9, S.No.61(163), H.No. 1 to 6, S.No.62(164), H.No.1, S.No.64(165), H.No. 1, 2, 3A, 3B, 3C, 3D, 4 to 8,9/1, 9/2, 10, S.No.65(168), H.No. 1, S.No.66, H.No. 1 to 15, 16/1, 16/2, 16/3, 16/4, 16/5, 15, 17 to 21, 22/1, 22/2, 22/3, 22/4, 23, 24/1, S.No.68(171), H.No. 1, S.No.69(173), H.No. 1 to 6, S.No.70(174), H.No. 1 to 4, 5/1, 5/2, 5/3, 5/4, 6, S.No.71(173), H.No. 1 to 5, S.No.72(167),

H.No. 1/1, 1/2, 1/3, 2, 3/1/1, 3/1/2, 3/2, 4 to 6, S.No.73(166), H.No. 1pt, 2 to 6, S.No.74(451), H.No. 1 to 15, S.No.75, S.No. 80, H.No. 1pt, S.No.81, S.No. 82(198), H.No. 1, S.No.83(191), H.No. 1, 2, 3pt, 4, S.No.84(189), H.No. 1 to 5, S.No.85(188), H.No. 1 to 3, S.No.86(187), H.No. 1 to 23, S.No.87(186), H.No. 1, 2, S.No.88(185), H.No. 1, 2A, 2B, 2C, S.No.89(184), H.No. 1, 2, S.No.90(183), H.No. 1 to 6, 7/1, to 7/16, S.No.91(176), H.No. 1/1,1/2,2,3, S.No.93(177), H.No. 1 & 2, S.No.94(182), H.No. 1 to 23, S.No.95(181), H.No. 1 to 23, S.No.96(178), H.No.1 to 3, 3A, 3B, 7A, 7B, S.No.97(179), H.No. 1 to 4, S.No.98(180), H.No. 1,2, S.No.99(201), H.No. 1 to 3, 4pt, S.No.100 (190), H.No. 1 to 3,4 pt, 5 to 7, S.No.101 (199), H.No. 1, 1pt, S.No.102(200), H.No. 1pt, 2 to 6, 5, S.No.103(472), H.No. A & B, S.No.104(202), H.No. 1 & 2, S.No.105(203), H.No. 1 to 3, S.No.106(204), H.No. 1, S.No.107(205), H.No. 1, S.No.109(206), H.No. 1pt, S.No.110(206), H.No. 1pt, S.No.111(427), H.No. 1,2, 3/1, 3/2, 4,5/1,5/2, S.No.112(212), H.No. 1 to 10, S.No.113(213), S.No. 146(148), H.No. 1 to 16, S.No.213(194), H.No. 1 to 4, S.No.234(193), H.No. 1 to 3, of Village: Dongre, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/06/2021-22, Dated:01/04/2021.

- 2) An application received by M/s- Ajay Wade & Associates, Dated:07/04/2021.
- 3) An application received by Developers, M/s- Priyesh Enterprises, Dated:21/07/2021
- 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:07/04/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/75/2012-13, Dated:27/07/2012.
- 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:07/04/2021.
- 7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:13/03/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021.
- 9) AMC Certificate by Developers, M/s- Priyesh Enterprises, Dated:21/07/2021
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/04/2021.
- 12) Structure Stability Certificate for M/s- Nimisha Structural Design Academy, Dated:06/03/2021.
- 13) RDP issued by VVCMC/TP/RDP/VP-0880/037/2014-15, Dated:15/05/2014.
- 14) Submitted Electric Certificate M/s- Narayan Jha, Dated:19/04/2021.
- 15) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines Ltd.
- 16) Submitted Developer Letter M/s- Priyesh Enterprises, Dated:30/11/2021 about Occupied Building.
- 17) C.F.O. site visit Dated:08/04/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Residential Building No. 17, Wing- F (Stilt / Gr + 13 floor) in 40.50mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Fire Bird Fire Services**, bearing License No. **MFS-LA/2021/RF-26, MFS-LA/2021/RD-20** and has submitted Certificate on 13/03/2021 in "Form A" Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2641.32sq.mtrs.

With reference to above on **08/04/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Priyesh Enterprises" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers – 02 Nos.
- B) Automatic Sprinkler System – 52 Nos.
- C) Smoke Detector System – 13 Nos.
- D) Hose Reel Hose – 13 Nos.
- E) Hose Box – 03 Nos.
- F) Mian Pump on under ground water storage tank (30hp) – 01 Nos
- G) Jockey Pump on under ground water storage tank - (5hp) – 01 Nos
- H) Booster Pump near over head water storage tank - (5hp) – 01 Nos
- I) Diesel Generator Set
- J) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 36,050/-, Rs. 91,975/-, Rs.1,92,700/-, Rs.64,450/-, Rs.1,88,100/-, Rs.56,350/-, Rs.1,23,500/-, Rs.13,57,080/- vide Receipt No.255132, Rs.1,98,110/- vide Receipt No.255133, Rs.74,850/- vide Receipt No.255134, Rs.63,440/- vide Receipt No.255135, Rs.1,98,110/- vide Receipt No.255136, Rs.1,29,990/- vide Receipt No.255137, Rs.63,850/- vide Receipt No.255138, Rs.1,24,550/- vide Receipt No.255139, Rs.2,72,600/- vide Receipt No.255140, Rs.63,400/- vide Receipt No.255141, Rs.63,400/- vide Receipt No.255142, Rs.2,72,600/- vide Receipt No.255143, Rs.2,97,200/- vide Receipt No.255144, Rs.60,700/- vide Receipt No.255145, Rs.2,64,300/- vide Receipt No.255146, Rs.63,850/- vide Receipt No.255147, Rs.3,28,100/- vide Receipt No.255148, Rs.3,61,900/- vide Receipt No.255149, Rs.3,52,550/- vide Receipt No.255150, Rs.3,42,050/- vide Receipt No.255151, Rs.1,98,500/- vide Receipt No.255152, Rs.74,950/- vide Receipt No.255153, Rs.66,400/- vide Receipt No.255154, Rs.5,29,900/- vide Receipt No.255155, Rs.2,64,950/- vide Receipt No.255156, Rs.63,700/- vide Receipt No.255157, Rs.2,97,450/- vide Receipt No.255159, Rs.60,900/- vide Receipt No.255160, Rs.2,73,450/- vide Receipt No.255161, Rs.63,400/- vide Receipt No.255162, Rs.3,36,850/- vide Receipt No.255163, Rs.3,58,350/- vide Receipt No.255164, Rs.9,40,888/- vide Receipt No.255165, Rs.5,85,850/- vide Receipt No.255166, Rs.3,55,460/- vide Receipt No.255167, Rs.29,140/- vide Receipt No.255168, Rs.2,43,000/- vide Receipt No.255169, Rs.27,300/- vide Receipt No.255170, Rs.6,13,200/- vide Receipt No.255171, Rs.2,66,700/- vide Receipt No.255172, Rs.2,66,700/- vide Receipt No.255173, Rs.6,84,000/- vide Receipt No.255174, Rs.2,38,550/- vide Receipt No.255180, Rs.5,61,450/- vide Receipt No.227647, Rs.2,64,250/- vide Receipt No.227648, Rs.3,28,630/- vide Receipt No.254551, Rs.3,28,630/- vide Receipt No.254544, Rs.3,28,100/- vide Receipt No.254541, Rs.1,27,400/- vide Receipt No.255191, Dated: 25/07/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s- Priyesh Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


Receiver

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५६०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५६०३
ई-मेल : vasavirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४६६६/२०२०
दिनांक : २९/१२/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Prama India Pvt Ltd,
Manav-8, Survey No.44, 45, 93, 94,
Building No.8,
Sativali Road,
Sativali, Vasai (E),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Commercial Building, "Prama India Pvt Ltd"
Manav-8, Survey No. 44, 45, 93, 94, Building No. 8, Sativali Road, Sativali, Vasai (E) of Village:
Sativali, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Prama India Pvt Ltd, Dated:20/08/2021.
2. This office Final No Objection Certificate No.VVCMC/ FIRE/ HQ/19/2019-20,
Dated:08/04/2019.
3. Occupancy Certificate Received by VVCMC/TP/POC/VP-0761/167/2019-20,
Dated: 03/03/2020
4. Certificate from License Agency M/s- Shreyas Enterprises, Dated:01/07/2021.
(Form- B)
5. Agreement of M/s- Prama India Pvt Ltd.
6. Submitted License copy of Maharashtra Fire Services, Dated: 13/11/2021.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 24/11/2021.
8. Submitted Electric Audit Certificate M/s- Pradhan Electrical Works, Dated:13/09/2021
9. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour
10. Diesel Engine Test Certificate of M/s- Kohler Power Indai Pvt Ltd, Dated:09/08/2021
11. C.F.O site visit Dated: 24/11/2021

With reference to Sr.No.1 above, this office is in received of your application for your Commercial Building, "Prama India Pvt Ltd" Manav-8, Survey No. 44, 45, 93, 94, Building No. 8, Sativali Road, Sativali, Vasai (E) of Village: Sativali, Tal- Vasai, Dist-Palghar, (Gr + 1 floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shreyas Enterprises bearing License No. MFS-LA/2020/RF-254 & MFS-LA/2020/RD-395 and has submitted Certificate On 01/07/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 1,50,000/- vide Receipt No. 895948, Book No. 8960, DD. No.094996 (HDFC Bank), Dated: 13/11/2021 & Rs. 1,50,000/- vide Receipt No. 895947, Book No. 8960, DD. No. 148363 (Union Bank), Dated: 13/11/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mhIndia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४७०५/२०२१
दिनांक : २२/१२/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.


Sub:- "Final No Objection Certificate" of Residential Building on land bearing S.No.53, H.No.2, S.No.76, H.No.1 & S.No.51, H.No.1B/2 of Village: More, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1115/2021-22, Dated:29/10/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:26/10/2021.
 - 3) An application received by M/s- S.A.Infra Builders & Developers, Dated:26/10/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:26/10/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/21/2016-17, Dated:11/04/2016.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:26/10/2021
 - 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:06/10/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate by Developer M/s- S.A.Infra Builders & Developers, Dated:18/10/2021.
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:18/10/2021
 - 12) Structure Stability Certificate for M/s-S.S & Associates, Dated:26/10/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-0768/286/2019-20, Dated:24/01/2020.
 - 14) Submitted Electric Certificate M/s- Bafna Electricals, Dated:21/10/2021.
 - 15) Diesel Engine Test Certificate of M/s- Kohler Power Indai Pvt Ltd, Dated:22/05/2018
 - 16) C.F.O. site visit Dated: 10/11/2021

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Residential Building (Type - F) (Stilt / Gr + 7th floor) in 22.95mtr Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/2021/RF-332, MFS-LA/2021/RD-305 and has submitted Certificate on 23/10/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1103.72sq.mtrs.

With reference to above on 10/11/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- S. A. Infra Builders & Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 05 Nos.
- B) Hose Reel Hose has been installed in every floor – 01 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Siamese Connection has been installed in entrance gate – 01 Nos.
- E) Courtyard Hydrant has been installed in the building & prominent places – 04 Nos.
- F) Booster Pump near over head water storage tank (5hp) – 01 Nos.
- G) Smoke Detectors – 30 Nos.
- H) Sprinklers in each floor lobby
- I) Manual Operated Electrical Fire Alarm System
- J) Diesel Generator Set



Tham
ENCON

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,20,000/-, vide Receipt No. 425896, DD. No. 498617 (RBL Bank), Dated: 18/03/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- S.A. Infra Builders & Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श म/अग्नि/मुका/४०९३/२०२१
दिनांक : २२/१२/२०२१



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Local Resource Based Industry on land bearing S.No.24/1/1 & 24/1/2 of Village: Kaman, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1335/2021-22, Dated:07/12/2021.
- 2) An application received by M/s- En Con Project Consultants, Dated:29/11/2021.
 - 3) An application received by M/s- ED Reality, Dated:29/11/2021
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:29/11/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/478/2017-18, Dated: 23/08/2019.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:29/11/2021.
 - 7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:27/11/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021
 - 9) AMC Certificate by M/s- ED Reality, Dated:29/11/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:21/12/2021.
 - 12) Structure Stability Certificate for M/s- GR Consultants, Dated:26/11/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-6131/238/2021-22, Dated:30/06/2021.
 - 14) Submitted Electric Certificate M/s- Shekhar Electric Works, Dated:15/11/2021.
 - 15) Diesel Engine Test Certificate of M/s-Mohammadi Power Service, Dated:14/12/2021
 - 16) C.F.O. site visit Dated: 21/12/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Local Resource Based Industry Buildings (Unit No. 1 to 5) Ground Floor only in 7.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-26, MFS-LA/RD-20 and has submitted Certificate on 27/11/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Unit No.1 – 1097.21sq.mtrs, Unit No. 2 – 1021.11sq.mtrs, Unit No. 3 – 2662.11sq.mtrs, Unit No. 4 – 746.90sq.mtrs, Unit No. 5 – 1800.47sq.mtrs.

With reference to above on 21/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- ED Reality" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places – 08 Nos
- B) Hose Box has been installed – 05 Nos
- C) Courtyard Hydrant has been installed in the building & prominent places – 11 Nos
- D) Main Pump on under ground water storage tank. (30hp) 01 Nos
- E) MCP / Hooter – 10 Nos
- F) Diesel Generator Set
- G) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Tham
EN/CON

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 11,30,000/- vide Receipt No.818335, DD.No.919953, Dated- 23/08/2019 of Bank of Baroda.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s-ED Reality.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४०२३/२०२१
दिनांक : २४/१२/२०१९

FIRE & EMERGENCY DEPARTMENT

To,
M/s- P. K. Hospitality Services Pvt Ltd,
(Hotel Golden Chariot & Spa),
S.No.44, 5/1, 10/1, Waliv,
Vasai (E),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Hotel Building known as "P.K. Hospitality Services Pvt Ltd" (Hotel Golden Chariot) located on land bearing S.No/H.No.44/5/1, 10/1 of Village: Waliv, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- P. K. Hospitality Services Pvt Ltd, Dated: 13/10/2021
2. This office Renewal of Final No Objection Certificate No.VVCMC/ FIRE/ HQ/2383/2019, Dated: 14/03/2020.
3. Certificate from License Agency M/s- Mamta Engineering, Dated: 12/08/2021 (Form- B)
5. Submitted License copy of Maharashtra Fire Services, Dated: 03/02/2021.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 06/12/2021.
8. Submitted Electricals Certificate M/s-Neetu Electricals, Dated:12/08/2021
9. C.F.O site visit Dated: 06/12/2021

With reference to Sr.No.1 above, this office is in received of your application for your Hotel Building Known as "P.K. Hospitality Services Pvt Ltd (Hotel Golden Chariot) (Gr + 2pt floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Mamta Engineering bearing License No. MFS-LA/2021/RF-108 & MFS-LA/2021/RD-94 and has submitted Certificate On 12/08/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 2,40,000/- vide Receipt No. 895822, Book No. 8959, DD No. 442159 (Fedral Bank), Dated: 22/10/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Handwritten signature and number:
9373157346

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasalvirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४०२४/२०२१
दिनांक : २४/१२/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Podar International School,
Sector No. 282 Old / 257 New,
Behind Dattani Mall,
Near Big Bazar, Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of School Building "Podar International School" on S.No.255, S.No.256, H.No.2 & 4, S.No. 257, H.No. 2/1, 3, 4, 5, 10/1, 11 of Village: Sandor, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Podar International School, Dated: 10/05/2021
2. This office Final No Objection Certificate No. VVCMC/ FIRE/ HQ/2322/2020, Dated: 02/03/2020.
3. Certificate from License Agency M/s- Kress Enterprises, Dated: 02/07/2021 (Form- B)
5. Submitted License copy of Maharashtra Fire Services, Dated: 27/11/2020.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 18/09/2021
8. Submitted Electricals Certificate M/s- Sharon Electricals, Dated: 15/06/2021
9. C.F.O site visit Dated: 18/09/2021.

With reference to Sr.No.1 above, this office is in received of your application for your School Building (Gr + 3 floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Kress Enterprises bearing License No. MFS-LA/2020/RF-328, MFS-LA/2020/RD-293 & MFS-LA/2020/RP-67 and has submitted Certificate On 02/07/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 1,25,000/- vide Receipt No. 30204, Book No.303, DD .No. 005659 (IDBI Bank), Dated: 07/12/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

1

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४७२५/२०२१
दिनांक : २०/१२/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Rashmi Sharma Telefilms,
Bldg No. 1 to 6,
S.No.53, H.No.1, S.No.54, S.No.2,
S.No.55, H.No.1 & 2, Village-Malzipada,
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Commercial CFC Building & Commercial Studio Building No. 1 to 6, S.No.53, H.No.1, S.No.54, S.No.2, S.No.55, H.No.1 & 2 of Village: Malzipada, Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s-Rashmi Sharma Telefilms, Dated: 01/07/2021
2. This office Renewal of Final No Objection Certificate No. VVCMC/ FIRE/ HQ/361/2020, Dated: 02/09/2020.
3. Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated: 01/07/2021 (Form- B)
5. Submitted License copy of Maharashtra Fire Services, Dated: 06/10/2020.
7. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 06/12/2021
8. Submitted Electricals Certificate M/s- N.G. Suryawanshi, Dated:20/01/2021
9. C.F.O site visit Dated: 06/12/2021

With reference to Sr.No.1 above, this office is in received of your application for your Commercial CFC Building & Commercial Studio Building No.1 to 6 at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/2020/RF-226 & MFS-LA/2020/RD-200 and has submitted Certificate On 01/07/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has paid the Fire cess fees Rs. 1,15,000/- vide Receipt No. 895894, Book No. 8959, DD .No. 009573 (IDBI Bank), Dated: 28/10/2021 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Received Dhanaji patil
Patil 8007982236

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 62,93,828.80/-, Vide Receipt 167932, Rs. 1,15,80,890/-, vide Receipt No. 167933, Rs.8,70,520/- vide Receipt No. 167935, Rs.17,63,030/- vide Receipt No. 167934, Rs.53,06,415/- vide Receipt No. 167938, Rs.5,95,920/- vide Receipt No. 167937, Rs.4,45,000/- vide Receipt No. 167936 & Rs400/- vide Receipt No. 167940, Dated:07/02/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "D. K. Kulkarni".

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s-Ekta World

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
न. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४७४३/२०२९
दिनांक : २४/१२/२०२९

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential cum Commercial Building in Sector – III of Village: Dongre, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1291/2021-22, Dated:26/11/2021.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:18/11/2021.
 - 3) An application received by Developer M/s- Ekta World, Dated:18/11/2021
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:18/11/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/177/2011-12, Dated:07/02/2012.
 - 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:18/11/2021.
 - 7) Certificate from License Agency M/s- DIPL, Dated:03/09/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Valid Dated:07/02/2022.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/12/2021.
 - 11) Structure Stability Certificate for M/s- JW Consultants, Dated:11/10/2019
 - 12) RDP issued by VVCMC/TP/RDP/VP-0880/037/2014-15, Dated:15/05/2014.
 - 13) Submitted Electric Certificate M/s-Rising Electricals, Dated:18/11/2021.
 - 14) Diesel Engine Test Certificate of M/s- Powerica Ltd, Dated: 22/04/2011.
 - 15) C.F.O. site visit Dated:16/12/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential cum Commercial Building No. 9 (Wing - H) (Gr + 12th floor) in 37.85mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- DIPL, bearing License No. MFS-LA/RF-136, MFS-LA/RD-123 and has submitted Certificate on 03/09/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing- H – 5045.56sq.mtrs.

With reference to above on 16/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Ekta World" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places.
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor .
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank .
- G) Jockey Pump on under ground water storage tank
- H) Booster Pump near over head water storage tank.
- I) Fire Alarm Panel
- J) Pill Box with Hooter
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुठा/४७४४/२०२९
दिनांक : २४/१२/२०२९



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential cum Commercial Building in Sector – III of Village: Dongre, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1290/2021-22, Dated:26/11/2021.
2) An application received by M/s- Ajay Wade & Associates, Dated:18/11/2021.
3) An application received by Developer M/s- Ekta World, Dated:18/11/2021
4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:18/11/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/177/2011-12, Dated:07/02/2012.
6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:18/11/2021.
7) Certificate from License Agency M/s- Beenee Ventures LLP, Dated:09/09/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:28/08/2021.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/12/2021.
11) Structure Stability Certificate for M/s- JW Consultants, Dated:18/08/2021
12) RDP issued by VVCMC/TP/RDP/VP-0880/037/2014-15, Dated:15/05/2014.
13) Submitted Electric Certificate M/s- Patel Electricals, Dated:18/11/2021.
14) Diesel Engine Test Certificate of M/s- Powerica Ltd, Dated: 22/04/2011.
15) C.F.O. site visit Dated:16/12/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential cum Commercial Building No. 8 (Wing - D) (Gr + 15 floor) in 47.55mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Beenee Ventures LLP, bearing License No. MFS-LA/RF-342, MFS-LA/RD-316, MFS-LA/RP-65 and has submitted Certificate on 09/09/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing- D – 3894.03sq.mtrs.

With reference to above on 16/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Ekta World" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 16 Nos.
B) Hose Reel Hose has been installed in every floor – 16 Nos.
C) Hose Box has been installed in Alternate floor – 19 Nos.
D) Siamese Connection has been installed in entrance gate
E) Courtyard Hydrant has been installed in the building & prominent places – 03 Nos.
F) Mian Pump on under ground water storage tank (60hp) - 01 Nos.
G) Jockey Pump on under ground water storage tank (15hp) – 01 Nos
H) Booster Pump near over head water storage tank (7.5hp) – 01 Nos.
I) Fire Alarm Panel – 01 Set
J) Pill Box with Hooter- 16 Nos.
K) Diesel Generator Set

24/12/2024

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 62,93,828.80/-, Vide Receipt 167932, Rs. 1,15,80,890/- ,vide Receipt No. 167933, Rs.8,70,520/- vide Receipt No. 167935, Rs.17,63,030/- vide Receipt No. 167934, Rs.53,06,415/- vide Receipt No. 167938, Rs.5,95,920/- vide Receipt No. 167937, Rs.4,45,000/- vide Receipt No. 167936 & Rs400/- vide Receipt No. 167940, Dated:07/02/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s-Ekta World

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४७४५/२०२१
दिनांक : २४/१२/२०२१

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential cum Commercial, Residential Building & CFC Building in Sector – II of Village: Dongre, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1293/2021-22,
Dated:26/11/2021.

- 2) An application received by M/s- Ajay Wade & Associates, Dated:18/11/2021.
- 3) An application received by Developer M/s- Ekta World, Dated:18/11/2021
- 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:18/11/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/177/2011-12,
Dated:07/02/2012.
- 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:18/11/2021.
- 7) Certificate from License Agency M/s- DIPL, Dated:03/09/2021
(Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
- 9) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour.
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/12/2021.
- 11) Structure Stability Certificate for M/s- JW Consultants, Dated:11/10/2019
- 12) RDP issued by VVCMC/TP/RDP/VP-0880/037/2014-15, Dated:15/05/2014.
- 13) Submitted Electric Certificate M/s-Shree Electric Corporation, Dated:27/10/2021.
- 14) Diesel Engine Test Certificate of M/s- Powerica Ltd, Dated: 08/04/2011.
- 15) C.F.O. site visit Dated:16/12/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential cum Commercial Building No. 9 (Wing – C, D & E) & Residential cum Commercial Building No. 10 (Wing – F, G, H, I, J & K) & Residential Building No.12 (Wing-K) (Stilt / Gr + 15 floor) in 47.55mtrs Height & CFC Building (Podium Floor) in 4.20mtrs Height. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- DIPL, bearing License No. MFS-LA/RF-136, MFS-LA/RD-123 and has submitted Certificate on 03/09/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No. 9 (Wing- C – 6774.02sq.mtrs; Wing- D – 3342.85sq.mtrs; Wing- E – 3384.25sq.mtrs) & Bldg No. 10 – (Wing- F - 5288.09sq.mtrs, Wing- G – 2784.23sq.mtrs; Wing- H – 3895.19sq.mtrs; Wing-I – 5576.76sq.mtrs; Wing- J – 4689.33sq.mtrs; Wing- K – 3637.84sq.mtrs & Bldg No.12 (Wing-K) – 3328.16sq.mtrs.

With reference to above on 16/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Ekta World" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places.
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor .
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank .
- G) Jockey Pump on under ground water storage tank
- H) Booster Pump near over head water storage tank.
- I) Fire Alarm Panel
- J) Pill Box with Hooter
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 62,93,828.80/-, Vide Receipt 167932, Rs. 1,15,80,890/- ,vide Receipt No. 167933, Rs.8,70,520/- vide Receipt No. 167935, Rs.17,63,030/- vide Receipt No. 167934, Rs.53,06,415/- vide Receipt No. 167938, Rs.5,95,920/- vide Receipt No. 167937, Rs.4,45,000/- vide Receipt No. 167936 & Rs400/- vide Receipt No. 167940, Dated:07/02/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s-Ekta World

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.

प्रतमिळाली

लिपिक (न.र.)

ई-विरार शहर महानगरपालिका

दि. २६/०९/२०२१

FIRE & EMERGENCY DEPARTMENT



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४७४५/२०२१

दिनांक : २६/०९/२०२१



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential cum Commercial Building in Sector – II of Village: Dongre, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1293/2021-22, Dated:26/11/2021.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:18/11/2021.
 - 3) An application received by Developer M/s- Ekta World, Dated:18/11/2021
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:18/11/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/177/2011-12, Dated:07/02/2012.
 - 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:18/11/2021.
 - 7) Certificate from License Agency M/s- DIPL, Dated:03/09/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/12/2021.
 - 11) Structure Stability Certificate for M/s- JW Consultants, Dated:11/10/2019
 - 12) RDP issued by VVCMC/TP/RDP/VP-0880/037/2014-15, Dated:15/05/2014.
 - 13) Submitted Electric Certificate M/s-Shree Electric Corporation, Dated:27/10/2021.
 - 14) Diesel Engine Test Certificate of M/s- Powerica Ltd, Dated: 08/04/2011.
 - 15) C.F.O. site visit Dated:16/12/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential cum Commercial Building No. 9 (Wing – C, D & E) & Residential cum Commercial Building No. 10 (Wing – F, G, H, I, J & K) (Stilt / Gr + 15 floor) in 47.55mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- DIPL, bearing License No. MFS-LA/RF-136, MFS-LA/RD-123 and has submitted Certificate on 03/09/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No. 9 (Wing- C – 6774.02sq.mtrs; Wing- D – 3342.85sq.mtrs; Wing- E – 3384.25sq.mtrs) & Bldg No. 10 – (Wing- F - 5288.09sq.mtrs, Wing- G – 2784.23sq.mtrs; Wing- H – 3895.19sq.mtrs; Wing-I – 5576.76sq.mtrs; Wing- J – 4689.33sq.mtrs; Wing- K – 3637.84sq.mtrs.

With reference to above on 16/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Ekta World" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places.
- B) Hose Reel Hose has been installed in every floor
- C) Hose Box has been installed in Alternate floor .
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank .
- G) Jockey Pump on under ground water storage tank
- H) Booster Pump near over head water storage tank.
- I) Fire Alarm Panel
- J) Pill Box with Hooter
- K) Diesel Generator Set
- L) Manual Operated Electrical Fire Alarm System.

26/09/2021

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 62,93,828.80/-, Vide Receipt 167932, Rs. 1,15,80,890/-, vide Receipt No. 167933, Rs.8,70,520/- vide Receipt No. 167935, Rs.17,63,030/- vide Receipt No. 167934, Rs.53,06,415/- vide Receipt No. 167938, Rs.5,95,920/- vide Receipt No. 167937, Rs.4,45,000/- vide Receipt No. 167936 & Rs400/- vide Receipt No. 167940, Dated:07/02/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s-Ekta World

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/४७५१/२०२१-२२
दिनांक : २८/१२/२०२१

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



प्रतमिळाली

लिपिक (न.र.)
वसाई-विरार महानगरपालिका
२८.१२.२०२१

Sub:- "Final No Objection Certificate" of Residential with Shopline Building on land bearing S.No.5, H.No.3 of Village: Mulgaon, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1374/2021-22, Dated:09/12/2021.
2) An application received by M/s- Ajay Wade & Associates, Dated:08/12/2021.
3) An application received by Developer M/s- Guru Prabhu Builder & Developer, Dated:07/12/2021
4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:08/12/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/234/2017-18, Dated:27/06/2017.
6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:08/12/2021.
7) Certificate from License Agency M/s- Anushka Fire Services, Dated:22/10/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:06/01/2021.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/12/2021.
11) Structure Stability Certificate for Mr. Sureshkumar Panicker, Dated:12/06/2021
12) RDP issued by VVCMC/TP/RDP/VP-5177/301/2021-22, Dated:15/07/2021.
13) Submitted Electric Certificate M/s-Shree Samarth Krupa Electrical Dated:07/12/2021.
14) C.F.O. site visit Dated:16/12/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building (Stilt / Gr + 7 floor) in 23.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Anushka Fire Services, bearing License No. MFS-LA/2021/RF-15, MFS-LA/2021/RD-15 and has submitted Certificate on 22/10/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2412.19sq.mtrs.

With reference to above on 16/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Guru Prabhu Builder & Developer" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 16 Nos
- B) Hose Reel Hose has been installed in every floor – 14 Nos
- C) Hose Box has been installed in Alternate floor – 17 Nos
- D) Siamese Connection has been installed in entrance gate
- E) Courtyard Hydrant has been installed in the building & prominent places.
- F) Mian Pump on under ground water storage tank (10hp) – 01 Nos
- G) Booster Pump near over head water storage tank (900lpm) – 02 Nos
- H) Sprinkler Head – 42 Nos
- I) Fire Alarm Panel – 02 Nos
- J) Pill Box with Hooter - 14 Nos
- K) Manual Operated Electrical Fire Alarm System.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,00,000/-, Vide Receipt 572140, DD.No.000268, Dated:27/06/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s-Guru Prabhu Builders & Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

Received
Dalmeida
17/1/2022

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. | आग्नि | मुका | १७५२ | २०२१ -
दिनांक : २८/१२/२०२१



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Educational Building on land bearing S.No.180, H.No.B, S.No.181, H.No.B./1/1, 1/2, 1/3, 2A, 2D, 2E, 2/1, 2/2, 3D, 3E, 3/2, S.No.182, H.No.1, 2, 3, 4 + 6, 5, 7, S.No.183, H.No.4, S.No.184, H.No.24B of Village: Sandor, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/886/2021-22, Dated:23/09/2021.
2) An application received by M/s- En Con Project Consultants, Dated:11/09/2021.
3) An application received by Developer M/s- S. T. Thomas Society, Dated:19/09/2021
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/09/2021.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/880/2016-17, Dated:17/01/2017.
6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:11/09/2021.
7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:20/08/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:08/01/2021.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/12/2021.
11) Structure Stability Certificate for M/s- S. S & Associates, Dated:17/08/2021
12) RDP issued by VVCMC/TP/RDP/VP-5479/093/2016-17, Dated:28/02/2017.
13) Submitted Electric Certificate M/s-Maurya Electric Works, Dated:18/10/2021
14) C.F.O. site visit Dated:23/12/2021.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Educational Building (Gr + 3 floor) in 15.75mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/2021/RF-26, MFS-LA/2021/RD-20 and has submitted Certificate on 20/08/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1907.06sq.mtrs.

With reference to above on 23/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- S. T. Thomas Society" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 07 Nos
- B) Hose Reel Hose has been installed in every floor – 06 Nos
- C) Hose Box has been installed in Alternate floor – 03 Nos
- D) Courtyard Hydrant has been installed in the building & prominent places – 08 Nos
- E) Mian Pump on under ground water storage tank (10hp) – 01 Nos
- F) Booster Pump near over head water storage tank (5hp) – 01 Nos
- G) MCP – 04 Nos
- H) Hooter – 04 Nos
- I) Smoke Detector – 04 Nos
- J) Panel Board (04 Zones) – 01 Nos
- K) Pill Box with Hooter - 14 Nos

17/12/21
ENCON

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,70,000/-, Vide Receipt 425878 (Bank of India), Dated: 11/03/2016 & Rs. 1,30,000/- vide Receipt No. 470213 (Bank of India), Dated: 17/01/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- S. T. Thomas Society

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.