

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/०९५/२०२२
दिनांक : ०७/०४/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Commercial Building No. II on land bearing S.No.392/A of Village: Bolinj & S.No.376 (Pt) of Village:Virar, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1566/2021-22, Dated:24/01/2022.
2) An application received by M/s- Architect Nitin A. Patil, Dated:20/11/2021
3) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/246/2019-20, Dated:19/06/2019.
4) Gross built up area certificate for M/s- Architect Nitin A. Patil, Dated:20/11/2021
5) Certificate from License Agency M/s-Vaishali Enterprises, Dated: 23/12/2021 (Form A).
6) Submitted License copy of Maharashtra Fire Services, Dated:01/01/2021.
7) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:04/02/2022.
9) Structure Stability Certificate for Mr.Satish C. Dhupelia, Dated:23/12/2021.
10) RDP issued by VVCMC/TP/RDP/VP-0191/81/2019-20, Dated:16/09/2019.
11) Submitted Electric Certificate M/s- Mahavitaran, Dated:Nil.
12) C.F.O. site visit Dated:04/02/2022.

With reference to Sr. No. 2 above, this office is in received of your application for your **Commercial Building No. II as (Gr + 3) in 16.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vaishali Enterprises, bearing License No. MFS-LA/2021/RF-01 & MFS-LA/2021/RD-01 and has submitted Certificate on 03/12/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1167.44sq.mtrs.

With reference to above on 04/02/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mhada" following Fire Fighting arrangements provided were found in satisfactory working condition.

- ABC Type Portable Fire Extinguishers has been installed – 12 Nos.
- Hose Reel Hose – 10 Nos.
- Hose Box has been installed in Alternate floor – 10 Nos.
- Hydrant Valve – 10 Nos.
- Stand by Pump (60 Hp) – 01 Nos.
- Sprinkler & Hydrant Pump (60 Hp) – 01 Nos.
- Jockey Pump (7.5 Hp) – 02 Nos.
- Booster Pump near over head water storage tank (12.5 Hp) - 01 Nos.
- Automatic Sprinkler – 188 Nos.
- Fire Bucket – 10 Nos.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 11,58,060/- vide Receipt No. 779340, DD. No. 765576, Dated: 11/06/2019 & DD.No.765576, Dated:31/05/2019 of Bank of Maharashtra.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Nitin A. Patil

2) Developer- M/s- Mhada

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

प्रतमिळाली

निमित्त (न.र.)
ई-विरार शहर महापालिका
क. ०२.१०.५.१२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of CFC Building CFC-7A (Gr + 2pt floor) located on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village: Dongre, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1742/2021-22, Dated:23/02/2022.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:07/02/2022.
 - 3) An application received by M/s- Shalibhadra Developers, Dated:07/03/2022
 - 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:07/02/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/756/2016-17, Dated:08/12/2016.
 - 6) Gross Built up area certificate for M/s- M/s- Shah Gattani Consultants, Dated:07/02/2022.
 - 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:04/02/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate by M/s- Shalibhadra Developers, Dated:07/03/2022
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/03/2022.
 - 11) Structure Stability Certificate for M/s- Struct Bombay Consultants, Dated:07/02/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-0453/58/2018-19, Dated:29/06/2018.
 - 13) Submitted Electric Certificate M/s- Eshwari Electricals, Dated:05/02/2022
 - 14) Diesel Engine Test Certificate of M/s- Kirloskar Oil Engines, Dated:01/2022
 - 15) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 16) C.F.O. site visit Dated:16/03/2022.

With reference to Sr.No.2 & 3 above, this office is in received of your application for your **CFC Building (CFC-7A) Gr + 2pt floor in 16.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/RF-332, MFS-LA/RD-305** and has submitted Certificate on 04/02/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 889.94sq.mtrs.

With reference to above on 16/03/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Shalibhadra Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places – 06 Nos.
- B) Fire Buckets with Sand – 04 Nos.
- C) Hose Reel Hose has been installed in every floor – 02 Nos.
- D) Hose Box has been installed in Alternate floor – 08 Nos.

K) Sprinkler Jockey Pump – (180 lpm) - 01 Nos.

L) Diesel Generator Set

M) Fire Alarm System – 01 set.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 10,00,000/- vide Receipt No.425890, DD.No.100657, (Vasai Vikas Sahakari Bank), Dated-17/03/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s-Shalibhadra Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/०२५/२०२२
दिनांक : ०४/०३/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building No. 5 (Wing-A to L), Building No.6 (Wing-A), Residential with Shopline Building No. 6 (Wing-B, C, D, E & F) & Residential Building No.7 (Wing-A & B) in Plot - I, Phase-II on S.No. 2, S.No.3, H.No.1, 7, 8, 10, S.No.4 etc... of Village: Tivri, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1828/2021-22, Dated:15/03/2022.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:17/03/2022.
 - 3) An application received by Developer M/s-Sunteck Realty Ltd, Dated:17/03/2022
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:17/03/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/156/2018-19, Dated:09/06/2018.
 - 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:17/03/2022.
 - 7) Certificate from License Agency M/s- S. K. Enterprises, Dated:01/03/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:19/06/2021.
 - 9) AMC Certificate by Developer M/s-Sunteck Realty Ltd, Dated:17/03/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:26/03/2022
 - 12) Structure Stability Certificate for M/s- Epicons Consultants Pvt Ltd, Dated:30/07/2021
 - 13) RDP issued by VVCMC/TP/RDP/SPA-VP-006/06/2019-20, Dated:08/07/2019.
 - 14) Submitted Electric Certificate M/s- Supriya Electricals, Dated:19/03/2022.
 - 15) Diesel Engine Test Certificate of M/s- Kirloskar Brothers Ltd, Dated:28/11/2019.
 - 16) C.F.O. site visit Dated:26/03/2022.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your Residential Building No. 5 (Wing- A to L) as (Stilt + 22th floor) in 68.20mtrs Height; Building No. 6 (Wing - A) (Stilt + 22th floor) in 68.85mtrs Height; Residential with Shopline Building No.6 (Wing- B) (Gr / Stilt + 22th floor) in 69.95mtrs Height; (Wing - C) (Basement + Gr/ Stilt + 22th floor) in 69.95mtrs Height; (Wing - D) (Basement + Gr/ Stilt + 22th floor) in 69.70mtrs Height; (Wing- E & F) (Gr / Stilt + 22th floor) in 69.95mtrs Height & Building No. 7 (Wing- A & B) (Stilt + 22th floor) in 68.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- S. K. Enterprises, bearing License No. MFS-LA/RF-295, MFS-LA/RD-270 and has submitted Certificate on 01/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 54674.936sq.mtrs, 31762.79sq.mtrs & 9114.621sq.mtrs.

With reference to above on 26/03/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Sunteck Realty Ltd" following Fire Fighting arrangements provided

- H) Booster Pump near over head water storage tank (180lpm) – 07 Nos.
- I) Double Hydrant Valve – 441 Nos.
- J) Single Hydrant Valve – 27 Nos.
- K) Pendant Sprinkler (68 deg) – 2920 Nos.
- L) Side Wall Sprinkler (68 deg) – 5920 Nos.
- M) Side Wall Sprinkler (79 deg) – 2520 Nos.
- N) Fire Alarm Panel – 06 Nos.
- O) Repeater Panel – 12 Nos.
- P) Digital Voice Evacuation Amplifiers – 06 Nos.
- Q) Gooseneck Microphone – 06 Nos.
- R) Fireman Telephone Panel – 06 Nos.
- S) Smoke Detectors – 1383 Nos.
- T) Heat Detectors – 2132 Nos.
- U) Multisensory Detector – 28 Nos.
- V) Control Module – 22 Nos.
- W) Hooter – 391 Nos.
- X) Manual Call Point – 391 Nos.
- Y) Wall Mounted Speaker – 1224 Nos.
- Z) Telephone Jack – 782 Nos.
- AA) Handset – 23 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 91,38,700/-, vide Receipt No.91348, DD.No.991603, Dated:25/04/2011 & Rs.84,34,900/- vide Receipt No.91349, DD.No.991605, Dated:25/04/2011 & Rs.1,54,30,245/- vide Receipt No.646100, DD.No.108628, Dated:09/05/2018 of Karnataka Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s-Sunteck Realty Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. / अग्नि/मुक्ता/ ०३५२२-२३
दिनांक : ०८-०८-२०२२

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Radheya Construction Co,
118, Goyal Shopping Arcade,,
S.V.Road, Opp. Rly.Station,
Borivali (W), Mumbai- 400 092.

Sub:-Renewal of "Final No Objection Certificate" of Residential-with Shopline Building Known as "Sai Enclave" located at S.No.317, H.No.9, 11 & 13 of Village: Juchandra, Tal-Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s- Radheya Construction Co, Dated:15/02/2022
2) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:21/02/2022 (Form B)
3) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:31/03/2022.
4) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/ 97/2018-19, Dated:03/05/2018.
5) Submitted Renewal of Final No Objection Certificate No. VVCMC/FIRE/HQ/ 561/2020, Dated:05/11/2020.
6) OC issued by VVCMC/RP/OC/VP-248/36/2020-21, Dated:11/11/2020
7) RDP issued by VVCMC/TP/RDP/VP-0248/344/2014-15, Dated:18/03/2015
8) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022
9) Electric Certificate received from M/s-S.R.Electricals, Dated:26/09/2016
10) C.F.O site visit Dated:31/03/2022.

With reference to Sr.No.1 above, this office is in received of your application for your Residential with Shopline Building (Wing- A & B) (Gr / Stilt + 14th Floor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71, MFS-LA/RD-69 and has submitted Certificate On 08/02/2022 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 1,79,500/- vide Receipt No. 30505, Book No. 306, DD No.067473 (HDFC Bank), Dated:22/03/2022 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फैक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/ ६६ /2022-23
दिनांक : २२/04/2022.

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Vidyavardhini's Collage of Engineering & Technology,
K.T.Marg,
Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of "VIDYAVARDHINI'S COLLEGE OF ENGINEERING & TECHNOLOGY", K.T.Marg, Vasai (W), Tal-Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s- Vidyavardhini's Collage of Engineering & Technology, Dated:20/04/2022.
2) Certificate from License Agency M/s- Fire Bird Fire Services, Dated: 21/04/2022 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/04/2022.
4) Submitted Renewal of Final No Objection Certificate No. VVCMC/FIRE/HQ/939/2020, Dated:18/02/2021.
5) Submitted Lift Maintenance Agreement M/s- Sun Shine Lift Co, Dated:01/02/2022
6) Submitted Electrical Certificate M/s- Vasant Electrical, Dated:Nil
7) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
8) C.F.O site visit Dated:22/04/2022.

With reference to Sr.No.1 above, this office is in received of your application for your M/s- Vidyavardhini's Collage of Engineering & Technology at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71, MFS-LA/RD-69 and has submitted Certificate On 02/02/2022 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 1,25,000/- vide Receipt No. 30697, Book No. 307, DD No.425225 (Union Bank), Dated:21/04/2022 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/२०/२०२२
दिनांक : २२/०४/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building located on land bearing S.No.219, H.No.1(Pt) & S.No.217 of Village: Pelhar, Tal:Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1918/2021-22, Dated:30/03/2022.
- 2) An application received by M/s- Himesh Gupta & Associates, Dated:11/03/2022.
 - 3) An application received by M/s- Nirmal Shah, Dated:11/03/2022
 - 4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated:11/03/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/250/2017-18, Dated:01/07/2017.
 - 6) Construction area certificate for M/s- Himesh Gupta & Associates, Dated:11/03/2022.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:01/03/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) Submitted AMC Contract by M/s- TFPC Infra LLP, Dated:01/03/2022
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/04/2022.
 - 11) Structure Stability Certificate for M/s- Pro-Tech Consultants, Dated:05/03/2021
 - 12) CC issued by VVCMC/TP/CC/VP-5225/7123/2017-18, Dated:30/01/2018.
 - 13) Submitted Electric Certificate M/s- Rudra Power Solutions, Dated:03/03/2022.
 - 14) D.G.Set Certificate of M/s-Perfect House Pvt Ltd, Dated:23/12/2021
 - 15) C.F.O. site visit Dated:08/04/2022

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building (Unit No. 77) as (Stilt / Gr + 2Pt) in 12.55mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384/ MFS-LA/RD-359 and has submitted Certificate on 01/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 345.89sq.mtrs.

With reference to above on 31/03/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Nirmal Shah" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (6kg) – 03 Nos.
- B) Hose Reel Hose has been installed in every floor – 02 Nos
- C) Hose Box has been installed in Alternate floor – 02 Nos.
- D) Booster Pump near over head water storage tank (5hp) – 01 Nos.
- E) Pump Control Panel – 01 Nos.
- F) Hydrant Valve – 04 Nos.
- G) Fire Alarm Control Panel – 01 Nos.
- H) MCP – 03 Nos.
- I) Hooter – 03 Nos.
- J) Sprinkler System – 24 Nos.

Received
Dmg

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.80,000/- vide Receipt No. 572149, DD. No. 050540, Dated:28/06/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Himesh Gupta & Associates
2) Developer- M/s- Nirmal Shah

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/१२४/२०२२
दिनांक : २५/०४/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No.9 located on land bearing S.No.242, 246, H.No.1,2, S.No.247, 248 of Village: Nilemore, Tal:Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/20/2022-23,
Dated:06/04/2022.

- 2) An application received by M/s- Ajay Wade & Associates, Dated:31/03/2022.
- 3) An application received by M/s- D.G.Land Developers Pvt Ltd, Dated:31/03/2022
- 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:31/03/2022.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/2425/2019, Dated:24/03/2020.
- 6) Construction area certificate for M/s- Ajay Wade & Associates, Dated:31/03/2022.
- 7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:21/03/2022 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
- 9) AMC Certificate by M/s- D.G.Land Developers Pvt Ltd, Dated:24/03/2022
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated:Nil
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/04/2022.
- 12) Structure Stability Certificate for M/s- Sameer Mohite & Associates, Dated:11/09/2019
- 13) RDP issued by VVCMC/TP/RDP/VP-0067,0320,0567,5399,5707/190/2019-20, Dated:13/11/2019.
- 14) Submitted Electric Certificate M/s- Shree Yogeshwari Electric Works, Dated:21/03/2022.
- 15) D.G.Set Certificate of M/s-Shyam Global Technoventure Pvt Ltd, Dated:31/10/2019
- 16) C.F.O. site visit Dated:22/04/2022

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building No. 9 (Wing- A to E) as (Stilt / Gr + 15 floor) in 47.75mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate on 21/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-A -5132.67sq.mtrs, Wing-B - 5121.74sq.mtrs, Wing-C -5116.45sq.mtrs, Wing-D -5124.42sq.mtrs & Wing-E -5121.74sq.mtrs

With reference to above on 06/04/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- D.G. Land Developers Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

Sr. No.	Material	Wing- A to E
1	Hydrant Valve	18 Nos

8	Jockey Pump 7.5hp	01 Nos
9	Booster Pump 7.5hp	01 Nos
10	Sprinkler	60 Nos
11	Fire Panel	01 Nos
12	Fire Alarm Panel	01 Nos
13	MCP/HOOTER	15 Nos
14	Smoke Detector	02 Nos
15	ABC (06 kg)	09 Nos

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.5,25,000/- vide Receipt No.226605, DD. No. 005304, Rs.3,40,000/- vide Receipt No.226607, DD. No. 005303, Rs.82,000/- vide Receipt No.312258, DD. No. 042088, Rs.1,23,000/- vide Receipt No.312257, DD. No.042079, Rs.4,50,000/- vide Receipt No.590314, DD. No. 788959, Rs.5,80,000/- vide Receipt No.818495, DD. No. 794718, Rs.22,85,000/- vide Receipt No.819093, DD. No. 017470, Dated:02/03/2020

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s- D. G. Land Developers Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.

प्रतमिळाली

निमित्त (न.र.)

वि. विरार शहर महानगरपालिका

०२/०५/२०२२



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुठा/१२८/२०२२
दिनांक : २५/०४/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Agro Based Industry on land bearing S.No.21, H.No.1/5 of Village: Bilalpada, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1706/2021-22, Dated:18/02/2022. (VP-0251)
- 2) An application received by M/s- Himesh Gupta & Associates, Dated:16/02/2022.
 - 3) An application received by Developer Mr.Hiraram Dhukaji Purohit, Dated:15/02/2022
 - 4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated:16/02/2022
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/69/2018-19, Dated:23/04/2018.
 - 6) Construction area certificate for M/s- Himesh Gupta & Associates, Dated:16/02/2022.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:15/02/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) AMC Certificate by Mr.Hiraram Dhukaji Purohit, Dated:15/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/03/2022.
 - 12) Structure Stability Certificate for M/s-Pro-Tech Consultants, Dated:01/10/2021.
 - 13) Submitted Electric Certificate M/s- Shiv Sai Electricals Works, Dated:15/02/2022.
 - 14) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:Nil/01/2022
 - 15) C.F.O. site visit Dated:16/03/2022.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Agro Based Industry Buildings (Gr + 1 Part Floor) in 10.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-TFPC Infra LLP**, bearing License No. **MFS-LA/RF-384, MFS-LA/RD-359** and has submitted Certificate on 15/02/2022 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 1125.35sq.mtrs.

With reference to above on **08/03/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr. Hiraram Dhukaji Purohit"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers (04 Kg) – 02 Nos.
- B) Hose Reel Hose has been installed in every floor – 01 Nos.
- C) Hose Box has been installed in Alternate floor – 01 Nos.
- D) Booster Pmup (5Hp) – 01 Nos.
- E) Panel for above pump set – 01 Nos.
- F) Single Hydrant Valve – 02 Nos.
- G) Fire alarm panel – 01 Nos.
- H) RRL Hose Pipe – 01 Nos.
- I) Branch Pipe – 01 Nos.

Received
And

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 1,70,000/- vide Receipt No. 646054, DD.No.161275, Dated- 16/04/2018 of Dena Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Himesh Gupta & Associates
2) Developer- Mr. Hiraram Dhukaji Purohit

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./प्रति/मुका/१९०/२०२२
दिनांक : ०५/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Transit Godowns Building No.1, CFC Building & Club House on land bearing S.No.1, H.No.2, 1/3 of Village:Kaman, Tal:Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/18/2022-23,
Dated:06/04/2022.

- 2) An application received by M/s- Himesh Gupta & Associates, Dated:19/03/2022.
- 3) An application received by Developers M/s- A.1.Enterprises, Dated:19/03/2022
- 4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated:19/03/2022.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/930/2017-18, Dated:29/01/2018.
- 6) Construction area certificate for M/s- Himesh Gupta & Associates, Dated:19/03/2022.
- 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:24/03/2022 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
- 9) Submitted AMC Contract by Developer M/s-TFPC Infra LLP , Dated:24/03/2022
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:25/04/2022.
- 11) Structure Stability Certificate for M/s- S.S.Associates, Dated:07/03/2022
- 12) RDP issued by VVCMC/TP/RDPVP-5979/217/2018-19, Dated:12/02/2019.
- 13) Submitted Electric Certificate M/s- Kranti Electricals, Dated:26/03/2022.
- 14) D.G.Set Certificate of M/s-Perfect House Pvt Ltd, Dated:23/12/2021
- 15) C.F.O. site visit Dated:25/04/2022

With reference to Sr.No.2 above, this office is in received of your application for your **Transit Godowns Building No. 1 as (Gr + 1Pt floor) in 10.60mtrs Height, CFC Building as (Gr + 1 floor) in 7.80mtrs Height & Club House as (Ground floor) in 4.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384, MFS-LA/RD-359 and has submitted Certificate on 24/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Transit Godowns Building - 3623.89sq.mtrs, CFC Building - 458.60sq.mtrs & Club House - 274.15sq.mtrs.

With reference to above on 25/04/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- A.1.Enterprises" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (4kg) - 08 Nos.
- B) Hose Reel Hose has been installed in every floor - 02 Nos
- C) Hose Box has been installed in Alternate floor - 16 Nos.
- D) Main Pump (40Hp) - 01 Nos.
- E) Jockey Pump (7.5Hp) - 01 Nos.
- F) Booster Pump near over head water storage tank (5hp) - 02 Nos.
- G) Ground Level Hydrant Valve - 16 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.4,80,000/- vide Receipt No. 609560, DD. No. 041336 (ICICI Bank), Dated:23/01/2018; Rs.80,000/- vide Receipt No. 609563, DD.No.158529 (Syndicate Bank), Dated:23/01/2018; Rs.80,000/- vide Receipt No.609564, DD.No.158530 (Syndicate Bank), Dated:23/01/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "J. P. Joshi".

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Himesh Gupta & Associates
2) Developer- M/s- A.1.Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म.अग्नि/मुका/२१०/२०२२
दिनांक : ०५/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of CFC Building on land bearing S.No.58, S.No.67, H.No.7/1 of Village:Maljipada, Tal:Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/32/2022-23, Dated:08/04/2022. (SPA VP-0016)
- 2) An application received by M/s- Ajay Wade & Associates, Dated:24/03/2022.
 - 3) An application received by Developers Mr.Parth B. Mehta & Others, Dated:28/02/2022
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:24/03/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/117/2015-16, Dated:30/03/2016
 - 6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/2168/2019-20, Dated:22/01/2020.
 - 7) Construction area certificate for M/s- Ajay Wade & Associates, Dated:24/03/2022.
 - 8) Certificate from License Agency M/s- Jay Jivdani Fire Services, Dated:20/01/2022 (Form A).
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:10/01/2022.
 - 10) Submitted AMC Contract by Developer Mr.Parth B. Mehta & Others , Dated:28/02/2022
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:27/04/2022.
 - 12) Structure Stability Certificate for M/s- JW Consultants LLP, Dated:28/03/2016
 - 13) Submitted Electric Certificate M/s-Aim Realty Engineering Pvt Ltd, Dated:28/03/2016.
 - 14) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.Dated :Nil.
 - 15) D.G.Set Certificate of M/s-Om Diesel Engineering, Dated:04/03/2022
 - 16) C.F.O. site visit Dated:27/04/2022

With reference to Sr.No.2 above, this office is in received of your application for your **CFC Building as (Ground floor) in 5.10mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Jay Jivdani Fire Services, bearing License No. MFS-LA/RF-07, MFS-LA/RD-08 and has submitted Certificate on 20/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 306.31sq.mtrs.

With reference to above on 27/04/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr.Parth B. Mehta & Others" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (5kg) – 06 Nos.
- B) Hose Reel Hose has been installed in every floor – 02 Nos
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Main Pump (25Hp) – 01 Nos.
- E) Booster Pump (5hp) – 01 Nos.
- F) Courtyard Hydrant Valve – 04 Nos.
- G) Fire Alarm Control Panel – 02 Nos.
- H) MCP & Hooter – 02 Nos.
- I) Smoke Detector – 05 Nos.
- J) Diesel Generator Set – 01 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.80,000/- vide Receipt No. 458105, DD. No. 001964, Dated:22/03/2016; Rs.6,00,000/- vide Receipt No. 818968, DD.No.025144, Dated:22/01/2020; Rs.80,000/- vide Receipt No.818971, DD.No.025115, Dated:19/01/2020 of Axis Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- Mr.Parth B. Mehta & Others

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/२२३/२०२२
दिनांक : ११/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of CFC Building on Plot bearing S.No.191, H.No.2 & 3 (Plot No. 1, 2 & 3) of Village: Bolinj, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1385/2021-22, Dated:14/12/2021.
- 2) An application received by Mr. Abhay Raut Architect, Dated:12/11/2021
 - 3) An application received by M/s- Giriraj Developers, Dated:29/10/2021.
 - 4) Work Completion certificate of Mr. Abhay Raut Architect, Dated:12/11/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/4047/2018-19, Dated:07/03/2019.
 - 6) Built up area certificate for Mr. Abhay Raut Architect, Dated:12/11/2021.
 - 7) Certificate from License Agency M/s- Shree Fire Guard Co, Dated:09/10/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
 - 9) AMC Certificate by M/s- Giriraj Developers, Dated:09/10/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:06/05/2022.
 - 12) Structure Stability Certificate for M/s- Paresh Unnarkar, Dated:15/11/2021.
 - 13) CC issued by VVCMC/TP/CC/VP-1415/223/2019-20, Dated:25/10/2019.
 - 14) Submitted Electric Certificate M/s- Eshwari Electricals, Dated:27/10/2021
 - 15) C.F.O. site visit Dated:06/05/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **CFC Building as (Gr + 2Pt) in 13.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree Fire Guard Co, bearing License No. MFS-LA/2020/RF-270 & MFS-LA/2020/RD-243 and has submitted Certificate on 09/10/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 480.98sq.mtrs.

With reference to above on 15/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Giriraj Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (4 kg) – 05 Nos.
- B) Hose Reel Hose – 03 Nos.
- C) Hose Box has been installed in Alternate floor – 05 Nos.
- D) Hydrant Valve – 02 Nos.
- E) Booster Pump near over head water storage tank (5 Hp) 01 Nos.
- F) Hydrant Main Pump (20Hp) 01 Nos.
- G) Fire Alarm Panel – 01 Nos
- H) MCP/HOOTER- 03 Nos
- I) Manual Fire Alarm System – 01 Nos.
- J) Automatic Sprinkler – 35 Nos.
- K) Smoke Detectors – 17 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 761208, DD. No. 023546, Dated: 13/02/2019 of Axis Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – Mr. Abhay Raut Architect
2) Developer- M/s- Giriraj Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/२००/२०२२
दिनांक : १२/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist. Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building on land bearing S.No.252, H.No.1, Plot No.1 of Village:Virar, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/167/2022-23,
Dated:27/04/2022.

- 2) An application received by M/s-Himesh Gupta & Associates, Dated:25/03/2022
- 3) An application received by Developer Mr.Puroshottam N. Badhe & Others, Dated:25/03/2022.
- 4) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:25/03/2022.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1032/2018-19, Dated:13/12/2018.
- 6) Built up area certificate for M/s-Himesh Gupta & Associates, Dated:25/03/2022.
- 7) Certificate from License Agency M/s- Bright Infra System Pvt Ltd, Dated:31/03/2022 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:04/09/2021.
- 9) AMC Certificate Developer by Mr.Puroshottam N. Badhe, Dated:31/03/2022
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/05/2022.
- 12) Structure Stability Certificate for Mr.Haresh L. Patel, Dated:12/04/2022.
- 13) RDP issued by VVCMC/TP/RDP/VP-5965/26/2021-22, Dated:06/04/2021.
- 14) Submitted Electric Certificate M/s- Electrom Engineering India Pvt Ltd, Dated:25/03/2022
- 15) Submitted Diesel Generator Test Certificate M/s-Kirloskar Brothers Ltd, Dated:Nil
- 16) C.F.O. site visit Dated:05/05/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Commercial Building as (Basement - 1 + Basement - 2 + Gr + 5Pt Floor) in 24.00mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Bright Infra Systems Pvt Ltd, bearing License No. MFS-LA/2021/RF-350 & MFS-LA/2021/RD-324 and has submitted Certificate on 31/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2879.28sq.mtrs.

With reference to above on **28/04/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr.Puroshottam N. Badhe & Others"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (4 kg) – 16 Nos.
- B) Fire Bucket (09 ltr) – 16 Nos.
- C) Hose Reel Hose – 07 Nos.
- D) Hose Box has been installed in Alternate floor – 11 Nos.
- E) Main Pump (2850 lpm) – 01 Nos.
- F) Sprinkler Pump (2850 lpm) – 01 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 4,80,000/- vide Receipt No. 605973, DD. No. 389054, Dated:25/01/2018 of Bank of Maharashtra.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s-Himesh Gupta & Associates
2) Developer- Mr.Purushottam N. Badhe & Others

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/२६६/२०२२
दिनांक : २८/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of CFC-1 School Building on land bearing S.No.164 & S.No.334, H.No.1 to 33 of Village:Bolinj, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/10/2022-23, Dated:04/04/2022.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:07/02/2022
 - 3) An application received by Developer M/s- C.M.Mehta & Others, Dated:07/02/2022.
 - 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:07/02/2022
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2079/2019-20, Dated:27/12/2019.
 - 6) Gross built up area certificate for M/s- Shah Gattani Consultants, Dated:07/02/2022
 - 7) Certificate from License Agency M/s- Jai Jivdani Fire Services, Dated:24/01/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:10/01/2022.
 - 9) AMC Certificate from M/s- Jai Jivdani Fire Services, Dated:26/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:06/05/2022.
 - 12) Structure Stability Certificate for M/s- A.S.Mindhe Consulting Structural Engineer, Dated:12/06/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0369/271/2019-20, Dated:04/01/2020.
 - 14) Submitted Electric Certificate M/s- AIM Realty Engineering Pvt Ltd, Dated:03/02/2022
 - 15) Submitted Diesel Generator Test Certificate M/s-Om Diesel Engineering, Dated:16/02/2022
 - 16) C.F.O. site visit Dated:06/05/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **School Building, CFC-1, Ground Floor + 5Pt Floor) in 25.80mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Jai Jivdani Fire Services bearing License No. MFS-LA/RF-07 & MFS-LA/RD-08 and has submitted Certificate on 24/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5734.661sq.mtrs.

With reference to above on 02/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- C.M.Mehta & Others" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (05 Kg) – 14 Nos.
- B) Hose Reel Hose – 10 Nos.
- C) Hose Box has been installed in Alternate floor – 14 Nos.
- D) Main Pump (25 hp) – 01 Nos.
- E) Jockey Pump (5 hp) – 01 Nos.
- F) Booster Pump near over head water storage tank (5 hp) - 01 Nos.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,70,000/- vide Receipt No.818760, DD.No.024442, Dated:28/11/2019 & Rs.8,30,000/-, vide Receipt No.818842, DD.No.024950, Dated:20/12/2019 of Axis Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "J. K. Kulkarni".

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s-Shah Gattani Consultants

2) Developer- M/s- C.M.Mehta & Others

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्ने/मुका/२९६/२०२२-२३
दिनांक : २८/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building Type TD-19, Type RD-27 & Type RD-28 IN Avenue "D" on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village:Dongre , Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/43/2022-23, Dated:12/04/2022.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:16/03/2022
 - 3) An application received by M/s- Venus Developer, Dated:16/03/2022.
 - 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:16/03/2022
 - 5) Gross built up area certificate for M/s- Shah Gattani Consultants, Dated:16/03/2022
 - 6) This office Provisional No objection Certificate No. VVCMC/FIRE/54B/2012-13, Dated:05/07/2012.
 - 7) This office Provisional No Objection Certificate No. VVCMC/FIRE/54C/2012-13, Dated:05/07/2012
 - 8) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:24/02/2022 (Form A).
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022
 - 10) Fire Fighting Work Completed Certificate from M/s- Fire Bird Fire Services, Dated:28/02/2022
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/05/2022.
 - 13) Structure Stability Certificate for M/s- Shanghvi & Associates Consultants Pvt Ltd, Dated:30/09/2021.
 - 14) RDP issued by VVCMC/TP/RDP/VP-0453/071/2012-13, Dated:13/06/2012.
 - 15) Submitted Electric Certificate M/s- Siddhivinayak Electricals, Dated:02/02/2015
 - 16) Submitted Diesel Generator Test Certificate M/s-Nidec Industrial Automation India Pvt Ltd, Dated:21/01/2022
 - 17) C.F.O. site visit Dated:11/05/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Residential Building Type TD-19, Type RD-27 & Type RD-28 as Stilt / Ground Floor + 7 Floor) in 24.00mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate on 24/02/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5364.83sq.mtrs.

With reference to above on 02/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Venus Developer" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 12 Nos.
- B) Hose Reel Hose – 21 Nos.
- C) Hose Box has been installed in Alternate floor – 06 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 7,20,000/- vide Receipt No.254647, Dated:02/07/2012 & Rs.4,80,000/-, vide Receipt No.254648, Dated:02/07/2012.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s-Shah Gattam Consultants
2) Developer- M/s- Venus Developer

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म.।आग्नि।मुका।२६।२०२२-२३
दिनांक : २८/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No. 5, Sctor VI on S.No.49, 50, 51, 52, 53, 54, 55, 56, 77, S.No.57, H.No.1 of Village:Achole, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/49/2022-23, Dated:12/04/2022.
2) An application received by M/s- En Con Project Consultants, Dated:11/04/2022
3) An application received by Developer M/s- G.M.Enterprises, Dated:11/04/2022.
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/04/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/428/2019-20, Dated:19/08/2019.
6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:11/04/2022.
7) Certificate from License Agency M/s- Om Surya Enterprises, Dated:02/03/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:19/02/2022.
9) AMC Certificate from M/s-G.M.Enterprises, Dated:01/01/2022
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/04/2022.
12) Structure Stability Certificate for M/s-Pro-Tech Consultants, Dated:25/03/2022.
13) RDP issued by VVCMC/TP/RDP/VP-0127/231/2019-20, Dated:03/12/2019.
14) Submitted Electric Certificate M/s- Dishant Electrical Service, Dated:05/01/2022
15) Submitted Diesel Generator Test Certificate M/s-Kirloskar Oil Engines Ltd, Dated:19/10/2021
16) C.F.O. site visit Dated:28/04/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Residential with Shopline Building No. 5, Sector VI (Wing-E) as (Stilt / Shop / Ground Floor + 14 Floor) in 43.85mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Om Surya Enterprises, bearing License No. MFS-LA/RF-93 & MFS-LA/RD-92 and has submitted Certificate on 02/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 3279.40sq.mtrs.

With reference to above on **28/04/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- G.M.Enterprises"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed - 16 Nos.
- B) Fire Bucket - 01 Nos.
- C) Hose Reel Hose - 07 Nos.
- D) Hose Box has been installed in Alternate floor - 03 Nos.
- E) Main Pump (35 hp) - 01 Nos.
- F) Sprinkler Pump (12.5 hp) - 01 Nos.
- G) Jockey Pump (7.5 hp) - 01 Nos.
- H) Booster Pump near over head water storage tank (5 hp) - 01 Nos.
- I) Court yard Hydrant - 03 Nos.
- J) Automatic Sprinkler - 28 Nos.
- K) Smoke Detectors - 02 Nos.
- L) MCP / Hooter - 14 Nos.
- M) Sign Edges - 15 Nos.

Ho
ENCOH

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 5,25,000/- vide Receipt No. 779246, DD. No. 023418, Dated:10/04/2019 of Bassein Catholic Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s-En Con Project Consultants
2) Developer- M/s-G.M.Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)

ता.वसई, जि.पालघर-४०१ ३०५.

दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फैक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

प्रतिमळाली

वि.वि.र. शहर महानगरपालिका
विभाग-३.२।०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. 1 on land bearing S.No.4, H.No.5 (CTS.No.328), S.No.5, H.No.1 (CTS.No.329), S.No.34, H.No.2 (CTS.No.331B) & S.No & H.No. 41/8/1 of Village:Malonde, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/270/2022-23, Dated:20/05/2022.
- 2) An application received by Mr- Abhay Raut Architect, Dated:11/05/2022
- 3) An application received by M/s- Ameya Builders & Property Developer, Dated:11/05/2022.
- 4) Development Completion certificate of Mr- Abhay Raut Architect, Dated:12/05/2022
- 5) Built up area certificate for Mr- Abhay Raut Architect, Dated:11/05/2022
- 6) This office Provisional No objection Certificate No. VVCMC/FIRE/051/2015-16, Dated:08/07/2015.
- 7) This office Final No objection Certificate No. VVCMC/FIRE/HQ/832/2017-18, Dated:03/01/2017.
- 8) This office Renewal of Final No Objection Certificate No. VVCMC/FIRE/1085/2021, Dated:23/03/2021
- 9) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/208/2022-23, Dated:05/05/2022.
- 10) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:19/05/2022 (Form B).
- 11) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022
- 12) AMC Certificate from M/s- Ameya Builders & Property Developer, Dated:28/05/2022
- 13) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 14) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:26/05/2022.
- 15) Structure Stability Certificate for M/s- R.D.Magdum, Dated:02/05/2022.
- 16) RDP issued by VVCMC/TP/RDP/VP-530/227/2020-21, Dated:24/03/2021.
- 17) OC issued by VVCMC/TP/OC/VP-530/167/2020-21, Dated:24/03/2021
- 18) Submitted Electric Certificate M/s- Ambika Power Works, Dated:12/05/2022
- 19) Submitted Diesel Generator Test Certificate M/s-Goel Power Engineers, Dated:26/07/2018
- 20) C.F.O. site visit Dated:26/05/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building No. 1 (Wing- A & B) as Pt Stilt / Pt Ground Floor + 7 Floor) in 24.00mtrs Height, at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate on 24/02/2022 in "Form B" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 4254.49sq.mtrs.

With reference to above on 24/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Ameya Builders & Property Developer" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) Hose Reel Hose – 14 Nos.
- C) Hose Box has been installed in Alternate floor – 14 Nos.
- D) Submersible Pump (20 hp) – 01 Nos
- E) Booster Pump near over head water storage tank (5 hp) - 02 Nos.
- F) Fire Panel – 01 Nos.
- G) MCP / Hooter –14 Nos.
- H) Fire Alarm Panel Board (8 Zones) – 02 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 3,20,000/- vide Receipt No.312213, DD.No. 109026 (Vasai Vikas Sahakari Bank), Dated:07/04/2015 & Rs.1,00,000/-, vide Receipt No.30726, DD.No. 118938 (Vasai Vikas Sahakari Bank), Dated:28/04/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



Copy to 1) Architect – Mr. Abhay Raut Architect

2) Developer- M/s-Ameya Builders & Property Developer

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार

विरार (पूर्व)

ता.वसई, जि.पालघर-४०१ ३०५.

दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फैक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

प्रतिमिळाली

वि.वि.र. (स.र.)

वि.वि.र. शहर पदमसाविका

दिनांक: 3.2.2022

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. 1 on land bearing S.No.4, H.No.5 (CTS.No.328), S.No.5, H.No.1 (CTS.No.329), S.No.34, H.No.2 (CTS.No.331B) & S.No & H.No. 41/8/1 of Village:Malonde, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/270/2022-23, Dated:20/05/2022.
- 2) An application received by Mr- Abhay Raut Architect, Dated:11/05/2022
- 3) An application received by M/s- Ameya Builders & Property Developer, Dated:11/05/2022.
- 4) Development Completion certificate of Mr- Abhay Raut Architect, Dated:12/05/2022
- 5) Built up area certificate for Mr- Abhay Raut Architect, Dated:11/05/2022
- 6) This office Provisional No objection Certificate No. VVCMC/FIRE/051/2015-16, Dated:08/07/2015.
- 7) This office Final No objection Certificate No. VVCMC/FIRE/HQ/832/2017-18, Dated:03/01/2017.
- 8) This office Renewal of Final No Objection Certificate No. VVCMC/FIRE/1085/2021, Dated:23/03/2021
- 9) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/208/2022-23, Dated:05/05/2022.
- 10) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:19/05/2022 (Form B).
- 11) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022
- 12) AMC Certificate from M/s- Ameya Builders & Property Developer, Dated:28/05/2022
- 13) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 14) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:26/05/2022.
- 15) Structure Stability Certificate for M/s- R.D.Magdum, Dated:02/05/2022.
- 16) RDP issued by VVCMC/TP/RDP/VP-530/227/2020-21, Dated:24/03/2021.
- 17) OC issued by VVCMC/TP/OC/VP-530/167/2020-21, Dated:24/03/2021
- 18) Submitted Electric Certificate M/s- Ambika Power Works, Dated:12/05/2022
- 19) Submitted Diesel Generator Test Certificate M/s-Goel Power Engineers, Dated:26/07/2018
- 20) C.F.O. site visit Dated:26/05/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building No. 1 (Wing- A & B) as Pt Stilt / Pt Ground Floor + 7 Floor) in 24.00mtrs Height, at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate on 24/02/2022 in "Form B" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 4254.49sq.mtrs.

With reference to above on 24/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Ameya Builders & Property Developer" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) Hose Reel Hose – 14 Nos.
- C) Hose Box has been installed in Alternate floor – 14 Nos.
- D) Submersible Pump (20 hp) – 01 Nos
- E) Booster Pump near over head water storage tank (5 hp) - 02 Nos.
- F) Fire Panel – 01 Nos.
- G) MCP / Hooter –14 Nos.
- H) Fire Alarm Panel Board (8 Zones) – 02 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 3,20,000/- vide Receipt No.312213, DD.No. 109026 (Vasai Vikas Sahakari Bank), Dated:07/04/2015 & Rs.1,00,000/-, vide Receipt No.30726, DD.No. 118938 (Vasai Vikas Sahakari Bank), Dated:28/04/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any tuture expansion, No Objection Certificate from this office is essential.**

Thanking you



Copy to 1) Architect – Mr. Abhay Raut Architect

2) Developer- M/s-Ameya Builders & Property Developer

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. / अमि / मुका / ३२६
दिनांक ३१/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building (Wing-A) & Residential Building Wing- (B, C & D) located on land Bearing S.No.241, H.No.2 & S.No.242, H.No.4 of Village:Virar, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/2083/2019-20, Dated:16/12/2019.
2) An application received by M/s- En Con Project Consultants, Dated:06/12/2019.
3) An Revised application received by M/s- En Con Project Consultants, Dated:09/05/2022.
4) An application received by M/s- D.G.land Developers Pvt Ltd, Dated:29/04/2022
5) Work Completion certificate of M/s- En Con Project Consultants, Dated:09/05/2022.
6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:09/05/2022
7) This office Provisional No objection Certificate No. VVCMC/FIRE/385/2017-18, Dated:11/08/2017.
8) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/1070/2020-21, Dated:17/03/2021
9) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:18/04/2022 (Form A).
10) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:29/04/2022 (Form A).
11) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
12) AMC Certificate by M/s- D.G. land Developers Pvt Ltd , Dated:09/05/2022
13) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :03/02/2021.
14) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:26/03/2022.
15) Structure Stability Certificate for M/s-Ankush Mohile & Associates, Dated:05/08/2019 & 07/04/2022.
16) RDP issued by VVCMC/TP/RDP/VP-0133/340/2019-20, Dated:17/03/2020.
17) RDP issued by VVCMC/TP/RDP/VP-0133/170/2018-19, Dated:20/11/2018.
18) Submitted Electric Certificate M/s- AIM Realty Engineering Pvt Ltd, Dated:15/11/2019.
19) Diesel Engine Test Certificate of M/s-Mahindra Heavy Engines Ltd, Dated:12/02/2022
20) C.F.O. site visit Dated:26/03/2022.

With reference to Sr.No.2 above, this office is in received of your application for your Commercial Building (Wing-A) as (Gr + 3 Floor) in 17.40mtrs Height & Residential Building (Wing- B & C) as (Gr + 10 Floor) in 32.80mtrs Height & Residential Building (Wing-D) as (Gr + 9 Floor) in 29.95mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate on 18/04/2022 & 29/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9005.85sq.mtrs.

With reference to above on 26/03/2022 representative of this office visited the building

- E) Booster Pump near over head water storage tank (7.5 hp) – 01 Nos.
- F) Automatic Sprinkler – 110 Nos.
- G) Fire Alarm Panel (04 Zones) – 01 Nos.
- H) MCP / Hooter – 04 Nos.
- I) Smoke Detector – 60 Nos.
- J) Fire Panel – 01 Nos.

(Wing- B, C & D)

- A) Portable Fire Extinguishers has been installed (06 kg) – 18 Nos.
- B) Hose Reel Hose has been installed in every floor – 29 Nos.
- C) Hose Box – 20 Nos.
- D) Main Pump (50 hp) – 01 Nos.
- E) Sprinkler Pump – 01 Nos.
- F) Jockey Pump – 02 Nos.
- G) Booster Pump near over head water storage tank – 03 Nos.
- H) MCP / Hooter – 29 Nos.
- I) Smoke Detector – 06 Nos.
- J) Fire Alarm Panel Board (11 Zones) – 03 Nos.
- K) Automatic Sprinkler – 165 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.1,70,000/- vide Receipt No . 590322, Book No. 5904, DD.No.788863 (Bharat Bank), Dated:08/08/2017; Rs.2,60,000/- vide Receipt No. 590317, Book No. 5904, DD.No.788864 (Bharat Bank), Dated:08/08/2017; Rs. 2,60,000/- vide Receipt No.590320, Book No.5904, DD. No. 788862 (Bharat Bank), Dated:08/08/2017 & Rs.2,10,000/- vide Receipt No.590321, Book No. 5904, DD.No.788861 (Bharat Bank), Dated:08/08/2017.

The Party has already paid the Rs.85,000/- vide Receipt No. 796299, DD.No.796299 (Bharat Bank), Dated:15/03/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/३२७/२०२२
दिनांक : ३१/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Convenient Shops Building No. 16 Wing-F (Pt Stilt + Pt Ground + 14 Floor) in Yashwant Nagar Constructed on land Bearing S.No.343B of Village:Bolinj, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/276/2022-23, Dated:25/05/2022.
2) An application received by Mr.Abhay Raut Architect, Dated:22/05/2022.
3) An application received by M/s- Ameya Builders & Property Developer, Dated:22/05/2022
4) Work Completion certificate of M/s- Ameya Builders & Property Developer, Dated:29/04/2022.
5) Construction area certificate for Mr.Abhay Raut Architect, Dated:22/05/2022
6) This office Provisional No objection Certificate No. VVCMC/FIRE/3008/2018-19, Dated:05/02/2019.
7) This office Final No objection Certificate No.VVCMC/FIRE/HQ/3071/2018-19, Dated:15/02/2019.
8) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/292/2022-23, Dated:25/05/2022
9) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:30/05/2022 (Form B).
10) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
11) AMC Certificate by M/s- Ameya Builders & Property Developer, Dated:02/05/2022
12) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :03/02/2021.
13) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/05/2022.
14) Structure Stability Certificate for Mr.Paresh Unnarkar, Dated:30/04/2022.
15) RDP issued by VVCMC/TP/RDP/VP-0147/310/2021-22, Dated:15/07/2021.
16) Submitted Electric Certificate M/s- Ambika Power Works, Dated:21/05/2022.
17) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:12/02/2022
18) C.F.O. site visit Dated:28/05/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Convenient Shops Building No.16 (Wing-F) as (Pt Stilt + Pt Gr + 14 Floor) in 45.00mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate on 30/05/2022 in "Form B" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 4921.28sq.mtrs.

With reference to above on 25/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Ameya Builders & Property Developer" following Fire Fighting arrangements provided were found in satisfactory working condition.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.26,70,000/- vide Receipt No. 694425, DD.No.114880 (Vasai Vikas Sahakari Bank), Dated:17/07/2018.

The Party has already paid the Rs.50,000/- vide Receipt No. 30875, Book No.309, DD.No.315458 (Union Bank), Dated:25/05/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – Mr. Abhay Raut Architect

2) Developer- M/s- Ameya Builders & Property Developer

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म.प्रतिनि/मुका/३२८/२०२२
दिनांक : ३१/०५/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building No. 2 located on land Bearing S.No.38, H.No.4 of Village:Sativali, Tal: Vasai, Dist: Palghar.**


Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/190/2022-23, Dated:04/05/2022.

- 2) An application received by M/s-Samrajya Architect, Dated:23/03/2022.
- 3) An application received by M/s- Nidhi Reality, Dated:23/03/2022
- 4) Work Completion certificate of M/s-Samrajya Architect, Dated:23/03/2022.
- 5) Gross built up area certificate for M/s-Samrajya Architect, Dated:23/03/2022
- 6) This office Provisional No objection Certificate No. VVCMC/FIRE/260/2016-17, Dated:12/07/2016.
- 7) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/476/2019-20, Dated:23/08/2019
- 8) Certificate from License Agency M/s- Dhanashri Fire Services, Dated:22/03/2022 (Form A).
- 9) Submitted License copy of Maharashtra Fire Services, Dated:17/07/2022.
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :03/02/2021.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/05/2022.
- 12) Structure Stability Certificate for M/s-S.S.Associates, Dated:08/12/2020.
- 13) RDP issued by VVCMC/TP/RDP/VP-5658/86/2020-21, Dated:26/11/2020.
- 14) Submitted Electric Certificate M/s- Dewang Electricals, Dated:09/03/2022.
- 15) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:Nil
- 16) C.F.O. site visit Dated:16/05/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No.2 as (Gr + 2Pt Floor) in 15.60mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Dhanashri Fire Services**, bearing License No. MFS-LA/RF-318 & MFS-LA/RD-289 and has submitted Certificate on 22/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3902.48sq.mtrs.

With reference to above on **16/05/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Nidhi Reality"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 kg) – 20 Nos.
- B) Hose Reel Hose has been installed in every floor – 10 Nos.
- C) Hose Box – 14 Nos.
- D) Courtyard Hydrant – 08 Nos.
- E) Electric Pump (2250Lpm) – 01 Nos.
- F) Diesel Pump (2250Lpm) – 01 Nos.
- G) Jockey Pump (180Lpm) – 01 Nos.



This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.2,40,000/- vide Receipt No. 470148, DD.No.020849, Dated:05/05/2016; Rs.2,40,000/- vide Receipt No. 470149, DD.No.020848, Dated:05/05/2016; Rs.5,20,000/- vide Receipt No.818339, DD.No.078150 (HDFC Bank), Dated:23/08/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




A handwritten signature in blue ink, appearing to be "D. K. Kulkarni".

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect – M/s- Samrajya Architect
2) Developer- M/s- Nidhi Reality

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/३३८/२०२२
दिनांक : ०२/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Industrial / Commercial Building located on land Bearing S.No.34, H.No.6/2, 6/3, 7/2, 7/3, 12/2, 12/3, 4, 5, 8 & 11 of Village:Gokhivare, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/214/2022-23, Dated:06/05/2022.

- 2) An application received by M/s-En Con Project Consultants, Dated:30/04/2022.
- 3) An application received by Developer Mr. Rakesh Agarwaal, Dated:30/04/2022
- 4) Work Completion certificate of M/s-En Con Project Consultants, Dated:30/04/2022.
- 5) Gross built up area certificate for M/s-En Con Project Consultants, Dated:30/04/2022
- 6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/325/2017, Dated:25/07/2017.
- 7) This office Final No Objection Certificate No. VVCMC/FIRE/HQ/787/2019, Dated:19/10/2019
- 8) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/729/2020-21, Dated:23/12/2020
- 9) Certificate from License Agency M/s- TFPC infra LLP, Dated:29/04/2022 (Form A).
- 10) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
- 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :03/02/2021.
- 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/05/2022.
- 13) Structure Stability Certificate for M/s-S.S. Associates, Dated:30/04/2022.
- 14) RDP issued by VVCMC/TP/RDP/VP-0929/265/2021-22, Dated:08/07/2021.
- 15) OC issued by VVCMC/TP/OC/VP-0929/123/2019-20, Dated:23/12/2019.
- 16) Submitted Electric Certificate M/s- Choice Electricals, Dated:02/02/2022
- 17) AMC Certificate issued by Developer Mr. Rakesh Agarwaal, Dated:30/04/2022.
- 18) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:Nil
- 19) C.F.O. site visit Dated:28/05/2022.

With reference to Sr.No.2 above, this office is in received of your application for your Industrial / Commercial Building as (Gr + 3 Floor) in 21.10mtrs Height. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC infra LLP, bearing License No. MFS-LA/RF-384 & MFS-LA/RD-359 and has submitted Certificate on 29/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9682.18sq.mtrs.

With reference to above on 20/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr. Rakesh Agarwaal" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 kg) – 04 Nos.
- B) Hose Reel Hose has been installed in every floor – 06 Nos.
- C) Hose Box – 05 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.10,00,000/- vide Receipt No. 572156, DD.No.197459, Dated:01/07/2017 of Syndicate Bank & Rs.5,00,000/- vide Receipt No. 819669, DD.No.024376, Dated:23/12/2020 of Bassein Catholic Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s- En Con Project Consultant
2) Developer- Mr. Rakesh Agarwal

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.

प्रतमिळाली

लिपिक (न.र.)

विरार शहर महानगरपालिका

दि. ०६/०६/२०२२



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०९

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/३४०/२०२२

दिनांक : ०६/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Primary School Building on land Bearing S.No.65, H.No.1B & 1C of Village:Dhaniv, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/156/2022-23, Dated:27/04/2022.

- 2) An application received by M/s-Himesh Gupta & Associates, Dated:19/04/2022.
- 3) An application received by M/s- Anmol Educational Charitable Trust, Dated:19/04/2022
- 4) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:19/04/2022.
- 5) Construction area certificate for M/s-Himesh Gupta & Associates, Dated:19/04/2022
- 6) This office Provisional No objection Certificate No.VVCMC/FIRE/HQ/170/2017-18, Dated:07/06/2017
- 7) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/ 809/2018-19, Dated:16/10/2018
- 8) Certificate from License Agency M/s- TFPC Infra LLP, Dated:25/03/2022 (Form A).
- 9) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated:Nil.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/05/2022.
- 12) Structure Stability Certificate for M/s-Seemu Consultancy, Dated:11/03/2022.
- 13) CC issued by VVCMC/TP/CC/VP-5162/292/2018-19, Dated:02/02/2019.
- 14) Submitted Electric Certificate M/s- Invoice Electrics & Electricals Devision, Dated:13/04/2022.
- 15) Submitted AMC Contract Certificate of M/s- TFPC Infra LLP, Dated:01/04/2022
- 16) Submitted Diesel Engine Performance Certificate of Mr.Dashrat D. Shinde, Dated:13/04/2022
- 17) C.F.O. site visit Dated:17/05/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Primary School Building as (Stilt + Gr + 3rd (Pt) Floor) in 15.00mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS-LA/RD-359 and has submitted Certificate on 25/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having Construction area admeasuring to 2422.15sq.mtrs.

With reference to above on 28/04/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Anmol Educational Charitable Trust" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (04 kg) – 04 Nos.
- B) Hose Reel Hose has been installed in every floor – 03 Nos.
- C) Hose Box – 05 Nos.
- D) Booster Pump near over head water storage tank (5 hp) – 01 Nos.
- E) Hydrant Valve – 05 Nos.
- F) 2 way Breeching Connection – 01 Nos.
- G) MCP – 04 Nos.
- H) Hooter – 04 Nos.
- I) Fire Alarm Control Panel – 01 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.1,70,000/- vide Receipt No. 572107, Book No. 5722, DD.No.012612 (Corporation Bank), Dated:06/06/2017 & Rs. 1,30,000/- vide Receipt No. 705511, Book No. 7056, DD.No.002281 (IDBI Bank), Dated:29/09/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you





CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s- Himesh Gupta & Associates
2) Developer- M/s- Anmol Educational Charitable Trust

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०९
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/३४९/२०२२
दिनांक : ०३/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building No. 2 Wing-A (Stilt + Ground + 14 Floor) on land Bearing New S.No.47B, H.No.1, 2 & 3 (Old S.No.47, H.No.9) of Village:Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/283/2022-23, Dated:25/05/2022.
- 2) An application received by M/s-Himesh Gupta & Associates, Dated:18/05/2022.
 - 3) An application received by M/s- Universe Enterprises, Dated:18/05/2022.
 - 4) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:18/05/2022.
 - 5) Construction area certificate for M/s-Himesh Gupta & Associates, Dated:18/05/2022
 - 6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/445/2018-19, Dated:28/08/2018.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:30/04/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) AMC Certificate by M/s- TFPC Infra LLP, Dated:01/06/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated:Nil.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/06/2022.
 - 12) Structure Stability Certificate for M/s-Seemu Consultancy, Dated:01/04/2022.
 - 13) CC issued by VVCMC/TP/CC/VP-5764/296/2018-19, Dated:02/02/2019.
 - 14) Submitted Electric Certificate M/s- Amar Electricals, Dated:03/06/2022.
 - 15) Diesel Engine Test Certificate of M/s-Perfect House Pvt Ltd, Dated:30/11/2021
 - 16) C.F.O. site visit Dated:03/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential Building No.2 (Wing-A) as (Stilt + Gr + 14 Floor) in 43.35mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s- TFPC Infra LLP**, bearing License No. **MFS-LA/RF-384 & MFS-LA/RD-359** and has submitted Certificate on 30/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 6034.03sq.mtrs.

With reference to above on **31/05/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "**M/s- Universe Enterprises**" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 kg) – 15 Nos.
- B) Hose Reel Hose has been installed in every floor – 14 Nos.
- C) Hose Box – 03 Nos.
- D) Main Hydrant Pump (60 hp) – 01 Nos.
- E) Main Sprinkler Pump (60 hp) – 01 Nos.
- F) Jockey Hydrant Pump (12 hp) – 01 Nos.
- G) Jockey Sprinkler Pump (12 hp) – 01 Nos.
- H) Stand by Pump – 01 Nos.
- I) Booster Pump near over head water storage tank (10 hp) – 01 Nos.
- J) Hydrant Valve – 17 Nos.
- K) Fire Alarm Control Panel – 01 Nos.
- L) MCP – 15 Nos.
- M) Hooter – 15 Nos.
- N) Automatic Sprinkler – 98 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.1,20,000/- vide Receipt No. 425469, DD.No.901388 & Rs.80,000/- vide Receipt No.425468, DD.No.901389, Dated:01/02/2016 of Fedral Bank. & Rs.80,000/- vide Receipt No.694406, DD.No.000513 & Rs.2,45,000/- vide Receipt No.694405, DD.No.000511 of Bassein Catholic Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s-Himesh Gupta & Associates
2) Developer- M/s- Universe Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/३४४/२०२२
दिनांक : ०३/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building No. 1 & 2 located on S.No.47/1/3, 47/1/4, 47/2/1, 47/4/1, 48/2/A/2, 48/2/B, 48/2/C, 48/2/D & 48/2/E of Village:Satali, Tal:Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/297/2022-23, Dated:25/05/2022.
- 2) An application received by M/s-En Con Project Consultants, Dated:10/05/2022.
 - 3) An application received by M/s- Manav Builders & Developers, Dated:10/05/2022
 - 4) Work Completion certificate of M/s-En Con Project Consultants, Dated:10/05/2022.
 - 5) Gross built up area certificate for M/s-En Con Project Consultants, Dated:10/05/2022
 - 6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/380/2019-20, Dated:31/07/2019.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:29/04/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/06/2022.
 - 11) Structure Stability Certificate for M/s-S.S. Associates, Dated:10/05/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-6133/14/2021-22, Dated:06/04/2021.
 - 13) Submitted Electric Certificate M/s- Jay Shree Walvadevi Electrical Contractor, Dated:30/04/2022
 - 14) AMC Certificate issued by Developer M/s- TFPC Infra LLP, Dated:04/05/2022.
 - 15) Diesel Engine Test Certificate of M/s-Advance Power, Dated:18/08/2021
 - 16) C.F.O. site visit Dated:03/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No.1 & Building No. 2 as (Gr + 2nd Floor) in 15.60mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS-LA/RD-359 and has submitted Certificate on 29/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 5007.97sq.mtrs for Building No.1 & 4229.25sq.mtrs for Building No.2.

With reference to above on **31/05/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Manav Builders & Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 kg) – 32 Nos.
- B) Hose Reel Hose has been installed in every floor – 08 Nos.
- C) Hose Box – 04 Nos.
- D) Courtyard Hydrant – 12 Nos.
- E) Main Hydrant Pump (40 hp) – 01 Nos.
- F) Main Sprinkler Pump (30 hp) – 01 Nos.
- G) Jockey Pump (7.5 hp) – 01 Nos.
- H) Jockey Sprinkler Pump (7.5 hp) – 01 Nos.
- I) Stand by Pump – 01 Nos.
- J) Booster Pump near over head water storage tank (5 hp) – 01 Nos.
- K) Fire Alarm Control Panel – 04 Nos.
- L) MCP – 12 Nos.
- M) Hooter – 12 Nos.
- N) Automatic Sprinkler System –273 Nos.
- O) Smoke Detector – 130 Nos.

H
N

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.4,80,000/- vide Receipt No. 818276, DD.No. 501771 (The Catholic Syrian Bank), Dated:31/07/2019 & Rs.5,20,000/- vide Receipt No. 895404, Book No. 8955, DD.No.000178 (The Saraswat Co-op Bank), Dated:20/04/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s- En Con Project Consultant
2) Developer- M/s- Manav Builders & Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/३४५/२०२२
दिनांक : ०३/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building No. 1 & 2 located on S.No.47/1/2, S.No.47/2/2, S.No.47/3, S.No.47/4/2 & S.No.47/6 of Village:Sativali, Tal:Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/299/2022-23, Dated:25/05/2022.
- 2) An application received by M/s-En Con Project Consultants, Dated:10/05/2022.
 - 3) An application received by Developer M/s-SKF Enterprises, Dated:09/05/2022
 - 4) Work Completion certificate of M/s-En Con Project Consultants, Dated:10/05/2022.
 - 5) Gross built up area certificate for M/s-En Con Project Consultants, Dated:10/05/2022
 - 6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/126/2019-20, Dated:14/05/2019.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:29/04/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/06/2022.
 - 11) Structure Stability Certificate for M/s-S.S. Associates, Dated:25/04/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-6116/12/2021-22, Dated:06/04/2021.
 - 13) Submitted Electric Certificate M/s- Jay Shree Walvadevi Electrical Contractor, Dated:30/04/2022
 - 14) AMC Certificate issued by Developer M/s- TFPC Infra LLP, Dated:04/05/2022.
 - 15) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:Nil
 - 16) C.F.O. site visit Dated:03/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No.1 & Building No. 2 as (Gr + 2nd Floor) in 15.60mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS-LA/RD-359 and has submitted Certificate on 29/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 7500.94sq.mtrs for Building No.1 & 3969.78sq.mtrs for Building No.2.

With reference to above on **31/05/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-SKF Enterprises"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 kg) – 50 Nos.
- B) Hose Reel Hose has been installed in every floor – 20 Nos.
- C) Hose Box – 06 Nos.
- D) Courtyard Hydrant – 26 Nos.
- E) Main Hydrant Pump (40 hp) – 01 Nos.
- F) Main Sprinkler Pump (30 hp) – 01 Nos.
- G) Jockey Pump (7.5 hp) – 01 Nos.
- H) Jockey Sprinkler Pump (7.5 hp) – 01 Nos.
- I) Stand by Pump – 01 Nos.
- J) Booster Pump near over head water storage tank (5 hp) – 01 Nos.
- K) Fire Alarm Control Panel – 01 Nos.
- L) MCP – 27 Nos.
- M) Hooter – 27 Nos.
- N) Automatic Sprinkler System – 807 Nos.
- O) Smoke Detector – 45 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.10,00,000/- vide Receipt No. 779278, DD.No. 301989 (Bank of Baroda), Dated:09/05/2019 & Rs.4,80,000/- vide Receipt No. 779279, DD.No.004408 (HDFC Bank), Dated:09/05/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s- En Con Project Consultant
2) Developer- M/s-SKF Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/३४६/२०२२
दिनांक : ०३/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Petrol Pump Building on land bearing S.No.398, S.No.221, H.No.13 of Village:Gass, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1603/2021-22, Dated:28/01/2022.
2) An application received by M/s-Chirag Mistry & Associates, Dated:17/01/2022.
3) An application received by Developer Mr.Kanahiyalal P. Kothari & 2 Others, Dated:17/01/2022
4) Work Completion certificate of M/s-Chirag Mistry & Associates, Dated:15/11/2021.
5) Built up area certificate for M/s-Chirag Mistry & Associates, Dated:06/04/2022
6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1148/2021, Dated:31/03/2021.
7) Certificate from License Agency M/s- Kalpesh Fire Service, Dated:11/04/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:19/02/2022.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated:Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/06/2021.
11) Structure Stability Certificate for M/s-Designers Consultancy Services, Dated:21/01/2022.
12) CC issued by VVCMC/TP/CC/VP-6315/259/2021-22, Dated:07/10/2021.
13) Submitted Electric Certificate M/s- Umadevi Electrical Works, Dated:15/04/2022
14) Diesel Engine Test Certificate of M/s-Goel Power Engineers, Dated:Nil
15) C.F.O. site visit Dated:03/06/2021.

With reference to Sr.No.2 above, this office is in received of your application for your **Petrol Pump Building as (Ground Floor) in 4.25mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Kalpesh Fire Service, bearing License No. MFS-LA/RF-102 & MFS-LA/RD-99 and has submitted Certificate on 11/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 53.55sq.mtrs.

With reference to above on **21/02/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr.Kanahiyalal P. Kothari & 2 Others "** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Fire Extinguisher (06 kg) – 06 Nos.
- B) ABC Type Fire Extinguisher (09 kg) – 06 Nos.
- C) Co2 Type Fire Extinguisher (4.5 kg) – 03 Nos.
- D) Mechanical Foam Type Fire Extinguisher (09 kg) – 06 Nos.
- E) Fire Buckets with Sand – 06 Nos.
- F) Hose Box – 03 Nos.
- G) Main Hydrant Pump (30 hp) – 01 Nos.
- H) Hydrant Jockey Pump (7.5 hp) – 01 Nos.
- I) Booster Pump (5 hp) – 01 Nos.
- J) Electric Control Panel – 01 Nos..

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Ashteen
22/6/2022

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.80,000/- vide Receipt No. 895440, Book No. 8955, DD.No. 001399 (Bassein Catholic Bank), Dated:10/05/2021 & Rs.80,000/- vide Receipt No.895441, Book No.8955, DD.No.001400 (Bassein Catholic Bank), Dated:10/05/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s- Chirag Mistry & Associates
2) Developer- Mr.Kanahiyalal P. Kothari & 2 Others

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

48/10/2021
5005/2/20

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/३४७/२०२२
दिनांक : ०३/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building located on S.No.48, H.No.2/A/3 of Village:Sativali, Tal:Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/298/2022-23, Dated:25/05/2022.
- 2) An application received by M/s-En Con Project Consultants, Dated:09/05/2022.
 - 3) An application received by Developer Mr.Yunus B. Hala, Dated:09/05/2022
 - 4) Work Completion certificate of M/s-En Con Project Consultants, Dated:09/05/2022.
 - 5) Gross built up area certificate for M/s-En Con Project Consultants, Dated:09/05/2022
 - 6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1018/2018-19, Dated:10/12/2018.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:29/04/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/06/2022.
 - 11) Structure Stability Certificate for M/s-S.S. Associates, Dated:26/04/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-6082/16/2021-22, Dated:06/04/2021.
 - 13) Submitted Electric Certificate M/s- Jay Shree Walvadevi Electrical Contractor, Dated:30/04/2022
 - 14) AMC Certificate issued by Developer M/s- TFPC Infra LLP, Dated:04/05/2022.
 - 15) Diesel Engine Test Certificate of M/s-Pradhan Electrical Works, Dated:Nil
 - 16) C.F.O. site visit Dated:03/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building as (Gr + 2nd Floor) in 15.60mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS-LA/RD-359 and has submitted Certificate on 29/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 11279.68sq.mtrs.

With reference to above on 31/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr.Yunus B. Hala" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 kg) – 88 Nos.
- B) Hose Reel Hose has been installed in every floor – 22 Nos.
- C) Hose Box – 08 Nos.
- D) Courtyard Hydrant – 30 Nos.
- E) Main Hydrant Pump (40 hp) – 01 Nos.
- F) Main Sprinkler Pump (30 hp) – 01 Nos.
- G) Jockey Pump (7.5 hp) – 01 Nos.
- H) Jockey Sprinkler Pump (7.5 hp) – 01 Nos.
- I) Stand by Pump – 01 Nos.
- J) Booster Pump near over head water storage tank (5 hp) – 01 Nos.
- K) Fire Alarm Control Panel – 11 Nos.
- L) MCP – 33 Nos.
- M) Hooter – 33 Nos.
- N) Automatic Sprinkler System – 738 Nos.
- O) Smoke Detector – 55 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.10,00,000/- vide Receipt No. 727037, DD.No. 004232 (HDFC Bank), Dated:22/11/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect – M/s- En Con Project Consultant
2) Developer- Mr.Yunus B. Hala

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुळा/३६३/२२-२३
दिनांक : ०४-०६-२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate"** of Residential with Shopline Building No.2 located on S.No.69, H.No.12 & 13 of Village:Manikpur & S.No.197-B, of Village:Chulne, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/151/2022-23, Dated:27/04/2022.
2) An application received by M/s-En Con Project Consultants, Dated:23/04/2022.
3) An application received by Developer M/s-Unique Land Realty Pvt Ltd, Dated:18/05/2022
4) Work Completion certificate of M/s-En Con Project Consultants, Dated:23/04/2022.
5) Gross built up area certificate for M/s-En Con Project Consultants, Dated:23/04/2022
6) This office Provisional No objection Certificate No. VVCMC/FIRE/173/2011-12, Dated:03/02/2012.
7) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/870/2017-18, Dated:10/01/2016
8) This office Part Final No Objection Certificate No. VVCMC/FIRE/HQ/206/2019-20, Dated:12/06/2019
9) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/2066/2019-20, Dated:27/12/2019
10) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:13/04/2022 (Form A).
11) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
12) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :03/02/2021.
13) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:26/05/2022.
14) Structure Stability Certificate for M/s-S.S. Associates, Dated:23/04/2022.
15) RDP issued by VVCMC/TP/RDP/VP-0554/294/2019-20, Dated:06/02/2020.
16) Submitted Electric Certificate M/s- R.R.Electricals, Dated:18/05/2022
17) AMC Certificate issued by Developer M/s-Unique Land Realty Pvt Ltd, Dated:18/05/2022.
18) Diesel Engine Test Certificate of M/s-Power Engineering (India) Pvt Ltd, Dated:Nil
19) C.F.O. site visit Dated:26/05/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building No. 2 (Wing-B) as (Stilt / Gr + 12 Floor) in 38.15mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/RF-332 & MFS-LA/RD-305 and has submitted Certificate on 13/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3844.57sq.mtrs.

With reference to above on **02/05/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Unique Land Realty Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed - 09 Nos.
- B) Fire Buckets with Sand - 02 Nos.
- C) Hose Reel Hose has been installed in every floor - 12 Nos.
- D) Hose Box - 09 Nos.
- E) Courtyard Hydrant - 03 Nos.
- F) Main Hydrant Pump - 01 Nos.
- G) Hydrant Jockey Pump - 01 Nos.
- H) Booster Pump near over head water storage tank - 01 Nos.
- I) Siamese Connection at Main Gate - 01 Nos.
- J) Fire Alarm Public address system - 01 Set.
- K) Smoke Detector - 02 Nos.

ENCLOSURE

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.4,00,000/- vide Receipt No. 150609, Dated:24/08/2011 & Rs.1,40,000/- vide Receipt No. 499017, DD.No.020373, Dated:16/11/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s- En Con Project Consultant
2) Developer- M/s-Unique Land Realty Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/५२३/२०२२
दिनांक : २४/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building & CFC Building located on land bearing S.No.38, H.No.1/1, 1/2, 1/3, 1/4 & 1/5 (Old), S.No.38/B, Plot No.1, 2, 3, 4, 5, 6, 7 (New) of Village:Waliv, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1650/2021-22, Dated:09/02/2022.
- 2) An application received by M/s- En Con Project Consultants, Dated:27/01/2022.
 - 3) An application received by Developer M/s-Avenue Supermarts Ltd, Dated:14/03/2022
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:27/01/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/398/2017-18, Dated:16/08/2017.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:27/01/2022.
 - 7) Certificate from License Agency M/s-Shree Ram Fire Controlling Systems, Dated:06/03/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:12/04/2021.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:04/05/2022.
 - 11) Structure Stability Certificate for M/s- Epicons Consultants Pvt Ltd, Dated:18/01/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-5391/183/2017-18, Dated:26/03/2018.
 - 13) Submitted Electric Certificate M/s- Rulka Electricals Pvt Ltd, Dated:05/03/2022.
 - 14) Diesel Generator Test Certificate of M/s-Kirloskar Brothers Ltd, D Dated:06/08/2021
 - 15) C.F.O. site visit Dated:04/05/2022.

With reference to Sr.No.2 above, this office is in received of your application for your Commercial Building No. 2 as (Basement + Lower Ground + Ground floor + 2nd floor) in 12.90mtrs Height & CFC Market Building as (Basement + Lower Ground + Ground floor + 2nd floor) in 12.15mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree Ram Fire Controlling Systems, bearing License No. MFS-LA/RF-188 & MFS/LA/RD-172 and has submitted Certificate on 06/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Commercial Bldg – 5931.64sq.mtrs & CFC Bldg – 570.25sq.mtrs.

With reference to above on 14/02/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Avenue Supermarts Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 54 Nos.
- B) Portable Fire Extinguishers has been installed (4.5 Kg) – 25 Nos.
- C) Hose Reel Hose has been installed in every floor – 14 Nos.
- D) Hose Box has been installed in Alternate floor – 20 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid the 10,00,000/- vide Receipt No.572111, DD.No.004136, (Bassein Catholic Bank), Dated:07/06/2017 & Rs.80,000/- vide Receipt No.572110, DD.No.004135 (Bassein Catholic Bank), Dated:07/06/2017

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Avenue Supermarts Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. / अग्नि / मुका / ५२६/२२-२३
दिनांक : २६-०६-२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building located on land bearing S.No.49, 50, 51, 52, 53, 54, 55, 56, 77 & S.No.57, H.No.1 of Village:Achole, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/213/2022-23, Dated:06/05/2022.
2) An application received by M/s- En Con Project Consultants, Dated:03/05/2022.
3) An application received by Developer M/s-Veer Global Infraconstruction Ltd, Dated:27/05/2022
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:03/05/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/668/2019-20, Dated:24/09/2019.
6) Gross Built up area certificate for M/s- M/s- En Con Project Consultants, Dated:03/05/2022.
7) Certificate from License Agency M/s-Bharat Fire Protection, Dated:12/04/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:03/02/2022.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/06/2022.
11) Structure Stability Certificate for M/s- Jay Shree Krishna Consulting Engg, Dated:28/03/2022.
12) RDP issued by VVCMC/TP/RDP/VP-0127/231/2019-20, Dated:03/12/2019.
13) Submitted Electric Certificate M/s-Maurya Electricals, Dated:26/05/2022.
14) Diesel Generator Test Certificate of M/s-Gangadhar Industries, Dated:24/03/2022
15) C.F.O. site visit Dated:09/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your Residential with Shopline Building No. 1 (Wing-C) in Sector- III as (Stilt / Ground floor + 14th floor) in 43.85mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Bharat Fire Protection, bearing License No. MFS-LA/RF-55, MFS/LA/RD-54, MFS/LA/RP-17 and has submitted Certificate on 12/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3305.40sq.mtrs.

With reference to above on **07/06/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Veer Global Infraconstruction Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 09 Nos.
- B) Hose Box has been installed in Alternate floor – 03 Nos.
- C) Courtyard Hydrant has been installed in the building & prominent places – 06 Nos.
- D) Main Pump (30 Hp) – 03 Nos.
- E) Jockey Pump (7.5 Hp) – 01 Nos.
- F) Booster Pump (7.5Hp) – 03 Nos.
- G) Automatic Sprinkler - 180 Nos.
- H) Fire Alarm Panel – 03 Nos.
- I) Electric Control Panel – 01 Nos.
- J) Smoke Detector – 03 Nos..
- K) Hooter – 27 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.5,25,000/- vide Receipt No.818340, DD.No.835548, (Union Bank), Dated:23/08/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "D. D. D." or similar.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants

2) Developer- M/s- Veer Global Infraconstruction Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

A handwritten signature in blue ink, appearing to be "H. H. H." or similar.
ENCON

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. /अभि/मुका/५२५/२२२३

दिनांक : २६-०६-२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building located on land bearing S.No.49, 50, 51, 52, 53, 54, 55, 56, 77 & S.No.57, H.No.1 of Village:Achole, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/444/2022-23, Dated:01/06/2022.
- 2) An application received by M/s- En Con Project Consultants, Dated:30/05/2022.
 - 3) An application received by Developer M/s-Shree Vimal Developers, Dated:27/05/2022
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:30/05/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/4717/2021-22, Dated:24/12/2021.
 - 6) Gross Built up area certificate for M/s- M/s- En Con Project Consultants, Dated:30/05/2022.
 - 7) Certificate from License Agency M/s-G-Force Fire Services, Dated:18/05/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:29/01/2022.
 - 9) AMC Certificate by M/s-Shree Vimal Developers, Dated:27/05/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/06/2022.
 - 12) Structure Stability Certificate for M/s- Jay Shree Krishna Consulting Engg, Dated:01/06/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0127/067/2015-16, Dated:09/06/2015.
 - 14) Submitted Electric Certificate M/s- Deep -Kamal Electric Works, Dated:15/01/2020.
 - 15) Diesel Generator Test Certificate of M/s-Gangadhar Industries, Dated:21/06/2017
 - 16) C.F.O. site visit Dated:13/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building No. 1 (Wing-H) in Sector- III as (Stilt / Ground floor + 14th floor) in 43.85mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- G-Force Fire Services, bearing License No. MFS-LA/RF-51 & MFS/LA/RD-52 and has submitted Certificate on 18/05/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5128.19sq.mtrs.

With reference to above on 06/06/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Shree Vimal Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 08 Nos.
- B) Hose Reel Hose has been installed in every floor – 14 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places – 190 Nos.
- E) Main Pump – 02 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.3,25,000/- vide Receipt No.818768, Book No.8188, DD.No.015279, (IDBI Bank), Dated:30/11/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Shree Vimal Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुक्का/५२८/२२-२३
दिनांक : २४/०६/२०२२

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Industrial / Commercial Building located on land bearing S.No.70 & H.No.1 + 5, Plot No.6/1, 6/2 & 6/3 of Village:Waliv, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/294/2022-23, Dated:25/05/2022.
- 2) An application received by M/s- En Con Project Consultants, Dated:10/05/2022.
 - 3) An application received by Developer M/s-Jinal Infra, Dated:10/05/2022
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:10/05/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/735/2020-21, Dated:23/12/2020.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:10/05/2022.
 - 7) Certificate from License Agency M/s-Om Surya Enterprises, Dated:25/04/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:19/02/2022.
 - 9) AMC Certificate by Developer M/s-Jinal Infra, Dated:11/04/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/06/2022.
 - 12) Structure Stability Certificate for M/s-S. S. & Associates, Dated:10/05/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-6142/475/2021-22, Dated:22/09/2021.
 - 14) CC issued by VVCMC/TP/CC/VP-6142/246/2021-22, Dated:22/09/2021
 - 15) Submitted Electric Certificate M/s-Dewang Electricals & Engineers, Dated:14/04/2022.
 - 16) Diesel Generator Test Certificate of M/s-Dazzle Power Generators, Dated:18/06/2022
 - 17) C.F.O. site visit Dated:17/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial / Commercial Building No. E as (Ground floor + 3Pt floor) in 20.10mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Om Surya Enterprises, bearing License No. MFS-LA/F-93 & MFS/LA/D-92** and has submitted Certificate on 25/04/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3614.41sq.mtrs.

With reference to above on 31/05/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Jinal Infra" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 04 Nos.
- B) Hose Reel Hose has been installed in every floor – 03 Nos.
- C) Hose Box has been installed in Alternate floor – 03 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places – 04 Nos.
- E) Main Pump (30 Hp) – 01 Nos.
- F) Sprinkler Pump (10 Hp) – 01 Nos.
- G) Jockey Pump Main (7.5 Hp) – 02 Nos.
- H) Jockey Pump Sprinkler (05 Hp) – 01 Nos.
- I) Booster Pump (5Hp) – 01 Nos.
- J) Hydrant Valve – 03 Nos.
- K) MCP & Hooter – 04 Nos.
- L) Smoke Detector – 60 Nos.
- M) Automatic Sprinkler – 210 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.24,00,000/- vide Receipt No.779394, DD.No.067024, (Bassein Catholic Bank), Dated:25/06/2019, Rs.40,000/- vide Receipt No.819561, DD.No.0668334, Dated:18/11/2020, Rs. 5,20,000/- vide Receipt No.819560, DD.No.068335, Dated:18/11/2020 & Rs.2,40,000/- vide Receipt No.819559, DD.No.068336, Dated:18/11/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Jinal Infra

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

Ther
ENION

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फैक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/५४२/२०२२
दिनांक : २१/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of CFC Building on land bearing New S.No.117, S.No.81(Old), H.No.1 (Old S.No.117, H.No.117, H.No.1, 2, 5, 6, 7, 8, S.No.119, H.No.13) of Village:Achole, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/447/2022-23, Dated:01/06/2022.
2) An application received by M/s- Shah Gattani Consultants, Dated:29/05/2022.
3) An application received by Developer M/s-Sai Ashirwad Developers, Dated:04/06/2022
4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:27/05/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/407/2018-19, Dated:13/08/2018.
6) Built up area certificate for M/s- Shah Gattani Consultants, Dated:29/05/2022.
7) Certificate from License Agency M/s-TFPC Infra LLP, Dated:24/03/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
9) AMC Certificate by M/s-TFPC Infra LLP, Dated:24/03/2022
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/06/2022.
12) Structure Stability Certificate for M/s- Shah Gattani Consultants, Dated:29/05/2022.
13) RDP issued by VVCMC/TP/RDP/VP-721/178/2015-16, Dated:01/09/2015.
14) Submitted Electric Certificate M/s- Narayan Electrical Works, Dated:29/05/2022.
15) Diesel Generator Test Certificate of M/s-Power Engineering (India) Pvt Ltd, Dated:27/01/2022
16) C.F.O. site visit Dated:1/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **CFC Building as (Ground floor + 4th floor) in 17.30mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS/LA/RD-359 and has submitted Certificate on 24/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 708.24sq.mtrs.

With reference to above on **11/06/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "**M/s-Sai Ashirwad Developers**" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (04 Kg) – 02 Nos.
- B) Hose Reel Hose has been installed in every floor – 04 Nos.
- C) Hose Box has been installed in Alternate floor – 01 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places – 05 Nos.
- E) Booster Pump (5Hp) – 01 Nos.
- F) Hydrant Valve – 05 Nos.
- G) MCP & Hooter – 05 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.80,000/- vide Receipt No.694465, DD.No.001007, (TJSB Sahakari Bank), Dated:01/08/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants

2) Developer- M/s- Sai Ashirwad Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म. १५६५/१५६५
दिनांक : २५-०६-२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building located on land bearing S.No.46C, H.No.1 & 2 of Village:Bilalpada, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/496/2022-23, Dated:10/06/2022.
- 2) An application received by M/s- Ajay Wade & Associates, Dated:08/06/2022.
 - 3) An application received by Developer M/s-JRT Construction and Co, Dated:08/06/2022
 - 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated:08/06/2022.
 - 5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/4474/ 2021-22, Dated:30/10/2021.
 - 6) Gross Built up area certificate for M/s- Ajay Wade & Associates, Dated:08/06/2022.
 - 7) Certificate from License Agency M/s-TFPC Infra LLP, Dated:06/06/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) AMC Certificate by Developer M/s-JRT Constructions and Co, Dated:10/06/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/06/2022.
 - 12) Structure Stability Certificate for Mr.Paresh Unnarkar, Dated:08/06/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-5317/441/2021-22, Dated:08/09/2021.
 - 14) Submitted Electric Certificate M/s-Zip Engineers, Dated:01/06/2022.
 - 15) Diesel Generator Test Certificate of M/s- M/s-Perfect House Pvt Ltd, Dated:22/12/2021
 - 16) C.F.O. site visit Dated:23/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building No. 1 as (Ground floor + 2 floor) in 15.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS/LA/RD-359** and has submitted **Certificate on 06/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 10369.19sq.mtrs.

With reference to above on **13/06/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-JRT Construction and Co"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) Hose Reel Hose has been installed in every floor – 11 Nos.
- C) Hose Box has been installed in Alternate floor – 08 Nos.
- D) Hydrant Valve – 19 Nos.
- E) Main Pump (40 Hp) – 01 Nos.
- F) Sprinkler Pump (20 Hp) – 01 Nos.
- G) Jockey Pump Main (7.5 Hp) – 01 Nos.
- H) Jockey Pump Sprinkler (7.5 Hp) – 01 Nos.
- I) Stand by Pump (40 Hp) – 01 Nos.
- J) Booster Pump (05 Hp) – 02 Nos.
- K) Fire Alarm Control Panel – 02 Nos.
- L) MCP – 06 Nos

- M) Hooter – 06 Nos.
N) Smoke Detector – 04 Nos.
O) Automatic Sprinkler – 470 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Capitation & scrutiny Fees of Rs. 5,70,000/- vide Receipt No.779285, Book No. 7793, DD. No. 124152 (Bharat Bank), Dated: 09/05/2019; Rs. 50,000/- vide Receipt No. 818323, Book No. 8184, DD. No. 125188 (Bharat Bank), Dated:22/08/2019; Rs. 80,000/- vide Receipt No. 601180, Book No.6012, DD. No. 123712 (Bharat Bank), Dated: 23/10/2017 & Rs.3,00,000/- vide Receipt No.601179, Book No.6012, DD.No.123711 (Bharat Bank), Dated: 23/10/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s-JRT Constructions and Co

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

Received
Dalme

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुक्रा/५५८/२०२२
दिनांक : २५/०६/२०२२

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Industrial Building located on land bearing Plot No.8, 9, 10, S.No.15/1(Pt) of Village:Sativali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/572/2022-23, Dated:22/06/2022.
2) An application received by M/s- En Con Project Consultants, Dated:07/06/2022.
3) An application received by Developer M/s-Kalpesh Engineering Works, Dated:09/06/2022
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:07/06/2022.
5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/204/ 2022-23, Dated:05/05/2022.
6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:07/06/2022.
7) Certificate from License Agency M/s-TFPC Infra LLP, Dated:06/06/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
9) AMC Certificate by Developer M/s-TFPC Infra LLP, Dated:25/06/2022
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/06/2022.
12) Structure Stability Certificate for M/s-S. S. & Associates, Dated:26/04/2022.
13) RDP issued by VVCMC/TP/RDP/VP-6129/355/2021-22, Dated:06/08/2021.
14) Submitted Electric Certificate M/s-Jay Shree Walvadevi Electical Contractor, Dated:10/06/2022.
15) Diesel Generator Test Certificate of M/s- M/s-Jay Shree Walvadevi Electical Contractor, Dated:30/05/2022
16) C.F.O. site visit Dated:24/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building as (Ground floor + 2 floor) in 16.85mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS/LA/RD-359** and has submitted Certificate on 07/06/2022 in **"Form A"** Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 6988.16sq.mtrs.

With reference to above on **23/06/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-Kalpesh Engineering Works"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 15 Nos.
- B) Hose Reel Hose has been installed in every floor – 10 Nos.
- C) Hose Box has been installed in Alternate floor – 06 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places – 16 Nos.
- E) Main Pump (40 Hp) – 01 Nos.
- F) Sprinkler Pump (20 Hp) – 01 Nos.
- G) Jockey Pump Main (7.5 Hp) – 01 Nos.
- H) Jockey Pump Sprinkler (7.5 Hp) – 01 Nos.
- I) Stand by Pump – 01 Nos.
- J) Booster Pump (5Hp) – 01 Nos.
- K) Hydrant Valve – 16 Nos.
- L) MCP – 03 Nos

- M) Hooter – 03 Nos.
- N) Smoke Detector – 04 Nos.
- O) Automatic Sprinkler – 543 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.9,50,000/- vide Receipt No.779342, DD.No.015056, (HDFC Bank), Dated:11/06/2019, Rs.50,000/- vide Receipt No.30619, Book No.307, DD.No.005167 (HDFC Bank), Dated:06/04/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s-Kalpesh Engineering Works

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/५५६/२०२२
दिनांक : २५/०६/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building on Plot No. 1 for Residential zone portion on land bearing S.No.50/B/1, S.No.50/B/2, Plot No.9, S.No.50/B/3, S.No.50/B/2 (New) out of the total layout consisting of Residential & Industrial Buildings on land bearing (New) Plot No.1 S.No.50/B/1, 50/B/2, Plot No.2, S.No.50/b/4, Plot No.9, S.No.50/B/3, Plot No.3, S.No.50/B/5, Plot No.4, S.No.50/B/7, Plot No.5, S.No.50/B/8, Plot No.6, S.No.50/B/9, Plot No.7, S.No.50/B/10 & Plot No.8, S.No.50/B/6 (Old) S.No.49, H.No.2/1B+2/2A(Pt), S.No.49, H.No.2/1B+2/2A(Pt), S.No.50, H.No.1Pt, S.No.50, H.No.2/2 of Village:Sativali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/575/2022-23, Dated:22/06/2022.
- 2) An application received by M/s- En Con Project Consultants, Dated:16/06/2022.
 - 3) An application received by Developer M/s-Manav Enterprises, Dated:10/06/2022
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:16/06/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2030/2019-20, Dated:21/12/2019.
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:16/06/2022.
 - 7) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:09/06/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021.
 - 9) AMC Certificate by Developer M/s-Manav Enterprises, Dated:10/06/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/06/2022.
 - 12) Structure Stability Certificate for Mr.Dilip P. Parekh, Dated:06/06/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-4354/359/2021-22, Dated:06/08/2021.
 - 14) Submitted Electric Certificate M/s-Khodiar Electricals, Dated:10/06/2022.
 - 15) Diesel Generator Test Certificate of M/s-Mahindra Powerol, Dated:27/05/2022
 - 16) C.F.O. site visit Dated:24/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential with Shopline Building as (Gr / Stilt floor + 9Pt floor) in 30.35mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sadanand Fire Systems, bearing License No. MFS-LA/RF-332 & MFS/LA/RD-305 and has submitted Certificate on 09/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having Gross built up area admeasuring to 7379.18sq.mtrs.

With reference to above on **23/06/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-Manav Enterprises"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed – 23 Nos.
- B) Hose Reel Hose has been installed in every floor – 09 Nos.
- C) Hose Box has been installed in Alternate floor – 08 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places – 04 Nos.
- E) Main Pump – 01 Nos.
- F) Sprinkler Pump (20 Hp) – 01 Nos.
- G) Jockey Pump Main – 01 Nos.
- H) Booster Pump – 01 Nos.
- I) Siamese Connection – 01 Nos.
- J) Sand Bucket – 02 Set
- K) Fire Alarm – 01 Set
- L) Smoke Detector – 02 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.3,40,000/- vide Receipt No.818835, DD.No.007882, (IDBI Bank), Dated:19/12/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s-Manav Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/६०/2022-23
दिनांक: ३०/१०/2022.

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- Grant of "Final No Objection Certificate" for your Proposed Industrial Building on land bearing Plot.No.26, 28 & 30, S.No.66(Pt) (Old), S.No.66/Plot No.26, S.No.66/Plot No.28 & S.No.66/Plot No.30 (New) of Village- Waliv, Tal-Vasai, Dist-Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/564/2022-23, Dated:29/06/2022.(VP-3011)
- 2) An application received by M/s- En Con Project Consultants, Dated:24/06/2022.
 - 3) An application received by Developer Mr.Bhupatray Jayantilal Mehta, Dated:20/06/2022
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:24/06/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/533/2021-22, Dated:23/07/2021
 - 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:24/06/2022.
 - 7) Certificate from License Agency M/s- SD Infra & Mep Services Pvt Ltd, Dated:27/06/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:17/01/2022.
 - 9) AMC Certificate by Developer Mr.Bhupatray Jayantilal Mehta, Dated:20/06/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:30/06/2022.
 - 12) Structure Stability Certificate for M/s- GR Consultants, Dated:15/06/2022
 - 13) RDP issued by VVCMC/TP/RDP/VP-3011/259/2021-22, Dated:08/07/2021.
 - 14) Submitted Electric Certificate M/s- Deepak Electro Control, Dated:09/06/2022.
 - 15) Diesel Generator Test Certificate of M/s- Deepak Electro Control, Dated:09/06/2022.
 - 16) C.F.O. site visit Dated:30/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Industrial Building as (Ground floor + 2 upper floor) in 16.10mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- SD Infra & Mep Services Pvt Ltd, bearing License No. MFS-LA/RF-26, MFS/LA/RD-28 and has submitted Certificate on 27/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1845.99sq.mtrs.

With reference to above on 30/06/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr.Bhupatray Jayantilal Mehta" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed ABC type (06 Kg) – 07 Nos.
- B) Portable Fire Extinguishers has been installed Co2 type (06 Kg) – 01 Nos.
- C) Hose Reel Hose has been installed in every floor – 04 Nos.
- D) Hose Box has been installed in Alternate floor – 07 Nos.
- E) Hydrant Valve – 07 Nos.
- F) Main Hydrant Pump (40Hp) – 01 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.1,70,000/- vide Receipt No.895524, Book No.8956, DD.No.974583 (Canara Bank), Dated:08/07/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- Mr.Bhupatray Jayantilal Mehta

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

Ther
ENCON

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/702/2022-23
दिनांक: 20/07/2022.

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- Grant of "Final No Objection Certificate" for your Proposed Residential Building No. 18 (New LIG-R1) on land bearing S.No.392/1A of Village: Bolinj & S.No.376(Pt) of Village- Virar, Tal-Vasai, Dist-Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/562/2022-23, Dated:29/06/2022.(VP- 0191)
- 2) An application received by Mr.Nitin A. Patil, Dated:20/06/2022.
 - 3) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/246/2019-20, Dated:19/06/2019
 - 4) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/3004/2021-22, Dated:08/10/2021
 - 5) Built up area certificate for Mr.Nitin A. Patil, Dated:20/06/2022.
 - 6) Certificate from License Agency M/s- Oustfire Safety Engineers Pvt Ltd, Dated:21/06/2022 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:05/11/2021.
 - 8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:18/07/2022.
 - 10) Structure Stability Certificate for M/s-B.G.Shirke Construction Technology Pvt Ltd, Dated:07/06/2022
 - 11) RDP issued by VVCMC/TP/RDP/VP-0191/3673 to 3681/2015-16, Dated:01/03/2016.
 - 12) Submitted Electric Certificate Mr.A.J.Potdar (License No.35092), Dated:13/09/2019.
 - 13) Diesel Generator Test Certificate of M/s- Kirloskar Oil Engines Ltd, Dated:13/06/2022.
 - 14) C.F.O. site visit Dated:18/06/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential Building as (Stilt + 10 upper floor) in 30.76mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Oustfire Safety Engineers Pvt Ltd, bearing License No. MFS-LA/RF-410, MFS/LA/RD-384, MFS-LA/RP-82 and has submitted Certificate on 21/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 4265.36sq.mtrs.

With reference to above on **18/07/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-Mumbai Housing & Area Development Board (MHADA)"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed – 12 Nos.
- B) Fire Bucket (09 Ltrs) – 06 Nos
- C) Hose Reel Hose has been installed in every floor – 11 Nos.
- D) Hydrant Valve – 13 Nos.
- E) Booster Pump (900 Lpm) – 01 Nos.
- F) Main Hydrant Pump (10 hp) – 01 Nos.
- G) Fire Alarm Panel – 01 Nos.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.11,58,060/- vide Receipt No.779340, DD.No.765576 (Bank of Maharashtra), Dated:31/05/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "D. D. D." or similar, written over the printed name.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect – Mr. Nitin A. Patil

2) Developer- M/s-Mumbai Housing & Area Development Board (MHADA)

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार (पूर्व)

दुरध्वनी : ०२५०-२५२५१/०१/०२/०३/०४/०५

ई-मेल: vasaivirarcorporation@yahoo.co

ता.वसई, जि.पालघर- ४०१ ३०५



अग्निशमन व आणीबाणी सेवा

मुख्यालय आचोळे, वसई (पूर्व)

भ्रमणध्वनी क्र.९८२२३२१६८४

ता.वसई, जि.पालघर- ४०१ २०९

ई-मेल: fire.vvmc@gov.in

जा.क्र. : व.वि.श.म./अग्नि/मुका / 64422-23

दिनांक : ०२/०८ / २०२२

FIRE & EMERGENCY DEPARTMENT

To,
M/s.Ela Suresh Gundaria
Plot no.81,Vasai Municipal Industrial Estate
Village-Dhovali,Papdi,
Vasai (W)
Tal-Vasai,Dist -Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Industrial Building (Gr+1)on land bearing Plot no.81,S.no.104A of Village-Dhovali,Tal- Vasai, Dist- Palghar.

Ref:-1. An application received by M/s. M/s.Ela Suresh Gundaria: 27/07/2022.

2.This office Final No Objection Certificate No.VVCMC/FIRE/HQ/210/
Dated:13/06/2019

3. Certificate from License Agency M/s- Bright Infra Systems Pvt.Ltd., Dated: 01/07/2022 (Form B)

4.Submitted License copy of Maharashtra Fire Services,Dated:04/09/2021

5.Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 15/07/2022

6.Electric Certificate Dated:25/07/2022

7.C.F.O.Site Visit on Dated : 26/07/2022

With reference to Sr.No.1 above, this office is in received for Industrial Building (Gr+1)on land bearing Plot no.81,S.no.104A in height 09.60 mtr " at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Bright Infra Systems Pvt.Ltd. License No. MFS-LA/RF-350/RD-324, and has submitted Certificate On 01/07/2022 in "Form B" & Submitted Certificate On 04/09/2021 in prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,,** this office is issuing a **"Renewal No Objection Certificate"** for your building.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of **"Maharashtra Fire Prevention and Life Safety Measures Act, 2006"** it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 30,000/- vide Receipt No. 31178,Book No.312,DD no.046107 (HDFC bank) Dated: 27/07/2022 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार

विरार (पूर्व)

ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६


फॅक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/ 834/2022-23

दिनांक: 10/08/2022.

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- Grant of "Final No Objection Certificate" for your Proposed Industrial Building No. 61 on land bearing S.No.111(266), H.No.1,2,3,7,8. S.No.112 (273), H.No.1/1, 1/2, 6, 7, 8, 9. S.No.113(265), H.No.1,2pt, 3, 4, 6, S.No.114(264), H.No. 1, 2, S.No.115(263), H.No. 2, 3, S.No. 116(262), H.No. 13, 14, S.No. 120(272), H.No.3, 4, 5pt, 5pt, 6, 7, 8pt, 8pt, 9, 10, 11, 12, 13, 14pt, 14pt, 15, 16, 17pt, 17pt, 18, 20, S.No. 121(353), S.No. 122(259), H.No. 5pt, 5pt, 6, 7pt, 7pt, 8, 9. S.No.123(325), H.No. 1, 2, 3, 4 S.No. 127(258), H.No. 1A/9, 1A/15, 1A/16, 1A/17, 1A/18, 1A/19, 1A/20, 1A/25, 1A/26, 1A/28, 1A/29, 1A/30pt, 1A/30pt, 1A/31, 1A/32, 1A/33, 1A/34, 1A/35, 1A/36, 1A/37, 1A/38pt, 1A/38pt, 1A/38pt, 1A/39, S.No.130(324), S.No.134(254), H.No.B, S.No.135(253), H.No.1/1, 1/2, 1/3, 2pt, 2pt, 2pt, S.No. 136(322), H.No. 1, 2, 3pt, 3pt, 3pt, 3pt, 3pt, S.No.137(252), S.No. 138(251), H.No.3pt, 3pt, 4pt, 4pt, 4pt, 13pt, 15, S.No. 139(274), H.No. 1, 2, 4pt, 4, 5 of Village- Chandansar, Tal-Vasai, Dist-Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/566/2022-23, Dated:29/06/2022.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:22/06/2022.
- 3) An application received by Developer M/s- Acetron Construction LLP, Dated:22/06/2022
- 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:25/05/2022.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/480/2018-19, Dated:29/08/2018.
- 6) Gross Built up area certificate for M/s- Shah Gattani Consultants, Dated:22/06/2022.
- 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:18/06/2022 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
- 9) Work Completion Certificate of M/s- TFPC Infra LLP, Dated:18/06/2022.
- 10) AMC Certificate by Developer M/s- Acetron Construction LLP, Dated:22/06/2022
- 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :Nil
- 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:04/08/2022.
- 13) Structure Stability Certificate for Mr.Arvind S. Mindhe Consulting Engineering, Dated:27/06/2022.
- 14) RDP issued by VVCMC/TP/RDP/VP-0311/095/2016-17, Dated:17/03/2017.
- 15) Submitted Electric Certificate M/s- Urja Infratech & Power Projects India Pvt Ltd, Dated:20/06/2022.
- 16) D.G.Set Certificate of M/s- Gangadhar Industries, Dated:09/07/2022
- 17) C.F.O. site visit Dated:04/08/2022.

With reference to Sr.No.2 above, this office is in received of your application for your Industrial Building No. 61 as (Gr + 2 Floor) in 15.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384, MFS-LA/RD-359 and has submitted Certificate on 18/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2282.20sq.mtrs.

- D) Hydrant Valve – 10 Nos.
- E) Main Hydrant Pump (40Hp) – 01 Nos.
- F) Main Sprinkler Pump (30Hp) – 01 Nos.
- G) Jockey Hydrant Pump (7.5Hp) – 01 Nos.
- H) Jockey Sprinkler Pump (7.5Hp) – 01 Nos.
- I) Stand by Pump (40 Hp) – 01 Nos.
- J) Booster Pump near over head water storage tank (1Hp) – 01 Nos.
- K) Sprinkler Pump (15 hp) – 01 Nos.
- L) Jockey Pump (10 hp) – 01 Nos.
- M) Automatic Sprinkler.
- N) Sand Bucket – 02 Nos.
- O) MCP – 04 Nos.
- P) Hooter – 04 Nos.
- Q) Smoke Detector – 04 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.3,00,000/- vide Receipt No. 694466, DD. No.250699 (Indian Overseas Bank), Dated:01/08/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s- Acetron Construction LLP

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फॅक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/866/2022-23

दिनांक: 17/08/2022.

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Abhay Raut Architect,
104, Gold Crest Business Center,
L.T.Road, Borivali (W),
Mumbai-400 092.

Sub:- Grant of "Final No Objection Certificate" for your Proposed Residential Building No.12A on plot bearing S.No.157/5/A/1, S.No.157/5A/2, S.No.157/5/B/1, S.No.157/5/B/2, S.No.423, H.No.A2, A3 & A4, S.No.316B of Village- Bolinj, Tal-Vasai, Dist-Palghar.

- Ref:- 1) An application received by Mr.Abhay Raut Architect, Dated:15/06/2022 (VP-0489)
2) An application received by Developer M/s-Star Builders & Developers, Dated:15/06/2022
3) Work Completion certificate of Mr.Abhay Raut Architect, Dated:15/06/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/79/2013-14, Dated:14/05/2013
5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/981/2019-20, Dated:26/11/2019
6) Built up area certificate for Mr.Abhay Raut Architect, Dated:15/06/2022.
7) Certificate from License Agency M/s- Jay Jivdani Fire Services, Dated:15/06/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:10/01/2022.
9) AMC Certificate by Developer M/s-Star Builders & Developers, Dated:15/06/2022
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/08/2022.
12) Structure Stability Certificate for Mr.Paresh Unnarkar, Dated:22/06/2022
13) RDP issued by VVCMC/TP/RDP/VP-0489/200/2020-21, Dated:22/02/2021.
14) Submitted Electric Certificate M/s-Jay Vagheshvari Electricals, Dated:26/05/2022.
15) Diesel Generator Test Certificate of M/s-Kirloskar Oil Engines, Dated:31/05/2022
16) C.F.O. site visit Dated:08/08/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential Building No.12A as (Stilt / Ground floor + 14 upper floor) in 44.95mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Jay Jivdani Fire Services, bearing License No. MFS-LA/RF-07, MFS/LA/RD-08 and has submitted Certificate on 15/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1959.87sq.mtrs.

With reference to above on 15/08/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Star Builders & Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed ABC type (04 Kg) – 02 Nos.
B) Hose Reel Hose has been installed in every floor – 14 Nos.
C) Hose Box has been installed in Alternate floor – 02 Nos.

- I) Manual Fire Alarm System – 01 Nos.
- J) MCP & Hooter – 14 Nos.
- K) Sprinkler Systems – 50 Nos.
- L) Sprinkler Riser – 01 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.3,25,000/- vide Receipt No. 105204, Dated:14/05/2019 & Rs.1,20,000/- vide Receipt No.818719 (Bassein Catholic Bank), Dated:15/11/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect –The Deputy Director, Town Planning, VVCMC
2) Developer- M/s-Star Builders & Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available at www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.




दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/865/2022-23

दिनांक: 18/08/2022.

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- Grant of "Final No Objection Certificate" of Residential Building Typ A2-729, Type B-730, Type A1-731 on land bearing New S.No. 1, H.No.1, S.No.2, H. No.1, S.No.3, H.No.1, S.No.4, H.No.1, S.No.57, H.No.3 & 6/1, S.No.59, H.No.1/3, S.No.254, H.No.13, 14, 15, 16, 3, 6, 7/1, 7/2 in at Village: Achole & S.No. 101, 103, 104, 107, 106 in Village- Manickpur & S.No.97B, 105B, 106B, 106, H.No.8, H.No.110, H.No.8/1, S.No.128, H.No.6 of Village - Gokhiware, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/632/2022-23, Dated:30/06/2022.
- 2) An application received by M/s- Shah Gattani Consultants, Dated:18/12/2021.
 - 3) An application received by Developer M/s- Radiant Entertainment Pvt Ltd, Dated:16/08/2022
 - 4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:18/12/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1974/2021-22, Dated:01/10/2021.
 - 6) Gross Built up area certificate for M/s- Shah Gattani Consultants, Dated:18/12/2021.
 - 7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:06/08/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
 - 9) AMC Certificate by Developer M/s- Rediant Entertainment Pvt Ltd, Dated:16/08/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated :Nil
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/08/2022.
 - 12) Structure Stability Certificate for M/s-Vijay Gurav & Associates, Dated:21/06/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0743/0146/2013-14, Dated:10/07/2013.
 - 14) Submitted Electric Certificate M/s- Siddhivinayak Electricals, Dated:15/02/2022.
 - 15) D. G. Set Certificate of M/s- Kirloskar Industries, Dated:18/12/2021
 - 16) C.F.O. site visit Dated:08/08/2022.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential Building A2-729, Type B-730, Type A1-731 as (Gr + 7 Floor) in 23.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71, MFS-LA/RD-69 and has submitted Certificate on 08/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3148.56sq.mtrs.

With reference to above on 08/08/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Rediant Entertainment Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (04 Kg) – 24 Nos.
- B) Hose Reel Hose has been installed in every floor – 21 Nos.
- C) Hose Box has been installed in Alternate floor – 09 Nos.
- D) Hydrant Valve – 24 Nos.
- E) Booster Pump near over head water storage tank (5Hp) – 03 Nos.
- F) Sprinkler – 24 Nos.
- G) Starter – 03 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.3,60,000/- vide Receipt No. 895588, DD. No.679282, Book No.8956 (Bank of Baroda), Dated:06/08/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants.

2) Developer- M/s- Radiant Entertainment Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.




दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फैक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/1143/2022-23

दिनांक: 25/08/2022.

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of CFC Building on Plot - A on land bearing S.No.24, H.No.14 of Village:Dongre, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/624/2022-23, Dated:30/06/2022.
- 2) An application received by M/s- Sameer R. Desai Architect, Dated:28/06/2022
 - 3) An application received by M/s- Dattakrupa Developer, Dated:28/06/2022.
 - 4) Work Completion certificate of M/s- Sameer R. Desai Architect, Dated:29/06/2022
 - 5) Gross built up area certificate for M/s- Sameer R. Desai Architect, Dated:29/06/2022
 - 6) This office Provisional No objection Certificate No. VVCMC/FIRE/57/2011-12, Dated:21/06/2011.
 - 7) This office Revised Provisional No Objection Certificate No. VVCMC/FIRE/HQ/935 2019-20, Dated:22/10/2019
 - 8) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:20/06/2022 (Form A).
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:29/07/2022.
 - 12) Structure Stability Certificate for M/s- Vijay Gurav & Associates, Dated:18/01/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0541/020/2014-15, Dated:28/04/2014.
 - 14) Submitted Electric Certificate M/s- Shree Swami Samartha Power Works, Dated:16/04/2015
 - 15) Submitted Diesel Generator Test Certificate M/s-Ghatge Karkera Power Industries, Dated:05/07/2022
 - 16) C.F.O. site visit Dated:29/07/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **CFC Building as Ground Floor + 4 upper floor) in 18.00mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate on 20/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 888.91sq.mtrs.

With reference to above on 29/07/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Dattakrupa Developer" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 05 Nos.
- B) Co2 Type Fire Extinguishers has been installed (4.5 Kg) – 01 Nos.
- C) Hose Reel Hose – 04 Nos.
- D) Hose Box has been installed in Alternate floor – 04 Nos.
- E) Hydrant Valve – 08 Nos.
- F) Booster Pump near over head water storage tank (5 hp) - 01 Nos.
- G) MCP / Hooter – 04 Nos.
- H) Panel Board (10 Zones) – 01 Nos.

o/c
up

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 44,200/- vide Receipt No.26279; Rs.2,35,800/-, vide Receipt No.100567 & 40,000/- vide Receipt No.100568, Dated:04/06/2011.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, written over the printed name.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect – M/s-Sameer R. Desai

2) Developer- M/s-Dattakrupa Developer

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/1144/2022-23

दिनांक: 25/08/2022.

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Sanat Mehta & Associates,
Rameshwar Tower, A-103,
Shimpoli Road,
Next to Gokhale School,
Borivali (W), Mumbai-400 092.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No.5 Wing-B (Plot-B) S.No.278A of Village:Nilemore, Tal: Vasai, Dist: Palghar.**

- Ref:-
- 1) An application received by M/s- Sanat Mehta & Associates, Dated:10/08/2022
 - 2) An application received by Developer M/s-Sai Leela Realtors, Dated:19/08/2022.
 - 3) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:23/08/2022
 - 4) Construction area certificate for M/s- Sanat Mehta & Associates, Dated:12/08/2022
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/54B/2012-13, Dated:05/07/2012.
 - 6) This office Provisional No Objection Certificate No. VVCMC/FIRE/HQ/952/2017-18, Dated:04/02/2018
 - 7) Certificate from License Agency M/s- Jai Jivdani Fire Services, Dated:30/07/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:10/01/2022
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/08/2022.
 - 11) Structure Stability Certificate for M/s- Shilplekha Consultants, Dated:05/08/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-041/0219/2014-15, Dated:04/02/2018.
 - 13) Submitted Electric Certificate M/s- Niraj Electric Works, Dated:12/08/2022
 - 14) Submitted Diesel Generator Test Certificate M/s-Kirloskar Oil Engines Ltd, Dated:01/06/2022
 - 15) C.F.O. site visit Dated:19/08/2022

With reference to Sr. No. 1 & 2 above, this office is in received of your application for your **Residential with Shopline Building No.5, Wing-B Plot-B as Stilt / Shop / Ground Floor + 12 Floor in 38.40mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Jivdani Fire Services bearing License No. MFS-LA/RF-07 & MFS-LA/RD-08 and has submitted Certificate on 30/07/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5364.83sq.mtrs.

With reference to above on 19/08/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Sai Leela Realtors" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (04 Kg) – 02 Nos.
- B) Hose Reel Hose – 12 Nos.
- C) Hose Box has been installed in Alternate floor – 02 Nos.
- D) Hydrant Valve – 02 Nos.
- E) Main Pump (20 hp) – 01 Nos.
- F) Booster Pump near over head water storage tank (5 hp) - 01 Nos.
- G) Court yard Hydrant – 02 Nos.
- H) Automatic Sprinkler – 90 Nos.
- I) MCP / Hooter – 12 Nos.
- J) Fire Alarm Systems – 01 Nos.

Received
Date

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,90,000/- vide Receipt No.351068, DD.No.008470, Dated:27/10/2015 & Rs.2,90,000/-, vide Receipt No.351067, DD.No.026243, Dated:27/10/2015 & Rs.50,000/- vide Receipt No.609587, DD.No.027628, Dated:02/02/2018 & Rs.50,000/- vide Receipt No.609588, DD.No.000338, Dated:02/02/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Sai Leela Realtors

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/154/2022-23
दिनांक: 12/09/2022.

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building on land bearing Plot.No.1/2, S.No.77, H.No.1(Pt) of Village:Waliv, Tal:Vasai, Dist:Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/704/2022-23, Dated:05/08/2022.

- 2) An application received by M/s- Prithvi Arch Consultants, Dated:29/06/2022
- 3) An application received by M/s- Riddhi Developer, Dated:22/06/2022.
- 4) Work Completion certificate of M/s- Prithvi Arch Consultants, Dated:29/06/2022
- 5) Construction area certificate for M/s- Prithvi Arch Consultants, Dated:29/06/2022
- 6) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/819/2020-21, Dated:19/01/2021.
- 7) Certificate from License Agency M/s- Sadanand Fire Systems, Dated:11/06/2022 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:31/07/2021
- 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/08/2022.
- 11) Structure Stability Certificate for M/s- Prithvi Arch Consultants, Dated:29/06/2022
- 12) RDP issued by VVCMC/TP/RDP/VP-4192/161/2019-20, Dated:24/10/2019.
- 13) Submitted Electric Certificate M/s- Choice Electricals, Dated:15/04/2022
- 14) Submitted Diesel Generator Test Certificate M/s-Gangadhar Industries, Dated:05/07/2022
- 15) AMC Certificate by Developer M/s- Riddhi Developer, Dated:20/06/2022
- 16) C.F.O. site visit Dated:22/08/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Industrial Building as Ground Floor + 3 Floor) in 17.98mtrs Height.** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Systems bearing License No. MFS-LA/RF-332 & MFS-LA/RD-305 and has submitted Certificate on 11/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 4419.39sq.mtrs.

With reference to above on **22/08/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Riddhi Developer" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 11 Nos.
- B) Co2 Type Fire Extinguishers has been installed – 11 Nos.
- C) Hose Reel Hose – 01 Nos.
- D) Hose Box has been installed in Alternate floor – 06 Nos.
- E) Main Pump (40 hp) – 01 Nos.
- F) Booster Pump near over head water storage tank (10 hp) - 01 Nos.
- G) Sprinkler Main Pump (25hp) – 01 Nos.
- H) Sprinkler Jockey Pump (10 hp) – 01 Nos.
- I) Stand By Pump (40 hp) – 01 Nos.
- J) Siamese Connection at main gate – 01 Nos.
- K) Court yard Hydrant – 05 Nos.
- L) Automatic Sprinkler – Lobby Area.

9326470748
13-9-22

- M) Smoke Detector – 140 Nos.
- N) MCP / Hooter – 24 Nos.
- O) Fire Alarm System – 01 Set.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 85,000/-, vide Receipt No.487344, Dated:01/07/2016; Rs.85,000/-, vide Receipt No.487343, Dated:01/07/2016; Rs.85,000/-, vide Receipt No.487409, Dated:22/08/2016; Rs. 10,780/-, vide Receipt No.1046, Dated:16/03/2004; Rs. 1,40,000/-, vide Receipt No.487425, Dated:29/08/2016; Rs. 1,70,000/-, vide Receipt No.779223, DD.No.082502, Dated:08/04/2016; Rs. 3,39,220/-, vide Receipt No.818262, DD.No.134846, Dated:23/07/2016; Rs. 5,00,000/-, vide Receipt No.895024, DD.No.338572, Dated:13/01/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



[Signature]

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect – M/s-Prithvi Arch Consultants
2) Developer- M/s- Riddhi Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

13-04-2021
338572-118



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/1601/2022-23

DATE: 15/09/2022

FIRE & EMERGENCY DEPARTMENT

To,

The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. 2 on plot bearing New S.No.70/B (Old S.No.70, H.No.1, S.No.75, H.No.3, S.No.76, H.No.4, 5 & 6A of Village:More, Tal:Vasai, Dist:Palghar.

Ref:- 1) A Letter from Deputy Director Town Planning No. V.V.C.M.C/TP/570/2022- 23,

Dated:22/06/2022 (VP- 0296)

- 2) An application received by M/s- Abhay Raut Architect, Dated:15/06/2022.)
- 3) An application received by Developer M/s-Assets Infrastructures Co, Dated:13/06/2022
- 4) Work Completion certificate of M/s- Abhay Raut Architect, Dated:15/06/2022.
- 5) Built up area certificate for M/s- Abhay Raut Architect, Dated:15/06/2022.
- 6) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/266/2019-20, Dated:24/06/2019
- 7) Certificate from License Agency M/s-Beenee Ventures LLP, Dated:08/06/2022. (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:28/08/2021
- 9) AMC Certificate by M/s-Assets Infrastructures Co, Dated:15/06/2022.
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/08/2022.
- 12) Structure Stability Certificate for Mr.Haresh L. Patel, Dated:20/12/2022.
- 13) RDP issued by VVCMC/TP/RDP/VP-296/206/2020-21, Dated:25/02/2011.
- 14) Submitted Electric Certificate M/s-Madhu Electrical, Dated:28/12/2022.
- 15) Submitted D.G.Set Certificate M/s-Kirloskar Oil Engines Ltd, Dated:06/11/20Nil
- 16) C.F.O. site visit Dated:24/08/2022.

With reference to Sr.No.1 above, this office is in received of your application for your Residential with Shopline Building as (Stilt / Ground floor + 14th floor) in 44.76mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Beenee Ventures LLP, bearing License No. MFS-LA/RF-342, MFS-LA/RD-316, MFS-LA/RP-65 has submitted Certificate on 08/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 10107.49sq.mtrs.

With reference to above on 24/08/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Assets Infrastructures Co" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 05 Nos.
- B) Fire Buckets – 05 Nos.
- C) Hose Reel Hose has been installed in every floor – 28 Nos.
- D) Hose Box has been installed in Alternate floor – 28 Nos.
- E) Main hydrant Pump (60 Hp) – 01 Nos.
- F) Main Sprinkler Pump (60 Hp) – 01 Nos.
- G) Fire Hydrant Jockey Pump (5.5 Hp) – 01 Nos.
- H) Fire Sprinkler Jockey Pump (5.5 Hp) – 01 Nos.
- I) Booster Pump (7.5 Hp) – 02 Nos.
- J) Courtyard Hydrant Valve – 06 Nos.
- K) Fire Alarm Panel- 02 Nos.
- L) Automatic Sprinkler – 60 Nos.

This certificate shall be treated valid up to one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.3,25,000/- vide Receipt No.779392, DD.No.750268 & Rs.1,20,000/- vide Receipt No.779393, DD.No.750269 (Vijaya Bank), Dated:24/06/2019

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

✓

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Assets Infrastructures Co.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

Copy Recd.
20/6/2019
Asstt. Commr.
9322791319.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1607/2022-23

DATE:15/09/2022

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank,
Station Road, Vasai Road (W),
Tal-Vasai, Dist.- Palghar.

Sub:- "Final No Objection Certificate" of School Building Reservation No. PS-489 & 490 on land bearing S.No.22B, H.No.1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27, 28, 29, 30, 31, 32, 33, Plot No.1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20, 21, 22, 23, 24, 25, 26, 27 of Village:Waliv, Tal: Vasai, Dist: Palghar.

- Ref:-
- 1) An application received by M/s- Shah Gattani Consultants, Dated:21/08/2022 (VP-3338).
 - 2) An application received by Developer M/s-ST.Anne's Junior College , Dated:16/06/2022
 - 3) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:25/08/2022.
 - 4) Gross built up Area certificate for M/s- Shah Gattani Consultants, Dated:25/08/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/521/2017-18, Dated:08/10/2017
 - 6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:12/07/2022 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 8) AMC Certificate by Developer M/s-ST.Anne's Junior College, Dated:16/06/2022
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/09/2022.
 - 11) Structure Stability Certificate for , M/s- Shah Gattani Consultants, Dated:29/07/2022.
 - 12) CC issued by VVCMC/TP/cc/VP-/3338/7008/2017-18, Dated:24/01/2018.
 - 13) Submitted Electric Certificate M/s- Rumao Electrical, Dated:05/07/2022.
 - 14) Diesel Generator Test Certificate of M/s-Kirloskar Oil Engines, Dated:Nil/07/2022.
 - 15) C.F.O. site visit Dated:19/09/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your School Building as (Ground floor + 4th Pt floor) in 19.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS/LA/RD-359 and has submitted Certificate on 12/07/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5004.44sq.mtrs.

With reference to above on 19/09/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-ST.Anne's Junior College" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (04 Kg) – 05 Nos.
- B) Hose Reel Hose has been installed in every floor – 04 Nos.
- C) Hose Box has been installed in Alternate floor – 01 Nos.
- D) Booster Pump (5Hp) – 01 Nos.
- E) Hydrant Valve – 05 Nos.
- F) Fire Alarm Control Panel – 01 Nos.
- G) MCP – 05 Nos.
- H) Hooter – 05 Nos.
- I) Sand Bucket – 02 Nos.

CMY
Received
20/09/22

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.5,00,000/- vide Receipt No.601106, DD.No.588862, Dated:09/10/2017 & Rs.5,00,000/- vide Receipt No.60107, DD.No.588863, DD.No.588863 (State Bank of India), Dated:22/06/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC.
2) Developer- M/s-ST.Anne's Junior College

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1610/2022-23

DATE:15/09/2022

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.1 located on land bearing S.No.48, H.No.1A to 1D/2(Pt), H.No.1A to 1D/3 of Village:sativali, Tal:Vasai, Dist:Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/623/2022-23, Dated:30/06/2022.
2) An application received by M/s- En Con Project Consultants, Dated:18/06/2022.
3) An application received by M/s- Dias Properties & Projects, Dated:16/06/2022
4) Work Completion certificate of M/s- En Con Project Consultants, Dated:18/06/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1224/2017-18, Dated:31/03/2018
6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated:18/06/2022.
7) Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:28/06/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:30/10/2021.
9) AMC Certificate by Developer M/s- Dias Properties & Projects, Dated:16/06/2022
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/09/2022.
12) Structure Stability Certificate for M/s- Epicons Consultants Pvt Ltd, Dated:18/06/2022.
13) RDP issued by VVCMC/TP/TDP/VP-0339/217/2019-20, Dated:25/11/2019.
14) Submitted Electric Certificate M/s-Sneha Enterprises, Dated:17/06/2022.
15) C.F.O. site visit Dated:16/09/2022.

With reference to Sr.No.2 above, this office is in received of your application for your Residential with shopline Building No. 1 (Wing-A) as (Stilt / Gr + 12th floor) in 37.95mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-389 & MFS-LA/RD-364 and has submitted Certificate on 28/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 4541.80sq.mtrs.

With reference to above on 16/09/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Dias Properties & Projects" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 kg) – 14 Nos.
- B) Sand Bucket – 04 Nos.
- C) Hose Reel Hose has been installed in every floor – 12 Nos.
- D) Hose Box has been installed in Alternate floor – 16 Nos.
- E) Hydrant Main Pump (60Hp) – 02 Nos.
- F) Sprinkler Main Pump (40 Hp) – 01 Nos.
- G) Jockey Pump (Hydrant & Sprinkler) (40Hp) – 02 Nos.
- H) Booster Pump (10Hp) – 01 Nos.
- I) Single Hydrant Valve – 16 Nos.
- J) Fire Alarm Control Panel – 01 Nos.
- K) MCP & Hooter – 12 Nos.
- L) Smoke Detector – 04 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.3,40,000/- vide Receipt No.636014, DD.No.004318, (IDBI Bank), Dated:16/03/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Dias Properties & Projects

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


EN/CON



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1858/2022-23

DATE:23/09/2022

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor, Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building No.12 on land Bearing S.No.2, H.No.3 of Village:Tivri, Tal: Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-Ajay Wade & Associates, Dated:22/09/2022 (VP-0006).
2) An application received by Developer M/s-JSB Homes LLP, Dated:22/09/2022
3) Work Completion certificate of M/s-Ajay Wade & Associates, Dated:22/09/2022.
4) Built up area certificate for M/s-Ajay Wade & Associates, Dated:22/09/2022.
5) This office Provisional No objection Certificate No.VVCMC/FIRE/HQ/196/2018-19, Dated:09/06/2018.
6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:08/08/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
8) Certificate from License Agency M/s-Water Power Engineering Service, Dated:24/07/2022 (Form A).
9) Submitted License copy of Maharashtra Fire Services, Dated:07/05/2022.
10) AMC Certificate by M/s-JSB Homes LLP, Dated:22/09/2022
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2022.
13) Structure Stability Certificate for M/s-Sura & Associates, Dated:22/09/2022.
14) RDP issued by VVCMC/TP/RDP/SPA-VP-006/21/2018-19, Dated:20/08/2018.
15) Submitted Electric Certificate M/s- Shivani Electricals & Contractor, Dated:22/09/2022.
16) Diesel Generator Test Certificate of M/s-VE Commercial Vehicles, Dated:Nil
17) C.F.O. site visit Dated:23/09/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Residential Building as (Stilt / Ground floor + 22 floor) in 68.00mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS/LA/RD-359 and has submitted Certificate on 08/08/2022 & M/s-Water Power Engineering Service, bearing License No. MFS-LA/RF-248 and MFS-LA/RD-241 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-C & D 15804.619sq.mtrs.

With reference to above on 23/09/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-JSB Homes LLP" following Fire Fighting arrangements provided were found in satisfactory working condition.

Wing- C

- A) Portable Fire Extinguishers has been installed (04 Kg) – 02 Nos.
- B) Portable Fire Extinguishers has been installed (06 Kg) – 04 Nos.
- C) Hose Reel Hose has been installed in every floor – 22 Nos.
- D) Hose Box has been installed in Alternate floor – 22 Nos.
- E) Booster Pump (7.5Hp) – 01 Nos.
- F) Fire Alarm Panel – 01 Nos.
- G) Double Headed Hydrant Valve – 22 Nos.
- H) Smoke Detectors – 235 Nos.
- I) Heat Detectors – 235 Nos.
- J) MCP & Hooter – 23 Nos.

Wing- D

- A) Portable Fire Extinguishers has been installed (06 Kg) – 26 Nos.
- B) Hose Reel Hose has been installed in every floor – 22 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Main Hydrant Pump (100 Hp) – 01 Nos.
- E) Main Sprinkler Pump (50 Hp) – 01 Nos.
- F) Jockey Hydrant Pump (10 Hp) – 01 Nos.
- G) Jockey Sprinkler Pump (10 Hp) – 01 Nos.
- H) Stand By Pump – 01 Nos.
- I) Booster Pump (10 Hp) – 01 Nos.
- J) Courtyard Hydrant Valve – 04 Nos.
- K) Internal Hydrant Valve – 22 Nos.
- L) Fire Alarm Panel – 01 Nos.
- M) MCP & Hooter – 23 Nos.
- N) Sprinkler Bulb – 599 Nos.
- O) Smoke Detectors – 136 Nos.
- P) Heat Detectors – 129 Nos.
- Q) Sand Bucket – 02 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.91,38,700/- vide Receipt No.91348, DD.No.991603, Dated:25/04/2011 & Rs.84,34,900/- vide Receipt No.91349, DD.No.991605, Dated:25/04/2011 & Rs.1,54,30,245/- vide Receipt No.646100, DD.No.108628 (Karnataka Bank), Dated:09/05/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC.
2) Developer- M/s-JSB Homes LLP

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1858/2022-23

DATE:23/09/2022

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor, Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building No.12 on land Bearing S.No.2, H.No.3 of Village:Tivri, Tal: Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-Ajay Wade & Associates, Dated:22/09/2022 (VP-0006).
2) An application received by Developer M/s-JSB Homes LLP, Dated:22/09/2022
3) Work Completion certificate of M/s-Ajay Wade & Associates, Dated:22/09/2022.
4) Built up area certificate for M/s-Ajay Wade & Associates, Dated:22/09/2022.
5) This office Provisional No objection Certificate No.VVCMC/FIRE/HQ/196/2018-19, Dated:09/06/2018.
6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:08/08/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
8) Certificate from License Agency M/s-Water Power Engineering Service, Dated:24/07/2022 (Form A).
9) Submitted License copy of Maharashtra Fire Services, Dated:07/05/2022.
10) AMC Certificate by M/s-JSB Homes LLP, Dated:22/09/2022
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2022.
13) Structure Stability Certificate for M/s-Sura & Associates, Dated:22/09/2022.
14) RDP issued by VVCMC/TP/RDP/SPA-VP-006/21/2018-19, Dated:20/08/2018.
15) Submitted Electric Certificate M/s- Shivani Electricals & Contractor, Dated:22/09/2022.
16) Diesel Generator Test Certificate of M/s-VE Commercial Vehicles, Dated:Nil
17) C.F.O. site visit Dated:23/09/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Residential Building as (Stilt / Ground floor + 22 floor) in 68.00mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-TFPC Infra LLP**, bearing License No. **MFS-LA/RF-384 & MFS/LA/RD-359** and has submitted Certificate on 08/08/2022 & **M/s-Water Power Engineering Service**, bearing License No. **MFS-LA/RF-248 and MFS-LA/RD-241** in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-C & D 15804.619sq.mtrs.

With reference to above on **23/09/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "**M/s-JSB Homes LLP**" following Fire Fighting arrangements provided were found in satisfactory working condition.

Wing- C

- A) Portable Fire Extinguishers has been installed (04 Kg) – 02 Nos.
- B) Portable Fire Extinguishers has been installed (06 Kg) – 04 Nos.
- C) Hose Reel Hose has been installed in every floor – 22 Nos.
- D) Hose Box has been installed in Alternate floor – 22 Nos.
- E) Booster Pump (7.5Hp) – 01 Nos.
- F) Fire Alarm Panel – 01 Nos.
- G) Double Headed Hydrant Valve – 22 Nos.
- H) Smoke Detectors – 235 Nos.
- I) Heat Detectors – 235 Nos.
- J) MCP & Hooter – 23 Nos.

Wing- D

- A) Portable Fire Extinguishers has been installed (06 Kg) – 26 Nos.
- B) Hose Reel Hose has been installed in every floor – 22 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Main Hydrant Pump (100 Hp) – 01 Nos.
- E) Main Sprinkler Pump (50 Hp) – 01 Nos.
- F) Jockey Hydrant Pump (10 Hp) – 01 Nos.
- G) Jockey Sprinkler Pump (10 Hp) – 01 Nos.
- H) Stand By Pump – 01 Nos.
- I) Booster Pump (10 Hp) – 01 Nos.
- J) Courtyard Hydrant Valve – 04 Nos.
- K) Internal Hydrant Valve – 22 Nos.
- L) Fire Alarm Panel – 01 Nos.
- M) MCP & Hooter – 23 Nos.
- N) Sprinkler Bulb – 599 Nos.
- O) Smoke Detectors – 136 Nos.
- P) Heat Detectors – 129 Nos.
- Q) Sand Bucket – 02 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.91,38,700/- vide Receipt No.91348, DD.No.991603, Dated:25/04/2011 & Rs.84,34,900/- vide Receipt No.91349, DD.No.991605, Dated:25/04/2011 & Rs.1,54,30,245/- vide Receipt No.646100, DD.No.108628 (Karnataka Bank), Dated:09/05/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC.
2) Developer- M/s-JSB Homes LLP

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

Received
[Signature]



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1859/2022-23

DATE:23/09/2022

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank,
Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building Type 1A (Wing-E), Type 1B (Wing-F) in Avenue L2 on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s- Shah Gattani Consultants, Dated:23/09/2022 (VP-0453)
2) An application received by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:23/09/2022
3) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:23/09/2022.
4) Built up area certificate for M/s- Ajay Wade & Associates, Dated:27/06/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/854/2018-19, Dated:24/10/2018
6) Certificate from License Agency M/s-Frontierr Enterprises, Dated:17/08/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:27/11/2021.
8) AMC Certificate by M/s-Keystone Infrastructure Pvt Ltd, Dated:16/09/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2022.
11) Structure Stability Certificate for M/s-JW Consultants LLP, Dated:03/02/2022.
12) RDP issued by VVCMC/TP/RDP/VP-0453/221/2019-20, Dated:27/11/2019.
13) Submitted Electric Certificate M/s- Arzoo Electrical Work, Dated:18/08/2022.
14) Submitted Lighting Arester Installation Work Certificate M/s-Karant Electricals LLP, Dated:24/08/2022
15) Submitted D.G Set Certificate M/s-Supernova Engineers Ltd, Dated:12/08/2022
16) C.F.O. site visit Dated:23/09/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Residential Building TYPE 1A (Wing-E) & Type 1B (Wing-F) as (Stilt / Ground floor + 14th floor) in 44.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Frontierr Enterprises, bearing License No. MFS-LA/RF-441, MFS/LA/RD-414, MFS/LA/RP-90 and has submitted Certificate on 17/08/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3280.93sq.mtrs.

With reference to above on 23/09/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Keystone Infrastructure Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (04 Kg) – 12 Nos.
- B) Fire Buckets – 24 Nos.
- C) Hose Reel Hose has been installed in every floor – 14 Nos.
- D) Hose Box has been installed in Alternate floor – 16 Nos.
- E) Booster Pump – 02 Nos.
- F) Fire Alarm Panel- 01 Nos.
- G) MCP – 12 Nos.
- H) Manual Fire Alarm System – 01 Nos.
- I) Pendent Sprinkler – 142 Nos.
- J) Side Wall Sprinkler With Extinguisher – 120 Nos.
- K) Sight Glass – 30 Nos.

Perul
BS

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.53,95,000/- vide Receipt No.705559, DD.No.006246 (HDFC Bank), Dated:12/10/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer - 2) Developer- M/s- ~~Keystone~~ Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1859/2022-23

DATE:23/09/2022

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank,
Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building Type 1A (Wing-E), Type 1B (Wing-F) in Avenue L2 on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s- Shah Gattani Consultants, Dated:23/09/2022 (VP-0453)
2) An application received by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:23/09/2022
3) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:23/09/2022.
4) Built up area certificate for M/s- Ajay Wade & Associates, Dated:27/06/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/854/2018-19, Dated:24/10/2018
6) Certificate from License Agency M/s-Frontierr Enterprises, Dated:17/08/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:27/11/2021.
8) AMC Certificate by M/s-Keystone Infrastructure Pvt Ltd, Dated:16/09/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/09/2022.
11) Structure Stability Certificate for M/s-JW Consultants LLP, Dated:03/02/2022.
12) RDP issued by VVCMC/TP/RDP/VP-0453/221/2019-20, Dated:27/11/2019.
13) Submitted Electric Certificate M/s- Arzoo Electrical Work, Dated:18/08/2022.
14) Submitted Lighting Arester Installation Work Certificate M/s-Karant Electricals LLP, Dated:24/08/2022
15) Submitted D.G Set Certificate M/s-Supernova Engineers Ltd, Dated:12/08/2022
16) C.F.O. site visit Dated:23/09/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Residential Building TYPE 1A (Wing-E) & Type 1B (Wing-F) as (Stilt / Ground floor + 14th floor) in 44.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Frontierr Enterprises, bearing License No. MFS-LA/RF-441, MFS/LA/RD-414, MFS/LA/RP-90 and has submitted Certificate on 17/08/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3280.93sq.mtrs.

With reference to above on **23/09/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Keystone Infrastructure Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (04 Kg) – 12 Nos.
- B) Fire Buckets – 24 Nos.
- C) Hose Reel Hose has been installed in every floor – 14 Nos.
- D) Hose Box has been installed in Alternate floor – 16 Nos.
- E) Booster Pump – 02 Nos.
- F) Fire Alarm Panel- 01 Nos.
- G) MCP – 12 Nos.
- H) Manual Fire Alarm System – 01 Nos.
- I) Pendent Sprinkler – 142 Nos.
- J) Side Wall Sprinkler With Extinguisher – 120 Nos.
- K) Sight Glass – 30 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.53,95,000/- vide Receipt No.705559, DD.No.006246 (HDFC Bank), Dated:12/10/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VCMC
Developer - 2) Developer- M/s- Keystone Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



**VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT**

Handwritten signature

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1982/2022-23

DATE: 28/09/2022

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building Type MC1 (Wing-B) (Stilt + Gr + 14 floor) & Residential Building (Wing-C) (Stilt + 14 floor) on land bearing New S.No.1, H.No.1, S.No.2, H.No.1, S.No.3, H.No.1, S.No.4, H.No.1, S.No.57, H.No.3 & 6/1, S.No.59, H.No.1/3, S.No.254, H.No.13, 14, 15, 16, 3, 6, 7/1, 7/2 in Village: Achole & S.No.101, 103, 104, 107, 106 in Village:Manikpur & S.No.97B, 105B, 106B, 106, H.No.8, S.No.110, H.No.8/1, S.No.128, H.No.6 in Village:Gokhiware, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/568/2022-23, Dated:29/06/2022. (VP-0743)
- 2) An application received by M/s-Shah Gattani Consultants, Dated:22/06/2022.
 - 3) An application received by Developer M/s-Shree Ganesh Ventures, Dated:22/06/2022
 - 4) Work Completion certificate of M/s-Shah Gattani Consultants, Dated:22/06/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/598/2020-21, Dated:11/11/2020.
 - 6) Gross built up area certificate for M/s-Shah Gattani Consultants, Dated:22/06/2022.
 - 7) Certificate from License Agency M/s-TFPC Infra LLP, Dated:16/06/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) AMC Certificate Developer by M/s-Shree Ganesh Ventures, Dated:22/06/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:Nil
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:01/11/2022
 - 12) Structure Stability Certificate for M/s- Pro-Tech Consultats, Dated:02/07/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0743/065/2015-16, Dated:02/06/2015.
 - 14) Submitted Electric Certificate M/s- Amar Electicals, Dated:22/06/2022
 - 15) Diesel Engine Test Certificate M/s-Goel Power Engineers, Dated:11/11/2021.
 - 16) C.F.O. site visit Dated:11/09/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Residential with Shopline Building Type MC1 (Wing-B) as (Stilt / Gr + 14 floor) & Residential Building (Wing-C) in 44.10mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384, MFS-LA/RD-359 and has submitted Certificate on 17/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-B – 2955.58sq.mtrs & Wing-C – 2598.02Sq.mtrs.

With reference to above on 11/11/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Shree Ganesh Ventures" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (6 kg) – 30 Nos.
- B) Hose Reel Hose has been installed in every floor – 28 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Hydrant Valve – 32 Nos.
- E) Main Hydrant Pump (60 HP) – 01 Nos.
- F) Main Sprinkler Pump (30 HP) – 01 Nos.
- G) Jockey Hydrant Pump (15 HP) – 01 Nos.

- H) Jockey Sprinkler Pump (15 HP) – 01 Nos.
I) Stand by Pump (60 HP) – 01 Nos.
J) Booster Pump near over head water storage tank (10 HP) - 02 Nos.
K) Fire Alarm Control Panel – 02 Nos.
L) MCP Cum Hooter – 30 Nos.
M) Sprinkler System – 60 Nos.
N) Smoke Detector – 02 Nos.
O) Sand Bucket – 04 Nos.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.9,70,000/- vide Receipt No.819517, DD.No.230984 (RBL Bank), Dated:05/11/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect - 1) Shah Gattani Consultants
Developer - 2) Developer- Shree Ganesh Ventures.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2014/2022-23

DATE: 05/10/2022

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.

2689



Sub:- "Final No Objection Certificate" of Residential Building No. 5 on land bearing S.No.31, H.No.1, 4A, 4B & 4C, S.No.34, H.No.1 & 2, S.No.35, H.No.1, 3, 4, 2/1 & 2/2, S.No.36, H.No.1A, 1B, 2A, 2B, 3A & 3B, S.No.37, H.No.1 to 5, 7, 8, 9, 14, 17, 18, 19, 20, 21, 22 & 23, S.No.38, 1A, 1B, 4, 5, 7, 8 & 9, S.No.39, H.No.1A, 1B, 2A, 2B, 3A, 3B, 4A, 4B, 5, 6, 7, 8, 9, 10, 12, 13, 14A, 14B, 15, 16, 17 & 18, S.No.40, H.No.1A, 1B, 2, 3A, 3B, 4, 5A, 5B, 6, 7A & 7B, S.No.41, H.No.2B, 4A, 4B, 7A, 7B, 8A, 8B, 3A, 3B/1, 3B/2, 5A/1, 5A/2, 5A/4, 5B/1, 5B/3, 6A/1, 6A/2, 6A/3, 6B/1 & 6B/2, S.No.42, H.No.1A, 6A & 7A, S.No.43, H.No.1B, 8A/3, 8A/4, 8A/5, 8A/6, 8B/1, 8B/2, 8C/4, S.No.44, H.No.20A/2, S.No.48, H.No.21A, 21B & 22 of Village: Barampur, Tal:Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-Prithvi Arch Consultants, Dated:30/09/2022
2) An application received by M/s- B.J. Enterprises, Dated:03/10/2022
3) Work Completion certificate of M/s-Prithvi Arch Consultants, Dated:30/09/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/201/2018-19, Dated:03/06/2018.
5) Gross built up area certificate for M/s-Prithvi Arch Consultants, Dated:30/09/2022.
6) Certificate from License Agency M/s- Nortex Fire Equipment Co.Pvt Ltd, Dated:19/09/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:27/11/2021.
8) AMC Certificate by M/s- B.J. Enterprises, Dated:10/06/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated:Nil
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/10/2022.
11) Structure Stability Certificate for Mr.Hiren M. Tanna, Dated:05/08/2022.
12) CC issued by VVCMC/TP/CC/VP-0202/287/2021-22, Dated:08/10/2021
13)Submitted Electric Certificate M/s- Choice Electricals, Dated:26/09/2022.
14) D.G.Set Certificate of M/s-Shyam Power Solutions, Dated:Nil
15) C.F.O. site visit Dated:05/10/2022

With reference to Sr.No. 1 & 2 above, this office is in received of your application for your Residential Building No.5 (Wing-A) as (Basement + Stilt floor + 18 upper floor) in 57.90mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Nortex Fire Equipment Co.Pvt Ltd, bearing License No. MFS-LA/RF-438, MFS-LA/RD-410 and has submitted Certificate on 19/09/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9916.23sq.mtrs.

With reference to above on **05/10/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- B.J. Enterprises" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kgs) – 10 Nos.
B) Co2 Type Fire Extinguishers has been installed (4.5Kgs) – 02 Nos.
C) Fire Buckets – 04 Nos.
D) Main Hydrant Pump (100hp) – 01 Nos.

- K) Single Hydrant Valve – 23 Nos.
- L) Siamese Connection at main gate:- 10 Nos.
- M) Pendent Type Automatic Sprinkler (68°C) – 498 Nos.
- N) Extended Coverage Side wall type Sprinklers (68°C) – 378 Nos.
- O) 20 Zone Main Fire Alarm Control Panel with P.A.System – 01 Nos.
- P) Smoke Detectors with base – 03 Nos.
- Q) Hooter – 19 Nos.
- R) Pill Box – 19 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.24,70,000/- vide Receipt No. 226692, DD. No. 031267, Dated:04/07/2014; Rs. 11,70,000/- vide Receipt No.226693, DD.No.031268 (Vasai Vikas Sahakari Bank), Dated:04/07/2014; Rs.5,00,000/- vide Receipt No.609406, DD.No.034728, Dated: 01/11/2017 & Rs6,00,000/- vide Receipt No.609405, DD.No.034740 (Vasai Vikas Sahakari Bank), Dated:01/11/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-B.J.Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2014/2022-23

DATE: 05/10/2022

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building No. 5 on land bearing S.No.31, H.No.1, 4A, 4B & 4C, S.No.34, H.No.1 & 2, S.No.35, H.No.1, 3, 4, 2/1 & 2/2, S.No.36, H.No.1A, 1B, 2A, 2B, 3A & 3B, S.No.37, H.No.1 to 5, 7, 8, 9, 14, 17, 18, 19, 20, 21, 22 & 23, S.No.38, 1A, 1B, 4, 5, 7, 8 & 9, S.No.39, H.No.1A, 1B, 2A, 2B, 3A, 3B, 4A, 4B, 5, 6, 7, 8, 9, 10, 12, 13, 14A, 14B, 15, 16, 17 & 18, S.No.40, H.No.1A, 1B, 2, 3A, 3B, 4, 5A, 5B, 6, 7A & 7B, S.No.41, H.No.2B, 4A, 4B, 7A, 7B, 8A, 8B, 3A, 3B/1, 3B/2, 5A/1, 5A/2, 5A/4, 5B/1, 5B/3, 6A/1, 6A/2, 6A/3, 6B/1 & 6B/2, S.No.42, H.No.1A, 6A & 7A, S.No.43, H.No.1B, 8A/3, 8A/4, 8A/5, 8A/6, 8B/1, 8B/2, 8C/4, S.No.44, H.No.20A/2, S.No.48, H.No.21A, 21B & 22 of Village: Barampur, Tal:Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-Prithvi Arch Consultants, Dated:30/09/2022
2) An application received by M/s- B.J. Enterprises, Dated:03/10/2022
3) Work Completion certificate of M/s-Prithvi Arch Consultants, Dated:30/09/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/201/2018-19, Dated:03/06/2018.
5) Gross built up area certificate for M/s-Prithvi Arch Consultants, Dated:30/09/2022.
6) Certificate from License Agency M/s- Nortex Fire Equipment Co.Pvt Ltd, Dated:19/09/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:27/11/2021.
8) AMC Certificate by M/s- B.J. Enterprises, Dated:10/06/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated:Nil
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/10/2022.
11) Structure Stability Certificate for Mr.Hiren M. Tanna, Dated:05/08/2022.
12) CC issued by VVCMC/TP/CC/VP-0202/287/2021-22, Dated:08/10/2021
13)Submitted Electric Certificate M/s- Choice Electricals, Dated:26/09/2022.
14) D.G.Set Certificate of M/s-Shyam Power Solutions, Dated:Nil
15) C.F.O. site visit Dated:05/10/2022

With reference to Sr.No. 1 & 2 above, this office is in received of your application for your Residential Building No.5 (Wing-A) as (Basement + Stilt floor + 18 upper floor) in 57.90mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Nortex Fire Equipment Co.Pvt Ltd, bearing License No. MFS-LA/RF-438, MFS-LA/RD-410 and has submitted Certificate on 19/09/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9916.23sq.mtrs.

With reference to above on 05/10/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- B.J. Enterprises" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kgs) – 10 Nos.
- B) Co2 Type Fire Extinguishers has been installed (4.5Kgs) – 02 Nos.
- C) Fire Buckets – 04 Nos.
- D) Main Hydrant Pump (100hp) – 01 Nos.

- K) Single Hydrant Valve – 23 Nos.
- L) Siamese Connection at main gate:- 10 Nos.
- M) Pendent Type Automatic Sprinkler (68°C) – 498 Nos.
- N) Extended Coverage Side wall type Sprinklers (68°C) – 378 Nos.
- O) 20 Zone Main Fire Alarm Control Panel with P.A.System – 01 Nos.
- P) Smoke Detectors with base – 03 Nos.
- Q) Hooter – 19 Nos.
- R) Pill Box – 19 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.24,70,000/- vide Receipt No. 226692, DD. No. 031267, Dated:04/07/2014; Rs. 11,70,000/- vide Receipt No.226693, DD.No.031268 (Vasai Vikas Sahakari Bank), Dated:04/07/2014; Rs.5,00,000/- vide Receipt No.609406, DD.No.034728, Dated: 01/11/2017 & Rs6,00,000/- vide Receipt No.609405, DD.No.034740 (Vasai Vikas Sahakari Bank), Dated:01/11/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-B.J.Enterprises

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

4/09

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2203/2022-23

DATE: 13/10/2022

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank,
Station Road,
Vasai (W),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Residential with Shopline Building Block No.10 Type C1 (Wing-A), Type C (Wing-B), Type D2 (Wing-C), Type C1 (Wing-D) Residential Building Type E (Wing-E), Stilt / Gr + 7 Floor on land bearing S.No.159, 160, 162 to 176, 238 to 246, 248, 257, 432, 738, 773, 776 to 778, 859 to 875 etc of Village: Agashi, Tal:Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s- Shah Gattani Consultants, Dated:18/08/2022. (VP-1030)
- 2) An application received by M/s- Tirupati Constructions Co. Dated:16/08/2022
 - 3) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:18/08/2022.
 - 4) Cidco issued by Praposal Noc Ref No. CIDCO/FIRE/KLM/2008/425, Dated:18/06/2008
 - 5) Gross built up area certificate for M/s- Shah Gattani Consultants, Dated:18/08/2022.
 - 6) Certificate from License Agency M/s- Sadanand Fire Controls, Dated:06/10/2022 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:11/06/2022.
 - 8) AMC Certificate by M/s- Tirupati Constructions Co, Dated:21/01/2022
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour. Dated:Nil
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/09/2022.
 - 11) Structure Stability Certificate for M/s- Shah Gattani Consultants, Dated:16/12/2017
 - 12) Amended plan approval issued by CIDCO/VVSR/AM/BP-82/W/2732, Dated:26/06/2007.
 - 13) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated:22/08/2022.
 - 14) D.G.Set Certificate of M/s-Kirloskar Make Generator, Dated:Nil
 - 15) C.F.O. site visit Dated:12/09/2022

Received
2 copy
Copy

With reference to Sr.No. 1 & 2 above, this office is in received of your application for your Residential with Shopline Building Block No. 10 Type C1 (Wing-A), Type C (Wing-B), Type D2 (Wing-C), Type C1 (Wing-D), Residential Building Type E (Wing-E) as (Stilt / Gr + 7 floor) in 23.80mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Controls, bearing License No. MFS-LA/RF-302 and has submitted Certificate on 06/10/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5494.38sq.mtrs.

With reference to above on 12/09/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Tirupati Constructions Co" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed – 10 Nos.
- B) Hose Reel Hose has been installed in every floor – 12 Nos
- C) Hose Box has been installed in Alternate floor – 07 Nos.
- D) Main Hydrant Pump (30hp) – 01 Nos.
- E) Booster Pump near over head water storage tank (5hp) – 01 Nos.
- F) Courtyard Hydrant – 12 Nos.
- G) Siamese Connection at main gate:- 10 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Rs.9,20,000/- vide Receipt No. 54314, DD.No. 023613 (IDBI Bank), Dated:15/09/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Tirupati Constructions Co

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2325 /2022-23

DATE: 19/10/2022

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Himesh Gupta & Associates,
103, Shubham Heritage,
Behind Gopal Building,
Off Ambadi Road, Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No. 1 with Hospital on 1st floor on land bearing S.No.54D of Village:Sativali, Tal: Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-Himesh Gupta & Associates, Dated:13/10/2022 (VP-0776)
2) An application received by Developer Mr.Ishtiyak A. B. Khan, Dated:01/12/2022
3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:13/10/2022.
4) Built up area certificate for M/s-Himesh Gupta & Associates, Dated:13/10/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/541/2022-23, Dated:24/06/2022
6) Certificate from License Agency M/s-Fire Bird Fire Services, Dated:18/08/2022. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022
8) AMC Certificate by M/s-One Star Developers, Dated:20/01/2023
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/02/2022.
11) Structure Stability Certificate for M/s-S.S & Associates, Dated:20/06/2022.
12) RDP issued by VVCMC/TP/RDP/VP-0776/616/2021-22, Dated:25/11/2021.
13) Submitted Electric Certificate M/s-Famous Electric Inspection Company, Dated:07/01/2023.
14) Submitted D.G. Set Certificate for M/s- M/s-Famous Electric Inspection Company, Dated:07/01/2023
15) C.F.O. site visit Dated:08/02/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Residential Cum Commercial Building No. 1 with Hospital on 1st floor as (Ground floor + 4th floor) in 16.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Fire Bird Fire Services, bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 has submitted Certificate on 18/08/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2815.65sq.mtrs.

With reference to above on 08/02/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr.Ishtiyak A. B. Khan" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 08 Nos.
B) Co2 Type Portable Fire Extinguishers has been installed (02 Kg) – 02 Nos.
C) Hose Reel Hose has been installed in every floor – 01 Nos.
D) Hose Box has been installed in Alternate floor – 02 Nos.
E) Booster Pump (5 Hp) – 01 Nos.
F) Single Hydrant Valve – 02 Nos.
G) Fire Alarm Panel Board - 01 Nos (04 Zones).



Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.80,000/- vide Receipt No.694431, Book No.6945, DD.No.022517 (Bassein Catholic Bank), Dated:17/07/2018; Rs.2,70,000/- vide Receipt No.694430, Book No.6945, DD.No.022531 (Bassein Catholic Bank), Dated:17/07/2018 & Rs.50,000/- vide Receipt No.30974, Book No.310, DD.No.003002 (Vasai Vikas Sahakari Bank), Dated:09/06/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




[Signature]

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Mr.Ishtiyak A. B. Khan.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.





VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2326/2022-23

DATE:19/10/2022

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7/8, "D" Wing, Sethi Palace,
Ambadi Road,
Vasai (W),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Industrial / Commercial Building on land bearing S.No.44/8/3/2 (Old), S.No.44/8A (New) of Village:Waliv, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s- En Con Project Consultants, Dated:17/10/2022 (VP-6351)
2) An application received by Developer M/s-Krishna Buildtech LLP, Dated:13/09/2022
3) Work Completion certificate of M/s- En Con Project Consultants, Dated:17/10/2022.
4) Built up area certificate for M/s- En Con Project Consultants, Dated:17/10/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1136/2021-22, Dated:12/08/2021
6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:19/08/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021
8) AMC Certificate by M/s-Krishna Buildtech LLP, Dated:13/09/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/10/2022.
11) Structure Stability Certificate for M/s-S.S & Associates, Dated:29/06/2022.
12) RDP issued by VVCMC/TP/RDP/VP-6351/132/2021-22, Dated:08/07/2021.
13) Submitted Electric Certificate M/s- Sonu Electrical & Contractor, Dated:13/09/2022.
14) Submitted D.G Set Certificate M/s-Nidec Industrial Automation India Pvt Ltd, Dated:17/07/2022
15) C.F.O. site visit Dated:19/10/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Industrial / Commercial Building as (Ground floor + 3rd floor) in 20.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384, MFS/LA/RD-359 and has submitted Certificate on 19/08/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3746.25sq.mtrs.

With reference to above on 19/10/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Krishna Buildtech LLP" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) Fire Sand Buckets – 04 Nos.
- C) Hose Reel Hose has been installed in every floor – 03 Nos.
- D) Hose Box has been installed in Alternate floor – 04 Nos.
- E) Main Hydrant Pump (40 hp) - 01 Nos.
- F) Main Sprinkler Pump (20 hp) – 01 Nos.
- G) Jockey Hydrant Pump (7.5 hp) – 01 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.4,80,000/- vide Receipt No.895520, Book No. 8956, DD.No.024670 (Bassein Catholic Bank), Dated:08/07/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer - 2) Developer- M/s- Krisha Buildtech LLP.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2327/2022-23

DATE:19/10/2022

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7/8, "D" Wing, Sethi Palace,
Ambadi Road,
Vasai (W),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Industrial / Commercial Building on Plot bearing S.No.62, H.No.1 (Plot No. B PT) (OLD), S.No.62C/3/Plot No.2 (New) of Village:Waliv, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s- En Con Project Consultants, Dated:11/10/2022 (VP-6352)
2) An application received by Developer M/s-Krishna Buildtech LLP, Dated:13/09/2022
3) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/10/2022.
4) Built up area certificate for M/s- En Con Project Consultants, Dated:11/10/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1135/2021-22, Dated:12/08/2021
6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:19/08/2022 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021
8) AMC Certificate by M/s-Krishna Buildtech LLP, Dated:13/09/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/10/2022.
11) Structure Stability Certificate for M/s-S.S & Associates, Dated:29/06/2022.
12) RDP issued by VVCMC/TP/RDP/VP-6352/635/2021-22, Dated:06/12/2021.
13) Submitted Electric Certificate M/s- Sonu Electrical & Contractor, Dated:13/09/2022.
14) Submitted D.G Set Certificate M/s-Ashok Leyland Ltd, Dated:30/04/2022
15) C.F.O. site visit Dated:19/10/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Industrial / Commercial Building as (Ground floor + 3rd floor) in 20.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384, MFS/LA/RD-359 and has submitted Certificate on 19/08/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5595.94sq.mtrs.

With reference to above on 19/10/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Krishna Buildtech LLP" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) Fire Sand Buckets – 02 Nos.
- C) Hose Reel Hose has been installed in every floor – 02 Nos.
- D) Hose Box has been installed in Alternate floor – 03 Nos.
- E) Main Hydrant Pump (40 hp) - 01 Nos.
- F) Main Sprinkler Pump (20 hp) – 01 Nos.
- G) Jockey Hydrant Pump (7.5 hp) – 01 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.10,00,000/- vide Receipt No.895557, Book No. 8956, DD.No.024692 (Bassein Catholic Bank), Dated:28/07/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer - 2) Developer- M/s- Krisha Buildtech LLP.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/2442/2022-23
दिनांक: 08/11/2022.

FIRE & EMERGENCY DEPARTMENT



To,
M/s-En Con Project Consultants,
G-7, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- **"Final No Objection Certificate" of Industrial / Commercial Building on land bearing S.No.95/1/2 of Village:Waliv, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:04/11/2022.
2) An application received by Developer, M/s-Acetron Developers, Dated:04/11/2022
3) Work Completion certificate of M/s-En Con Project Consultants, Dated:04/11/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/427/2019-20, Dated:19/08/2019.
5) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/594/2022-23, Dated:30/06/2022.
6) Built up area certificate for M/s-En Con Project Consultants, Dated:04/11/2022.
7) Certificate from License Agency M/s-TFPC Infra LLP, Dated:31/10/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022.
9) AMC Certificate by M/s-Acetron Developers LLP, Dated:04/11/2022
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/11/2022.
12) Structure Stability Certificate for M/s-S.S & Associates, Dated:29/06/2022.
13) RDP issued by VVCMC/TP/RDP/VP-0655/140/2022-23, Dated:30/06/2022.
14) Submitted Electric Certificate M/s-Zip Engineers, Dated:31/10/2022.
15) Diesel Generator Test Certificate of M/s-Precision Engineering Works, Dated:25/05/2022
16) C.F.O. site visit Dated:07/11/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Industrial / Commercial Building as (Basement + Ground floor + 4 (Pt) upper floor) in 23.90mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RF-474 & MFS/LA/RD-457 and has submitted Certificate on 31/10/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 8676.14sq.mtrs.

With reference to above on 07/11/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Acetron Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 06 Nos.
- B) Hose Reel Hose has been installed in every floor – 08 Nos.
- C) Hose Box has been installed in Alternate floor – 06 Nos.
- D) Main Hydrant Pump (50 Hp) – 01 Nos.
- E) Main Sprinkler Pump (30 Hp) – 01 Nos.
- F) Jockey Hydrant Pump (05 Hp) – 01 Nos.
- G) Jockey Sprinkler Pump (05 Hp) – 01 Nos.
- H) Stand by Pump (50 Hp) – 01 Nos.
- I) Booster Pump (05 Hp) – 01 Nos.
- J) Courtyard Hydrant Valve – 06 Nos.
- K) Internal Hydrant Valve – 08 Nos.
- L) Fire Alarm Control Panel – 01 Nos.

This certificate shall be treated valid up to 31/03/2023 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.10,00,000/- vide Receipt No.818223, DD.No.007624 (IDBI Bank), Dated:05/07/2019 & Rs.5,00,000/- vide Receipt No.819670, DD.No.490196 (Indian Overseas Bank), Dated:26/11/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s- Acetron Developers LLP

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

Ther
ENCON

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फैक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/2443/2022-23
दिनांक: 08/11/2022.

FIRE & EMERGENCY DEPARTMENT



To,
M/s-En Con Project Consultants,
G-7, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building on land bearing S.No.13, H.No.1 of Village:More, Tal: Vasai, Dist: Palghar.**

- Ref:-
- 1) An application received by M/s-En Con Project Consultants, Dated:04/11/2022.
 - 2) An application received by Developer, M/s-Zehra Land Developers, Dated:15/10/2022
 - 3) Work Completion certificate of M/s-En Con Project Consultants, Dated:04/11/2022.
 - 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/177/2016-17, Dated:09/06/2016.
 - 5) Built up area certificate for M/s-En Con Project Consultants, Dated:04/11/2022.
 - 6) Certificate from License Agency M/s-Fire Bird Fire Services, Dated:15/10/2022 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
 - 8) AMC Certificate by M/s-Zehra Land Developers, Dated:15/10/2022
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/11/2022.
 - 11) Structure Stability Certificate for M/s-Dipjit Associates, Dated:20/10/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-5585/331/2021-22, Dated:20/07/2022.
 - 13) Submitted Electric Certificate M/s-Ram Electric Works & Services, Dated:15/10/2022.
 - 14) Diesel Generator Test Certificate of M/s-M & M Ltd, Dated:31/05/2022
 - 15) C.F.O. site visit Dated:07/11/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential Building (Wing-D) as (Stilt floor + 7 upper floor) in 24.40mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-Fire Bird Fire Services, bearing License No. MFS-LA/RF-71 & MFS/LA/RD-69** and has submitted Certificate on 15/10/2022 in **"Form A"** Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 1923.88sq.mtrs.

With reference to above on **07/11/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-Zehra Land Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 07 Nos.
- B) Hose Reel Hose has been installed in every floor – 07 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Hydrant Valve – 10 Nos.
- E) Main Hydrant Pump (25 Hp) – 01 Nos.
- F) Jockey Pump (05 Hp) – 01 Nos.
- G) Jockey Sprinkler Pump (05 Hp) – 01 Nos.
- H) Booster Pump (05 Hp) – 01 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.1,20,000/- vide Receipt No.470118, DD.No.020282 (Bassein Catholic Bank), Dated:26/04/2016; Rs.3,60,000/- vide Receipt No.470119, DD.No.033122 (Vasai Vikas Sahakari Bank), Dated:26/04/2016 & Rs.2,40,000/- vide Receipt No.470120, DD.No.016350 (PMC Bank), Dated:26/04/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s- Zehra Land Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


ENCON

मुख्य कार्यालय, विरार

विरार (पूर्व)

ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फॅक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/2514/2022-23

दिनांक: 21/11/2022.



FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor, Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No.8 on land bearing S.No.44, 45, 93 & 94 of Village:Sativali, Tal: Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s- Ajay Wade & Associates, Dated:19/11/2022.
2) An application received by Developer Mr.Bhavin Shah, Dated:19/11/2022
3) Built up area certificate of M/s- Ajay Wade & Associates, Dated:19/11/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1683/2022-23, Dated:21/09/2022.
5) Built up area certificate for M/s- Ajay Wade & Associates, Dated:19/11/2022.
6) Certificate from License Agency M/s-Vision Fire & Safety Engineering, Dated:08/11/2022. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:04/10/2022.
8) AMC Certificate by M/s-Landmark Developers, Dated:11/11/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:04/10/2022.
11) Structure Stability Certificate for M/s-Sameer Mohile & Associates, Dated:18/10/2022.
12) RDP issued by VVCMC/TP/RDP/VP-0761/142/2022-23, Dated:30/06/2022.
13) Submitted Electric Certificate M/s- Pradhan Electrical Works, Dated:14/11/2022.
14) Diesel Generator Test Certificate of M/s-Kirloskar Brother Ltd, Dated:16/12/2020
15) C.F.O. site visit Dated:04/10/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Industrial Building No. 8 as (Ground floor + 3rd floor) in 18.00mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-491 & MFS/LA/RD-473 and has submitted Certificate on 08/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5304.03sq.mtrs.

With reference to above on 19/11/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Landmark Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hose Reel Hose has been installed in every floor – 11 Nos.
- B) Single Door Hose Box – 15 Nos.
- C) Double Door Hose Box – 04 Nos.
- D) Sprinkler – 182 Nos.
- E) Single Hydrant Valve – 15 Nos.
- F) Double Hydrant Valve – 04 Nos.

This certificate shall be treated valid up to one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs. 1,50,000/- vide Receipt No. 48116, DD.No.081475 & Rs.1,50,000/- vide Receipt No.458117, DD.No.081474 (HDFC Bank), Dated:31/03/2016 & Rs.1,80,000/- vide Receipt No.895815, Book No.8959, DD.No.094939 (HDFC Bank), Dated:22/10/2021 & Rs. 5,20,000/- vide Receipt No.30729, Book No.308, DD.No.095631 (HDFC Bank), Dated:28/04/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

Received
D. J. S.



CDU

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s- Landmark Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फैक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/2518/2022-23
दिनांक : 22/11/2022.

FIRE & EMERGENCY DEPARTMENT

To,
M/s- Nine Realty,
Shop No.7, Nakoda Heights,
Bldg No.3, Near Shantinagar Complex,
Nalasopara (W), Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Residential Building (Wing-D) M/s-Nine Realty Builders Building known as "SEA GRAPES" on land bearing S.No.191 Phase-I, Sector No. III, Bldg No.7 of Village:Nilemore, Tal- Vasai, Dist-Palghar.

- Ref:- 1) An Application received by M/s-Nine Realty, Dated:08/10/2022.
2) Certificate from License Agency M/s- Fire Bird Fire Services, Dated:13/07/2022 (Form B).
3) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:04/11/2022
4) Submitted Renewal of Final No Objection Certificate No. VVCMC/FIRE/HQ/1006/2019, Dated:30/11/2019.
5) Structural Stability Certificate M/s-Shilplekha Consultant, Dated:22/07/2015.
6) Submitted Electrical Certificate M/s-T & K Electrical, Dated:08/10/2022
7) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
8) C.F.O site visit Dated:04/11/2022.

With reference to Sr.No.1 above, this office is in received of your application for your Residential Building (Wing-D) Gr + 9 Floor in 29.60mtrs height. at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71 & MFS-LA/RD-69 and has submitted Certificate On 13/07/2022 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to One year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 96,000/- vide Receipt No. 54648, Book No. 547, DD No.022901 (HDFC Bank), Dated:22/11/2022 & Rs. 8,000/- vide Receipt No. 54649, Book No. 547, DD.No.022975 (HDFC Bank), Dated:22/11/2022 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect / Developer-

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/2520/2022-23
दिनांक: 22/11/2022.

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Shree Consultants,
B-203, Akanksha Tower,
Nr Railway Station,
Nalasopara (E),
Tal-Vasai, Dist-Palghar.



Sub:- **"Final No Objection Certificate" of Residential With Shopline Building on land bearing S.No.283, H.No.3B of Village:Virar, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) An application received by M/s-Shree Consultants, Dated:01/11/2022.
2) An application received by Developer, M/s-Shree Sai Sangam Developers, Dated:01/11/2022
3) Work Completion certificate of M/s-Shree Consultants, Dated:01/11/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1123/2020-21, Dated:31/03/2021.
5) Built up area certificate for M/s-Shree Consultants, Dated:01/11/2022.
6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:18/11/2022. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022.
8) AMC Certificate by M/s-TFPC Infra LLP, Dated:11/10/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:18/11/2022.
11) Structure Stability Certificate for M/s-Shilplekha Consultants, Dated:10/09/2022.
12) RDP issued by VVCMC/TP/RDP/VP-5099/41/2021-22, Dated:22/04/2021.
13) Submitted Electric Certificate M/s-Shri Swami Samarth Power Works, Dated:18/11/2022.
14) Diesel Generator Bill of M/s-Om Diesel Engineering, Dated:16/11/2022
15) C.F.O. site visit Dated:18/11/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential with Shopline Building (Wing- A & B) as (Stilt floor + 9 upper floor) in 30.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-474 & MFS/LA/RD-457 and has submitted Certificate on 18/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1923.88sq.mtrs.

With reference to above on 18/11/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Shree Sai Sangam Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 26 Nos.
B) Hose Reel Hose has been installed in every floor – 18 Nos.
C) Hose Box has been installed in Alternate floor – 14 Nos.
D) Courtyard Hydrant Valve – 04 Nos.
E) Internal Hydrant Valve – 18 Nos.
F) Main Hydrant Pump (50 Hp) – 01 Nos.

[Handwritten signature]
12/11/2022

- N) Automatic Sprinkler – 89 Nos.
- O) MCP / Hooter – 20 Nos.
- P) Sand Bucket – 04 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.4,00,000/- vide Receipt No.819555, DD.No.117856 (Vasai Vikas Sahakari Bank), Dated:18/11/2020 & Rs.2,80,000/- vide Receipt No.895273, Book No.8953, DD.No.118117 (Vasai Vikas Sahakari Bank), Dated:25/03/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "L. P. Kulkarni", written over the official title of the Chief Fire Officer.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s- Shree Sai Sangam Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/2520/2022-23
दिनांक: 22/11/2022.

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shree Consultants,
B-203, Akanksha Tower,
Nr Railway Station,
Nalasopara (E),
Tal-Vasai, Dist-Palghar.

Sub:- **"Final No Objection Certificate" of Residential With Shopline Building on land bearing S.No.283, H.No.3B of Village:Virar, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) An application received by M/s-Shree Consultants, Dated:01/11/2022.
2) An application received by Developer, M/s-Shree Sai Sangam Developers, Dated:01/11/2022
3) Work Completion certificate of M/s-Shree Consultants, Dated:01/11/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1123/2020-21, Dated:31/03/2021.
5) Built up area certificate for M/s-Shree Consultants, Dated:01/11/2022.
6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:18/11/2022. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022.
8) AMC Certificate by M/s-TFPC Infra LLP, Dated:11/10/2022
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:18/11/2022.
11) Structure Stability Certificate for M/s-Shilplekha Consultants, Dated:10/09/2022.
12) RDP issued by VVCMC/TP/RDP/VP-5099/41/2021-22, Dated:22/04/2021.
13) Submitted Electric Certificate M/s-Shri Swami Samarth Power Works, Dated:18/11/2022.
14) Diesel Generator Bill of M/s-Om Diesel Engineering, Dated:16/11/2022
15) C.F.O. site visit Dated:18/11/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential with Shopline Building (Wing- A & B) as (Stilt floor + 9 upper floor) in 30.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-474 & MFS/LA/RD-457 and has submitted Certificate on 18/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 1923.88sq.mtrs.

With reference to above on **18/11/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-Shree Sai Sangam Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 26 Nos.
- B) Hose Reel Hose has been installed in every floor – 18 Nos.
- C) Hose Box has been installed in Alternate floor – 14 Nos.
- D) Courtyard Hydrant Valve – 04 Nos.
- E) Internal Hydrant Valve – 18 Nos.
- F) Main Hydrant Pump (50 Hp) – 01 Nos.

- N) Automatic Sprinkler – 89 Nos.
- O) MCP / Hooter – 20 Nos.
- P) Sand Bucket – 04 Nos.

This certificate shall be treated **valid up to 31/03/2023** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.4,00,000/- vide Receipt No.819555, DD.No.117856 (Vasai Vikas Sahakari Bank), Dated:18/11/2020 & Rs.2,80,000/- vide Receipt No.895273, Book No.8953, DD.No.118117 (Vasai Vikas Sahakari Bank), Dated:25/03/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "A. B. W.", written over the official stamp.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) The Deputy Director Town Planning, VVCMC

2) Developer- M/s- Shree Sai Sangam Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrfireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2579/2022-23

DATE:06/12/2022

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Sanat Mehta & Associates,
Rameshwar Tower,
A-103, Shimpoli Road,
Next to Gokhale School,
Borivali (W), Mumbai-400 092.



Sub:- **"Final No Objection Certificate" of Residential Building No. 2 (Wing-A to E) on S.No.29B, 3, 5, 73, 74 & 76 of Village:Waliv, Tal:Vasai, Dist:Palghar.**

Ref:- 1) An application received by M/s-Sanat Mehta & Associates, Dated:19/11/2022 (VP- 0151)

2) An application received by Developer M/s- Rajlaxmi Developers, Dated:14/11/2022

3) Work Completion certificate of M/s-Sanat Mehta & Associates, Dated:19/11/2022.

4) Construction area certificate for M/s-Sanat Mehta & Associates, Dated:19/11/2022.

5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/ 5088/2021-22, Dated:21/03/2022

6) Certificate from License Agency M/s-Water Power, Dated:08/11/2022 (Form A).

7) Submitted License copy of Maharashtra Fire Services, Dated:07/05/2022

8) AMC Certificate by M/s- Rajlaxmi Developers, Dated:14/11/2022

9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.

10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/11/2022.

11) Structure Stability Certificate for M/s-Jay Shree Krishna, Dated:16/11/2022.

12) RDP issued by VVCMC/TP/RDP/VP-0151/696/2021-22, Dated:28/12/2021.

13) Submitted Electric Certificate M/s-Jignesh Vidyut Service, Dated:05/11/2022.

14) Submitted D.G Set Certificate M/s-Kirloskar Oil Engines, Dated:Nil/10/2022.

15) Submitted Affidavit of M/s-Water Fire, Dated:05/12/2022.

16) C.F.O. site visit Dated:24/11/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential Building No.12 (Wing- A, B & C) as (Stilt / Ground floor + 15th floor) in 47.40mtrs Height & (Wing- D & E as (Stilt / Ground floor + 15th floor) in 47.10mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s- Water Power, bearing License No. MFS-LA/RF-248, MFS/LA/RD-241 and has submitted Certificate on 08/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to Wing-A & B – 6364.70; Wing- C – 5162.44 & Wing- D & E – 7273.21sq.mtrs.

With reference to above on **24/11/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s- Rajlaxmi Developers"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- Portable Fire Extinguishers has been installed (06 Kg) – 45 Nos.
- Hose Reel Hose has been installed in every floor – 75 Nos.
- Hose Box has been installed in Alternate floor – 45 Nos.
- Main Hydrant Pump (75 hp) - 01 Nos.
- Main Sprinkler Pump (75 hp) – 01 Nos.
- Jockey Hydrant Pump (15 hp) – 01 Nos.
- Jockey Sprinkler Pump (7.5 hp) – 01 Nos.
- Booster Pump (7.5 hp) – 01 Nos.
- Hydrant Valve – 81 Nos.
- Fire Alarm Panel- 05 Nos.
- Sprinkler System – 901 Nos.
- Smoke Detector – 210 Nos.
- MCP & Hooter – 75 Nos.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.7,40,000/- vide Receipt No.672776, Book, DD.No.002199, Dated:22/06/2018; Rs.4,20,000/-, vide Receipt No.761242, DD.No.0397, Dated:28/02/2019; Rs.1,20,000/-, Vide Receipt No.761252, DD.No.000397, Dated:05/03/2019 & Rs.11,27,000/- vide Receipt No.818911, DD.No.001113 (TJSB Bank), Dated:31/12/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "A. K. Kulkarni".

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer - 2) Developer- M/s- Rajlaxmi Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार

विरार (पूर्व)

ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फॅक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/2609/2022-23

दिनांक: 13/12/2022.

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.



Sub:- Grant of "Final No Objection Certificate" for your Proposed Residential Building No.1 (Wing-A to D) (Stilt / Podium + 19th Floor) & CFC Building (Prayer Hall & Dormitory) (Gr + 1st / Gr + 3rd floor) on land bearing S.No.133, H.No.1 of Village-Bolinj & S.No.3, H.No.1 of Village:Dongre, Tal-Vasai, Dist-Palghar.

Ref:-

1. An application received by M/s- En Con Project Consultants, Dated:09/12/2022. (VP- 5370)
2. An application received by Developer M/s-Bachraj Developers, Dated:14/11/2022.
3. Work Completion certificate of M/s- En Con Project Consultants, Dated:09/12/2022.
4. Built up area certificate for M/s- En Con Project Consultants, Dated:09/12/2022.
5. This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/72/2015-16, Dated:26/02/2016.
6. This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/731/2018-19, Dated:06/10/2018.
7. This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/1074/2019-20, Dated:01/01/2019.
8. Certificate from License Agency M/s-Ceasex Fire Fighters, Dated:14/11/2022 (Form A).
9. Submitted License copy of Maharashtra Fire Services, Dated:21/10/2022.
10. AMC Certificate by Developer M/s-Bachraj Developers, Dated:14/11/2022
11. License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
12. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/12/2022.
13. Structure Stability Certificate for M/s-JW Consultants LLP, Dated:17/11/2022.
14. RDP issued by VVCMC/TP/RDP/VP-5370/143/2020-21, Dated:17/12/2020.
15. Submitted Electric Certificate M/s- Eshwari Electricals, Dated:08/11/2022
16. Submitted D. G. Set Test Certificate from M/s-Kirloskar Oil & Engineers Ltd, Dated:20/10/2022.
17. C.F.O. site visit Dated:13/12/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential Building No. 1 as (Wing- A to D (Stilt / Podium + 19th Floor) in 59.75mtrs Height & CFC Building (Prater Hall & Dormitory) Gr + 1st / Gr + 3rd floor) in 14.70mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Ceasex Fire Fighters, bearing License No. MFS-LA/RF-503 & MFS-LA/RD-483 and has submitted Certificate on 14/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-A to D – 35819.28sq.mtrs & CFC Building – 385.38sq.mtrs.

With reference to above on 13/12/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Bachraj Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 60 Nos.
- B) Fire Bucket with Bracket – 20 Nos.
- C) Hose Reel Hose has been installed in every floor – 79 Nos.
- D) Single Door Hose Box has been installed in Alternate floor – 53 Nos.
- E) Hydrant Main Pump (120 Hp) – 03 Nos.

- F) Jockey Pump (20 Hp) – 02 Nos.
- G) Booster Pump (10 Hp) – 05 Nos.
- H) Hydrant Valve – 93 Nos.
- I) Sprinkler System – 2461 Nos.
- J) Fire Alarm Panel – 05 Nos.
- K) Smoke Detector – 12 Nos.
- L) MCP – 83 Nos.
- M) Hooter – 83 Nos.
- N) Public Address System- 04 Nos.
- O) Siamese Connection at main gate – 01 Nos.

This certificate shall be treated **valid up to One Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Capitation & scrutiny Fees of Rs.2,40,000/- vide Receipt No.425477, DD. No. 024564 (Axis Bank), Dated: 05/02/2016 & Rs. 19,85,000/- vide Receipt No.635902, DD.No.845122 (Punjab National Bank), Dated:08/02/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer- 2) M/s-Bachraj Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

For ENCON
Arch Copy & T.P. Copy

मुख्य कार्यालय, विरार

विरार (पूर्व)

ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फॅक्स : ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र. : VVCMC/FIRE/HQ/2610/2022-23

दिनांक: 13/12/2022.

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.



Sub:- Grant of "Final No Objection Certificate" for your Proposed Industrial / Commercial Building on land bearing S.No.5 of Village- Sativali, Tal-Vasai, Dist-Palghar.

Ref:- 1) An application received by M/s- En Con Project Consultants, Dated:08/12/2022. (VP-6085)

2) An application received by Developer M/s-Arihant Creation, Dated:08/12/2022.

3) Work Completion certificate of M/s- En Con Project Consultants, Dated:08/12/2022.

4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1138/2020-21, Dated:31/03/2021.

5) Built up area certificate for M/s- En Con Project Consultants, Dated:08/12/2022.

6) Certificate from License Agency M/s- Ronak Fire Industries, Dated:03/12/2022 (Form A).

7) Submitted License copy of Maharashtra Fire Services, Dated:06/02/2022.

8) AMC Certificate by Developer M/s-Arihant Creation, Dated:08/12/2022

9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.

10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/12/2022.

11) Structure Stability Certificate for M/s-S.S & Associates, Dated:30/06/2022.

12) RDP issued by VVCMC/TP/RDP/VP-6085/92/2021-22, Dated:30/04/2021.

13) Submitted Electric Certificate M/s- Walvadevi Electric Works, Dated:24/11/2022

14) C.F.O. site visit Dated:17/12/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Industrial / Commercial Building as (Basement + Ground floor + 3 upper floor) in 21.70mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Ronak Fire Industries, bearing License No. MFS-LA/RF-69, MFS/LA/RD-59 and has submitted Certificate on 03/12/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 8695.35sq.mtrs.

With reference to above on 17/12/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Arihant Creation" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 22 Nos.
- B) Fire Bucket – 02 Nos.
- C) Hose Reel Hose has been installed in every floor – 08 Nos.
- D) Hose Box has been installed in Alternate floor – 13 Nos.
- E) Main Pump (2400 Lpm) – 01 Nos.
- F) Sprinkler Pump (2400 Lpm) – 01 Nos.
- G) Jockey Pump (180 Lpm) – 01 Nos.
- H) Stand By Pump (2400 Lpm) – 01 Nos.
- I) Booster Pump (900 Lpm) – 01 Nos.
- J) Hydrant Valve – 13 Nos.
- K) Main Control Panel – 01 Nos.
- L) Sprinkler – 700 Nos.
- M) MCP – 10 Nos.
- N) Hooter – 10 Nos.

This certificate shall be treated **valid up to One Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.6,00,000/- vide Receipt No.727120, DD.No.591577; Rs.4,00,000/- vide Receipt No.727121, DD.No.591576 (Dena Bank), Dated:04/01/2018 & Rs.5,00,000/- vide Receipt No.895448, Book No.8955, DD.No.291583 (Bank of Baroda).

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer- 2) M/s-Arihant Creation

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

*For
ENCOM*

C/S


मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/2611/2022-23
दिनांक: 13/12/2022

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Sanat Mehta & Associates,
Rameshwar Tower,
A - 103, Shimpoli Road,
Next to Gokhale School,
Borivali (W), Mumbai-400 092.



Sub:- Grant of "Final No Objection Certificate" for your Proposed Residential Building No. 8 in Sector - I on land bearing S.No.277, H.No.2 out of larger layout of Group Housing Scheme of Village- Gokhiware, Tal-Vasai, Dist-Palghar.

Ref:- 1) An application received by M/s-Sanat Mehta & Associates, Dated:26/11/2022. (VP- 0329, 0815 & 0509)

2) An application received by Developer M/s-Nicon Infra LLP, Dated:26/11/2022.

3) Work Completion certificate of M/s-Sanat Mehta & Associates, Dated:26/11/2022.

4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/908/2020-21, Dated:10/02/2021

5) Built up area certificate for M/s-Sanat Mehta & Associates, Dated:26/11/2022.

6) Certificate from License Agency M/s-Vision Fire & Safety Engineering, Dated:15/11/2022. (Form A)

7) Submitted License copy of Maharashtra Fire Services, Dated:04/10/2022.

8) AMC Certificate by Developer M/s-Nicon Infra LLP, Dated:29/11/2022

9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.

10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/12/2022.

11) Structure Stability Certificate for Mr.Hiren M. Tanna, Dated:24/11/2022.

12) RDP issued by VVCMC/TP/RDP/VP-0329, 0815 & 0509/241/2022-23, Dated:29/06/2022.

13) Submitted Electric Certificate M/s-Jay Vagheshvari Electricals, Dated:28/11/2022

14) Submitted D.G.Set Test certificate of M/s-Koel Care, Dated:29/01/2020

15) C.F.O. site visit Dated:13/12/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential Building No. 8 (Wing- A & B) as (Stilt floor + 14 upper floor) in 43.85mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering bearing License No. MFS-LA/RF-491, MFS/LA/RD-473 and has submitted Certificate on 15/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-A - 3899.37sq.mtrs & Wing-B - 3899.37sq.mtrs.

With reference to above on 13/12/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Nicon Infra LLP" following Fire Fighting arrangements provided were found in satisfactory working condition.

- Portable Fire Extinguishers has been installed (06 Kg) - 32 Nos.
- Fire Bucket - 04 Nos.
- Hose Reel Hose has been installed in every floor - 28 Nos.
- Hose Box has been installed in Alternate floor - 18 Nos.
- Main Pump - 03 Nos.
- Jockey Pump - 02 Nos.
- Booster Pump - 02 Nos.
- Hydrant Valve - 32 Nos.
- Main Control Panel - 01 Nos.
- Smoke Detector - 06 Nos.
- Combine Mcp & Hooter - 28 Nos.
- Fire Alarm Control Panel - 02 Nos.



This certificate shall be treated **valid up to One Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.4,45,000/- vide Receipt No.470243, DD.No.661092 (Bank of Baroda), Dated:09/02/2017 for Wing-A & Rs.4,45,000/- vide Receipt No.470244, DD.No.661091 (Bank of Baroda), Dated:09/02/2017 for Wing-B.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer- 2) M/s-Nicon Infra LLP.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/2681/2022-23
दिनांक: 28/12/2022.

FIRE & EMERGENCY DEPARTMENT



To,
M/s-En Con Project Consultants,
G-7, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- Grant of "Part Final No Objection Certificate" for your Proposed Residential Cum Commercial Building No. 2 (Wing-A & B) (Basement + Ground + 1st Floor) on land bearing S.No.395, H.No.2/3, S.No.396, H.No.1/2, 1/1/1 & 2/1/1 (Old), S.No.395/2/3/A, 395/2/3/B, 396/1/2/A, 396/1/2/B, 396/2/1/1/A, 396/2/1/1/B, 396/2/1/1/C, 396B/1, 396B/2, 396B/3, 396B/4, 396/1/1/1/2, 396/1/1/1/3 (New) of Village- Virar, Tal-Vasai, Dist-Palghar.

- Ref:- 1) An application received by M/s- En Con Project Consultants, Dated:20/12/2022. (VP-0136)
- 2) An application received by Developer Mr.Hemant Ramesh Mhatre, Dated:20/12/2022.
 - 3) Work Completion certificate of M/s- En Con Project Consultants, Dated:20/12/2022.
 - 4) Built up area certificate for M/s- En Con Project Consultants, Dated:20/12/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1055/2016-17, Dated:24/03/2017.
 - 6) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/319/2019-20, Dated:11/07/2019.
 - 7) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/592/2022-23, Dated:30/06/2022.
 - 8) Certificate from License Agency M/s-Sadanand Fire Controls, Dated:28/11/2022 (Form A).
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:11/06/2022.
 - 10) AMC Certificate by Developer Mr.Hemant Ramesh Mhatre, Dated:03/12/2022
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/12/2022.
 - 13) Structure Stability Certificate for M/s-JW Consultants LLP, Dated:05/12/2022.
 - 14) RDP issued by VVCMC/TP/RDP/VP-0136/641/2021-22, Dated:09/12/2021.
 - 15) Submitted Electric Certificate M/s- Maharashtra Electricals, Dated:15/11/2022
 - 16) Submitted D. G. Set Test Certificate from M/s-Stamford, Dated:Nil.
 - 17) C.F.O. site visit Dated:28/12/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential Cum Commercial Building No. 2 as Wing- A & B (Basement + Ground floor + 1st floor)** in 8.70mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sadanand Fire Controls , bearing License No. MFS-LA/RF-302 and has submitted Certificate on 28/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 4337.09sq.mtrs.

With reference to above on 28/12/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr.Hemant Ramesh Mhatre" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 08 Nos.
- B) Fire Bucket with Sand – 06 Nos.
- C) Hose Reel Hose has been installed in every floor – 01 Nos.
- D) Hose Box has been installed in Alternate floor – 06 Nos.
- E) Hydrant Main Pump (50 Hp) – 01 Nos.
- F) Sprinkler Main Pump (50 Hp) – 01 Nos.
- G) Hydrant Jockey Pump (7.5 Hp) – 01 Nos.
- H) Sprinkler Jockey Pump (7.5 Hp) – 01 Nos.

- I) Siamese Connection at main gate – 01 Nos.
J) Sprinkler Bulbs – 225 Nos.

This certificate shall be treated **valid up to One Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Capitation & scrutiny Fees of Rs.4,20,000/- & Rs.1,20,000/- vide Receipt No.499071, 470293, DD. No. 007468, 021062, Dated: 19/12/2016, 24/03/2017; 6,50,000/- vide Receipt No.818227, DD.No.794411, Dated:05/07/2019 & Rs. 7,94,000/- vide Receipt No.31039, Book No.811, DD.No.018498 (ICICI Bank), Dated:23/06/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



[Signature]
CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer- 2) Mr.Hemant Ramesh Mhatre

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

[Signature]
ENCLOSURE
Arch Copy & T.P. Copy

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
2686
जा.क्र. : VVCMC/FIRE/HQ/ 12022-23
दिनांक: 29/12/2022.

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.



Sub:- Grant of "Final No Objection Certificate" for your Proposed Residential with Shopline Building No.3 located on land bearing S.No.346, H.No.1 to 8, 10 to 22, 24 to 29. S.No.355, H.No.6 & 7 of Village- Bolinj, Tal-Vasai, Dist-Palghar.

- Ref:- 1) An application received by M/s- En Con Project Consultants, Dated:16/12/2022. (VP- 0663)
- 2) An application received by Developer M/s-Prieska Real Estates Pvt Ltd, Dated:26/11/2022.
 - 3) Work Completion certificate of M/s- En Con Project Consultants, Dated:16/12/2022.
 - 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2191/2019-20, Dated:03/02/2020
 - 5) Built up area certificate for M/s- En Con Project Consultants, Dated:16/12/2022.
 - 6) Certificate from License Agency M/s- Ceasex Fire Fighters, Dated:25/11/2022 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:21/10/2022.
 - 8) AMC Certificate by Developer M/s-Arihant Cre M/s-Prieska Real Estates Pvt Ltd, Dated:26/11/2022
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:25/11/2022.
 - 11) Structure Stability Certificate for M/s-Nimisha Structural Design Academy, Dated:Nil.
 - 12) RDP issued by VVCMC/TP/RDP/VP-0663/233/2020-21, Dated:26/03/2021.
 - 13) Submitted Electric Certificate M/s- Power Works, Dated:26/11/2022
 - 14) C.F.O. site visit Dated:25/11/2022.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your **Residential with Shopline Building No. 3 (Wing- A & B) as (Stilt / Ground floor + 12 upper floor) in 40.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Ceasex Fire Fighters bearing License No. MFS-LA/RF-503, MFS/LA/RD-483 and has submitted Certificate on 25/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 8194.32sq.mtrs.

With reference to above on 25/11/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Prieska Real Estates Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed – 24 Nos.
- B) Fire Bucket – 10 Nos.
- C) Hose Reel Hose has been installed in every floor – 24 Nos.
- D) Hose Box has been installed in Alternate floor – 05 Nos.
- E) Main Pump (75 Hp) – 02 Nos.
- F) Jockey Pump (15 Hp) – 02 Nos.
- G) Booster Pump (10 Hp) – 02 Nos.
- H) Hydrant Valve – 29 Nos.
- I) Main Control Panel – 01 Nos.
- J) Sprinkler – 150 Nos.
- K) Combine Mcp Hooter – 24 Nos.
- L) Smoke Detector – 04 Nos.

This certificate shall be treated **valid up to One Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.10,50,000/- vide Receipt No.818978, DD.No.010044 (ICICI Bank), Dated:31/01/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**


Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
Developer- 2) M/s-Prieska Real Estate Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


ENCON
Arch. Copy & T.P. Copy



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/3295/2022-23

DATE: 03/02/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Industrial Cum Commercial Building on land bearing S.No.40, H.No.1B/3 & H.No.5 of Village:Gokhiware, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by M/s-Prithvi Arch Consultants, Dated:21/12/2022 (VP-6277)

2) An application received by Developer M/s-Rajprabha Developers pvt Ltd, Dated:29/11/2022.

3) Work Completion certificate of M/s-Prithvi Arch Consultants, Dated:21/12/2022.

4) Built up area certificate for M/s-Prithvi Arch Consultants, Dated:21/12/2022.

5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1813/2021 -22, Dated:22/09/2021.

6) Certificate from License Agency M/s-Vision Fire & Safety Engineering, Dated:15/11/2022. (Form A)

7) Submitted License copy of Maharashtra Fire Services, Dated:04/10/2022

8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.

9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/01/2023.

10) Structure Stability Certificate for M/s-S.S & Associates, Dated:17/11/2022.

11) RDP issued by VVCMC/TP/RDP/VP-6277/59/2022-23, Dated:17/06/2022.

12) Submitted Electric Certificate M/s-Choice Electricals, Dated:27/12/2022.

13) Submitted D.G. Set Certificate for M/s- M/s-Kirloskar Brothers Ltd, Dated:Nil.

14) C.F.O. site visit Dated:03/01/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Industrial Cum Commercial Building as (Stilt / Ground floor + 3rd floor) in 20.05mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-491, MFS-LA/RD-473 has submitted Certificate on 15/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9359.95sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **03/01/2023** for inspection from the point of view of fire prevention & protection provided by "M/s-Rajprabha Developers pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 28 Nos.
- B) Fire Bucket – 06 Nos.
- C) Hose Reel Hose has been installed in every floor – 12 Nos.
- D) Single Door Hose Box – 12 Nos.
- E) Double Door Hose Box – 05 Nos.
- F) Main Pump – 03 Nos.
- G) Jockey Pump – 02 Nos.
- H) Booster Pump – 02 Nos.
- I) Control Panel for Pump – 01 Nos.
- J) Single Hydrant Valve – 17 Nos.
- K) Fire Alarm Control Panel - 01 Nos.
- L) MCP – 12 Nos.
- M) Hooter – 12 Nos.
- N) Sprinkler – 917 Nos.
- O) Smoke Detector – 182 Nos.

Recd
[Signature]

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire Cess Fees of Rs.10.00,000/- vide Receipt No.895467, Book No. 8955, DD.No.008414 (IDBI Bank), Dated:21/05/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Rajprabha Developers Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/32-98/2022-23

DATE: 13/02/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Himesh Gupta & Associates,
103, Shubham Heritage,
Behind Gopal Bldg,
Off Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Industrial Building (Unit No.6) on land bearing New S.No.21, H.No.B/3/Plot A (Old S.No.21, H.No.5, Plot A) of Village:Bilalpada, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Himesh Gupta & Associates, Dated:26/08/2022 (VP-5446)
2) An application received by Developer Mr.Mukesh G. Agarwal, Dated:06/12/2022.
3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:26/08/2022.
4) Built up area certificate for M/s-Himesh Gupta & Associates, Dated:26/08/2022.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/634/2017-18, Dated:17/10/2017.
6) Certificate from License Agency M/s-Vision Fire & Safety Engineering, Dated:29/11/2022. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:04/10/2022
8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:30/01/2023.
9) AMC Certificate by Mr.Mukesh G. Agarwal, Dated:06/12/2022.
10) Structure Stability Certificate for M/s-Seemu Consultancy, Dated:28/11/2022.
11) CC issued by VVCMC/TP/CC/VP-5446/12/2019-20, Dated:22/05/2019.
12) Submitted Electric Certificate M/s-Shree Hari Electricals, Dated:28/11/2022.
13) Submitted D.G. Set Certificate for M/s-Shree Hari Electricals, Dated:28/11/2022.
14) C.F.O. site visit Dated:30/01/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Industrial Building (Unit No. 6) as Ground floor in 5.60mtrs Height at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-491, MFS-LA/RD-473 has submitted Certificate on 29/11/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 783.53sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 30/01/2023 for inspection from the point of view of fire prevention & protection provided by "Mr.Mukesh G. Agarwal" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) Fire Bucket – 02 Nos.
- C) Single Door Hose Box – 02 Nos.
- D) Booster Pump (10Hp) – 01 Nos.
- E) Single Hydrant Valve – 02 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.


Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire Cess Fees of Rs.80,000/- vide Receipt No.590389, DD.No.472744 (The Vijaya Bank), Dated:14/09/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Mukesh G. Agarwal.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/3306/2022-23

DATE: 14/02/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Architect Umesh Kekre,
Shop No.2, Kishor kunj Apartment,
Shastri Nagar,Nr. IIHM College
Ambadi Road, Vasai (W),
Tal-Vasai, Dist.-Palghar.



Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No. 1 on land bearing S.No.7 to 11, 15 to 17, 19 to 25, Plot No.12 & 13 of Village:More, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Architect Umesh Kekre, Dated:06/02/2023 (VP-5673)
2) An application received by Developer M/s-Shree Balaji Enterprises, Dated:28/11/2022.
3) Work Completion certificate of M/s-Architect Umesh Kekre, Dated:06/02/2023.
4) Built up area certificate for M/s-Architect Umesh Kekre, Dated:06/02/2023.
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/724/2019-20, Dated:14/10/2019.
6) Certificate from License Agency M/s-Om Surya Enterprises, Dated:19/01/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:19/02/2022.
8) AMC Certificate by M/s-Shree Balaji Enterprises, Dated:01/01/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:29/09/2022.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:18/01/2023.
11) Structure Stability Certificate for M/s-Jay Shree Krishna, Dated:19/01/2023.
12) RDP issued by VVCMC/TP/RDP/VP-5673/407/2021-22, Dated:30/08/2021.
13) Submitted Electric Certificate M/s-Sagar Enterprises, Dated:16/01/2023.
14) Submitted Diesel generator test certificate for M/s-Stamford, Dated:14/03/2022.
15) C.F.O. site visit Dated:18/01/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Cum Commercial Building No. 1 (Wing-A) as (Stilt / Ground floor + 12th floor) in 38.55mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Om Surya Enterprises, bearing License No. MFS-LA/RD-92, MFS-LA/RF-93 has submitted Certificate on 19/01/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3705.51sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 18/01/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Shree Balaji Enterprises" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 14 Nos.
- Hose Reel Hose has been installed in every floor – 12 Nos.
- Hose Box has been installed in Alternate floor – 04 Nos.
- Main Hydrant Pump (60 Hp) – 01 Nos.
- Sprinkler Pump (30 Hp) – 01 Nos.
- Jockey Pump (7.5 Hp)– 02 Nos.
- Booster Pump (5 Hp) – 01 Nos.
- Hydrant Valve – 16 Nos.
- Fire Alarm Control Panel – 01 Nos.
- MCP Cum Hooter – 12 Nos.
- Fire Alarm Panel – 01 Nos.
- Sprinkler System – 36 Nos.
- Sign Edges – 14 Nos.

Rec 14 Feb 23
Mr. D. J.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.5,25,000/-, vide Receipt No.818545, DD.No.002480 (Bassein Catholic Bank), Dated:09/10/2019 & 5,25,000/- vide Receipt No.818544, DD.No.818544 (Bassein Catholic Bank), Dated:09/10/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Shree Balaji Enterprises.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४८५४/२०२२
दिनांक : २६/०१/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building Type- 1A (Wing-C), Type-1B (Wing-D) in Avenue "L1" on land bearing New S.No.5, 5B, 5D, 5F, 5G of Village: Dongre, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1513/2021-22, Dated: 14/01/2022.
2) An application received by M/s- Shah Gattani Consultants, Dated: 03/01/2022.
3) An application received by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:24/01/2022
4) Work Completion certificate of M/s- Shah Gattani Consultants, Dated:03/01/2022
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/854/2018-19, Dated: 24/10/2018.
6) Gross Built up area certificate for M/s- Shah Gattani Consultants, Dated:03/01/2022.
7) Certificate from License Agency M/s- Alpha National Fire Safety Services Pvt Ltd, Dated: 19/01/2022 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:26/05/2021.
9) AMC Certificate by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:24/01/2022.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/01/2022.
11) Structure Stability Certificate for M/s-JW Consultants LLP, Dated:15/11/2021
12) RDP issued by VVCMC/TP/RDP/VP-0453/221/2019-20, Dated:27/11/2019.
13) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
14) Submitted Electric Certificate M/s- Supernova Engineers Ltd, Dated:05/01/2022.
15) Diesel Engine Test Certificate of M/s-Supernova Engineers Ltd, Dated:05/01/2022
16) C.F.O. site visit Dated:24/01/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Residential Building Type-1A (Wing-C) & Type-1B (Wing-D) Ground floor to 14th floor in 44.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Alpha National Fire Safety Services Pvt Ltd, bearing License No. MFS-LA/RF-250 & MFS-LA/RD-229 and has submitted Certificate on 19/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring 9695.70sq.mtrs.

With reference to above on **24/01/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s- Keystone Infrastructure Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers (6 Kg - A.B.C. Type) – 06 Nos.
- B) Sand Bucket – 12 Nos.
- C) Hose Reel Hose has been installed – 15 Nos.
- D) Smoke Detector has been installed – 52 Nos.
- E) Heat Detector has been installed – 04 Nos.
- F) MCP – 30 Nos.
- G) Hooter – 30 Nos.
- H) Booster Pump (900 lpm) – 01 Nos.
- I) Hydrant Valve – 16 Nos.
- J) Hose Box – 08 Nos
- K) Pendent Sprinkler – 38 Nos.
- L) Concealed Sprinkler – 02 Nos
- M) Side Wall Sprinkler – 33 Nos.
- N) Fire Alarm Panel – 01 Nos

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 53,95,000/- vide Receipt No.705559, DD.No.006246 (HDFC Bank), Dated- 12/10/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Shah Gattani Consultants
2) Developer- M/s- Keystone Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर- ४०१ ३०५



दुरध्वनी : ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फैक्स : ०२५०-२५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जा.क्र.:व.वि.श.म./अग्नि/मुका/४८५७ /२०२१-२२.

दिनांक : २९ / ०९ / २०२२

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Scrubex Corporation,
Ankit II Industrial Estate, Plot no.4,
Dhanya Sativali nagari, near Regal Industrial, Sativali,
Vasai (E), Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Industrial Building Plot no.4 & Plot no.5 (Gr.+2 floor) located on land bearing S.no.49,H.no.2/1 B+2 /2 A (Pt.),S.no .49, H.no. 2/1 B+2/2 A (Pt.),S.no.50,H.no.(pt.) & S.no.50,H.no.2/2 of Village –Sativali, Tal- Vasai, Dist- Palghar.

Ref: - 1. An application received by M/s- Scrubex Corporation, Dated: 31/03/2021
2. Certificate from License Agency M/s-Ray Fire Protection Services, Dated:18/03/2021(Form B).
3. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated 19/03/2021
4. Submitted Renewal Final No Objection Certificate No.VVCMC/FIRE/HQ/2389/Dated:24/03/2020
5. Submitted License copy of Maharashtra Fire Services, Dated:05/05/2019
6. Electric Certificate received from M/s.Electrical inspector, Dated:15/07/2000
7. C.F.O.Site Visit on Dated : 23/03/2021

With reference to Sr.No.1 above, this office is in received of your application for your "M/s-Scrubex Corporation" at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Ray Fire Protection Services , bearing License No. MFS-LA/2019RF-59, MFS-LA/2019/RD-64 and has submitted Certificate On 02/05/2019 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/03/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 20,000/- vide Receipt No. 895324 Dated: 02/04/2021, DD.no.474836 Issued by Kotak Mahindra Bank, renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर- ४०१ ३०५



दुरध्वनी : ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फैक्स: ०२५०-२५२५१०७

ई-मेल: vasavirarcorporation@yahoo.com

जा.क्र.: व.वि.श.म./अग्नि/मुका/४८६२/२०२२.

दिनांक: १७/०२/२०२२.

FIRE & EMERGENCY DEPARTMENT

To,
M/s. The Capital Mall,
Achole developers private limited (ADPL)
New Link Road, Achole Nallasopra (East)
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of "Final No Objection Certificate" of The Capital, S.no. 49,50, 21,52, 53,54, 55, 56,77 & S.no.57H.no. 1,Village-Achole , Tal- Vasai, Dist- Palghar.

Ref: - 1. An application received by M/s- The Capital Mall, Dated: 29/01/2022.

2. Certificate from License Agency M/s- TFPC Infra LLP., Dated: 16/12/2021 (Form B).

3. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated 28/01/2022

4. Submitted Renewal Final No Objection Certificate No.VVCMC/FIRE/HQ/7805/2021 Dated:14/1/2021.

5. Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021

6. Electric Certificate received from M/s. Electrical inspector, Dated:18/8/2021

7. C.F.O. Site Visit on Dated : 07/02/2022

With reference to Sr.No.1 above, this office is in received of your application for your "The Capital " at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP., bearing License No. MFS-LA/RF-384, and has submitted Certificate On 15/10/2021 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/12/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 4,80,408/- vide Receipt No. 30351 Dated: 10/02/2022, Issued by Standard Chartand Bank, renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect:-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Signature
7045883394

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/४८८०/२०२२
दिनांक : ०९/०२/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of LNG Station on S.No.13/1, 21/2 & 3, 22/1 of Village: Rajawali, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1427/2021-22, Dated: 21/12/2021.
2) An application received by M/s- Sanat Mehta & Associates, Dated: 10/12/2021.
3) An application received by Developer M/s-Gujrat Gas Ltd, Dated:19/01/2022
4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:10/12/2021
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/870/2021-22, Dated:29/07/2021.
6) Gross Built up area certificate for M/s- Sanat Mehta & Associates, Dated:10/12/2021.
7) Certificate from License Agency M/s- Safe Pro Fire Services Pvt Ltd, Dated:23/10/2021 (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:15/01/2021.
9) AMC Certificate by Developer M/s- Gujrat Gas Ltd, Dated:12/01/2022.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/01/2022.
11) CC issued by VVCMC/TP/CC/VP-PMAY-1/246/2019-20, Dated:25/10/2019.
12) Submitted Electric Certificate M/s- Tare Electrical Contractor, Dated:14/10/2018.
13) Diesel Engine Test Certificate of M/s-Supernova Engineers Ltd, Dated:12/07/2021
14) C.F.O. site visit Dated:12/01/2022

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **LNG Station (Ground floor) in 5.75mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sage Pro Fire Services Pvt Ltd, bearing License No. MFS-LA/2021/RF-40** and has submitted Certificate on 23/10/2021 in **"Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring 56.08sq.mtrs.

With reference to above on **12/01/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"M/s-Gujrat Gas Ltd"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers (5 Kg - A.B.C. Type) – 06 Nos.
- B) Portable Fire Extinguishers (9 Kg - D.C.B. Type) – 06 Nos.
- C) Foam Extinguishers (9 Ltr) – 06 Nos.
- D) Hose Reel Hose has been installed – 03 Nos.
- E) Sand Bucket – 12 Nos.
- F) Hose Box has been installed – 03 Nos.
- G) Electric Pump (900 lpm) – 01 Nos.
- H) Jockey Pump – 01 Nos.
- I) Diesel Pump – (900 lpm) – 01 Nos.



This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Received by
Safay
01/02/22
9833852171

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 80,000/- vide Receipt No.895553, Book No.8956, DD.No.000050 (HDFC Bank), Dated- 28/07/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**


Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Sanat Mehta & Associates
2) Developer- M/s- Gujrat Gas Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०९
ई-मेल : vasavirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/१८००/२०२२
दिनांक : ०३/०२/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Commercial Building located on land bearing S.No.1A, H.No.1/1/10/2/1, 1/1/10/2/2, 1/1/10/3/1, 1/1/10/3/2, 1/1/10/6/1, 1/1/10/7/1 of Village: Dongre, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1423/2021-22, Dated: 21/12/2021.

- 2) An application received by M/s- En Con Project Consultants, Dated: 20/12/2021
- 3) An application received by Developer Mr. Anil Baban Patil, Dated: 20/12/2021
- 4) Work Completion certificate of M/s- En Con Project Consultants, Dated: 20/12/2021
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1019/2018-19, Dated: 10/12/2021.
- 6) Gross Built up area certificate for M/s- En Con Project Consultants, Dated: 20/12/2021.
- 7) Certificate from License Agency M/s- Bright Infra Systems Pvt Ltd, Dated: 30/07/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated: 04/09/2021.
- 9) AMC Certificate by Developer Mr. Anil Baban Patil, Dated: 20/12/2021
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 21/01/2022.
- 11) Structure Stability Certificate for M/s- S.S & Associates, Dated: 21/12/2021.
- 12) RDP issued by VVCMC/TP/RDP/VP-0510/230/2018-19, Dated: 18/02/2019.
- 13) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated: 21/10/2021.
- 14) Diesel Engine Test Certificate of M/s- Kirloskar Brothers Ltd, Dated: 29/12/2021
- 15) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 16) C.F.O. site visit Dated: 21/01/2022.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your **Commercial Building No.1 (Wing-C) (Gr + 2 floor) in 13.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Bright Infra System Pvt Ltd, bearing License No. MFS-LA/2020/RF-166, MFS-LA/2020/RD-148** and has submitted Certificate on 30/07/2021 in **"Form A"** Prescribed in **Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring 997.14sq.mtrs.

With reference to above on **22/01/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Mr. Anil Baban Patil"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places – 06 Nos.
- B) Hose Reel Hose has been installed in every floor – 02 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Courtyard Hydrant has been installed in the building & prominent places. – 02 Nos.
- E) Main Pump on under ground water storage tank (1620lpm) – 01 Nos.
- F) Stand by Pump under ground water storage tank (1620lpm) – 01 Nos.
- G) Booster Pump Over head water storage tank (5hp) – 01 Nos.
- H) Automatic Sprinkler System – 81 Nos.
- I) Smoke Detector each Floor – 27 Nos.
- J) Manual Call Point – 03 Nos.
- K) Hooter – 03 Nos.
- L) Fire Alarm System – 01 Nos.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Received
07/02/2022
10/02/22

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 80,000/- vide Receipt No.425458, DD.No.110766,, Dated- 01/02/2016 of Vasai Vikas Sahakari Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, positioned above the official title.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- Mr. Anil Baban Patil

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/अग्नि/मुका/१८३६/२०२२
दिनांक : १०/०२/२०२२

तमिळाली

लिपिक (न.र.)

विरार शहर महानगरपालिका

०२/०५/२०२२

To:
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

FIRE & EMERGENCY DEPARTMENT



Sub:- **"Final No Objection Certificate" of Local Resource Industry Building / Automobile Shops & Godowns (Unit No.14) located on land bearing S.No.69, H.No.1(Pt), S.No.71,H.No.Pt & S.No.213, H.No.2(P) & S.No.72, + 75/1 + 75/2 + 77/1(P) + 77/2 + 65 + 69/1 + 70 + 71 (P) + 78 + 213/2 (P) of Village: Pelhar, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1431/2021-22, Dated: 22/12/2021.
- 2) An application received by M/s- Himesh Gupta & Associates, Dated: 18/10/2021.
 - 3) An application received by Developer Mr. Pradip Keshav Savla, Dated:20/12/2021
 - 4) Work Completion certificate of M/s- Himesh Gupta & Associates, Dated:18/10/2021
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/59/2018-19, Dated:16/04/2019.
 - 6) Gross Built up area certificate for M/s- Himesh Gupta & Associates, Dated:18/10/2021.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:23/12/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) AMC Certificate by Developer Mr. Pradip Keshav Savla, Dated:20/12/2021.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/01/2022.
 - 11) Structure Stability Certificate for Mr. Vinay Kania, Dated:23/12/2021.
 - 12) CC issued by VVCMC/TP/CC/VP-0898 & 5224/134/2019-20, Dated:25/09/2019.
 - 13) Submitted Electric Certificate M/s- Jignesh Vidyut Service, Dated: 23/12/2021.
 - 14) Diesel Engine Test Certificate of M/s-Power Engineering Pvt Ltd, Dated: 09/12/2020
 - 15) C.F.O. site visit Dated: 07/01/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Local Resource Based Industry Building / Automobile Shops & Godowns (Unit No.14) (Stilt / Gr + 2 floor) in 12.55mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384, MFS-LA/RD-359 and has submitted Certificate on 23/12/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring 1692.73sq.mtrs.

With reference to above on 07/01/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr. Pradip Keshav Savla" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor & prominent places – 02 Nos.
- B) Hose Reel Hose has been installed in every floor – 02 Nos.
- C) Hose Box has been installed in Alternate floor – 03 Nos.
- D) Booster Pump on over head water storage tank (5 hp) – 01 Nos.
- E) Fire Alarm System – 01 Nos.
- F) MCP Hooter – 03 Nos.
- G) Smoke Detector – 02 Nos.

This certificate shall be treated **valid up to 31/03/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Received Copy
Amol

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has all ready paid the Rs. 80,000/- vide Receipt No.761305, DD.No.195005,, Dated- 28/03/2019 & Rs. 80,000/- vide Receipt No. 779239, DD. No. 012267, Dated: 10/04/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Himesh Gupta & Associates
2) Developer- Mr. Pradip Keshav Savla

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.

प्रतमिळाली

लिपिक (न.र.)

वि. विरार शहर महानगरपालिका
दि. १२/०४/२०२२



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./आग्नि/मुका/४२३०/२०२२

दिनांक : १०/०२/२०२२

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- **"Final No Objection Certificate" of Residential with Shopline Building, in Sector-II on S.No.63, H.No.2/1, S.No.64, H.No.3, out of larger layout on land bearing S.No.62, H.No.1, 2/Pt. 3, 4, 5, 7, S.No.63, H.No.2/1, 2/2, 3, S.No.64, H.No.2, 3, S.No.65, S.No.68, H.No.1, 2 & 3, S.No.69, H.No.1, 2, 3, 4, 5, S.No.72, S.No.73, S.No.75, H.No.1, 2/1, 2/2, 3, 4, 5, 7, S.No.76, S.No.77, H.No.2, 3, 4, 5, 6, 7, S.No.81, H.No.2, 4, 5, 6, 8, 9, 10, 12, 13, 14, 15, 16, 17, 18, 19, 21, 22, 23, S.No.82, H.No.3/3, 5, 7, 8/1, 9, 10, S.No.83, H.No.1/Pt. S.No.84, H.No.3, 4, 6/Pt. 7/Pt. 10, S.No.85, H.No.3B, 6, 9, 10 & 12, S.No.87, H.No.1A, 1B, 1C, 2A, 2B, 3 & 7, S.No.88, H.No.1A, 1B, 2A & 2B, S.No.89, H.No.1, 2 & 4, S.No.271, S.No.272, S.No.273, S.No.274, H.No.1, 2, 3, S.No.275, H.No.1, 2, S.No.276, H.No.1, 2, 3, 4, 5, S.No.277, H.No.2 & 3, S.No.278, H.No.1, 2, 3, 4, S.No.279, H.No.1, S.No.280, H.No.1, 2, 3, 4, 5 of Village: Gokhiware, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/137/2021-22, Dated: 27/04/2021.
- 2) An application received by M/s- Sanat Mehta & Associates, Dated:22/04/2021 & 07/02/2022.
 - 3) An application received by M/s- Sai Sangam Developer, Dated: 05/02/2022.
 - 4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:22/04/2021 & 07/02/2022.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1054/2016-17, Dated: 24/03/2017.
 - 6) Gross built up area certificate for M/s- Sanat Mehta & Associates, Dated:22/04/2021.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated: 04/02/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated: 15/10/2021.
 - 9) AMC Certificate by M/s- Sai Sangam Developer, Dated: 02/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.Dated : 15/10/2021.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/11/2021.
 - 12) Structure Stability Certificate for M/s- Jay Shree Krishna, Dated:22/04/2021 & 06/02/2022.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0329, 0815 & 0509/363/2021-22, Dated:12/08/2021.
 - 14) Submitted Electric Certificate M/s- Vishal Electricals, Dated: 14/04/2021
 - 15) Diesel Engine Test Certificate of M/s- Gangadhar, Dated: 22/03/2021.
 - 16) C.F.O. site visit Dated:16/11/2021.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Residential with Shopline Building No. 2 (Wing- A & B) as (Stilt / Gr + 9) in Sector No. II in 29.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS-LA/RD-359 and has submitted Certificate on 04/02/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 6401.04sq.mtrs.

With reference to above on **04/05/2021** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by " **Sai Sangam Developers**" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (4 kg) – 10 Nos.
- B) Hose Reel Hose has been installed in every floor – 18 Nos.
- C) Hose Box has been installed in Alternate floor – 05 Nos.
- D) MCP/Hooter – 20 Nos.
- E) Main Hydrant Pump (30 Hp) – 01 Nos.

Received by
10/02/2022

- F) Jockey Pump (5 Hp) – 01 Nos.
- G) Sprinkler Pump (15 Hp) – 01 Nos.
- H) Booster Pump near over head water storage tank.
- I) Diesel Generator Set

This certificate shall be treated **valid up to 31/12/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.4,20,000/- vide Receipt No. 470251, DD.No.022447, Dated: 17/02/2017 & Rs.1,79,000/-, vide Received No.30338, Book No. 304, DD.No.000240 (Bassein Catholic Bank), Dated: 03/02/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Sanat Mehta & Associates
2) Developer- M/s- Sai Sangam Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मूका/१६२२/२२
दिनांक : १०-०२-२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential with Shopline Building No. 5 on land bearing S.No.278A of Village: Nilemore, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1453/2021-22, Dated: 29/12/2021.
- 2) An application received by M/s- Sanat Mehta & Associates, Dated:22/12/2021.
 - 3) An application received by M/s- Akash Developer, Dated: 02/02/2022.
 - 4) Work Completion certificate of M/s- Sanat Mehta & Associates, Dated:22/12/2021.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/952/2017-18, Dated: 02/02/2018.
 - 6) Gross built up area certificate for M/s- Sanat Mehta & Associates, Dated:22/12/2021.
 - 7) Certificate from License Agency M/s- Shree FIREGUARD Co, Dated: 18/10/2021 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:03/11/2020.
 - 9) AMC Certificate by M/s- Akash Developer, Dated:02/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/02/2021.
 - 12) Structure Stability Certificate for M/s- Shilplekha Consultants, Dated:19/11/2021.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0041/268/2019-20, Dated:31/12/2019.
 - 14) Submitted Electric Certificate M/s- Sneha Enterprises, Dated: 18/11/2021
 - 15) Diesel Engine Test Certificate, Dated: 22/03/2021.
 - 16) C.F.O. site visit Dated:03/02/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Residential with Shopline Building No. 5 (Wing- A) as (Stilt / Gr + 12) in 38.40mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree FIREGUARD Co, bearing License No. MFS-LA/RF-270 & MFS-LA/RD-243 and has submitted Certificate on 18/10/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2242.59sq.mtrs.

With reference to above on 03/01/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Akash Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (4 kg) – 02 Nos.
- B) Hose Reel Hose has been installed in every floor – 12 Nos.
- C) Hose Box has been installed in Alternate floor – 02 Nos.
- D) MCP/Hooter – 12 Nos.
- E) Court Yard Hydrant – 02 Nos.
- F) Main Hydrant Pump (20 Hp) – 01 Nos.
- G) Jockey Pump (5 Hp) – 01 Nos.
- H) Booster Pump near over head water storage tank (5 Hp) 01 Nos.
- I) Manual Fire Alarm System – 01 Nos.
- J) Automatic Sprinkler System – 90 Nos.
- K) Diesel Generator Set



Received by
10/02/22

This certificate shall be treated **valid up to 31/12/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 2,90,000/- vide Receipt No. 351068, Book No. 20, DD. No. 008470 (HDFC Bank), Dated: 27/10/2015 & Rs. 50,000/- vide Receipt No. 609587, Book No. 6096, DD. No. 027628 (Bassein Catholic Bank), Dated: 02/02/2018

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**


Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- Sanat Mehta & Associates
2) Developer- M/s- Akash Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



016

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४२००/२०२२
दिनांक : १८/०२/२०२२



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building on plot bearing S.No.411A, H.No.2 (Old), S.No.411/C/1, C/2, C/3 & C/4 (New) of Village: Bolinj, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1597/2021-22, Dated:28/01/2022.

- 2) An application received by M/s- Khubi Design Studio, Dated:20/01/2022.
- 3) An application received by M/s- Avenue Supermarts Ltd, Dated:13/01/2022.
- 4) Work Completion certificate of M/s- Khubi Design Studio, Dated:20/01/2022.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/221/2019-20, Dated:17/06/2019.
- 6) Gross built up area certificate for M/s- Khubi Design Studio, Dated:20/01/2022.
- 7) Certificate from License Agency M/s- Advant Edge, Dated:14/01/2022 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:03/02/2021.
- 9) AMC Certificate by M/s- Avenue Supermarts Ltd, Dated:13/01/2022
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/02/2022.
- 12) Structure Stability Certificate for M/s- Epicons Consultants Pvt Ltd, Dated:06/01/2022.
- 13) RDP issued by VVCMC/TP/RDP/VP-5851/103/2019-20, Dated:23/09/2019.
- 14) Submitted Electric Certificate M/s- Rulka Electricals Pvt Ltd, Dated:19/01/2022
- 15) Diesel Engine Test Certificate M/s- Kirloskar Brothers Ltd, Dated:03/12/2021.
- 16) C.F.O. site visit Dated:07/02/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Commercial Building No. 8A (Old) A (New) as (Basement + Gr + 4) in 22.50mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Advant Edge**, bearing License No. MFS-LA2021/RF-99 and has submitted Certificate on 14/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 7023.08sq.mtrs.

With reference to above on 31/01/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "**Avenue Supermarts Limited**" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (6 kg) – 87 Nos.
- B) Co2 Type Fire Extinguishers has been installed (4.5 kg) – 28 Nos.
- C) Hose Reel Hose has been installed in every floor – 12 Nos.
- D) Hose Box has been installed in Alternate floor – 19 Nos.
- E) Manual Fire Alarm System – 01 Nos.
- F) Automatic Sprinkler System – 710 Nos.
- G) Diesel Generator Set

This certificate shall be treated valid up to 31/12/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 1,50,000/- vide Receipt No. 470165, Dated: 24/05/2016; Rs. 1,50,000/- vide Receipt No. 470166, Dated: 24/05/2016; Rs. 6,00,000/- vide Receipt No. 470167, Dated: 24/05/2016; Rs. 2,40,000/- vide Receipt No. 470168, Dated: 24/05/2016 & Rs. 13,50,000/- vide Receipt No. 635973, Dated: 05/03/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Khubi Design Studio

2) Developer- M/s- Avenue Supermarts Limited

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.


23/02/2022

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/४०००/२०२२
दिनांक : २८/०२/२०२२



FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building located on land bearing S.No.280A, H.No.1/1-Old (S.No.233, H.No.1/A-New), S.No.214, H.No.8/1-Old (S.No.232, H.No.8/A-New) of Village: Sandor, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1356/2021-22, Dated:08/12/2021
- 2) An application received by M/s- En Con Project Consultants, Dated:04/12/2021
 - 3) An application received by Developer Mr. Anil R. Goyal, Dated:14/12/2021.
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:04/12/2021.
 - 5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/669/2018-19, Dated:18/09/2018.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:04/12/2021.
 - 7) Certificate from License Agency M/s- Vision Fire & Safety Engineering, Dated:05/01/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:30/10/2021.
 - 9) AMC Certificate by Mr. Anil R. Goyal, Dated:14/12/2021
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:01/02/2022.
 - 12) Structure Stability Certificate for M/s- G.R. Consultants, Dated:08/12/2021.
 - 13) This office issued by No Objection Certificate No. VVCMC/FIRE/69/2011-12, Dated:15/07/2011
 - 14) RDP issued by VVCMC/TP/RDP/VP-0679/175/2020-21, Dated:14/01/2021
 - 15) Submitted Electric Certificate License No. 95940, Dated:14/12/2021
 - 16) Diesel Engine Test Certificate M/s- Ghatge Karkera Leypower, Dated:14/08/2012.
 - 17) C.F.O. site visit Dated:01/02/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your Commercial Building No. 1 (Restaurant / Guest House) (Gr + 4) in 19.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-389 & MFS-LA/RD-364 and has submitted Certificate on 05/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1555.74sq.mtrs.

With reference to above on 29/12/2021 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr. Anil R. Goyal" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (4 kg) – 04 Nos.
- B) Hose Reel Hose – 06 Nos.
- C) Hose Box has been installed in Alternate floor – 02 Nos.
- D) Hydrant Valve – 01 Nos.
- E) Sprinkler Systems – 10 Nos.
- F) Fire Alarm Control Panel- 01 Nos.
- G) Manual Call Point – 01 Nos.
- H) Hooter – 01 Nos.
- I) Smoke Detector – 06 Nos.
- J) Diesel Generator Set

Ther
ENCON

This certificate shall be treated valid up to 31/12/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 85,000/- vide Receipt No. 112186, DD. No. 027223 & Rs. 85,000/- vide Receipt No.112185, DD.No.027222, Dated: 21/06/2011 of Bassein Catholic Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION


Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- Mr. Anil R.Goyal

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com



जावक क्र. : व.वि.श.म./अग्नि/मुका/५००३/२०२२
दिनांक : २८/०२/२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Industrial / Commercial Building on land bearing S.No.70/1/5, Plot.No.6/1, 6/2, 6/3 of Village: Waliv, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1506/2021-22, Dated: 13/01/2022.
- 2) An application received by M/s- En Con Project Consultants, Dated:07/01/2022
 - 3) An application received by Developer M/s- Rohan Associates, Dated: 07/01/2022.
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated: 07/01/2022.
 - 5) This office Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/735/ 2020-21, Dated:23/12/2020.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:07/01/2022.
 - 7) Certificate from License Agency M/s- TFPC Infra LLP, Dated:17/01/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021.
 - 9) AMC Certificate by M/s- Rohan Associates, Dated: 01/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/02/2022.
 - 12) Structure Stability Certificate for M/s- S.S. & Associates, Dated:07/01/2022.
 - 13) CC issued by VVCMC/TP/CC/VP-6142/79/2019-20, Dated:11/07/2019.
 - 14) RDP issued by VVCMC/TP/RDP/VP-6142/475/2021-22, Dated:22/09/2021
 - 15) Submitted Electric Certificate M/s- Rudra Power Solutions, Dated:28/01/2022
 - 16) Diesel Engine Test Certificate M/s- Kirloskar Oil Engines Limited, Dated: July:2021.
 - 17) C.F.O. site visit Dated: 08/02/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Industrial / Commercial Building No. B Unit No. 4, 5, 6 & 7 as (Gr + 3 Pt) in 19.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- TFPC Infra LLP, bearing License No. MFS-LA/RF-384 & MFS-LA/RD-359** and has submitted Certificate on 17/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 3476.27sq.mtrs.

With reference to above on **17/01/2022** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Rohan Associates"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (6 kg) – 08 Nos.
- B) Hose Reel Hose – 05 Nos.
- C) Hose Box has been installed in Alternate floor – 04 Nos.
- D) Hydrant Valve – 09 Nos.
- E) Hydrant Main Pump near Under ground water storage tank (40 Hp) – 01 Nos.
- F) Jockey Pump near Under ground water storage tank (7.5 Hp) – 01 Nos.
- G) Sprinkler Main Pump (20 Hp) - 01 Nos.
- H) Sprinkler Jockey Pump (7.5 Hp) – 01 Nos.
- I) Stand by Pump (40 Hp) – 01 Nos.
- J) Booster Pump near over head water storage tank (5 Hp) 01 Nos.
- K) Fire Alarm Control Panel – 02 Nos.
- L) MCP – 07 Nos.
- M) Hooter – 07 Nos.
- N) Sand Bucket – 04 Nos.
- O) Sprinkler Systems – 62 Nos.
- P) Diesel Generator Set

Ther
ENCON

This certificate shall be treated **valid up to 31/12/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 24,00,000/- vide Receipt No. 779394, DD. No. 067024 (Bassein Catholic Bank), Dated:25/06/2019; Rs. 40,000/- vide Receipt No. 819561, DD. No. 068334, Dated:18/11/2020; Rs. 5,20,000/- vide Receipt No. 819560, DD. No. 068335, Dated:18/11/2020; Rs.2,40,000/- vide Receipt No. 819559, DD.No.068335, Dated: 18/11/2020 of Bassein Catholic Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s- Rohan Associates

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म/प्रशि/मुका/५०६५
दिनांक : १४/०३/२०२२

तमिळाली

लिपि (न.र.)

विरार शहर महानगरपालिका

१४.०५.२०२२

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Industrial Building on land bearing Plot.No.3, S.No.96/1/2/6/7Pt/8 of Village: Waliv, Tal: Vasai, Dist: Palghar.**

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1489/2021-22, Dated: 05/01/2022.

- 2) An application received by M/s- Devendra Mistry Architect, Dated:07/01/2022
- 3) An application received by M/s- R. D. Construction, Dated: 07/01/2022.
- 4) Work Completion certificate of M/s- Devendra Mistry Architect, Dated:20/12/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1681/2020-21, Dated: 11/12/2020.
- 6) Gross built up area certificate for M/s- Devendra Mistry Architect, Dated:07/01/2022.
- 7) Certificate from License Agency M/s-Vision Fire & Safety Engineering, Dated: 23/12/2021 (Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated:30/10/2021.
- 9) AMC Certificate by M/s- R.D. Construction, Dated: 07/01/2022
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/02/2022.
- 12) Structure Stability Certificate for M/s- S. P. Associates, Dated:20/12/2021.
- 13) RDP issued by VVCMC/TP/RDP/VP-4104/161/2020-21, Dated:24/12/2020.
- 14) CC issued by VVCMC/TP/CC/VP-4104/107/2019-20, Dated:18/09/2019.
- 15) Submitted Electric Certificate M/s- ZIP Engineers, Dated: 10/01/2022
- 16) Diesel Engine Test Certificate M/s- Nidec Industrial Automation, Dated: 22/11/2021.
- 17) C.F.O. site visit Dated:09/02/2022.

With reference to Sr. No. 2 & 3 above, this office is in received of your application for your **Industrial Building as (Gr + 3) in 18.00mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-389 & MFS-LA/RD-364 and has submitted Certificate on 23/12/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1167.44sq.mtrs.

With reference to above on 09/02/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by " R.D. Construction " following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (6 kg) – 06 Nos.
- B) Hose Reel Hose – 03 Nos.
- C) Hose Box has been installed in Alternate floor – 02 Nos.
- D) Hydrant Valve – 05 Nos.
- E) Booster Pump near over head water storage tank (5 Hp) 01 Nos.
- F) Diesel Generator Set

This certificate shall be treated **valid up to 31/12/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 727197, DD. No. 001548 Dated: 08/02/2019; Rs. 80,000/- vide Receipt No. 819412, DD. No. 001887, Dated: 14/09/2020 & Rs. 10,000/- vide Receipt No. 819562, DD. No. 001917, Dated: 24/11/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Devendra Mistry Architect
2) Developer- M/s- R. D. Construction

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर- ४०१ ३०५



दुरध्वनी : ०२५०-२५२५१०१/०२/०३/०४/०५/०६

फैक्स: ०२५०-२५२५१०७

ई-मेल: vasaivirarcorporation@yahoo.com

जा.क्र.: व.वि.श.म./अग्नि/मुका/ ५९९७ /२०२१-२२.

दिनांक : ३० / ०३ / २०२२.

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Mega Rubber Technologies Pvt Ltd,
Bldg No.1, Agarwal Udyog Nagar,
Waliv, Vasai (E)
Tal-Vasai, Dist-Palghar.

Sub:-Renewal of No Objection Certificate" of Industrial Building M/s-Mega Rubber Technologies Pvt Ltd , Bldg No.1, Agarwal Udyog Nagar, Waliv Tal- Vasai, Dist-Palghar.

- Ref: - 1. An application received by M/s- Mega Rubber Technologies Pvt Ltd, Dated: 17/01/2022.
2. Certificate from License Agency M/s-Jai Jivdani Fire Services, Dated:10/08/2021(Form B).
3. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated 20/01/2022
4. Submitted Renewal Final No Objection Certificate No.VVCMC/FIRE/HQ/564/Dated:05/11/2020
5. Submitted License copy of Maharashtra Fire Services, Dated:10/01/2022
6. Electric Certificate received from M/s.Electrical inspector, Dated:16/12/2020
7. C.F.O.Site Visit on Dated : 21/01/2022.

With reference to Sr.No.1 above, this office is in received of your application for your "M/s-Mega Rubber Technologies Pvt " at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Jai Jivdani Fire Services, bearing License No. MFS-LA/RF-07/RD-08 and has submitted Certificate On 10/01/2022 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to 31/12/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 37,500/- vide Receipt No. 30298 Dated: 20/01/2022, Rs. 37,500/- vide Receipt No. 30532 Dated: 23/03/2022 Issued by ICICI, renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/५१४०
दिनांक : ३१/०३/२०२२

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Residential Building on land bearing S.No.145B, H.No.1D, s.No.145B, H.No.1, 2, 3, 4, 5, 6 & 7 (Old), S.No.145/B/1, 145/B/2, 145/B/3, 145/B/4, 145/B/5, 145/B/6, 145/B/7, S.No.145/1/D (New) of Village: Nilemore, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1708/2021-22, Dated:18/02/2022.
- 2) An application received by M/s- En Con Project Consultants, Dated:11/02/2022.
 - 3) An application received by Developer M/s- Ruturaj Vastu-Shilp, Dated:11/02/2022
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/02/2022
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/475/2019-20, Dated:23/08/2019.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:11/02/2022
 - 7) Certificate from License Agency M/s- Sandeep Construction, Dated:24/01/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:23/02/2021.
 - 9) AMC Certificate by M/s- Sandeep Construction, Dated:11/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/03/2022.
 - 12) Structure Stability Certificate for M/s- S.S & Associates, Dated:06/09/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-3909/0387/2013-14, Dated:29/03/2014.
 - 14) Submitted Electric Certificate M/s- Aim Realty Engineering Pvt Ltd, Dated:02/02/2022.
 - 15) Diesel Generator Test Certificate of M/s-Crompton Greaves Ltd, Dated:24/02/2019
 - 16) C.F.O. site visit Dated:07/03/2022

With reference to Sr.No.2 & 3 above, this office is in received of your application for your Residential Building No. 2 (Wing- B & C) as (Gr./ Stilt + 7) in 23.80mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Sandeep Construction, bearing License No. MFS-LA/2021/RF-163 & MFS-LA/2021/RD-147 and has submitted Certificate on 24/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-B – 2955.63sq.mtrs & Wing-C-3140.09sq.mtrs.

With reference to above on 23/02/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Ruturaj Vastu-Shilp" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers (06 Kg) – 02 Nos.
- B) Hose Reel Hose has been installed in every floor – 14 Nos.
- C) Hose Box has been installed in Alternate floor – 08 Nos.
- D) Siamese Connection has been installed in entrance gate – 02 Nos

This certificate shall be treated **valid up to 31/12/2022** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.2,40,000/- vide Receipt No. 818336, DD.No.025696 (Dena Bank), Dated:23/08/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer, written over the printed name.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants

2) Developer- M/s- Ruturaj Vastu-Shilp

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.




दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/५१४०
दिनांक : ३१/०३/२०२२

FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.



Sub:- "Final No Objection Certificate" of Residential Building on land bearing S.No.145B, H.No.1D, s.No.145B, H.No.1, 2, 3, 4, 5, 6 & 7 (Old), S.No.145/B/1, 145/B/2, 145/B/3, 145/B/4, 145/B/5, 145/B/6, 145/B/7, S.No.145/1/D (New) of Village: Nilemore, Tal: Vasai, Dist: Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1708/2021-22, Dated:18/02/2022.
- 2) An application received by M/s- En Con Project Consultants, Dated:11/02/2022.
 - 3) An application received by Developer M/s- Ruturaj Vastu-Shilp, Dated:11/02/2022
 - 4) Work Completion certificate of M/s- En Con Project Consultants, Dated:11/02/2022
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/475/2019-20, Dated:23/08/2019.
 - 6) Gross built up area certificate for M/s- En Con Project Consultants, Dated:11/02/2022
 - 7) Certificate from License Agency M/s- Sandeep Construction, Dated:24/01/2022 (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:23/02/2021.
 - 9) AMC Certificate by M/s- Sandeep Construction, Dated:11/02/2022
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/03/2022.
 - 12) Structure Stability Certificate for M/s- S.S & Associates, Dated:06/09/2021
 - 13) RDP issued by VVCMC/TP/RDP/VP-3909/0387/2013-14, Dated:29/03/2014.
 - 14) Submitted Electric Certificate M/s- Aim Realty Engineering Pvt Ltd, Dated:02/02/2022.
 - 15) Diesel Generator Test Certificate of M/s-Crompton Greaves Ltd, Dated:24/02/2019
 - 16) C.F.O. site visit Dated:07/03/2022

With reference to Sr.No.2 & 3 above, this office is in received of your application for your Residential Building No. 2 (Wing- B & C) as (Gr./ Stilt + 7) in 23.80mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Sandeep Construction, bearing License No. MFS-LA/2021/RF-163 & MFS-LA/2021/RD-147** and has submitted Certificate on 24/01/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to Wing-B – 2955.63sq.mtrs & Wing-C-3140.09sq.mtrs.

With reference to above on 23/02/2022 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by **"Ruturaj Vastu-Shilp"** following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers (06 Kg) – 02 Nos.
- B) Hose Reel Hose has been installed in every floor – 14 Nos.
- C) Hose Box has been installed in Alternate floor – 08 Nos.
- D) Siamese Connection has been installed in entrance gate – 02 Nos.

This certificate shall be treated valid up to 31/12/2022 it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.2,40,000/- vide Receipt No. 818336, DD.No.025696 (Dena Bank), Dated:23/08/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants

2) Developer- M/s- Ruturaj Vastu-Shilp

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

*For
ENCERT*