



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/47/2023-24

DATE: 10/04/2023

FIRE & EMERGENCY DEPARTMENT



To,
Mr. Abhay Raut Architect,
1104, Gold Crest Business Center,
L.T. Road, Borivali (W),
Mumbai - 400 092.

Sub:- "Final No Objection Certificate" of Residential Cum Commercial Building No.12 (Wing-A & B - Gr + 14 floor) on Plot bearing S.No.157/5/A/1, S.No.157/5/A/2, S.No.157/5/B/1, S.No.157/5/B/2, S.No.423, H.No.A2, 43 & A4, S.No.316B, S.No.148/B/20 of Village:Bolini, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by Mr.Abhay Raut Architect, Dated:04/03/2023 (VP - 0489)

2) An application received by Developer M/s-Sairam Realtors Builders & Developers, Dated:04/03/2023.

3) Built up area certificate for Mr.Abhay Raut Architect, Dated:04/03/2023.

4) Work Completed certificate by Mr.Abhay Raut Architect, Dated:04/03/2023

5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/76/2013-14, Dated:14/05/2013.

6) Certificate from License Agency M/s-Fire Bird Fire Services, Dated:06/02/2023 (Form A)

7) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2023.

8) AMC Certificate by M/s-Sairam Realtors Builders & Developers, Dated:04/03/2023.

9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:26/01/2023.

10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/04/2023.

11) Structure Stability Certificate for M/s-Nimisha Structural Design Academy, Dated:15/02/2023.

12) RDP issued by VVCMC/TP/RDP/VP-0489/399/2021-22, Dated:27/08/2021.

13) Submitted Electric Certificate Mr.Vijay Mahadik, Dated:04/03/2023.

14) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines Ltd, Dated:11/11/2022.

15) C.F.O. site visit Dated:08/04/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential cum Commercial Building No. 12 (Wing-A & B) Ground floor + 14th floor in 45.00mtrs Height at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services, bearing License No. MFS-LA/RF-71, MFS-LA/RD-69 & has submitted Certificate on 06/02/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 4917.59sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 08/04/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Sairam Realtors Builders & Developers" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 11 Nos.
- B) Hose Reel Hose has been installed in every floor – 19 Nos.
- C) Hose Box has been installed in Alternate floor – 06 Nos.
- D) Hydrant Valve - 24 Nos.
- E) Main Pump (60 Hp) - 01 Nos.
- F) Jockey Pump (5 Hp) – 01 Nos.
- G) Booster Pump (7.5 Hp) - 01 Nos.
- H) Fire Alarm Panel (16 Zones) – 01 Nos.
- I) MCP & Hooter – 19 Nos.
- J) Manual Fire Alarm System - 02 Nos.
- K) Smoke Detectors - 19 Nos.

Recd
19/04/23

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.5,75,000/- vide Receipt No.105203, Dated:14/05/2013.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC

2) Developer- M/s-Sairam Realtors Builders & Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

मुख्य कार्यालय, विरार
विरार (पूर्व),
ता. वसई, जि. पालघर - ४०१ ३०५.



दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६
फॅक्स : ०२५० - २५२५१०७
ई-मेल : vasaivirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म.प्रगति/मुका/२२५/२०२३
दिनांक : ०५/०५/२०२३

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- **"Final No Objection Certificate" of Residential Building No.T5 on land bearing S.No.296, 297, 298, 299, 303, 304 & 390-B of Village:Bolinj, Tal: Vasai, Dist: Palghar.**

- Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:15/04/2023.
2) An application received by M/s-Joyville Shapoorji Housing Pvt Ltd, Dated:15/04/2023
3) Work Completion certificate of M/s-En Con Project Consultants, Dated:15/04/2023.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1076/2019-20, Dated:01/01/2019.
5) Built up area certificate for M/s-En Con Project Consultants, Dated:15/04/2023.
6) Certificate from License Agency M/s- Water Power, Dated:25/03/2023 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:07/05/2022.
8) Certificate from License Agency M/s- Monsher Fire Protection Systems (P) Ltd, Dated:28/03/2023 (Form A)
9) Submitted License copy of Maharashtra Fire Services, Dated:06/02/2023.
10) AMC Certificate by Developer M/s-Joyville Shapoorji Housing Pvt Ltd, Dated:15/04/2023
11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:Nil
12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:03/05/2023.
13) Structure Stability Certificate for M/s-Epicons Consultants Pvt Ltd, Dated:17/02/2022.
14) RDP issued by VVCMC/TP/RDP/VP-0059/209/2018-19, Dated:02/02/2019.
15) Submitted Electric Certificate M/s- Noor Electrical Contractor, Dated:15/04/2023.
16) Diesel Engine Test Certificate of M/s-Sterling & Wilson Company, Dated:31/12/2019.
17) C.F.O. site visit Dated:03/05/2023.

With reference to Sr.No.2 above, this office is in received of your application for your **Residential Building No. T5 as Stilt + 23 Floor in 69.90mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- Water Power**, bearing License No. MFS-LA/F-248, MFS-LA/D-241 and has submitted Certificate on 25/03/2023 in "Form A" & Monsher Fire Protection Systems (P) Ltd, bearing License No. MFS-LA/RF-72, MFS-LA/RD-67 and has submitted Certificate on 28/03/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 13037.74sq.mtrs.

With reference to above on **03/05/2023** representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Joyville Shapoorji Housing Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor (06 Kg) – 08 Nos.
- B) Fire Extinguishers - 52 Nos.
- C) 12W Speaker (Wall Mounted) - 02 Nos.
- D) 6W Speaker - 73 Nos.
- E) Hose Box – 11 Nos..
- F) Fire Buckets – 02 Nos..
- G) Hydrant Valve - 11 Nos.
- H) Hose Reel Hose - 24 Nos.
- I) Smoke Detector - 73 Nos.
- J) Multi Sensor Detectors - 05 Nos.
- K) MCP - 24 Nos.

- L) Sounder Cum Strobe - 24 Nos.
- M) Pressure Gauge - 04 Nos.
- N) Pendent Sprinkler - 73 Nos.
- O) Side Wall Sprinkler - 1012 Nos.
- P) Alarm Valve - 01 Nos.
- Q) F. A. Panel - 01 Nos.
- R) Amplifier - 01 Set.
- S) Main Hydrant Pump (120 Hp) - 01 Nos.
- T) Main Sprinkler Pump (120 Hp) - 01 Nos.
- U) Jockey Pump (7.5 Hp) - 02 Nos.
- V) Booster Pump (12.5 Hp) - 01 Nos.
- W) Diesel Pump (152 Bhp) - 01 Nos.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 33,00,000/- vide Receipt No.487467, DD.No.084307 & Rs.10,40,000/- vide Receipt No.487424, DD.No.033221 (Standard Chartered Bank), Dated-29/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s-Joyville Shapoorji Housing Pvt Ltd

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/251 /2023-24

DATE: 13/05/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Umesh Gala Architect,
1st Floor, Tripathi House,
Behind Gurudwara,
Off. Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Vehicle Fuel Filling Station on land bearing S.No.118, H.No.18 of Village:Bilalpada, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received from M/s-Umesh Gala Architect, Dated:12/04/2023.
(VP - 5871)

- 2) An application received from Developer Mr.Avinash Gharat, Dated:12/04/2023.
- 3) Built up area certificate for M/s-Umesh Gala Architect, Dated:12/04/2023.
- 4) Work Completed Certificate for M/s-Umesh Gala Architect, Dated:12/04/2023
- 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/819/2017-18, Dated:27/12/2017.
- 6) Certificate from License Agency M/s-Shree Fire Guard Co, Dated:19/04/2023.
(Form A)
- 7) Submitted License copy of Maharashtra Fire Services, Dated:18/06/2022.
- 9) AMC Certificate by Mr.Avinash Gharat, Dated:14/04/2023.
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/04/2023.
- 11) Structure Stability Certificate for Mr.Harish D. Chhatbar, Dated:28/03/2023.
- 12) Submitted Electric Certificate M/s-Hind Electric & Engineering Corporation, Dated:17/04/2023.
- 13) Submitted Diesel generator test certificate for M/s-CG Power & Industrial Solutions Ltd, Dated:08/03/2023.
- 14) Submitted Request letter from Developer Mr.Avinash Gharat, Dated:12/04/2023.
- 15) C.F.O. site visit Dated:22/04/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Vehicle Fuel Filling Station as (Ground floor) in 7.30mtrs Height** at above mentioned address. Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-Shree Fire Guard**, bearing License No. MFS-LA/RF-318, MFS-LA/RD-307 & has submitted Certificate on 19/04/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area measuring to 40.00sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **22/04/2023** for inspection from the point of view of fire prevention & protection provided by "Mr.Avinash Gharat" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) ABC Type Portable Fire Extinguishers has been installed (09 Kg) – 06 Nos.
- C) Co2 Type Portable Fire Extinguishers has been installed (02 Kg) – 06 Nos.
- D) Fire Bucket - 06 Nos.
- E) Hydrant Valve - 03 Nos.
- F) Hose Box Double - 01 Nos.
- G) Hose Box Single - 02 Nos.
- H) Hose Reel Hose – 03 Nos.
- I) Hydrant Main Pump (20 Hp) - 01 Nos.
- J) Jockey Pump (5 Hp) – 01 Nos.
- K) Fire Auto Panel - 01 Nos.
- L) Sprinkler Head - 02 Nos.
- M) 2 Zone Panel - 01 Nos.
- N) Smoke Detector – 04 Nos.
- O) MCP - 02 Nos.
- P) Hooter - 01 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs. 80,000/- vide Receipt No.609499, DD.No.027563 (Bassein Catholic Bank), Dated:22/12/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "S. K. Kulkarni".

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Mr.Avinash Gharat

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/469 /2023-24

DATE: 24/05 /2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor, Sai Tower,
Ambadi Road,
Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.1 (Wing-B & C) on land bearing S.No.5, H.No.6 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received from M/s-Ajay Wade & Associates, Dated:22/05/2023 (VP - 5718)
2) An application received from Developer M/s-Pabal Housing Pvt Ltd, Dated:22/05/2023.
3) Built up area certificate from M/s-Ajay Wade & Associates, Dated:22/05/2023.
4) Work Completed Certificate from M/s-Ajay Wade & Associates, Dated:22/05/2023.
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/1462/2021-22, Dated:04/09/2021.
6) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:16/04/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:30/03/2023.
8) AMC Certificate from M/s-Pabal Housing Pvt Ltd, Dated:05/05/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:23/05/2023.
10) Structure Stability Certificate from Mr.Paresh Unnarkar, Dated:27/03/2023.
11) Submitted Electric Certificate M/s-Jignesh Vidyut Service, Dated:22/04/2023.
12) Submitted Lighting Arrester Testing Certificate M/s-Daksh Electrical, Dated:20/04/2023.
13) Submitted Diesel generator test certificate from M/s-Gangadhar Industries, Dated:07/04/2023.
14) RDP issued by VVCMC/TP/RDP/VP-5718/172/2022-23, Dated:21/07/2022.
15) C.F.O. site visit Dated:23/05/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline Building No. 1 (Wing-B & C) as (Shop / Stilt / Ground Floor + 11th Floor) in 36.40mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sadanand Fire Systems, bearing License No. MFS-LA/RF-181, MFS-LA/RD-170 & has submitted Certificate on 16/04/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-B - 5171.57sq.mtrs & Wing-C - 5901.94sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 23/05/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Pabal Housing Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 11 Nos.
- B) Fire Buckets with Stand - 06 Nos.
- C) Courtyard Hydrant - 10 Nos.
- D) Hose Box - 22 Nos.
- E) Hose Reel Hose - 22 Nos.
- F) Main Hydrant Pump (100 Hp) - 01 Nos.
- G) Sprinkler Pump (100 Hp) - 01 Nos.
- H) Stand by Pump (100 Hp) - 01 Nos.
- I) Sprinkler Jockey Pump (10Hp) - 02 Nos.
- J) Booster Pump (10Hp) - 02 Nos.
- K) Fire Alarm System - 02 Sets.
- L) Smoke Detector - 90 Nos.
- M) Sprinkler System - 185 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs.1,90,500/- vide Receipt No.895544, Book No.8957, DD.No.021291(HDFC Bank), Dated:23/07/2021, Rs.2,34,500/- vide Receipt No.895543, Book No.8956, DD.No.021290 (HDFC Bank), Dated:23/07/2021 & Rs.36,000/- vide Receipt No.895620, Book No.8957, DD.No.021388 (HDFC Bank), Dated:23/08/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

Received
Dalme
24/5/23



[Signature]

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Pabal Housing Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.




VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 514 /2023-24

DATE: 31/05/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s – En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.5 Wing-A & B in Sector No. VI located on land bearing S.No.49, 50, 51, 52, 53, 54, 55, 56, 77, S.No.57, H.No.1 of Village:Achole, Tal: Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:10/05/2023.
2) An application received by M/s-Space Homes, Dated:10/05/2023
3) Work Completion certificate of M/s-En Con Project Consultants, Dated:27/06/2022.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/667/2019-20, Dated:24/09/2019.
5) Built up area certificate for M/s-En Con Project Consultants, Dated:10/05/2023.
6) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:26/04/2023 (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:30/03/2023.
8) AMC Certificate by Developer M/s-Space Homes, Dated:01/04/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:Nil
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/05/2023.
11) Structure Stability Certificate for M/s-Pro-Tech Consultants, Dated:20/06/2022.
12) RDP issued by VVCMC/TP/RDP/VP-0127/231/2019-20, Dated:03/12/2019.
13) RDP issued by VVCMC/TP/RDP/VP-0127/344/2019-20, Dated:17/03/2020.
14) Submitted Electric Certificate M/s-Rohan Hitect Engineering, Dated:01/03/2021.
15) Diesel Engine Test Certificate of M/s-Gangadhar Industries, Dated:18/12/2021.
16) C.F.O. site visit Dated:17/05/2023.

With reference to Sr.No.2 above, this office is in receive of your application for your Residential with Shopline Building No. 5 (Wing-A & B) Sector No. VI as Stilt / Ground + 14th Floor in 43.85mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sadanand Fire Systems, bearing License No. MFS-LA/RF-181, MFS-LA/RD-170 and has submitted Certificate on 26/04/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-A - 3286.97sq.mtrs & Wing-B - 5088.51sq.mtrs.

With reference to above on 17/05/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Space Homes" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in every floor (04 Kg) – 05 Nos.
- B) Fire Bucket with Stand - 04 Nos.
- C) Fire Alarm with Public Address System- 02 Sets.
- D) Hose Box – 19 Nos..
- E) Courtyard Hydrant - 05 Nos.
- F) Hose Reel Hose - 28 Nos.
- G) Smoke Detector - 02 Nos.
- H) Siamese Connection at main gate - 01 Nos.
- I) Main Hydrant Pump (50Hp) - 01 Nos.
- J) Main Sprinkler Pump (40Hp) - 01 Nos.
- K) Hydrant Jockey Pump (7.5 Hp) - 01 Nos.
- L) Stand by Pump (50Hp) - 01 Nos.
- M) Booster Pump (10Hp) - 02 Nos.

This certificate shall be treated valid up to one year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 5,25,000/- vide Receipt No.818342, DD.No.001511 & Rs.5,25,000/- vide Receipt No.818341, DD.No.001512 (Vasai Vikas Sahakari Bank), Dated- 23/08/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, likely of the Chief Fire Officer.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) Architect - M/s- En Con Project Consultants
2) Developer- M/s-Space Homes

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 574 /2023-24

DATE: 07/06/2023

FIRE & EMERGENCY DEPARTMENT



To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:-"Final No Objection Certificate" of Industrial Building on land bearing S.No.47, H.No.2/1 of Village:Bilalpada, Tal:Vasai, Dist:Palghar.

- Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/571/2022-23, Dated:22/06/2022
2) An application received by M/s-Architect Umesh Kekre, Dated:16/06/2022 (VP-5696)
3) An application received by Developer M/s-Prayas Pen & Plastic Industries, Dated:22/06/2022.
4) Work Completion certificate of M/s-Architect Umesh Kekre, Dated:16/06/2022.
5) Built up area certificate for M/s-Architect Umesh Kekre, Dated:16/06/2022.
6) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/63/2016-17, Dated:28/04/2016.
7) Certificate from License Agency M/s-TFPC Infra LLP, Dated:04/07/2022. (Form A)
8) Submitted License copy of Maharashtra Fire Services, Dated:15/10/2021
9) AMC Certificate by M/s-TFPC Infra LLP, Dated:06/06/2022.
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :10/03/2021.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/07/2022.
12) Structure Stability Certificate for M/s-Krupa Mehta Consulting Engineers, Dated:26/09/2019.
13) Submitted Electric Certificate M/s-Dewang Electricals & Engineers, Dated:07/04/2023.
14) Submitted D.G. Set Test Certificate for M/s-Dewang Electricals & Engineers, Dated:07/04/2023.
15) C.F.O. site visit Dated:05/07/2022.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Industrial Building as (Ground floor + Mezzanine floor + 1st & 2nd floor) in 15.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RD-359, MFS-LA/RF-384 has submitted Certificate on 04/07/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1051.02sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **05/07/2022** for inspection from the point of view of fire prevention & protection provided by "M/s-Prayas Pen & Plastic Industries" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (04 Kg) – 15 Nos.
- B) Hose Reel Hose has been installed in every floor – 04 Nos.
- C) Hose Box has been installed in Alternate floor – 07 Nos.
- D) Main Hydrant Pump – 01 Nos.
- E) Main Sprinkler Pump – 01 Nos.
- F) Jockey Hydrant Pump – 01 Nos.
- G) Jockey Sprinkler Pump – 01 Nos.
- H) Booster Pump – 01 Nos.
- I) Pump Control Panel – 01 Nos.
- J) Hydrant Valve – 07 Nos.
- K) Fire Alarm Control Panel – 01 Nos.
- L) MCP / Hooter – 07 Nos.
- M) Sprinkler System – 57 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.2,00,000/-, 50,000/- vide Receipt No.470121, 470122, DD.No.014070, 014311 (Saraswat Bank), Dated:26/04/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s-Architect Umesh Kekre
2) Developer- M/s-Prayas Pen & Plastic Industries.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

- M) Booster Pump Starter - 01 Nos.
- N) Pump Control Panel - 01 Nos.
- O) Fire Alarm Control Panel - 01 Nos.
- P) MCP Cum Hooter - 21 Nos.
- Q) Sprinkler Bulb - 413 Nos.
- R) Butterfly Valve - 28 Nos.
- S) NRV - 06 Nos.
- T) Smoke Detector - 06 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year, in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs.4,80,000/- vide Receipt No.425454, DD. No. 033015, Dated:27/01/2016; Rs.4,45,000/- vide Receipt No.609432, Dated:09/11/2017; Rs.90,000/- vide Receipt No.609433, Dated:09/11/2017; Rs.4,45,000/- vide Receipt No.609425, Dated:09/11/2017; Rs.3,25,000/- vide Receipt No.609428, Rs.80,000/- vide Receipt No.609429, Rs.3,25,000/- vide Receipt No.609426, Rs.80,000/- vide Receipt No.609427; Rs.1,05,000/- vide Receipt No.819127; Rs.20,000/- vide Receipt No.819128; Rs.50,000/- vide Receipt No.819129, Rs.14,500/- vide Receipt No.819130; Rs.13,500/- vide Receipt No.819131; Rs.2000/- vide Receipt No.819132 & Rs.8,98,000/- vide Receipt No.895291, Book No.8953, DD.No.068727 (Bassein Catholic Bank), Dated:30/03/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Sethi Construction Company.
Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting systems only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/ /2023-24 DATE: / /2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s - Shape Consultants,
D-1 & D-2, Aakanksha Commercial Complex,
Opp HDFC Bank, Achole Road,
Nallasopara (E), Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building (Wing-F) on land bearing S.No.188B, H.No.1 to 8, S.No.189, H.No.12 of Village:Sandor, Tal:Vasai, Dist:Palghar.

Ref:- (1) An application received by M/s - Shape Consultants, Dated:06/05/2023.
(VP - 5793)
(2) An application received by Developer M/s-Sethi Construction Company, Dated:08/05/2023.

(3) Built up area certificate for M/s - Shape Consultants, Dated:06/05/2023.
(4) Work Completed Certificate for M/s - Shape Consultants, Dated:06/05/2023.
(5) This office issued Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/1107/2020-21, Dated:31/03/2021.
(6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:07/05/2023.
(Form A)

(7) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022.
(8) AMC Certificate by M/s-Sethi Construction Company, Dated:08/05/2023.
(9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:31/05/2023.
(10) Structure Stability Certificate for M/s-Jay Shree Krishna Consulting Engineer, Dated:03/05/2023.
(11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:23/03/2023.

(12) RDP issued by VVCMC/TP/RDP/VP-5793/36/2021-22, Dated:16/04/2021.
(13) Submitted Electric Certificate M/s-Zip Engineers, Dated:29/04/2023.
(14) Submitted Diesel generator test certificate for M/s-Stamford, Dated:07/03/2023.
(15) Submitted Hardship Letter from M/s-Sethi Construction Company, Dated:08/05/2023.
(16) C.F.O. site visit Dated:31/05/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline Building (Wing-F) as (Still / Shop / Ground floor + 20th floor) in 61.70mts Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RD-474, MFS-LA/RD-457 has submitted Certificate on 01/06/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your each building having total built up area admeasuring to 4957.42sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 31/05/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Sethi Construction Company" in inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Fire Extinguishers has been installed (4 Kg) - 21 Nos.
- B) Sand Buckets - 02 Nos.
- C) Courtyard Hose Box - 02 Nos.
- D) Internal Hose Box - 10 Nos.
- E) Hose Reel Set - 20 Nos.
- F) Courtyard Hydrant Valve - 02 Nos.
- G) Internal Hydrant Valve - 20 Nos.
- H) Main Hydrant Pump (100 Hp) - 01 Nos.
- I) Main Sprinkler Pump (50 Hp) - 01 Nos.
- J) Hydrant Jockey Pump (10 Hp) - 01 Nos.
- K) Jockey Sprinkler Pump (10 Hp) - 01 Nos.
- L) Booster Pump (7.5 Hp) - 01 Nos.

- M) Booster Pump Starter - 01 Nos.
N) Pump Control Panel - 01 Nos.
O) Fire Alarm Control Panel - 01 Nos.
P) MCP Cum Hooter - 21 Nos.
Q) Sprinkler Bulb - 41 Nos.
R) Butterfly Valve - 28 Nos.
S) NRV - 06 Nos.
T) Smoke Detector - 06 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs.4,80,000/- vide Receipt No.425454, DD. No. 033015, Dated:27/01/2016; Rs.4,45,000/- vide Receipt No.609432, Dated:09/11/2017; Rs.90,000/- vide Receipt No.609433, Dated:09/11/2017; Rs.4,45,000/- vide Receipt No.609425, Dated:09/11/017; Rs.3,25,000/- vide Receipt No.609428, Rs.80,000/- vide Receipt No.609429, Rs.3,25,000/- vide Receipt No.609426, Rs.80,000/- vide Receipt No.609427; Rs.1,05,000/- vide Receipt No.819127; Rs.20,000/- vide Receipt No.819128; Rs.50,000/- vide Receipt No.819129, Rs.14,500/- vide Receipt No.819130; Rs.13,500/- vide Receipt No.819131; Rs.2000/- vide Receipt No.819132 & Rs.8,98,000/- vide Receipt No.895291, Book No.8953, DD.No.068727 (Bassein Catholic Bank), Dated:30/03/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Sethi Construction Company.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975321, 88888864283, 8888864275

VVCMC/FIRE/HQ/582/2023-24

DATE: 08/06/2023



FIRE & EMERGENCY DEPARTMENT

To,

M/s - Shape Consultants,

D-1 & D-2, Aakanksha Commercial Complex,

Opp HDFC Bank, Achole Road,

Nallasopara (E), Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building (Wing-F) on land bearing S.No.188B, H.No.1 to 8, S.No.189, H.No.12 of Village:Sandor, Tal:Vasai, Dist:Palghar.

Ref:- (1) An application received by M/s - Shape Consultants, Dated:06/05/2023.

(VP - 5793)

(2) An application received by Developer M/s-Sethi Construction Company,

Dated:08/05/2023.

(3) Built up area certificate for M/s - Shape Consultants, Dated:06/05/2023.

(4) Work Completed Certificate for M/s - Shape Consultants, Dated:06/05/2023.

(5) This office issued Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/1107/2020-21, Dated:31/03/2021.

(6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:07/05/2023.

(Form A)

(7) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022.

(8) AMC Certificate by M/s-Sethi Construction Company, Dated:08/05/2023.

(9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:31/05/2023.

(10) Structure Stability Certificate for M/s-Jay Shree Krishna Consulting Engineer,

Dated:03/05/2023.

(11) License to work the Lift from Govt. of Maharashtra Industries, Energy &

Labour, Dated:23/03/2023.

(12) RDP issued by VVCMC/TP/RDP/VP-5793/36/2021-22, Dated:16/04/2021.

(13) Submitted Electric Certificate M/s-Zip Engineers, Dated:29/04/2023.

(14) Submitted Diesel generator test certificate for M/s-Stamford, Dated:07/03/2023.

Dated:08/05/2023.

(16) C.F.O. site visit Dated:31/05/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline Building (Wing-F) as (Still / Shop / Ground floor + 20th floor) in 61.70mts Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RP-474, MFS-LA/RD-457 has submitted Certificate on 01/06/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your each building having total built up area admeasuring to 4957.42sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 31/05/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Sethi Construction Company" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

A) ABC Type Fire Extinguishers has been installed (4 Kg) - 21 Nos.

B) Sand Buckets - 02 Nos.

C) Courtyard Hose Box - 02 Nos.

D) Internal Hose Box - 10 Nos.

E) Hose Reel Set - 20 Nos.

F) Courtyard Hydrant Valve - 02 Nos.

G) Internal Hydrant Valve - 20 Nos.

H) Main Hydrant Pump (100 Hp) - 01 Nos.

I) Main Sprinkler Pump (50 Hp) - 01 Nos.

J) Hydrant Jockey Pump (10 Hp) - 01 Nos.

K) Jockey Sprinkler Pump (10 Hp) - 01 Nos.

L) Booster Pump (7.5 Hp) - 01 Nos.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/756/2023-24

DATE: 28/06/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s – Shree Consultants,
B-203, Akanksha Tower,
Nr Rly Stn, Nallasopara (E),
Tal-Vasai, Dist-Palghar.

Sub:- “Final No Objection Certificate” of Residential with Shopline & Commercial Building on land bearing S.No.1/A/A/A/10/10 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s –Shree Consultants, Dated:22/05/2023.
(VP - 0264)
- 2) An application received by Developer M/s-Om Sadguru Associates, Dated:15/05/2023
 - 3) Built up area certificate for M/s –Shree Consultants, Dated:22/05/2023.
 - 4) Work Completed Certificate for M/s –Shree Consultants, Dated:22/05/2023
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/4853/2021-22, Dated:29/01/2022.
 - 6) Certificate from License Agency M/s-Om Surya Enterprises, Dated:23/06/2023.
(Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:21/02/2023.
 - 8) AMC Certificate by M/s-Om Sadguru Associates, Dated:15/05/2023.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:26/06/2023.
 - 11) Structure Stability Certificate for M/s-S.S & Associates, Dated:22/05/2023.
 - 12) RDP issued by VVCMC/TP/RDP/VP-0264/325/2022-23, Dated:29/08/2022.
 - 13) Submitted Electric Certificate M/s-K.L.Rathod Electrical Works,
Dated:11/05/2023.
 - 14) Submitted Diesel generator Bill for M/s-Goel Power Engineers, Dated:31/05/2023.
 - 15) C.F.O. site visit Dated:26/06/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline & Commercial Building as (Basement + Ground floor + 12th floor) in 41.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Om Surya Enterprises, bearing License No. MFS-LA/RF-102, MFS-LA/RD-94 has submitted Certificate on 23/06/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 4081.26sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 26/06/2023 for inspection from the point of view of fire prevention & protection provided by “M/s-Om Sadguru Associates” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hose Reel Hose has been installed in every floor – 12 Nos.
- B) Hose Box has been installed in Alternate floor – 04 Nos.
- C) Hydrant Valve - 12
- D) Two Way Inlet - 01
- E) Courtyard Hydrant - 03
- F) Sprinkler - 236
- G) MCP Cum Hooter - 12
- H) Smoke Detector - 32
- I) Fire Alarm Panel - 01
- J) Main Pump - 01 Nos.
- K) Sprinkler Pump - 01 Nos.
- L) Jockey Pump – 02 Nos.
- M) Stand by Pump - 01 Nos.
- N) Booster Pump - 01 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs. 3,80,000/- vide Receipt No. 818869, DD.No.001181 (Bassein Cahtolic Bani), Dated:26/12/2019 & Rs.3,25,000/- vide Receipt No.30303, Book No.304, DD.No.026632 (Bassein Catholic Bank), Dated:20/01/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "S. S. S.", written over the printed name of the Chief Fire Officer.

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Om Sadguru Associates

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250- 2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 890 /2023-24

DATE: 13/07/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s.Ladkoo plaza
Olanda Naka,Agashi
Virar (W) Tal-Vasai,Dist -Palghar.

Sub:-Renewal of "Final No Objection Certificate" of Commercial Building Known as Ladkoo Plaza (Basement+G+1stfloor) at ladkoo plaza,Olanda naka,Agashi,Virar (W) Tal-Vasai, Dist-Palghar.

- Ref:-** 1. An application received by M/s. Ladkoo Plaza: 08/05/2023.
2. This office Final No Objection Certificate No.VVCMC/FIRE/HQ/1513/Dated:03/09/2022
3. Certificate from License Agency M/s- Shree Fireguard co., Dated: 05/05/2023 (Form B)
4. Submitted License copy of Maharashtra Fire Services,Dated:18/06/2022
5. Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 19/05/2023
6. Electric Certificate
7. C.F.O.Site Visit on Dated : 19/05/2023

With reference to Sr.No.1 above, this office is in received of your application for your Commercial Building (Basement+G+1stfloor) at above mentioned address. Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Shree Fireguard co., bearing License No. MFS-LA/RF-318/RD-307, and has submitted Certificate On 18/06/2022 in "Form B" prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009,, this office is issuing a "Renewal No Objection Certificate" for your building.

This certificate shall be treated valid up to One Year it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has paid the Fire cess fees Rs. 21,250/- vide Receipt No. 69757,Book No.698,DD no.028770 (Axis bank) Dated: 22/05/2023 renewal fees for the said Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you.



CHIEF FIRE OFFICER

VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to Architect-

Please Note:- The Developer / Owner / Occupier have to Renew the N.O.C. after every one year & submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on 1st July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org

Agashi
13/7/23



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 995 /2023-24

DATE: 09/08/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s –Sanat Mehta & Associates,
Rameshwar Tower,
A-103, Shimpoli Road,
Next to Gokhale School,
Borivali (W), Mumbai-400 092.

Sub:- “Final No Objection Certificate” of Residential Building No. 1 (Wing-B) in Sector - II (Other) on S.No.63, H.No.2/1 out of larger Layout of land bearing Village:Gokhiware, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s – Sanat Mehta & Associates, Dated:07/08/2023. (VP - 0329, 0815 & 0509)
- 2) An application received by Developer M/s-Shantee Housing, Dated:07/08/2023.
 - 3) Built up area certificate for M/s –Sanat Mehta & Associates, Dated:07/08/2023.
 - 4) Work Completed Certificate for M/s – Sanat Mehta & Associates, Dated:07/08/2023
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/172/2015-16, Dated:26/08/2015.
 - 6) This office issued Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/ 115/2016-17, Dated:07/05/2016.
 - 7) This office issued Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/ 955/2023-24, Dated:26/07/2023.
 - 8) Certificate from License Agency M/s-Om Surya Enterprises, Dated:06/02/2023. (Form A)
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:19/02/2022.
 - 10) AMC Certificate by M/s-Shantee Housing, Dated:07/08/2023.
 - 11) Submitted Lift Certificate of M/s-Jay Shree Krishna, Dated:27/09/2022.
 - 12) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:24/11/2022.
 - 13) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:07/08/2023.
 - 14) Structure Stability Certificate for M/s-Jay Shree Krishna, Dated:11/02/2023.
 - 15) RDP issued by VVCMC/TP/RDP/VP-0329, 0815 & 0509/363/2021-22, Dated:12/08/2021.
 - 16) Submitted Electric Certificate M/s-Sagar Enterprises, Dated:02/01/2023.
 - 17) Submitted Diesel generator Bill for M/s-Gangadhar Industries Ltd Dated:20/02/2023.
 - 18) C.F.O. site visit Dated:07/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building No. 1 (Wing-B) in Sector - II as (Stilt / Ground floor + 14th floor) in 43.85mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Om Surya Enterprises, bearing License No. MFS-LA/RF-93, MFS-LA/RD-92 & has submitted Certificate on 06/02/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 3453.06sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **07/08/2023** for inspection from the point of view of fire prevention & protection provided by “M/s-Shantee Housing” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 16 Nos.
- B) Hose Reel Hose has been installed in every floor – 14 Nos.
- C) Single Door Hose Box – 05 Nos.
- D) Hydrant Valve - 16 Nos.
- E) Two Way Inlet - 01 Nos.
- F) MCP Cum Hooter - 14 Nos.
- G) Fire Alarm Panel - 01 Nos.
- H) Main Pump - 01 Nos.
- I) Jockey Pump - 01 Nos.
- J) Booster Pump - 01 Nos.
- K) Butterfly Valve (80mm) - 02 Nos.
- L) Butterfly Valve (100mm) - 02 Nos.

Mr. D. D. 69/ Aug 123

- M) NRV (80MM) - 02 Nos.
- N) NRV (100mm) - 01 Nos.
- O) Sign Edges - 1 Job.
- P) RYB - 01 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs. 5.65,000/- vide Receipt No. 312290, DD.No.026027 (Bassein Catholic Bank), Dated:20/07/2015; Rs.1,20,000/- vide Receipt No.470134, Book No.01, DD.No.020305 (Bassein Catholic Bank), Dated:29/04/2016 & Rs.3,25,000/- vide Receipt No.69135, Book No.692, DD.No.001854 (Bassein Catholic Bank), Dated:11/03/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "S. J. K.", written over the official title.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Shantee Housing.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/997/2023-24

DATE: 09/08/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shah Gattani Cosultants,
103, Lucky Palace, Near SBI Bank,
Station Road, Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building & Residential with Shopline Building Type YI(1A) 10, 11, Type YI2A-12, Type YI(1A) 13, Type TI(1A) 14, 15, 16, Type YI(1A), 17, 18, Residential Building Type YI(1B) 19, 20 & Type RSI-1 (21, 22, 23) & Podium 1 & 2 in old Avenue "I" & in New Avenue" I1- on land bearing old S.No.5, 5B, 5D, 5F, 5G & New S.No.5/1, 5/2, 5/3, 5/4, 5/5A, 5/5B, 5/5C, 5/5D, 5/5E, 5/6, 5/7, 5/8 of Village:Dongre, Tal-Vasai, Dist-Palghar.

- Ref:- 1) An application received by M/s-Shah Gattani Consultants, Dated:14/07/2023 (VP-0453)
2) An application received by Developer M/s-Evershine Developers, Dated:14/07/2023.
3) Work Completion certificate of M/s-Shah Gattani Consultants, Dated:14/07/2023.
4) Built up area certificate for M/s- M/s-Shah Gattani Consultants, Dated:14/07/2023.
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/110/2018 -19, Dated:09/05/2018.
6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/148/2023 -24, Dated:25/04/2023.
7) Certificate from License Agency M/s-Ceasex Fire Fighters, Dated:06/07/2023. (Form A)
8) Submitted License copy of Maharashtra Fire Services, Dated:21/10/2022.
9) Submitted Lightning Arester Certificate for M/s-R.K.Corporation, Dated:14/07/2023.
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:24/04/2023.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/07/2023.
12) Structure Stability Certificate for M/s-SACPL, Dated:10/07/2023.
13) RDP issued by VVCMC/TP/RDP/VP-0453/81/2018-19, Dated:16/07/2018.
14) RDP issued by VVCMC/TP/RDP/VP-0453/37/2022-23, Dated:24/05/2022.
15) Submitted Electric Certificate M/s-Jignesh Vidyut Service, Dated:11/07/2023.
16) Submitted D.G. Set test Certificate, M/s-Cummins India Ltd, Dated:25/02/2023
17) C.F.O. site visit Dated:24/07/2023.

With reference to Sr.No.1 & 2 above, this office is in receival of your application for your Residential with Shopline Building Type YI(1A) 10, 11 as (Stilt / Ground floor + 14th floor) in 44.95mtrs Height; Type YI2A-12 as (Stilt / Ground floor + 14th floor) in 44.95mtrs Height; Type YI(1A) 13 as (Stilt / Ground floor + 14th floor) in 44.95mtrs Height; Type TI(1A) 14, 15, 16 as (Stilt / Ground floor + 14th floor) in 44.30mtrs Height; Type YI(1A), 17, 18 as (Stilt / Ground floor + 14th floor) in 44.95mtrs Height & Residential Building Type YI(1B) 19, 20 as (Stilt / Ground floor + 14th floor) in 44.95mtrs Height; Type RSI-1 (21, 22, 23) as (Stilt / Ground floor + 14th floor) in 44.95mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Ceasex Fire Fighters, bearing License No. MFS-LA/RF-503, MFS-LA/RD-483 & has submitted Certificate on 06/07/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to YI (1A) - 10, 11 - 6365.80sq.mtrs, YI2A-12 - 3206.38sq.mtrs, YI (1A) - 13 - 3186.86sq.mtrs, TI (1A) - 14, 15, 16 - 8319.33sq.mtrs, YI (1A) - 17, 18 - 6365.80sq.mtrs, YI (1B) - 19 - 3161.96sq.mtrs, YI (1B) - 20 - 3161.96sq.mtrs, RSI-1 (21,22,23) - 12605.58sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 24/07/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Evershine Developers" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

RG - 3 Bldg No.10 to 13

- Main Hydrant Pump (120 Hp) - 01 Nos.
- Main Sprinkler Pump (120 Hp) - 01 Nos.
- Stand by Pump (120 Hp) - 01 Nos.
- Jockey Pump (7.5Hp) - 02 Nos.

2 copy
Received
CMA

- E) Booster Pump (10 Hp) - 04 Nos.
- F) Booster Pump Panel - 04 Nos.
- G) Control Panel - 01 Nos.
- H) Single Hydrant Valve - 60 Nos.
- I) Hose Reel Drum Set - 60 Nos.
- J) Double Door Hose Box Set - 60 Nos.
- K) 2 Way - 01 Nos.
- L) 4 Way - 01 Nos.
- M) Sprinkler - 191 Nos.
- N) Fire Alarm Panel with PA - 04 Nos.
- O) MCP Combined with Hooter - 60 Nos.
- P) Flow Switch - 60 Nos.
- Q) Monitor Module - 08 Nos.
- R) ABC type Fire Extinguisher (06 Kg) - 68 Nos.
- S) Fire Bucket with Bracket - 32 Nos.
- T) Smoke Detectors - 20 Nos.

RG - 2 Bldg No.14 to 16


- a. Main Hydrant Pump (120 Hp) - 01 Nos.
- b. Main Sprinkler Pump (120 Hp) - 01 Nos.
- c. Stand by Pump (120 Hp) - 01 Nos.
- d. Jockey Pump (7.5Hp) - 02 Nos.
- e. Booster Pump (10 Hp) - 03 Nos.
- f. Booster Pump Panel - 03 Nos.
- g. Control Panel - 01 Nos.
- h. Single Hydrant Valve - 45 Nos.
- i. Hose Reel Drum Set - 45 Nos.
- j. Double Door Hose Box Set - 45 Nos.
- k. 2 Way - 01 Nos.
- l. 4 Way - 01 Nos.
- m. Sprinkler - 126 Nos.
- n. Fire Alarm Panel with PA - 03 Nos.
- o. MCP Combined with Hooter - 45 Nos.
- p. Flow Switch - 45 Nos.
- q. Monitor Module - 06 Nos.
- r. ABC type Fire Extinguisher (06 Kg) - 51 Nos.
- s. Fire Bucket with Bracket - 24 Nos.
- t. Smoke Detectors - 15 Nos.

RG - 1 Bldg No.17 to 20

- a) Main Hydrant Pump (120 Hp) - 01 Nos.
- b) Main Sprinkler Pump (120 Hp) - 01 Nos.
- c) Stand by Pump (120 Hp) - 01 Nos.
- d) Jockey Pump (7.5Hp) - 02 Nos.
- e) Booster Pump (10 Hp) - 04 Nos.
- f) Booster Pump Panel - 04 Nos.
- g) Control Panel - 01 Nos.
- h) Single Hydrant Valve - 60 Nos.
- i) Hose Reel Drum Set - 60 Nos.
- j) Double Door Hose Box Set - 60 Nos.
- k) 2 Way - 01 Nos.
- l) 4 Way - 01 Nos.
- m) Sprinkler - 192 Nos.
- n) Fire Alarm Panel with PA - 04 Nos.
- o) MCP Combined with Hooter - 60 Nos.
- p) Flow Switch - 60 Nos.
- q) Monitor Module - 08 Nos.
- r) ABC type Fire Extinguisher (06 Kg) - 68 Nos.
- s) Fire Bucket with Bracket - 32 Nos.
- t) Smoke Detectors - 20 Nos.

RG - 1 Bldg No.21 to 23

- I. Main Hydrant Pump (120 Hp) - 01 Nos.
- II. Main Sprinkler Pump (120 Hp) - 01 Nos.
- III. Stand by Pump (120 Hp) - 01 Nos.
- IV. Jockey Pump (7.5Hp) - 02 Nos.



- V. Booster Pump (10 Hp) - 03 Nos.
- VI. Booster Pump Panel - 03 Nos.
- VII. Control Panel - 01 Nos.
- VIII. Single Hydrant Valve - 45 Nos.
- IX. Hose Reel Drum Set - 45 Nos.
- X. Double Door Hose Box Set - 45 Nos.
- XI. 2 Way - 01 Nos.
- XII. 4 Way - 01 Nos.
- XIII. Sprinkler - 402 Nos.
- XIV. Fire Alarm Panel with PA - 03 Nos.
- XV. MCP Combined with Hooter - 45 Nos.
- XVI. Flow Switch - 45 Nos.
- XVII. Monitor Module - 06 Nos.
- XVIII. ABC type Fire Extinguisher (06 Kg) - 51 Nos.
- XIX. Fire Bucket with Bracket - 24 Nos.
- XX. Smoke Detectors - 15 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Fire & Emergency Service Fees of Rs. 94.01,350/- vide Receipt No.646068, DD.No.621699 & Rs.4,58,650/- vide Receipt No.646067, DD.No.621697 (Oriental Bank), Dated:20/04/2018; Rs.5,40,000/- vide Received No.30307, Book No.304, DD.No.343756 (Punjab National Bank), Dated:20/01/2022; Rs.50,000/- vide Receipt No.69496, Book No.695, DD.No.293676 (Punjab National Bank), Dated:20/04/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "J. K. J.", located above the official title.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Evershine Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1995 /2023-24

DATE: 30 / 08 /2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s – Himesh Gupta & Associates,
103, Shubham Heritage,
Bhind Gopal Bldg, Off Ambadi Road,
Vasai (W), Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building Plot -B Building No. 1 & 2 on land bearing New S.No.55B/Plot A1 to A5, S.No.55B/Plot B1 to B3 & S.No.55B/Plot C1 to C3 (Old S.No.55, H.No.1/1Pt, 1/3Pt, S.No.56, H.No.2, S.No.57, H.No.2/1, 2/2, 3/2 of Village:Kaman, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s –Himesh Gupta & Associates, Dated:25/08/2023. (VP - 2987)
2) An application received by Developer M/s-Gunagya Realtors LLP, Dated:25/08/2023.
3) Built up area certificate for M/s –Himesh Gupta & Associates, Dated:25/08/2023.
4) Work Completed Certificate for M/s –Himesh Gupta & Associates, Dated:25/08/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/1949/ 2022-23, Dated:27/09/2022.
6) Certificate from License Agency M/s-Om Surya Enterprises, Dated:24/07/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:21/02/2023.
8) AMC Certificate by M/s-Gunagya Realtors LLP, Dated:25/08/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/08/2023.
10) Structure Stability Certificate for M/s-Seemu Consultants, Dated:22/07/2023.
11) RDP issued by VVCMC/TP/RDP/VP-2987/457/2022-23, Dated:27/12/2022.
12) CC issued by VVCMC/TP/CC/VP-2987/391/2021-22, Dated:06/12/2021.
13) Submitted Electric Certificate M/s-G.S. Elecon, Dated:22/07/2023.
14) Submitted Diesel generator Test Certificate for M/s-Powerica Ltd, Dated:30/08/2023.
15) C.F.O. site visit Dated:28/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Industrial Building No. 1 & 2 Plot-B as (Ground floor + 1st Pt floor) in 12.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Om Surya Enterprises, bearing License No. MFS-LA/RF-102, MFS-LA/RD-94 & has submitted Certificate on 24/07/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having Gross built up area admeasuring to Bldg No.1 & 2 - 1929.08sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 28/08/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Gunagya Realtors LLP" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Pump (20Hp) - 01 Nos.
- B) Sprinkler Pump (15 Hp) - 01 Nos.
- C) Stand by Pump - (20 Hp) - 01 Nos.
- D) Jockey Pump - (7.5Hp) - 01 Nos.
- E) Jockey Pump - (5 Hp) - 01 Nos.
- F) Butterfly Valve - (150mm) - 01 Nos.
- G) Butterfly Valve - (100mm) - 06 Nos.
- H) Butterfly Valve - (80mm) - 02 Nos.
- I) NRV - (100mm) - 03 Nos.
- J) NRC - (80mm) - 02 Nos.
- K) Hydrant Valve - 09 Nos.
- L) Hose Reel Drum - 02 Nos.
- M) Hose Box - 04 Nos.
- N) Fire Brigade Inlet - 01 Nos.
- O) Sprinkler - 256 Nos.

- P) Fire Extinguisher (06 Kg) - 06 Nos.
Q) MCP cum Hooter - 02 Nos.
R) Fire Alarm Panel - 02 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Capitation & scrutiny Fees of Rs. 3,20,000/-, vide Receipt No.31181, Book No. 312, DD No.000632 (Bassein Catholic Bank), Dated:01/08/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Gunagya Realtors LLP.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1403/2023-24

DATE: 08/09/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s –Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank, Station Road,
Vasai (W), Tal-Vasai, Dist-Palghar.

Sub:- “Final No Objection Certificate” of Commercial Building No.1 in Avenue "L1" on land bearing Old S.No.5, 5B, 5D, 5F, 5G New S.No.5/1, 5/2, 5/3, 5/4, 5/5A, 5/5B, 5/5C, 5/5D, 5/5F, 5/6, 5/7, 5/8 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s –Shah Gattani Consultants, Dated:08/08/2023. (VP - 0453)
2) An application received by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
3) Built up area certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023.
4) Work Completed Certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/854/2018-19, Dated:24/10/2018.
6) Certificate from License Agency M/s-Gs Firecon, Dated:18/07/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:22/03/2023.
8) AMC Certificate by M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/08/2023.
10) Structure Stability Certificate for M/s-J.W. Consultants LLP, Dated:15/06/2023.
11) RDP issued by VVCMC/TP/RDP/VP-0453/150/2018-19, Dated:05/11/2018.
12) Submitted Electric Certificate M/s-Jarsheni Electricals Solutions, Dated:08/08/2023.
13) Submitted Diesel generator Test Certificate for M/s-Supernova Engineers Ltd, Dated:18/07/2023.
14) C.F.O. site visit Dated:19/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Commercial Building No. 1 as (Ground floor + 4th Pt floor) in 17.75mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Gs Firecon, bearing License No. MFS-LA/RF-167 MFS-LA/RD-160 & has submitted Certificate on 18/07/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having Gross built up area admeasuring to 1718.82sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **19/08/2023** for inspection from the point of view of fire prevention & protection provided by “M/s-Keystone Infrastructure Pvt Ltd” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Booster Pump (7.5 Hp) – 01 Nos.
B) 100mm dia Wet Riser
C) 100mm dia Butterfly Valve - 02 Nos.
D) 100mm dia Non Return Valve - 01 Nos.
E) Pressure Gauge - 01 Nos.
F) "Y" Type Strainer - 01 Nos.
G) Pressure Switch - 01 Nos.
H) 15mtr RRL Hose Pipe - 10 Nos.
I) S.S. Branch Pipe - 05 Nos.
J) Single headed landing Valve - 05 Nos.
K) 30mtr Hose Reel Drum - 05 Nos.
L) 68C Pendent Type Sprinkler - 109 Nos.
M) ABC Type Fire Extinguisher (4 Kg) - 10 Nos.
N) Co2 Type Fire Extinguisher (3 Kg) - 02 Nos.
O) 9ltr Fire Bucket - 04 Nos.

o/c
Received
8/9/2023

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Capitation & scrutiny Fees of Rs. 53,95,000/-, vide Receipt No 705559, DD No. 006246, Dated:12/10/2018 of HDFC Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning - VVCMC
2) Developer- M/s-Keystone Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 1403 /2023-24

DATE: 08 /08 /2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s –Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank, Station Road,
Vasai (W), Tal-Vasai, Dist-Palghar.

Sub:- “Final No Objection Certificate” of Commercial Building No.1 in Avenue "L1" on land bearing Old S.No.5, 5B, 5D, 5F, 5G New S.No.5/1, 5/2, 5/3, 5/4, 5/5A, 5/5B, 5/5C, 5/5D, 5/5F, 5/6, 5/7, 5/8 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s –Shah Gattani Consultants, Dated:08/08/2023. (VP - 0453)
2) An application received by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
3) Built up area certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023.
4) Work Completed Certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/854/ 2018-19, Dated:24/10/2018.
6) Certificate from License Agency M/s-Gs Firecon, Dated:18/07/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:22/03/2023.
8) AMC Certificate by M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/08/2023.
10) Structure Stability Certificate for M/s-J.W. Consultants LLP, Dated:15/06/2023.
11) RDP issued by VVCMC/TP/RDP/VP-0453/150/2018-19, Dated:05/11/2018.
12) Submitted Electric Certificate M/s-Jarsheni Electricals Solutions, Dated:08/08/2023.
13) Submitted Diesel generator Test Certificate for M/s-Supernova Engineers Ltd, Dated:18/07/2023.
14) C.F.O. site visit Dated:19/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Commercial Building No. 1 as (Ground floor + 4th Pt floor) in 17.75mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Gs Firecon, bearing License No. MFS-LA/RF-167 MFS-LA/RD-160 & has submitted Certificate on 18/07/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having Gross built up area admeasuring to 1718.82sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 19/08/2023 for inspection from the point of view of fire prevention & protection provided by “M/s-Keystone Infrastructure Pvt Ltd” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Booster Pump (7.5 Hp) – 01 Nos.
- B) 100mm dia Wet Riser
- C) 100mm dia Butterfly Valve - 02 Nos.
- D) 100mm dia Non Return Valve - 01 Nos.
- E) Pressure Gauge - 01 Nos.
- F) "Y" Type Strainer - 01 Nos.
- G) Pressure Switch - 01 Nos.
- H) 15mtr RRL Hose Pipe - 10 Nos.
- I) S.S. Branch Pipe - 05 Nos.
- J) Single headed landing Valve - 05 Nos.
- K) 30mtr Hose Reel Drum - 05 Nos.
- L) 68C Pendent Type Sprinkler - 109 Nos.
- M) ABC Type Fire Extinguisher (4 Kg) - 10 Nos.
- N) Co2 Type Fire Extinguisher (3 Kg) - 02 Nos.
- O) 9ltr Fire Bucket - 04 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Capitation & scrutiny Fees of Rs. 53,95,000/-, vide Receipt No 705559, DD No. 006246, Dated:12/10/2018 of HDFC Bank.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Keystone Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1404/2023-24

DATE: 08/09/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s –Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank, Station Road,
Vasai (W), Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building in Avenue "D1" on land bearing Old S.No.5, 5B, 5D, 5F, 5G New S.No.5/1, 5/2, 5/3, 5/4, 5/5A, 5/5B, 5/5C, 5/5D, 5/5E, 5/6, 5/7, 5/8 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s –Shah Gattani Consultants, Dated:08/08/2023. (VP - 0453)
2) An application received by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
3) Built up area certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023.
4) Work Completed Certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/111/2018-19, Dated:09/05/2018.
6) Certificate from License Agency M/s-Gayatri Enterprises, Dated:24/07/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:14/01/2023.
8) AMC Certificate by M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/08/2023.
10) Structure Stability Certificate for M/s-J.W. Consultants LLP, Dated:15/06/2023.
11) RDP issued by VVCMC/TP/RDP/VP-0453/81/2018-19, Dated:16/07/2018.
12) Submitted Electric Certificate M/s-Jarsheni Electricals Solutions, Dated:08/08/2023.
13) Submitted Diesel generator Test Certificate for M/s-Sterling Generators, Dated:Nil.
14) C.F.O. site visit Dated:19/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Commercial Building as (Stilt / Ground floor + 1st Pt floor) in 7.65mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Gayatri Enterprises, bearing License No. MFS-LA/RF-35 & has submitted Certificate on 024/07/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having Gross built up area admeasuring to 445.07sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 19/08/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Keystone Infrastructure Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Booster Pump – 01 Nos.
B) 150mm Butterfly Valve - 01 Nos.
C) 100mm Butterfly Valve - 02 Nos.
D) 65mm Butterfly Valve - 02 Nos.
E) 25mm dia forged Brass ball Valve - 06 Nos.
F) 15mm dia forged Brass ball Valve - 03 Nos.
G) 100mm dia Non Return Valve - 01 Nos.
H) Dial Type (100mm) Pressure Gauge - 03 Nos.
I) 100mm dia "Y" Strainer - 01 Nos.
J) Pressure Switch - 01 Nos.
K) First aid hose reel - 02 Nos.
L) Single headed landing Valve - 03 Nos.
M) Non - Percolating rubber reinforced lined fire hose pipe - 03 Nos.
N) S.S. Branch Pipe - 03 Nos.
O) Pendent Sprinkler - 49 Nos.
P) Air Release Valve - 02 Nos.

o/c
Received
08/09/23

- Q) Sand Bucket - 03 Nos.
- R) Fire Extinguisher - 03 Nos.
- S) Sight Glass - 02 Nos.
- T) Fire Alarm Control Panel - 01 Nos.
- U) Amplifier - 01 Nos.
- V) Hooter - 02 Nos.
- W) MCP - 02 Nos.
- X) Smoke Detector - 15 Nos.
- Y) Speaker - 04 Nos.
- Z) Mic - 1 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Capitation & scrutiny Fees of Rs. 10,31,350/-, vide Receipt No 646066, DD No. 005847, & Rs. 4,58,650/- vide Receipt No.646069, DD.No.621698, Dated 20/04/2018. Of HDFC Bank & Oriental Bank of Commerce.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "D. D. D." or similar, written over the official name.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Keystone Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1404/2023-24

DATE: 08/09/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s –Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank, Station Road,
Vasai (W), Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building in Avenue "D1" on land bearing Old S.No.5, 5B, 5D, 5F, 5G New S.No.5/1, 5/2, 5/3, 5/4, 5/5A, 5/5B, 5/5C, 5/5D, 5/5F, 5/6, 5/7, 5/8 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s –Shah Gattani Consultants, Dated:08/08/2023.
(VP - 0453)
2) An application received by Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
3) Built up area certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023.
4) Work Completed Certificate for M/s –Shah Gattani Consultants, Dated:08/08/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/111/2018-19, Dated:09/05/2018.
6) Certificate from License Agency M/s-Gayatri Enterprises, Dated:24/07/2023.
(Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:14/01/2023.
8) AMC Certificate by M/s-Keystone Infrastructure Pvt Ltd, Dated:08/08/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:19/08/2023.
10) Structure Stability Certificate for M/s-J.W. Consultants LLP, Dated:15/06/2023.
11) RDP issued by VVCMC/TP/RDP/VP-0453/81/2018-19, Dated:16/07/2018.
12) Submitted Electric Certificate M/s-Jarsheni Electricals Solutions, Dated:08/08/2023.
13) Submitted Diesel generator Test Certificate for M/s-Sterling Generators, Dated:Nil.
14) C.F.O. site visit Dated:19/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Commercial Building as (Stilt / Ground floor + 1st Pt floor) in 7.65mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Gayatri Enterprises, bearing License No. MFS-LA/RF-35 & has submitted Certificate on 024/07/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having Gross built up area admeasuring to 445.07sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 19/08/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Keystone Infrastructure Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Booster Pump – 01 Nos.
- B) 150mm Butterfly Valve - 01 Nos.
- C) 100mm Butterfly Valve - 02 Nos.
- D) 65mm Butterfly Vave - 02 Nos.
- E) 25mm dia forged Brass ball Valve - 06 Nos.
- F) 15mm dia forged Brass ball Valve - 03 Nos.
- G) 100mm dia Non Return Valve - 01 Nos.
- H) Dial Type (100mm) Pressure Gauge - 03 Nos.
- I) 100mm dia "Y" Strainer - 01 Nos.
- J) Pressure Switch - 01 Nos.
- K) First aid hose reel - 02 Nos.
- L) Single headed landing Valve - 03 Nos.
- M) Non - Percolating rubber reinforced lined fire hose pipe - 03 Nos.
- N) S.S. Branch Pipe - 03 Nos.
- O) Pendent Sprinkler - 49 Nos.
- P) Air Release Valve - 02 Nos.

- Q) Sand Bucket - 03 Nos.
- R) Fire Extinguisher - 03 Nos.
- S) Sight Glass - 02 Nos.
- T) Fire Alarm Control Panel - 01 Nos.
- U) Amplifier - 01 Nos.
- V) Hooter - 02 Nos.
- W) MCP - 02 Nos.
- X) Smoke Detector - 15 Nos.
- Y) Speaker - 04 Nos.
- Z) Mic - 1 Nos.

This No Objection certificate shall be treated **valid up to one year** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Capitation & scrutiny Fees of Rs. 10,31,350/-, vide Receipt No 646066, DD No. 005847, & Rs. 4,58,650/- vide Receipt No.646069, DD.No.621698, Dated 20/04/2018. Of HDFC Bank & Oriental Bank of Commerce.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Keystone Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1537/2023-24

DATE: 07/09/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s – One Source Architects,
A-1/203, Philips HSG. Complex,
Near Dattani Square Mall,
Vasai (W), Tal-Vasai, Dist-Palghar.

Sub:- “Final No Objection Certificate” of Industrial Building (Unit No. 2 & 3) on land bearing S.No.33/1/1, S.No.33/1/2 & S.No.43/1 of Village:Tokre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s – One Source Architects, Dated:10/08/2023.
(SPA VP - 089)
2) An application received by Developer Mr.Francis Bavtis Dmello, Dated:10/08/2023.
3) Built up area certificate for M/s – One Source Architects, Dated:10/08/2023.
4) Work Completed Certificate for M/s – One Source Architects, Dated:10/08/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/3434/2022-23, Dated:02/03/2023.
6) Certificate from License Agency M/s-Shree Fire Guard Co, Dated:17/06/2023.
(Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:18/06/2022.
8) AMC Certificate by M/s-Shree Fire Guard Co, Dated:03/06/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/08/2023.
10) Structure Stability Certificate for Er.Pragnesh Oza, Dated:10/06/2023.
11) RDP issued by VVCMC/TP/RDP/SPA VP-089/05/2022-23, Dated:25/05/2022.
12) Submitted Electric Certificate M/s-Hina Electricals, Dated:29/06/2023.
13) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines Ltd, Dated:20/06/2023.
14) C.F.O. site visit Dated:16/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Industrial Building (Unit No.2 & 3) as (Ground floor + 1st floor) in 9.15mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-Shree Fire Guard Co,** bearing License No. MFS-LA/RF-376, MFS-LA/RD-360 & has submitted Certificate on 17/06/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 1269.59sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **16/08/2023** for inspection from the point of view of fire prevention & protection provided by “**Mr.Francis Bavtis Dmello**” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hydrant Valve (63mm) - 05 Nos.
- B) Hose Box - 05 Nos.
- C) 2 Way Inlet - 01 Nos.
- D) Hose Reel Drum- 01 Nos.
- E) Main Pump (20 Hp) - 01 Nos.
- F) Jockey Pump (5 Hp) - 01 Nos.
- G) Stand By Pump (20 Hp) - 01 Nos.
- H) Sprinkle Head (68° C) - 08 Nos.
- I) Fire Auto Panel - 01 Nos.
- J) Air Release Valve - 01 Nos.
- K) Pressure Gauge - 01 Nos.
- L) NRV 3" - 01 Nos.
- M) NRV 4" - 02 Nos.
- N) Butter Fly Valve 3" - 02 Nos.
- O) Butter Fly Valve 4" - 05 Nos.
- P) Ring (100mm) - 01 Nos.
- Q) 2 Zone Panel - 01 Nos.
- R) Smoke Detector - 08 Nos.
- S) MCP - 04 Nos.
- T) Hooter - 02 Nos.
- U) FRLS 2 Zones

Heypocho
24/09/23

- V) ABC Type Fire Extinguisher (06 Kg) - 08 Nos.
W) Co2 Type (02 Kg) - 04 Nos.
X) Fire Bucket - 02 Nos.

This No Objection certificate shall be treated **valid up to one year** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs. 80,000/- vide Receipt No. 69100, Book No.691, DD.No.015170 (Bassein Catholic Bank), Dated:27/02/2023 of Unit No.1; Rs.1,70,000/- vide Receipt No.69101, Book No.691, DD.No.015168 (Bassein Catholic Bank), Dated:27/02/2023 of Unit No.2 & 3; Rs.1,70,000/- vide Receipt No.69102, Book No.691, DD.No.015169 (Bassein Catholic Bank), Dated:27/02/2023 of Unit No.4 & Rs.80,000/- vide Receipt No.69103, Book No.015171 (Bassein Catholic Bank), Dated:27/02/2023 of Amenity Building.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Mr.Francis Bavtis Dmello

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1739/2023-24

DATE: 16/09/2023

FIRE & EMERGENCY DEPARTMENT



To,
Mr. Abhay Raut, Architect,
1104, Gold Crest Business Center,
L.T. Road, Borivali (W),
Mumbai- 400 092.

Sub:- "Final No Objection Certificate" of Residential Building (Wing-A & B) on Plot bearing S.No.20/B/1, 20/B/2 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:-**
- 1) An application received by Mr. Abhay Raut, Architect, Dated:07/09/2023 (VP - 5409)
 - 2) An application received by Developer M/s-CD Builders & Developers, Dated:07/09/2023.
 - 3) Built up area certificate for Mr. Abhay Raut, Architect, Dated:07/09/2023.
 - 4) Work Completed certificate by Mr. Abhay Raut, Architect, Dated:07/09/2023
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/1024/2020-21, Dated:06/03/2021.
 - 6) Certificate from License Agency M/s-Om Surya Enterprises, Dated:21/06/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:21/02/2023.
 - 8) AMC Certificate by M/s-CD Builders & Developers, Dated:01/07/2023.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:08/09/2023.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:09/09/2023.
 - 11) Structure Stability Certificate for M/s-Jay Shree Krishna Consulting Engineering, Dated:20/03/2023.
 - 12) RDP issued by VVCMC/TP/RDP/VP-05409/158/2022-23, Dated:15/07/2022.
 - 13) Submitted Electric Certificate M/s-Maharashtra Electricals, Dated:23/08/2023.
 - 14) Submitted Diesel generator Bill for M/s-Gangadhar Enterprises, Dated:29/08/2023.
 - 15) C.F.O. site visit Dated:09/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Residential Building (Wing-A & B) Stilt / Ground floor + 16th floor in 51.05mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s- Om Surya Enterprises**, bearing License No. **MFS-LA/RF-102, MFS-LA/RD-94** & has submitted Certificate on 21/06/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-A - 5778.84sq.mtrs & Wing-B - 7931.48sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **09/09/2023** for inspection from the point of view of fire prevention & protection provided by "**M/s-CD Builders & Developers**" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hydrant Valve on Riser - 32 Nos.
- B) Hose Reel Drum - 32 Nos.
- C) Hose Box full Set - 14 Nos.
- D) Two way inlet - 01 Nos.
- E) Courtyard Hydrant - 04 Nos.
- F) Sprinklers - 816 Nos.
- G) MCP cum Hooter - 32 Nos.
- H) Smoke Detector - 64 Nos.
- I) Fire Alarm Panel - 01 Nos.
- J) Fire Extinguisher ABC Type - 34 Nos.



- K) Butterfly Valve (150mm) - 02 Nos.
- L) Butterfly Valve (100mm) - 04 Nos.
- M) Butterfly Valve (80mm) - 06 Nos.
- N) Butterfly Valve (65mm) - 16 Nos.
- O) Butterfly Valve (50mm) - 18 Nos.
- P) NRV (100mm) - 03 Nos.
- Q) NRV (80mm) - 04 Nos.
- R) Main Pump - 01 Nos.
- S) Sprinkler Pump - 01 Nos.
- T) Stand by Pump - 01 Nos.
- U) Jockey Pump - 02 Nos.
- V) Booster Pump - 01 Nos.
- W) RYB - 01 Nos.
- X) Booster Pump - 01 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.8,90,000/- vide Receipt No.895142, Book No.8952, DD.No.670713 (Punjab National Bank), Dated:16/02/2021 & 2,86,000/- vide Receipt No.96016, Book No.961, DD.No.931044 (Bank of Maharashtra), Dated:14/09/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s- CD Builders & Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1960/2023-24

DATE: 26 / 09 / 2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s – Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.



Sub:- “Final No Objection Certificate” of Residential Building No.2 located on land bearing S.No.5, H.No.4 and S.No.9, H.No.12, 13, 14, 15 & 16 of Village:Diwanman, Tal:Vasai, Dist: Palghar. (VP - 1478 & 1504)

- Ref:- 1) An application received by M/s – Prithvi Arch Consultants, Dated:13/09/2023.
2) An application received by M/s-Pragati Associates, Dated:13/09/2023.
3) Work Completion certificate of M/s – Prithvi Arch Consultants, Dated:13/09/2023.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/880/2017-18, Dated:12/01/2018.
5) Built up area certificate for M/s – Prithvi Arch Consultants, Dated:13/09/2023.
6) Certificate from License Agency M/s-Sandeep Construction, Dated:04/09/2023. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:25/03/2023.
8) AMC Certificate by Developer M/s-Sandeep Construction, Dated:01/01/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:28/08/2023.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/09/2023.
11) Structure Stability Certificate for M/s-Finite Consultants, Dated:26/08/2023.
13) RDP issued by VVCMC/TP/RDP/VP-1478 & 1504/226/2020-21, Dated:19/03/2021.
14) Submitted Electric Certificate M/s- Choice Electricals, Dated:06/09/2023.
15) Submitted Diesel generator Test Certificate for M/s-Kirloskar Oil Engines Ltd, Dated:19/06/2023.
16) C.F.O. site visit Dated:13/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receive of your application for your Residential Building No. 2 as Stilt / Ground + 13th Floor in 46.25mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sandeep Construction, bearing License No. MFS-LA/RF-411, MFS-LA/RD-388 and has submitted Certificate on 04/09/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 7570.208sq.mtrs.

With reference to above on 13/09/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by “M/s-Pragati Associates” following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Pump (75 Hp) - 02 Nos.
- B) Jockey Pump (7.5 Hp) - 02 Nos.
- C) Booster Pump (7.5 Hp) - 01 Nos.
- D) Single Headed Hydrant Valve - 28 Nos.
- E) Double Door Fire Hose Box - 33 Nos.
- F) Hose Reel Drum with Shut off Nozzel - 28 Nos.
- G) RRL Type Hose - 66 Nos.
- H) Branch Pipe / Nozzle - 33 Nos.
- I) Fire Pump Panel - 01 Nos.
- J) Courtyard Single Headed Hydrant Valve - 05 Nos.



- K) Fire Brigade Inlet Connection - 01 Nos.
- L) Tank Inlet - 01 Nos.
- M) Pendent Sprinkler 68 degree - 316 Nos.
- N) Side wall Sprinkler 68 degree - 359 Nos.
- O) Sand Bucket - 05 Nos.
- P) Duel Starter - 02 Nos.
- Q) Wet Riser (150mm dia) - 02 Nos.
- R) Sprinkler Riser (150 mm dia) - 01 Nos.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 5,32,800/- vide Receipt No.609481, DD.No.034863 (Vasai Vikas Sahakari Bank), Dated-20/12/2017 & Rs.1,24,000/- vide Receipt No.96027, Book No.961, DD.No.044102 (Vasai Vikas Sahakari Bank), Dated:18/09/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Pragati Associates.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT




Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1900/2023-24

DATE: 26/09/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s – Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.



Sub:- “Final No Objection Certificate” of Residential Building No.2 located on land bearing S.No.5, H.No.4 and S.No.9, H.No.12, 13, 14, 15 & 16 of Village:Diwanman, Tal:Vasai, Dist: Palghar. (VP - 1478 & 1504)

- Ref:- 1) An application received by M/s – Prithvi Arch Consultants, Dated:13/09/2023.
2) An application received by M/s-Pragati Associates, Dated:13/09/2023.
3) Work Completion certificate of M/s – Prithvi Arch Consultants, Dated:13/09/2023.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/880/2017-18, Dated:12/01/2018.
5) Built up area certificate for M/s – Prithvi Arch Consultants, Dated:13/09/2023.
6) Certificate from License Agency M/s-Sandeep Construction, Dated:04/09/2023. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:25/03/2023.
8) AMC Certificate by Developer M/s-Sandeep Construction, Dated:01/01/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:28/08/2023.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/09/2023.
11) Structure Stability Certificate for M/s-Finite Consultants, Dated:26/08/2023.
13) RDP issued by VVCMC/TP/RDP/VP-1478 & 1504/226/2020-21, Dated:19/03/2021.
14) Submitted Electric Certificate M/s- Choice Electricals, Dated:06/09/2023.
15) Submitted Diesel generator Test Certificate for M/s-Kirloskar Oil Engines Ltd, Dated:19/06/2023.
16) C.F.O. site visit Dated:13/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building No. 2 as Stilt / Ground + 13th Floor in 46.25mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sandeep Construction, bearing License No. MFS-LA/RF-411, MFS-LA/RD-388 and has submitted Certificate on 04/09/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 7570.208sq.mtrs.

With reference to above on 13/09/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by “M/s-Pragati Associates” following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Pump (75 Hp) - 02 Nos.
- B) Jockey Pump (7.5 Hp) - 02 Nos.
- C) Booster Pump (7.5 Hp) - 01 Nos.
- D) Single Headed Hydrant Valve - 28 Nos.
- E) Double Door Fire Hose Box - 33 Nos.
- F) Hose Reel Drum with Shut off Nozzel - 28 Nos.
- G) RRL Type Hose - 66 Nos.
- H) Branch Pipe / Nozzle - 33 Nos.
- I) Fire Pump Panel - 01 Nos.
- J) Courtyard Single Headed Hydrant Valve - 05 Nos.



- K) Fire Brigade Inlet Connection - 01 Nos.
- L) Tank Inlet - 01 Nos.
- M) Pendent Sprinkler 68 degree - 316 Nos.
- N) Side wall Sprinkler 68 degree - 359 Nos.
- O) Sand Bucket - 05 Nos.
- P) Duel Starter - 02 Nos.
- Q) Wet Riser (150mm dia) - 02 Nos.
- R) Sprinkler Riser (150 mm dia) - 01 Nos.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 5,32,800/- vide Receipt No.609481, DD.No.034863 (Vasai Vikas Sahakari Bank), Dated-20/12/2017 & Rs.1,24,000/- vide Receipt No.96027, Book No.961, DD.No.044102 (Vasai Vikas Sahakari Bank), Dated:18/09/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Pragati Associates.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1966/2023-24

DATE: 26/09/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s – Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.



Sub:- “Final No Objection Certificate” of Residential Building No.2 located on land bearing S.No.5, H.No.4 and S.No.9, H.No.12, 13, 14, 15 & 16 of Village:Diwanman, Tal:Vasai, Dist: Palghar. (VP - 1478 & 1504)

- Ref:- 1) An application received by M/s – Prithvi Arch Consultants, Dated:13/09/2023.
2) An application received by M/s-Pragati Associates, Dated:13/09/2023.
3) Work Completion certificate of M/s – Prithvi Arch Consultants, Dated:13/09/2023.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/880/2017-18, Dated:12/01/2018.
5) Built up area certificate for M/s – Prithvi Arch Consultants, Dated:13/09/2023.
6) Certificate from License Agency M/s-Sandeep Construction, Dated:04/09/2023. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:25/03/2023.
8) AMC Certificate by Developer M/s-Sandeep Construction, Dated:01/01/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:28/08/2023.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/09/2023.
11) Structure Stability Certificate for M/s-Finite Consultants, Dated:26/08/2023.
13) RDP issued by VVCMC/TP/RDP/VP-1478 & 1504/226/2020-21, Dated:19/03/2021.
14) Submitted Electric Certificate M/s- Choice Electricals, Dated:06/09/2023.
15) Submitted Diesel generator Test Certificate for M/s-Kirloskar Oil Engines Ltd, Dated:19/06/2023.
16) C.F.O. site visit Dated:13/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building No. 2 as Stilt / Ground + 13th Floor in 46.25mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sandeep Construction, bearing License No. MFS-LA/RF-411, MFS-LA/RD-388 and has submitted Certificate on 04/09/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 7570.208sq.mtrs.

With reference to above on 13/09/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by “M/s-Pragati Associates” following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Pump (75 Hp) - 02 Nos.
- B) Jockey Pump (7.5 Hp) - 02 Nos.
- C) Booster Pump (7.5 Hp) - 01 Nos.
- D) Single Headed Hydrant Valve - 28 Nos.
- E) Double Door Fire Hose Box - 33 Nos.
- F) Hose Reel Drum with Shut off Nozzel - 28 Nos.
- G) RRL Type Hose - 66 Nos.
- H) Branch Pipe / Nozzle - 33 Nos.
- I) Fire Pump Panel - 01 Nos.
- J) Courtyard Single Headed Hydrant Valve - 05 Nos.

- K) Fire Brigade Inlet Connection - 01 Nos.
- L) Tank Inlet - 01 Nos.
- M) Pendent Sprinkler 68 degree - 316 Nos.
- N) Side wall Sprinkler 68 degree - 359 Nos.
- O) Sand Bucket - 05 Nos.
- P) Duel Starter - 02 Nos.
- Q) Wet Riser (150mm dia) - 02 Nos.
- R) Sprinkler Riser (150 mm dia) - 01 Nos.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 5,32,800/- vide Receipt No.609481, DD.No.034863 (Vasai Vikas Sahakari Bank), Dated-20/12/2017 & Rs.1,24,000/- vide Receipt No.96027, Book No.961, DD.No.044102 (Vasai Vikas Sahakari Bank), Dated:18/09/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Pragati Associates.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1904/2023-24

DATE: 27/09/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Himesh Gupta & Associates,
103, Shubham Heritage,
Behind Gopal Bldg,
Off Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building on land bearing New S.No.214, H.No.1/6, 1/7, 2/3, 2/4 (Old S.No.214, H.No.1Pt, 2Pt) of Village:Palhar, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Himesh Gupta & Associates, Dated:02/09/2023 (VP- 6187)
- 2) An application received by Developer Mrs.Sonal Bhaven Sheth, Dated:02/09/2023.
 - 3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:02/09/2023.
 - 4) Built up area certificate for M/s-Himesh Gupta & Associates, Dated:02/09/2023.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/1577/2022-23, Dated:15/09/2022.
 - 6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:12/08/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022
 - 8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:04/09/2023.
 - 9) AMC Certificate by M/s-TFPC Infra LLP, Dated:12/08/2023.
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:23/07/2023.
 - 11) Structure Stability Certificate for M/s-Seemu Consultancy, Dated:12/03/2023.
 - 12) RDP issued by VVCMC/TP/RDP/VP-6187/374/2022-23, Dated:13/10/2022.
 - 13) Submitted Electric Certificate M/s-Jivdani Electricals Company, Dated:12/08/2023.
 - 14) Submitted D.G. Set Bill for M/s-Riddance Engineering, Dated:15/06/2023.
 - 15) C.F.O. site visit Dated:12/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial Building as Ground + 2nd Floor in 16.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RF-474, MFS-LA/RD-457 has submitted Certificate on 12/08/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2175.73sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 12/09/2023 for inspection from the point of view of fire prevention & protection provided by "Mrs.Sonal Bhaven Sheth" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Hydrant Pump (30 Hp) - 01 Nos.
- B) Main Sprinkler Pump (15 Hp) - 01 Nos.
- C) Jockey Hydrant Pump (5 Hp) - 01 Nos.
- D) Jockey Sprinkler Pump 5 Hp) - 01 Nos.
- E) Stand by Pump (30 Hp) - 01 Nos.
- F) Booster Pump (5 Hp) - 01 Nos.
- G) Booster Pump Starter - 01 Nos.
- H) Pump Control Panel - 01 Nos.
- I) Courtyard Hydrant Valve - 04 Nos.
- J) Internal Hydrant Valve - 04 Nos.
- K) 2/4 Way Breeching Connection - 02 Nos.

- L) Hose Reel Set - 04 Nos.
- M) Courtyard Hose Box - 04 Nos.
- N) Hose Reel Hose - 04 Nos.
- O) Fire Alarm Control Panel - 01 Nos.
- P) ABC Type Fire Extinguisher (4 Kg) - 08 Nos.
- Q) MCP - 06 Nos.
- R) Hooter - 06 Nos.
- S) Sprinkler Bulb - 51 Nos.
- T) Smoke Detector - 48 Nos.
- U) Butterfly Valve - 18 Nos.
- V) NRV - 06 Nos.
- W) Sand Bucket - 04 Nos.
- X) Signage - 06 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs.80,000/- vide Receipt No.818827, Book No.8189, DD.No.790742, Dated:16/12/2019; Rs.1,30,000/- vide Receipt No.31028, Book No.311, DD.No.013249 (SVC Co Bank Ltd), Dated:22/06/2022; Rs.90,000/- vide Receipt No.30925, Book No.310, DD.No.013236 (SVC Co Bank Ltd) & Now the party has paid Fire & Emergency Service Fees of Rs.50,000/- vide Receipt No.96026, Book No.961, DD.No.381014 (Kotak Mahindra Bank), Dated:18/09/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



[Signature]

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Mrs.Sonal Bhaven Sheth.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/1906/2023-24

DATE: 27/09/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Himesh Gupta & Associates,
103, Shubham Heritage,
Behind Gopal Bldg,
Off Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building Plot C Building No.1 (Gr + 2), Building No.2 (Gr + 2) on land bearing New S.No.55B/Plot A1 to A5, S.No.55B/Plot B1 to B3 & S.No.55B/Plot C1 to C3 (Old S.No.55, H.No.1/1Pt, 1/3Pt, S.No.56, H.No.2, S.No.57, H.No.2/1, 2/2, 3/2 of Village:Kaman, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Himesh Gupta & Associates, Dated:02/09/2023 (VP- 2987)
- 2) An application received by Developer M/s-Gunagya Realtors LLP, Dated:02/09/2023.
 - 3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:02/09/2023.
 - 4) Built up area certificate for M/s-Himesh Gupta & Associates, Dated:02/09/2023.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/4981/2021-22, Dated:21/02/2022.
 - 6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:25/08/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022
 - 8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:14/09/2023.
 - 9) AMC Certificate by M/s-Gunagya Realtors LLP, Dated:02/09/2023.
 - 10) Structure Stability Certificate for M/s-Seemu Consultancy, Dated:02/09/2023.
 - 11) RDP issued by VVCMC/TP/RDP/VP-2987/457/2022-23, Dated:27/12/2022.
 - 12) CC issued by VVCMC/TP/CC/VP-2987/291/2021-22, Dated:06/12/2021.
 - 13) Submitted Electric Certificate M/s-G.S.Elecon, Dated:27/07/2023.
 - 14) Submitted D.G. Set Certificate for M/s-Kirloskar Oil Engines Ltd, Dated:11/08/2009.
 - 15) C.F.O. site visit Dated:14/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Plot C - Industrial Building No. 1 & Industrial Building No. 2 as Ground + 2nd Floor in 16.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RF-474, MFS-LA/RD-457 has submitted Certificate on 25/08/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No.1 - 3341.87sq.mtrs & Bldg No.2 - 4612.70sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 14/09/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Gunagya Realtors LLP" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Hydrant Pump (75 Hp) - 01 Nos.
- B) Main Sprinkler Pump (40 Hp) - 01 Nos.
- C) Jockey Hydrant Pump (15 Hp) - 01 Nos.
- D) Jockey Sprinkler Pump (15 Hp) - 01 Nos.
- E) Stand by Pump (75 Hp) - 01 Nos.
- F) Booster Pump (5 Hp) - 01 Nos.
- G) Booster Pump Starter - 01 Nos.
- H) Pump Control Panel - 01 Nos.
- I) Courtyard Hydrant Valve - 09 Nos.
- J) Internal Hydrant Valve - 12 Nos.

- K) 4 Way Breeching Connection - 02 Nos.
- L) Hose Reel Set - 12 Nos.
- M) Hose Box - 09 Nos.
- N) Hose Reel Hose - 09 Nos.
- O) Fire Alarm Control Panel - 06 Nos.
- P) ABC Type Fire Extinguisher (4 Kg) - 18 Nos.
- Q) MCP - 18 Nos.
- R) Hooter - 18 Nos.
- S) Sprinkler Bulb - 96 Nos.
- T) Smoke Detector - 18 Nos.
- U) Butterfly Valve - 32 Nos.
- V) NRV - 06 Nos.
- W) Sand Bucket - 12 Nos.
- X) Signage - 12 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs.10,00,000/- vide Receipt No.30202, Book No.303, DD.No.069202 (Bassein Catholic Bank), Dated:07/12/2021; Rs.10,00,000/- vide Receipt No.30220, Book No.303, DD.No.000601 (Bassein Catholic Bank), Dated:09/12/2021; Rs.4,80,000/- vide Receipt No.30221, Book No.303, DD.No.000599 (Bassein Catholic Bank), Dated:09/12/2021 & Rs.9,50,000/- vide Receipt No.30222, Book No.303, DD.No.000600 (Bassein Catholic Bank), Dated:09/11/2021; Rs.2,00,000/- vide Receipt No.96010, Book No.961, DD.No.070228 (Bassein Catholic Bank), Dated:14/09/2023; Rs.1,11,000/- vide Receipt No.96011, Book No.961, DD.No.070226 (Bassein Catholic Bank), Dated:14/09/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVMC
2) Developer- M/s-Gunagya Realtors LLP.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/1911/2023-24

DATE: 29/09/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.



Sub:-"Final No Objection Certificate" of Residential with Shopline Building No.1 (Wing-A & B) on land bearing S.No.240 of Village:Nilemore, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Ajay Wade & Associates, Dated:07/09/2023 (VP - 0321)
2) An application received by Developer M/s-Om Sai Developers, Dated:07/09/2023.
3) Built up area certificate for M/s-Ajay Wade & Associates, Dated:07/09/2023.
4) Work Completed certificate by M/s-Ajay Wade & Associates, Dated:07/09/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/633/2017-18, Dated:17/10/2017.
6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/026/2021-22, Dated:08/04/2022.
7) Certificate from License Agency M/s-Kinjal Enterprises, Dated:08/09/2023 (Form A)
8) Submitted License copy of Maharashtra Fire Services, Dated:04/09/2023.
9) AMC Certificate by M/s-Om Sai Developers, Dated:14/08/2023.
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:25/07/2023.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/09/2023.
12) Structure Stability Certificate for Mr.Paresh Unnarkar Consulting Structural Engineers, Dated:02/08/2023.
13) RDP issued by VVCMC/TP/RDP/VP-0321/473/2021-22, Dated:22/09/2021.
14) CC issued by VVCMC/TP/CC/VP-0321/695, Dated:22/07/2011.
15) CC issued by VVCMC/TP/CC/VP-0321/694, Dated:22/07/2011.
16) Submitted Electric Certificate M/s-Maharashtra Electricals, Dated:23/08/2023.
17) Submitted Diesel generator test certificate for M/s-Ashok Leyland Ltd, Dated:16/05/2023.
18) C.F.O. site visit Dated:11/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline Building No. 1 (Wing-A & B) Shop / Stilt / Ground floor + 11th floor in 35.00mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Kinjal Enterprises, bearing License No. MFS-LA/RF-438, MFS-LA/RD-411 & has submitted Certificate on 08/09/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-A - 1724.81sq.mtrs & Wing-B - 2639.66sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 11/09/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Om Sai Developers" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Risers 1500mm dia for each wing - 02 Nos.
- B) Booster Pump (7.5 Hp) each wing - 02 Nos.
- C) Landing Valve at each floor - 22 Nos.
- D) Courtyard Hydrant System - 05 Nos.
- E) Fire Extinguishers ABC Type (6 Kg) - 24 Nos.
- F) Hose Box with canvas hose & Branch pipe - 04 Nos.



- G) Fire Inlet - 01 Nos.
- H) Butterfly Valve 3", 4", 6" - 15 Nos.
- I) Air release valve - 02 Nos.
- J) Starter for Booster Pump - 02 Nos.
- K) Manual Fire Alarm PA Panel System - 02 Nos.
- L) MCP Hooter Pill Box - 22 Nos.
- M) Main Pump (40 Hp) - 01 Nos.
- N) Sprinkler Pump (30 Hp) - 01 Nos.
- O) Jockey Pump (7.5 Hp) - 02 Nos.
- P) Sprinkler - 388 Nos.
- Q) Electric Control Panel - 01 Nos.
- R) Smoke Detector - 02 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.3,40,000/- vide Receipt No.267411, Book No.36, DD.No.041014 (Axis Bank), Dated:27/01/2015 & Rs.3,40,000/- vide Receipt No.267410, Book No.36, DD.No.041013 (Axis Bank), Dated:27/01/2015. & Rs.2,00,000/- vide Receipt No.30227, Book No.303, DD.No.027228 (Axis Bank), Dated:18/12/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



[Signature]

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Om Sai Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

- G) Fire Inlet - 01 Nos.
- H) Butterfly Valve 3", 4", 6" - 15 Nos.
- I) Air release valve - 02 Nos.
- J) Starter for Booster Pump - 02 Nos.
- K) Manual Fire Alarm PA Panel System - 02 Nos.
- L) MCP Hooter Pill Box - 22 Nos.
- M) Main Pump (40 Hp) - 01 Nos.
- N) Sprinkler Pump (30 Hp) - 01 Nos.
- O) Jockey Pump (7.5 Hp) - 02 Nos.
- P) Sprinkler - 388 Nos.
- Q) Electric Control Panel - 01 Nos.
- R) Smoke Detector - 02 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.3,40,000/- vide Receipt No.267411, Book No.36, DD.No.041014 (Axis Bank), Dated:27/01/2015 & Rs.3,40,000/- vide Receipt No.267410, Book No.36, DD.No.041013 (Axis Bank), Dated:27/01/2015. & Rs.2,00,000/- vide Receipt No.30227, Book No.303, DD.No.027228 (Axis Bank), Dated:18/12/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Om Sai Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 1911 /2023-24

DATE: 29 /09/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:-"Final No Objection Certificate" of Residential with Shopline Building No.1 (Wing-A & B) on land bearing S.No.240 of Village:Nilemore, Tal:Vasai, Dist:Palghar.

- Ref:-
- 1) An application received by M/s-Ajay Wade & Associates, Dated:07/09/2023 (VP - 0321)
 - 2) An application received by Developer M/s-Om Sai Developers, Dated:07/09/2023.
 - 3) Built up area certificate for M/s-Ajay Wade & Associates, Dated:07/09/2023.
 - 4) Work Completed certificate by M/s-Ajay Wade & Associates, Dated:07/09/2023
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/633/ 2017-18, Dated:17/10/2017.
 - 6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/026 /2021-22, Dated:08/04/2022.
 - 7) Certificate from License Agency M/s-Kinjal Enterprises, Dated:08/09/2023 (Form A)
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:04/09/2023.
 - 9) AMC Certificate by M/s-Om Sai Developers, Dated:14/08/2023.
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:25/07/2023.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/09/2023.
 - 12) Structure Stability Certificate for Mr.Paresh Unnarkar Consulting Structural Engineers, Dated:02/08/2023.
 - 13) RDP issued by VVCMC/TP/RDP/VP-0321/473/2021-22, Dated:22/09/2021.
 - 14) CC issued by VVCMC/TP/CC/VP-0321/695, Dated:22/07/2011.
 - 15) CC issued by VVCMC/TP/CC/VP-0321/694, Dated:22/07/2011.
 - 16) Submitted Electric Certificate M/s-Maharashtra Electricals, Dated:23/08/2023.
 - 17) Submitted Diesel generator test certificate for M/s-Ashok Leyland Ltd, Dated:16/05/2023.
 - 18) C.F.O. site visit Dated:11/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Residential with Shopline Building No. 1 (Wing-A & B) Shop / Stilt / Ground floor + 11th floor in 35.00mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Kinjal Enterprises, bearing License No. MFS-LA/RF-438, MFS-LA/RD-411 & has submitted Certificate on 08/09/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-A - 1724.81sq.mtrs & Wing-B - 2639.66sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 11/09/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Om Sai Developers" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Risers 1500mm dia for each wing - 02 Nos.
- B) Booster Pump (7.5 Hp) each wing - 02 Nos.
- C) Landing Valve at each floor - 22 Nos.
- D) Courtyard Hydrant System - 05 Nos.
- E) Fire Extinguishers ABC Type (6 Kg) - 24 Nos.
- F) Hose Box with canvas hose & Branch pipe - 04 Nos.





VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2344/2023-24

DATE: 27/10/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Design Consortium Architects,
Pride 16, 2nd Floor,
Opp Ashar IT park,
Road No.16-Z, Wagle Industrial Estate,
Thane (W) - 400 604.

Sub:-**"Final No Objection Certificate" of Residential Cum Commercial Building No.1 Wing-B & Parking Tower on land bearing S.No.392, Plot No.5 & 6 of Village:Bolini, Tal:Vasai, Dist:Palghar.**

- Ref:-
- 1) An application received by M/s-Design Consortium Architects, Dated:11/10/2023. (VP - 5111)
 - 2) An application received by Developer M/s-Shree Vainkatesh Co Op Hsg. Society, Dated:11/10/2023.
 - 3) Gross built up area certificate for M/s-Design Consortium Architects, Dated:11/10/2023.
 - 4) Work Completed certificate by M/s-Design Consortium Architects, Dated:11/10/2023.
 - 5) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/008/2015-16, Dated:06/04/2015.
 - 6) This office Revised Provisional No Objection Certificate No. VVCMC/FIRE/HQ/16/2018-19, Dated:09/04/2018.
 - 7) This office Final No Objection Certificate No.VVCMC/FIRE/HQ/816/2019-20, Dated:22/10/2019.
 - 8) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:22/05/2023. (Form A)
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:30/03/2023.
 - 10) AMC Certificate by M/s-Shree Vainkatesh Co Op Hsg. Society, Dated:10/10/2023
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:13/12/2022.
 - 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:14/10/2023.
 - 13) Structure Stability Certificate for M/s-Nimisha Structural Design Academy, Dated:30/06/2023.
 - 14) RDP issued by VVCMC/TP/RDP/VP-5111/88/2018-19, Dated:21/07/2018.
 - 15) Submitted Electric Certificate M/s-Eshwari Electricals, Dated:30/06/2023.
 - 16) Submitted Diesel generator Bill for M/s-Goel Power Engineers, Dated:22/06/2019
 - 17) C.F.O. site visit Dated:14/10/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Residential Cum Commercial Building No.1 (Wing-B & Parking Tower) as (Stilt / Ground floor + 12th floor) in 41.40mtrs Height.** as at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sadanand Fire Systems, bearing License No. MFS-LA/RF-181, MFS-LA/RD-170 & has submitted Certificate on 22/05/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3070.21sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 14/10/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Shree Vainkatesh Co Op Hsg. Society" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Vertical Riser - 01 Nos.
- B) Single Landing Valves - 01 Nos.
- C) Courtyard Hydrant - 04 Nos.

- D) Hose Box - 10 Nos.
- E) Hose Reel Hose - 12 Nos.
- F) Hydrant Main Pump (75 Hp) - 01 Nos.
- G) Sprinkler Main Pump (75 Hp) - 01 Nos.
- H) Sprinkler Jockey Pump (7.5 Hp) - 02 Nos.
- I) Booster Pump (10 Hp) - 02 Nos.
- J) Siamese Connection - 01 Nos.
- K) Fire Brigade Inlet - 01 Nos.
- L) Fire Extinguisher - 08 Nos.
- M) Fire Buckets with Sand - 04 Nos.
- N) Fire Alarm Systems - 01 Set.
- O) Smoke Detectors - 02 Nos.
- P) Sprinkler

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs. 6,90,000/- vide Receipt No.312209, DD.No.032239 (Vasai Vikas Co Op Bank), Dated:06/04/2015; Rs.2,00,000/- vide Receipt No.254510, Dated:20/06/2012 & Rs.4,40,000/- vide Receipt No.96078, Book No.961, DD.No.044257 (Vasai Vikas Sahakari Bank), Dated:11/10/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you

*Received
Gharat*



[Signature]
**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Shree Vainkatesh Co Op Hsg. Society.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2530/2023-24

DATE: 07/11/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s - En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No.1 & Industrial / Commercial Building No. 2 located on land bearing S.No.47/5D/2, S.No.48 & S.No.49/2 of Village:Gokhivare, Tal:Vasai, Dist: Palghar. (VP - 6183)

- Ref:-
- 1) An application received by M/s-En Con Project Consultants, Dated:07/09/2023.
 - 2) An application received by M/s-Raj Construction, Dated:25/08/2023.
 - 3) Work Completion certificate of M/s-En Con Project Consultants, Dated:07/09/2023.
 - 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2282/2019-20, Dated:24/02/2020.
 - 5) This office Provisional No Objection Certificate No.VVCMC/FIRE/HQ/198/2022-23, Dated:05/05/2022.
 - 6) Built up area certificate for M/s-En Con Project Consultants, Dated:07/09/2023.
 - 7) Certificate from License Agency M/s-Ronak Fire Industries, Dated:14/08/2023. (Form A).
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:25/03/2023.
 - 9) AMC Certificate by Developer Mr.Jayesh B. Desai, Dated:25/08/2023
 - 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:20/10/2023.
 - 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/09/2023.
 - 12) Structure Stability Certificate for M/s-S.S & Associates, Dated:20/03/2023.
 - 13) RDP issued by VVCMC/TP/RDP/VP-6183/44/2022-23, Dated:08/06/2022.
 - 14) Submitted Electric Certificate M/s- Kamlesh Electric, Dated:21/08/2023.
 - 15) Submitted Diesel generator Bill for M/s-Power House, Dated:01/09/2023.
 - 16) C.F.O. site visit Dated:12/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receive of your application for your **Industrial Building No. 1 as Gr + 2nd Floor in 16.35mtrs Height & Industrial / Commercial Building No. 2 as Gr + 3rd Floor** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Ronak Fire Industries, bearing License No. MFS-LA/RF-180, MFS-LA/RD-168 and has submitted Certificate on 14/08/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No. 1 - 1345.22sq.mtrs & Bldg No.2 - 2509.49sq.mtrs.

With reference to above on 12/09/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Raj Construction" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Single Hydrant Valve - 12 Nos.
- B) Two Way Inlet - 01 Nos.
- C) Butterfly Valve (100mm) - 05 Nos.
- D) Butterfly Valve (80mm) - 04 Nos.
- E) Butterfly Valve (65mm) - 04 Nos.
- F) NRV (80mm) - 04 Nos.
- G) NRV (100mm) - 03 Nos.
- H) Gm Air Release Valve - 04 Nos.
- I) Hose Reel Hose - 05 Nos.
- J) Single Door Hose Box - 06 Nos.
- K) Pressure Gauge - 04 Nos.
- L) Main Pump (1800lpm) - 03 Nos.
- M) Jockey Pump (180lpm) - 02 Nos.
- N) Booster Pump (900lpm) - 01 Nos.
- O) Booster Pump (400lpm) - 01 Nos.

- P) ABC Type Fire Extinguisher (06 Kg) - 08 Nos.
- Q) Fire Bucket - 04 Nos.
- R) Mani Control Panel - 01 Nos.
- S) Starter - 02 Nos.
- T) Pendant Type Sprinkler - 140 Nos.
- U) Sluice Valve (150mm) - 01 Nos.
- V) 4 Zone Fire Alarm Panel Board - 01 Nos.
- W) MCP - 04 Nos.
- X) Hooter - 04 Nos.
- Y) Smoke Detector - 64 Nos.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 1,70,000/- vide Receipt No.819039, DD.No.073364 (Bank of Baroda), Dated-24/02/2020 for Bldg No.1 & Rs.1,70,000/- vide Receipt No.819038, DD.No.073367 (Bank of Baroda), Dated:24/02/2020 & Rs.1,30,000/- vide Receipt No.30709, Book No.6183, DD.No.062748 (ICICI Bank), Dated:26/04/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Raj Construction.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



**VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT**



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2572/2023-24

DATE: 07/11/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st floor, Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- Grant of "Final No Objection Certificate" for your Proposed Industrial Building No. 43 on land bearing S.No.266(111), H.No.1,2,3,7,8. S.No.273 (112), H.No.1/1, 1/2, 6, 7, 8, 9. S.No.113(265), H.No.1, 2pt, 3, 4, 6, S.No.264(114), H.No. 1, 2, S.No.263(115), H.No. 2, 3, S.No. (262), (116), 15pt, 16, 17pt, 17pt, 18, 20, S.No. 353(121), S.No. 259(122), H.No. 5pt, 5pt, 6pt, 7, 7pt, 8pt, 9. S.No.325 (123), H.No. 1, 2, 3, 4 S.No. 258 (127), H.No. 1A/9, 1A/15, 1A/16, 1A/17, 1A/18, 1A/19, 1A/20, 1A/25, 1A/26, 1A/28, 1A/29, 1A/30pt, 1A/30pt, 1A/31, 1A/32, 1A/33, 1A/34, 1A/35, 1A/36, 1A/37, 1A/38pt, 1A/38pt, 1A/38pt, 1A/39, S.No.324 (130), S.No.254 (134), H.No.B, S.No.253 (135), H.No.1/1, 1/2, 1/3, 2, 2pt, 2pt, pt, S.No. 322 (136), H.No. 1, 2, 3pt, 3pt, 3pt, pt, 15pt, S.No.274 (139), H.No. 1, 2, 4, 4pt, 5 of Village- Chandansar, Tal-Vasai, Dist-Palghar.

- Ref:- 1) An application received by M/s-Ajay Wade & Associates, Dated:02/10/2023 (VP- 0311)
2) An application received by Developer M/s-Shree Enterprises, Dated:02/10/2023.
3) Work Completion certificate of M/s-Ajay Wade & Associates, Dated:02/10/2023.
4) Construction area certificate for M/s-Ajay Wade & Associates, Dated:02/10/2023.
5) This office Provisional No Objection Certificate No.VVCMC/FIRE/HQ/269/2017-18, Dated:05/07/2017.
6) Certificate from License Agency M/s-Kinjal Enterprises, Dated:08/09/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:04/09/2023
8) AMC Certificate by M/s-Shree Enterprises, Dated:04/09/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:22/10/2023.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/10/2023.
11) Structure Stability Certificate for M/s-Darsh Consult, Dated:29/03/2023.
12) RDP issued by VVCMC/TP/RDP/VP-0311/0270/2013-14, Dated:23/10/2013.
13) Submitted Electric Certificate M/s-Magan Electrical, Dated:10/07/2023.
14) Diesel Generator Bill of M/s-GOEM for Mahindra & Mahindra Ltd, Dated:23/08/2023
15) C.F.O. site visit Dated:05/10/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial Building No. 43 as (Ground floor + 2nd floor) in 15.60mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s-Kinjal Enterprise, bearing License No. MFS-LA/RF-438, MFS-LA/RD-411 & has submitted Certificate on 08/09/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3077.84sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **05/10/2023** for inspection from the point of view of fire prevention & protection provided by "**M/s-Shree Enterprises**" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Risers (100mm dia) - 03 Nos.
- B) Booster Pump (7.5 Hp) - 01 Nos.
- C) Landing Valve - 06 Nos.
- D) Courtyard Hydrants - 06 Nos.

Handwritten signature and date: 08/11/2023

- E) ABC Type Portable Fire Extinguisher (6 Kg) - 04 Nos.
- F) Hose Box - 03 Nos.
- G) Booster pump starter - 01 Nos.
- H) Manual fire Alarm Panel System - 01 Nos.
- I) MCP Hooter Pill Box - 06 Nos.
- J) Main Pump (40 Hp) - 01 Nos.
- K) Sprinkler Pump (30 Hp) - 01 Nos.
- L) Jockey Pump (7.5 Hp) - 01 Nos.
- M) Sprinkler - 202 Nos.
- N) Electric Control Panel - 01 Nos.
- O) Smoke Detector - 96 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs. 4,80,000/- vide Receipt No.572164, DD.No.086395 (HDFC Bank), Dated:01/07/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Shree Enterprises.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2583/2023-24

DATE: 08/11/2023

FIRE & EMERGENCY DEPARTMENT



To,
Architect-James Dias,
8-Suram Complex,
Azad Road, Ramedy,
Vasai, Tal-Vasai, Dist-Palghar-401 201.

Sub:- "Final No Objection Certificate" of Educational Building on land bearing S.No.19, H.No.5 of Village:Tulinj, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by Architect - Mr.James A. Dias, Dated:11/08/2023 (VP- 1743)
- 2) An application received by Developer M/s- The Trust for National Welfare & Education (Regd.), Dated:11/08/2023.
 - 3) Work Completion certificate of Architect - Mr.James A. Dias, Dated:11/08/2023.
 - 4) Built up area certificate for Architect - Mr.James A. Dias, Dated:11/08/2023.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/205/2022-23, Dated:05/05/2022.
 - 6) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:16/04/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:30/03/2023
 - 8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/08/2023.
 - 9) AMC Certificate for M/s- The Trust for National Welfare & Education (Regd.), Dated:22/06/2023.
 - 10) License to work the Lift from Govt. of Maharashtra Industries, Energy & Labour, Dated:01/08/2018.
 - 11) Structure Stability Certificate for Mr.D.D.Kulkarni, Structural Engineering, Dated:13/12/2021.
 - 12) CIDCO issued by Provisional No Objection Certificate No.CIDCO/FIRE/KLM/543/2006, Dated:08/04/2006.
 - 13) Submitted Electric Certificate M/s-Sanjay Electrical Works, Dated:27/05/2023.
 - 14) Submitted D.G. Set Certificate for M/s-Mahindra Heavy Engines Ltd, Dated:01/09/2022.
 - 15) C.F.O. site visit Dated:16/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Educational Building as Ground + 7th Floor in 29.40mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sadanand Fire Systems bearing License No. MFS-LA/RF-181, MFS-LA/RD-170 has submitted Certificate on 16/04/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3660.96sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 16/08/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-The Trust for National Welfare & Education (Regd.)" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hydrant Main Pump (10 Hp) - 01 Nos.
- B) Sprinkler Jockey Pump (5 Hp) - 01 Nos.
- C) Stand by Pump (100 Hp) - 01 Nos.
- D) Vertical Riser - 01 Nos.
- E) Single Landing Valve (Each floor) - 01 Nos.
- F) Courtyard Hydrant - 04 Nos.
- G) Hose Reel Hose - 07 Nos.
- H) Hose Box - 07 Nos.
- I) Siamese Connection - 01 Nos.

Received
JDM
08/11/23

- J) Fire Extinguisher (6 Kg) - 11 Nos.
- K) Fire Buckets - 04 Nos.
- L) Fire Alarm Systems - 01 Set.
- M) Smoke Detectors - 90 Nos.
- N) Sprinkler All floors

This No Objection certificate shall be treated **valid up to one year from date of issue** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire cess Fees from Cidco of Rs.3,300/-, 16,500/-, 40,600/-, Dated:20/04/2006 & Rs.11,100/-, 1400/-, Dated:07/08/2007 & The party has paid Fire & Emergency Service Fees of Rs.42,885/- vide Receipt No.105119, Book No.08, DD.No.023389 (Bassein Catholic Bank), Dated:14/05/2018 & Rs.3,82,100/- vide Receipt No.818420, Book No.8185, DD.No.028602 (Bassein Catholic Bank), Dated:30/08/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-The Trust for National Welfare & Education (Regd.).

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2730/2023-24

DATE:22/11/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor, Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.



Sub:-**"Final No Objection Certificate"** of Industrial Building No. 2A & 2B on land bearing S.No.204, H.No.4A, 4B, 5, S.No.214, H.No.2, 3, S.No.215, H.No.1 of Village:Gokhiware, Tal:Vasai, Dist:Palghar.

- Ref:-
- 1) An application received by M/s-Ajay Wade & Associates, Dated:05/10/2023. (VP - 6079)
 - 2) An application received by Developer M/s-Bliss Developers, Dated:05/10/2023.
 - 3) Total Construction area certificate for M/s- M/s-Ajay Wade & Associates, Dated:05/10/2023.
 - 4) Work Completed certificate by M/s-Ajay Wade & Associates, Dated:05/10/2023
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/844/ 2018-19, Dated:22/10/2018.
 - 6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/390 2020-21, Dated:15/09/2020.
 - 7) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/194/ 2022-23, Dated:05/05/2022.
 - 8) Certificate from License Agency M/s-TFPC Infra LLP, Dated:06/09/2023. (Form A)
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:18/10/2023.
 - 10) AMC Certificate by M/s-Bliss Developers, Dated:05/10/2023.
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:18/09/2023.
 - 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:20/11/2023.
 - 13) Structure Stability Certificate for M/s-Sameer Mohile & Associates, Dated:10/09/2022.
 - 14) RDP issued by VVCMC/TP/RDP/VP-6079/776/2021-22, Dated:04/01/2022.
 - 15) Submitted Electric Certificate M/s-Powertech Electricals, Dated:05/09/2023.
 - 16) Submitted D.G. Set certificate for M/s-Jakson Ltd, Dated:17/02/2023.
 - 17) C.F.O. site visit Dated:20/11/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial Building No. 2A & 2B as Ground + Mezzanine + 2nd floor in 17.95mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s- TFPC Infra LLP**, bearing License No. MFS-LA/RF-474, MFS-LA/RD-457 & has submitted **Certificate on 18/10/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009**. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to Bldg No.2A & 2B - 8237.21sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **20/11/2023** for inspection from the point of view of fire prevention & protection provided by **"M/s-Bliss Developers"** In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Hydrant Pump (40 Hp) - 01 Nos.
- B) Main Sprinkler Pump (20 Hp) - 01 Nos.
- C) Jockey Hydrant Pump (7.5 Hp) - 01 Nos.
- D) Jockey Sprinkler Pump (7.5 Hp) - 01 Nos.
- E) Stand by Pump (40 Hp) - 01 Nos.
- F) Booster Pump (5 Hp) - 02 Nos.
- G) Automatic Booster Pump Starter - 02 Nos.

- H) Pump Control Panel - 01 Nos.
- I) Courtyard Hydrant Valve - 08 Nos.
- J) Internal Hydrant Valve - 04 Nos.
- K) 2 / 4 Way Breeching Connections - 02 Nos.
- L) Hose Reel Set - 04 Nos.
- M) Hose Box - 08 Nos.
- N) Branch Pipe - 08 Nos.
- O) RRL Hose Pipe - 08 Nos.
- P) ABC Type Fire Extinguisher (4 Kg) - 02 Nos.
- Q) Fire Alarm Control Panel - 02 Nos.
- R) MCP - 04 Nos.
- S) Hooter - 04 Nos.
- T) Smoke Detector - 04 Nos.
- U) Butterfly Valve - 24 Nos.
- V) NRV - 07 Nos.
- W) Sprinkler Bulb - 714 Nos.
- X) Glo Signage - 07 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.10,00,000/- vide Receipt No.714227, DD.No.030273 (Axis Bank), Dated:22/10/2018; Rs.1,00,000/- vide Receipt No.30350, Book No.304, DD.No.034707 (Axis Bank), Dated:10/02/2022 & Rs.11,30,000/- vide Receipt No.30349, Book No.304, DD.No.034706 (Axis Bank), Dated:10/02/2022 & Now the party has paid Rs.2,50,000/- vide Receipt No.112503, Book No.1126, DD.No.036563 (Axis Bank), Dated:08/11/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Bliss Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2731/2023-24

DATE: 22/11/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s – En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- "Part Final No Objection Certificate" of Residential Building for Tower No.1 Podium-1 & Podium-2 on land bearing S.No.296, 297, 298, 299, 303, 304, 324 & 390B (Old), S.No.296/1, 296/2, 296/3, 296/4, 296/5, 296/6, 296/7 & 296/8, S.No.297/1, 297/2 & 297/3, S.No.297/1, 298/2, 298/3, 298/4, 298/5 & 298/6 S.No.299/1, 299/2 & 299/3, S.No.303, 304, S.No.324/1, 324/2, 324/3 & 324/4, S.No.390B/1, S.No.390B/2 (New) of Village:Bolini, Tal:Vasai, Dist: Palghar.

- Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:25/08/2023.
2) An application received by M/s-Joyville Shapoorji Housing Pvt Ltd, Dated:25/08/2023.
3) Work Completion certificate of M/s-En Con Project Consultants, Dated:25/08/2023.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/535/2016-17, Dated:30/09/2016.
5) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/431/2019-20, Dated:19/08/2019.
6) Built up area certificate for M/s-En Con Project Consultants, Dated:25/08/2023.
7) Certificate from License Agency M/s-Water Power, Dated:05/01/2023. (Form A).
8) Submitted License copy of Maharashtra Fire Services, Dated:07/05/2022.
9) Certificate from License Agency M/s-J & T Engineering Works, Dated:17/06/2023. (Form A).
10) Certificate from License Agency M/s-VL Astra Engineers (India) Pvt Ltd, Dated:02/01/2023 (Form B)
11) AMC Certificate by M/s-Joyville Shapoorji Housing Pvt Ltd, Dated:12/01/2023.
12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/09/2023.
13) Structure Stability Certificate for M/s-Epicons Consultants Pvt Ltd, Dated:11/01/2023.
14) RDP issued by VVCMC/TP/RDP/VP-0059/143/2019-20, Dated:16/10/2019.
15) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:Nil.
16) Submitted Electric Certificate M/s-Noor Electrical Contractor, Dated:04/01/2023.
17) D.G.Set Bill Certificate of M/s-Sterling Generators Pvt Ltd, Dated:20/12/2022.
18) C.F.O. site visit Dated:05/09/2023.

With reference to Sr.No.1 & 2 above, this office is in receive of your application for your Residential Building for Tower No.1 Podium-1 & Podium-2 as 8.90mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Water Power, bearing License No. MFS-LA/RF-248, MFS-LA/RD-241 and has submitted Certificate on 05/01/2023 & License Agency i.e. M/s-J & T Engineering Works, bearing License No. MFS-LA/RF-569, MFS-LA/RD-545 and has submitted Certificate on 17/06/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5018.56sq.mtrs.

With reference to above on 05/09/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Joyville Shapoorji Housing Pvt Ltd" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Fire Extinguisher (06 Kg) - 08 Nos.
- B) Wet Riser for Drencher - 01 Nos.
- C) Upright Type Sprinkler - 488 Nos.



- D) Pendent Type Sprinkler - 14 Nos.
- E) Wet Riser for Hydrant - 02 Nos.
- F) Double Headed Hydrant Valve - 04 Nos.
- G) RRL Hose Canvas Hose & Coupling - 08 Nos.
- H) Hose Reel Drum - 04 Nos.
- I) Short Branch Pipe - 04 Nos.
- J) Water Curtain Nozzles - 86 Nos.

This certificate shall be treated **valid for the period of one year from the date of issue** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs.33,00,000/- vide Receipt No.487467, DD.No.084307 & Rs.10,40,000/- vide Receipt No.487424, DD.No.033221 (Standard Charter Bank), Dated:29/08/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VCMC

2) Developer- M/s-Joyville Shapoorji Housing Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2759/2023-24

DATE: 01/12/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Shah Gattani Consultants,
103, Lucky Palace,
Near SBI Bank, Station Road
Vasai Road (W),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Residential Building Type 1A Wing-I & Type 1B WING-J in avenue L4 on land bearing old S.No.5, 5B, 5D, 5F, 5G & New S.No.5/1, 5/2, 5/3, 5/4, 5/5A, 5/5B, 5/5C, 5/5D, 5/5F, 5/6, 5/7, 5/8 of Village:Dongre, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received from M/s-Shah Gattani Consultants, Dated:23/11/2023 (VP - 0453)
2) An application received from Developer M/s-Keystone Infrastructure Pvt Ltd, Dated:23/11/2023.
3) Gross built up area certificate from M/s-Shah Gattani Consultants, Dated:23/11/2023.
4) Work Completed Certificate from M/s-Shah Gattani Consultants, Dated:23/11/2023.
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/854/ 2018-19, Dated:24/10/2018.
6) Certificate from License Agency M/s-Gayatri Enterprises, Dated:02/11/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:14/01/2023.
8) AMC Certificate from M/s- Keystone Infrastructure Pvt Ltd, Dated:03/11/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:27/11/2023.
10) Structure Stability Certificate from M/s-JW Consultants LLP, Dated:02/11/2023.
11) Submitted Electric Certificate M/s-KGN Electrical Work, Dated:01/11/2023.
12) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:05/04/2023.
13) Submitted Diesel generator Completion certificate from M/s-Perfect House Pvt Ltd, Dated:31/10/2023.
14) RDP issued by VVCMC/TP/RDP/VP-0453/221/2019-20, Dated:27/11/2019.
15) C.F.O. site visit Dated:27/11/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Residential Building Type 1A (Wing-I) & Type 1B (Wing-J) in Avenue L4 as (Stilt / Ground + 14th Floor) in 44.20mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Gayatri Enterprises, bearing License No. MFS-LA/RF-35 & has submitted Certificate on 02/11/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having Gross built up area admeasuring to Type 1A (Wing-I) - 4847.85sq.mtrs & Type 1B WING-J - 4847.85.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 27/11/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Keystone Infrastructure Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed – 12 Nos.
- B) Co2 Type Fire Extinguishers has been installed – 12 Nos.
- C) Fire Buckets with Stand - 24 Nos.
- D) Single handed Hydrant Valve - 06 Nos.
- E) Hose Box - 06 Nos.



- F) Pendent Sprinkler - 387 Nos.
- G) Side Wall Sprinkler - 38 Nos.
- H) Main Pump - 02 Nos.
- I) Jockey Pump - 02 Nos.
- J) Alarm Valve - 01 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs. 53,95,000/- vide Receipt No.705559, DD.No.006246 (HDFC Bank), Dated:12/10/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Keystone Infrastructure Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



**VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT**




Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2851 /2023-24

DATE: 15/12/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Himesh Gupta & Associates,
103, Shubham Heritage,
Behind Gopal Bldg,
Off Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial / Commercial Building on land bearing S.No.295, H.No.1/1/1 of Village:Palhar, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by M/s-Himesh Gupta & Associates, Dated:04/12/2023.
(VP - 6272)

- 2) An application received by Developer M/s-Bhakti Ventures,
Dated:04/12/2023.
- 3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:04/12/2023.
- 4) Total Construction area certificate for M/s-Himesh Gupta & Associates,
Dated:04/12/2023.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/789/2022-23,
Dated:02/08/2022.
- 6) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:13/10/2023.
(Form A)
- 7) Submitted License copy of Maharashtra Fire Services, Dated:30/03/2023.
- 8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:14/12/2023.
- 9) AMC Certificate by M/s-Bhakti Ventures, Dated:23/11/2023.
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour, Dated:01/11/2023.
- 11) Structure Stability Certificate for M/s-S.S & Associates, Dated:24/03/2023.
- 12) RDP issued by VVCMC/TP/RDP/VP-6272/278/2022-23, Dated:04/08/2022.
- 13) Submitted Electric Audit Report M/s-Zip Engineers, Dated:20/11/2023.
- 14) Submitted D.G. Set Details for M/s-East West Energy Systems Pvt Ltd,
Dated:26/10/2023.
- 15) C.F.O. site visit Dated:14/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial / Commercial Building as Ground + 2nd upper floor in 16.60mtr Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-Sadanand Fire Systems**, bearing License No. MFS-LA/RF-181, MFS-LA/RD-170 & has submitted Certificate on 13/10/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1885.97sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **14/12/2023** for inspection from the point of view of fire prevention & protection provided by "**M/s-Bhakti Ventures**" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Vertical Riser - 02 Nos.
B) Single Landing Valves on each floor - 02 Nos.
C) Courtyard Hydrant - 04 Nos.
D) Hose Box set with canvas hose - 08 Nos.
E) Hose reel drum sets with shut up nozzle on each floor - 04 Nos.
F) Hydrant Main Pump (25 Hp) - 01 Nos.
G) Sprinkler Pump (25 Hp) - 01 Nos.
H) Jockey Pump (5.5 Hp) - 02 Nos.
I) Booster Pump (10 Hp) - 01 Nos.
J) Siamese Connection at main Gate - 01 Nos.

*Recd. &
Ganesh
95x5613x10*

- K) Fire Inlet - 08 Nos.
- L) Fire Extinguisher - 08 Nos.
- M) Sprinkler Bulbs - 100 Nos.
- N) Smoke Detectors - 40 Nos.
- O) Fire Bucket - 04 Nos.
- P) Fire Alarm System - 01 Set.

This No Objection certificate shall be treated valid for the period of one year from the date of issue. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs. 80,000/- vide Receipt No.819686, Book No.8197, DD No.001685 (Bassein Catholic Bank), Dated:31/12/2020 & Rs.90,000/- vide Receipt No.31179, Book No.312, DD No.033844 (HDFC Bank), Dated:01/08/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director, Town Planning, VCMC
2) Developer- M/s-Bhakti Ventures.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtralfireservice.org or www.mtsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2852/2023-24

DATE: 15/12/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s – En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.1 Wing-E & F in Sector No. III located on land bearing S.No.49, 50, 51, 52, 53, 54, 55, 56, 77, S.No.57, H.No.1 of Village:Achole, Tal: Vasai, Dist: Palghar.

- Ref:-
- 1) An application received by M/s-En Con Project Consultants, Dated:12/07/2023.
 - 2) An application received by M/s-Sai Crystal Group, Dated:12/07/2023.
 - 3) Work Completion certificate of M/s-En Con Project Consultants, Dated:12/07/2023.
 - 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/404/2019-20, Dated:07/08/2019.
 - 5) Total Construction area certificate for M/s-En Con Project Consultants, Dated:12/07/2023.
 - 6) Certificate from License Agency M/s-Jai Jivdani Fire Services, Dated:05/07/2023 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:02/01/2023.
 - 8) AMC Certificate by Developer M/s- Sai Crystal Group, Dated:01/04/2023.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:13/06/2018.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/11/2023.
 - 11) Structure Stability Certificate for M/s-Jay Shree Krishna, Dated:24/03/2023.
 - 12) RDP issued by VVCMC/TP/RDP/VP-0127/067/2015-16, Dated:09/06/2015.
 - 13) Submitted Electric Certificate M/s-Niraj Electrical Works, Dated:05/04/2023.
 - 14) Diesel Engine Test Certificate of M/s-VE Commercial Vehicles Ltd, Dated:18/03/2019.
 - 15) C.F.O. site visit Dated:05/11/2023.

With reference to Sr.No.2 above, this office is in receive of your application for your Residential with Shopline Building No. 1 (Wing-E & F) Sector No. III as Shop / Stilt / Ground + 14th Floor in 43.85mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Jai Jivdani Fire Services, bearing License No. MFS-LA/RF-01, MFS-LA/RD-01 and has submitted Certificate on 05/07/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing - E - 6821.58sq.mtrs & Wing-F - 5096.63sq.mtrs.

With reference to above on 05/11/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Sai Crystal Group" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Courtyard Hydrant Valve – 04 Nos.
- B) Single Landing Hydrant Valve - 28 Nos.
- C) Hose Reel Pipe - 28 Nos.
- D) Hose Box with Hose Pipe - 12 Nos.
- E) Short Branch - 12 Nos.
- F) 2 Way Inlet - 02 Nos.
- G) Fire Alarm Panel - 02 Nos.
- H) MCP & Hooters - 28 Nos.
- I) Manual Fire Alarm System - 02 Nos.

- J) Hydrant Main Fire Pump (25 Hp) - 01 Nos.
- K) Jockey Pump (7.5 Hp) - 01 Nos.
- L) Sprinkler Main Pump (25 Hp) - 01 Nos.
- M) Sprinkler Jockey Pump - 01 Nos.
- N) Hydrant & Sprinkler Pump Panel - 02 Nos.
- O) Sprinkler - 230 Nos.
- P) ABC Type Fire Extinguisher (04 Kg) - 14 Nos.

This certificate shall be treated **valid for the period of one year from the date of issue** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 2,00,000/- vide Receipt No.267444, DD.No.025581 (Bassein Catholic Bank), Dated:05/03/2015 & Rs.2,00,000/- vide Receipt No.267443, DD.No.025580 (Bassein Catholic Bank), Dated- 05/03/2015.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer-M/s-Sai Crystal Group

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2853/2023-24

DATE: 15/12/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s – En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No.1 Wing-G in Sector No. III located on land bearing S.No.49, 50, 51, 52, 53, 54, 55, 56, 77, S.No.57, H.No.1 of Village:Achale, Tal: Vasai, Dist: Palghar.

- Ref:-
- 1) An application received by M/s-En Con Project Consultants, Dated:12/07/2023.
 - 2) An application received by M/s-Aura Navkar Developers, Dated:12/07/2023.
 - 3) Work Completion certificate of M/s-En Con Project Consultants, Dated:12/07/2023.
 - 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/405/2019-20, Dated:07/08/2019.
 - 5) Total Construction area certificate for M/s-En Con Project Consultants, Dated:12/07/2023.
 - 6) Certificate from License Agency M/s-Jai Jivdani Fire Services, Dated:31/03/2023 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:02/01/2023.
 - 8) AMC Certificate by Developer M/s-Aura Navkar Developers, Dated:01/04/2023.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:12/05/2022.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:05/11/2023.
 - 11) Structure Stability Certificate for M/s-Jay Shree Krishna, Dated:24/03/2023.
 - 12) RDP issued by VVCMC/TP/RDP/VP-0127/231/2019-20, Dated:03/12/2019.
 - 13) Submitted Electric Certificate M/s-Niraj Electrical Works, Dated:12/07/2023.
 - 14) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines, Dated:Nil/02/2023.
 - 15) C.F.O. site visit Dated:05/11/2023.

With reference to Sr.No.2 above, this office is in receipt of your application for your Residential with Shopline Building No. 1 (Wing-G) Sector No. III as Shop / Stilt / Ground + 14th Floor in 43.85mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Jai Jivdani Fire Services, bearing License No. MFS-LA/RF-01, MFS-LA/RD-01 and has submitted Certificate on 31/03/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3281.33sq.mtrs.

With reference to above on 05/11/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Aura Navkar Developers" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Courtyard Hydrant Valve – 02 Nos.
- B) Single Landing Hydrant Valve - 14 Nos.
- C) Hose Reel Pipe - 14 Nos.
- D) Hose Box with Hose Pipe - 06 Nos.
- E) Short Branch - 06 Nos.
- F) 2 Way Inlet - 01 Nos.
- G) Fire Alarm Panel - 01 Nos.
- H) MCP & Hooters - 14 Nos.
- I) Manual Fire Alarm System - 01 Nos.

- J) Hydrant Main Fire Pump (25 Hp) - 01 Nos.
- K) Jockey Pump (7.5 Hp) - 01 Nos.
- L) Booster Pump (5 Hp) - 01 Nos.
- M) Booster Pump Starter - 01 Nos.
- N) Hydrant Pump Panel - 01 Nos.
- O) Sprinkler - 80 Nos.
- P) ABC Type Fire Extinguisher (04 Kg) - 07 Nos.

This certificate shall be treated **valid for the period of one year from the date of issue** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 94,01,350/- vide Receipt No.646068, DD.No.621699 & Rs.4,58,650/- vide Receipt No.646067, DD.No.621697 (Oriental Bank of Commerce), Dated- 20/04/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you


CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Aura Navkar Developers

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2856/2023-24

DATE: 15/12/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s – En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial / Commercial Building No.1 & 2 in Plot No.3 located on land bearing S.No.20, H.No.C/2, S.No.22, H.No.1 (Old), S.No.20/C/2/3 (New) of Village:Satali, Tal:Vasai, Dist:Palghar.

- Ref:-
- 1) An application received by M/s-En Con Project Consultants, Dated:02/12/2023.
 - 2) An application received by Mr.Sanjay V. Savla, Dated:02/12/2023.
 - 3) Work Completion certificate of M/s-En Con Project Consultants, Dated:02/12/2023.
 - 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/113/2019-20, Dated:10/05/2019.
 - 5) This office Final No Objection Certificate No.VVCMC/FIRE/HQ/1947/2021-22, Dated:27/09/2021.
 - 6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/578/2022-23, Dated:28/06/2022.
 - 7) Total Construction area certificate for M/s-En Con Project Consultants, Dated:12/07/2023.
 - 8) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:23/10/2023. (Form A).
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:30/03/2023.
 - 10) AMC Certificate by Developer Mr.Sanjay V. Savla, Dated:20/11/2023.
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:04/11/2023.
 - 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/12/2023.
 - 13) Structure Stability Certificate for M/s-GR Consultants, Dated:14/03/2023.
 - 14) RDP issued by VVCMC/TP/RDP/VP-5419-B3/101/2022-23, Dated:29/06/2022.
 - 15) Submitted Electric Certificate M/s-Pradhan Electricals Works, Dated:21/11/2023.
 - 16) Diesel Engine Test Certificate of M/s-Kirloskar Oil Engines Ltd, Dated:07/12/2021.
 - 17) C.F.O. site visit Dated:11/12/2023.

With reference to Sr.No.2 above, this office is in receipt of your application for your Industrial / Commercial Building No. 1 (Plot No.3) as Ground + 3rd Floor in 21.00mtrs Height & Industrial / Commercial Building No. 2 (Plot No.3) as Ground + 3rd Floor in 20.90mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sadanand Fire Systems, bearing License No. MFS-LA/RF-181, MFS-LA/RD-170 and has submitted Certificate on 23/10/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No.1 - 1664.25sq.mtrs & Bldg No.2 - 3471.93sq.mtrs.

With reference to above on 11/12/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr.Sanjay V. Savla" following Fire Fighting arrangements provided were found in satisfactory working condition.

Bldg No.1

- A) Vertical Riser – 01 Nos.
- B) Single Landing Valves on each floor - 01 Nos.
- C) Courtyard Hydrant - 04 Nos.
- D) Hose Box set with Canvas hose - 04 Nos.



- E) Hose Reel drum sets with shut up nozzle on each floor - 01 Nos.
- F) Hydrant Main Pump (40 Hp) - 01 Nos.
- G) Sprinkler Pump (25 Hp) - 01 Nos.
- H) Jockey Pump (7.5 Hp) - 02 Nos.
- I) Booster Pump (5 Hp) - 01 Nos.
- J) Siamese Connection at main gate - 01 Nos.
- K) Fire Inlet - 01 Nos.
- L) Fire Extinguisher - 06 Nos.
- M) Sprinkler Bulbs - 130 Nos.
- N) Smoke Detectors - 35 Nos.
- O) Fire Alarm System - 02 Sets.

Bldg No.2

- a) Vertical Riser - 02 Nos.
- b) Single Landing Valves on each floor - 01 Nos.
- c) Courtyard Hydrant - 04 Nos.
- d) Hose Box set with Canvas hose - 10 Nos.
- e) Hose Reel drum sets with shut up nozzle on each floor - 01 Nos.
- f) Hydrant Main Pump (40 Hp) - 01 Nos.
- g) Sprinkler Pump (25 Hp) - 01 Nos.
- h) Jockey Pump (7.5 Hp) - 02 Nos.
- i) Booster Pump (5 Hp) - 01 Nos.
- j) Siamese Connection at main gate - 01 Nos.
- k) Fire Inlet - 01 Nos.
- l) Fire Extinguisher - 08 Nos.
- m) Sprinkler Bulbs - 325 Nos.
- n) Smoke Detectors - 65 Nos.
- o) Fire Alarm System - 02 Sets.

This certificate shall be treated valid for the period of one year from the date of issue it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.


Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 2,50,000/- vide Receipt No.779292, DD.No.709593 (Bank of India), Dated:10/05/2019; Rs.2,50,000/- vide Receipt No.779290, DD.No.709595 (Bank of India), Dated:10/05/2019; Rs.2,40,000/- vide Receipt No.779289, DD.No.709594 (Bank of India), Dated:10/05/2019; Rs.2,50,000/- vide Receipt No.779291, DD.No.709593 (Bank of India), Dated:10/05/2019 & Rs.4,90,000/- vide Receipt No.31033, Book No.311, DD.No.067567 (Bank of India), Dated:23/06/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you


CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) The Deputy Director Town Planning, VVCMC
2) Developer-Mr.Sanjay V. Savla

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

THA
ENCOM



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2872/2023-24

DATE: 19/12/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7, 8 "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:-"Final No Objection Certificate" of Residential Building No.2 Wing-A & B & Residential Building No.3 Wing-C located on land bearing S.No.48, H.No.5 of Village:Waliv, Tal:Vasai, Dist:Palghar.

- Ref:-
- 1) An application received by M/s-En Con Project Consultants, Dated:11/10/2023. (VP - 5812)
 - 2) An application received by Developer M/s-Heritage Builders & Developers, Dated:11/10/2023.
 - 3) Total Construction area certificate for M/s-En Con Project Consultants, Dated:11/10/2023.
 - 4) Work Completed certificate by M/s-En Con Project Consultants, Dated:11/10/2023
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/33/2019-20, Dated:14/10/2019.
 - 6) Certificate from License Agency M/s-Fire Bird Fire Services, Dated:30/08/2023 (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:01/03/2023.
 - 8) AMC Certificate by M/s-Heritage Builders & Developers, Dated:31/08/2023.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:30/12/2022.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/10/2023.
 - 11) Structure Stability Certificate for M/s-Frames, Dated:14/09/2023.
 - 12) RDP issued by VVCMC/TP/RDP/VP-5812/841/2021-22, Dated:23/03/2022.
 - 13) CC issued by VVCMC/TP/CC/VP-5812/8197/2017-18, Dated:17/03/2018.
 - 14) Submitted Electric Certificate M/s-Shrinath Enterprise, Dated:14/09/2023.
 - 15) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines, Dated:Nil/04/2023.
 - 16) C.F.O. site visit Dated:13/10/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building No. 2 (Wing-A & B) & Residential Building No. 3 (Wing-C) as (Stilt / Ground + 7th floor) in 22.65mtrs Height. as at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Fire Bird Fire Services, bearing License No. MFS-LA/RF-128, MFS-LA/RD-119 & has submitted Certificate on 30/08/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Residential Bldg No.2 - 3145.55sq.mtrs & Residential Bldg No.3 - 2750.30sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 13/10/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Heritage Builders & Developers" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hydrant Valve - 27 Nos.
- B) Butterfly Valve "4" - 05 Nos.
- C) Butterfly Valve "3" - 06 Nos.
- D) NRV "3" - 03 Nos.
- E) NRV "4" - 01 Nos.
- F) Air Release Valve - 04 Nos.

- G) Pressure Gauge - 04 Nos.
- H) Ball Valve "1" - 21 Nos.
- I) Fire Brigade Inlet 2 way - 01 Nos.
- J) Hose Reel Drum - 21 Nos.
- K) Hose Box - 10 Nos.
- L) Booster Pump (5 Hp) - 03 Nos.
- M) Main Electrical Pump (30 Hp) - 01 Nos.
- N) Starter with Cable - 04 Nos.
- O) Fire Panel - 01 Nos.
- P) Sprinkler - 28 Nos.
- Q) MCP / Hooter - 24 Nos.
- R) Smoke Detector - 32 Nos.
- S) Panel Board 10 Zones - 03 Nos.
- T) ABC Type Fire Extinguisher (06 Kg) - 24 Nos.
- U) Co2 Type Fire Extinguisher (4.5 Kg) - 04 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.3,60,000 vide Receipt No.425836, DD.No.004247 (Axis Bank), Dated:23/02/2016.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you


CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Heritage Builders & Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



**VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT**



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2877/2023-24

DATE: 20/12/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s –Sanat Mehta & Associates,
Rameshwar Tower,
A-103, Shimpoli Road,
Next to Gokhale School,
Borivali (W), Mumbai-400 092.

Sub:- **“Final No Objection Certificate” of Residential with Shopline Building No. 1 (Wing-D) in Sector - III on S.No.72 out of larger Layout of land bearing Village:Gokhiware, Tal:Vasai, Dist:Palghar.**

- Ref:- 1) An application received by M/s – Sanat Mehta & Associates, Dated:05/12/2023. (VP - 0329, 0815 & 0509)
2) An application received by Developer Mr.Devendra R. Ladhani, Dated:05/12/2023.
3) Total Construction area certificate for M/s –Sanat Mehta & Associates, Dated:05/12/2023.
4) Work Completed Certificate for M/s – Sanat Mehta & Associates, Dated:05/12/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/3014/2018-19, Dated:05/07/2019.
6) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/2438/2019-20, Dated:31/03/2020.
7) Certificate from License Agency M/s-Bright Infra System Pvt Ltd, Dated:18/10/2023. (Form A)
8) Submitted License copy of Maharashtra Fire Services, Dated:22/07/2023.
9) AMC Certificate by Mr.Devendra R. Ladhani, Dated:19/12/2023.
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:26/04/2023.
11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:12/12/2023.
12) Structure Stability Certificate for M/s-Jay Shree Krishna, Dated:14/08/2023.
13) RDP issued by VVCMC/TP/RDP/VP-0329, 0815 & 0509/672/2022-23, Dated:31/03/2023.
14) Submitted Electric Certificate M/s-Sagar Enterprises, Dated:10/09/2023.
15) Submitted Diesel generator test certificate for M/s-Nidec Industrial Automation, Dated:14/07/2023.
16) C.F.O. site visit Dated:12/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Residential with Shopline Building No. 1 (Wing-D) in Sector - III as (Ground floor + 16th floor) in 49.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Bright Infra System Pvt Ltd, bearing License No. MFS-LA/RF-387, MFS-LA/RD-371 & has submitted Certificate on 18/10/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 7654.53sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **12/12/2023** for inspection from the point of view of fire prevention & protection provided by “**Mr.Devendra R. Ladhani**” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hydrant Main Pump (2400 lpm) - 01 Nos.
- B) Stand by Pump (2400 lpm) - 01 Nos.
- C) Hydrant Sprinkler Pump (2400 lpm) - 01 Nos.
- D) Hydrant Jockey Pump (180 lpm) - 01 Nos.
- E) Hydrant Sprinkler Pump (180 lpm) - 01 Nos.
- F) Head Booster Pump (900 lpm) - 01 Nos.

- G) Single outlet Hydrant Valve - 04 Nos.
- H) Single Door Hose Box - 04 Set.
- I) 2 Way Fire Brigade Intel Connections - 01 Nos.
- J) Single Outlet Hydrant Valve - 16 Nos.
- K) Single Door Hose Box - 08 Set.
- L) Hose Reel Assembly - 16 Nos.
- M) ABC Type Fire Extinguisher (6 Kg) - 15 Nos.
- N) Co2 Type Fire Extinguisher (4.5 Kg) - 01 Nos.
- O) Fire Alarm Panel with PA Connectivity - 01 Nos.
- P) MCP cum Hooter - 17 Nos.
- Q) Smoke Detector - 07 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.


Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs. 2,00,000/- vide Receipt No. 705485, Book No.7055, DD.No.010317 (HDFC Bank), Dated:25/09/2018 & Rs.4,94,000/- vide Receipt No.819063, DD.No.016732 (ICICI Bank), Dated:25/02/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **if any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you


CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC

2) Developer- **Mr.Devendra R. Ladhani.**

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2879/2023-24

DATE: 20/12/2023

FIRE & EMERGENCY DEPARTMENT



To,
Architect-James Dias,
8-Suram Complex,
Azad Road, Ramedy,
Vasai, Tal-Vasai, Dist-Palghar-401 201.

Sub: - "Final No Objection Certificate" of Orphanage Building on land bearing Plot No.55,
56, 57, S.No.71/2, 71/1, 191, 84/1/2, 84/1/3, 84/1/4 of Village:More, Tal:Vasai,
Dist:Palghar.

Ref:- 1) An application received by Architect - Mr.James A. Dias, Dated:11/08/2023
(VP-4050)

- 2) An application received by Developer M/s- Pranab Kanya Sangha,
Dated:11/08/2023.
- 3) Work Completion certificate of Architect - Mr.James A. Dias, Dated:11/08/2023.
- 4) Built up area certificate for Architect - Mr.James A. Dias, Dated:11/08/2023.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/967/2020-21,
Dated:23/02/2020.
- 6) Certificate from License Agency M/s-Ronak Fire Industries, Dated:02/12/2023.
(Form A)
- 7) Submitted License copy of Maharashtra Fire Services, Dated:25/03/2023
- 8) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:16/08/2023.
- 9) AMC Certificate for M/s- Pranab Kanya Sangha, Dated:22/08/2023.
- 10) Structure Stability Certificate for M/s-A.M.Faroz & Associates, Dated:08/12/2020.
- 11) Submitted Electric Certificate M/s-J.D. Electricals, Dated:25/05/2016.
- 12) C.F.O. site visit Dated:16/08/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Orphanage Building as Ground + 2nd Floor in 10.50mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Ronak Fire Industries bearing License No. MFS-LA/RF-180, MFS-LA/RD-168 & has submitted Certificate on 02/12/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 1703.32sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 16/08/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Pranab Kanya Sangha" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Fire Extinguisher (6 Kg) - 02 Nos.
- B) ABC Type Fire Extinguisher (4 Kg) - 04 Nos.
- C) Co2 Type Fire Extinguisher (4.5 Kg) - 01 Nos.
- D) Modular Type Fire Extinguisher (5 Kg) - 02 Nos.

This No Objection certificate shall be treated valid up to one year from the date of issue. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.


Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency service fees of Rs.1,70,000/- vide Receipt No.819007, DD.No.363126 (Canara Bank), Dated:12/02/2020.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Pranab Kanya Sangha.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensee Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



Reviewed
[Signature]



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/2885/2023-24

DATE: 20/12/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s -Himesh Gupta & Associates,
103, Shubham Heritage,
Bhind Gopal Bldg,
Off Ambadi Road,
Vasai Road (W),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Industrial Building on land bearing S.No.157, H.No.1/1, S.No.158, H.No.2/1/B, 2/2 of Village:Kaman, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s -Himesh Gupta & Associates,
Dated:04/12/2023. (VP - 5551)
2) An application received by Developer M/s-Tesla Industrial Construction LLP,
Dated:04/12/2023.
3) Total Construction area certificate for M/s -Himesh Gupta & Associates,
Dated:04/12/2023.
4) Work Completed Certificate for M/s -Himesh Gupta & Associates, Dated:04/12/2023
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/1048/
2021-22, Dated:04/08/2021.
6) Certificate from License Agency M/s-Vision Fire & Safety Engineering,
Dated:20/11/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:01/11/2023.
8) AMC Certificate by M/s-Tesla Industrial Construction LLP, Dated:20/11/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour, Dated:06/12/2023.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/12/2023.
11) Structure Stability Certificate for M/s-Seemu Consultancy, Dated:31/08/2023.
12) RDP issued by VVCMC/TP/RDP/VP-5551/120/2022-23, Dated:30/06/2022.
13) Submitted Electric Certificate M/s-Kamlesh Electric, Dated:10/11/2023.
14) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines,
Dated:Nil/02/2023.
15) C.F.O. site visit Dated:11/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial Building as (Ground + 2nd Floor) in 16.90mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-537, MFS-LA/RD-503 & has submitted Certificate on 20/11/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area measuring to 14391.26sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 11/12/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Tesla Industrial Construction LLP" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Hydrant Main Pump - 03 Nos.
- B) Hydrant Jockey Pump - 02 Nos.
- C) Monoblok Booster Pump - 03 Nos.
- D) First Aid Hose Reel Drum - 10 Nos.
- E) S.S.Single Hydrant Valve - 18 Nos.
- F) Branch Pipe - 18 Nos.
- G) Canvas Pipe - 26 Nos.
- H) 2 Way Inlet Breaching - 01 Nos.

- I) Fire Alarm Control Panel - 03 Nos.
- J) ABC Type Fire Extinguisher (6 Kg) - 38 Nos.
- K) MCP & Hooter - 18 Nos.
- L) Safety Signage's - 01 Job.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs.10.00,000/- vide Receipt No. 895628, Book No.8957, DD.No.080716 (HDFC Bank), Dated:26/08/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Tesla Industrial Construction LLP.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/ 2386/2023-24

DATE: 20/12/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s - En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Dist-Palghar.

Sub:- "Final No Objection Certificate" of School Building No.15 located on land bearing S.No.120, H.No.1, S.No.122, H.No.1, S.No.124, 125, 126, 130, 131, 132, 133, 134, 135 & 259 of Village:Gokhivare, Tal:Vasai, Dist: Palghar. (VP - 3292)

- Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:02/12/2023.
2) An application received by M/s-Society of the Franciscan brothers of Gokhivara, Dated:02/12/2023.
3) Work Completion certificate of M/s-En Con Project Consultants, Dated:02/12/2023.
4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/871/2017-18, Dated:10/01/2018.
5) Total Construction area certificate for M/s-En Con Project Consultants, Dated:02/12/2023.
6) Certificate from License Agency M/s-Shree Fire Guard Co, Dated:04/10/2023. (Form A).
7) Submitted License copy of Maharashtra Fire Services, Dated:08/07/2023.
8) AMC Certificate by M/s-Society of the Franciscan brothers of Gokhivara, Dated:21/09/2023.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:24/11/2023.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:14/12/2023.
11) Structure Stability Certificate for M/s-R.D.Magdum, Dated:30/03/2023.
12) RDP issued by VVCMC/TP/RDP/VP-3292/173/2023-24, Dated:22/11/2023.
13) Submitted Electric Certificate M/s-Micro Power tech Engineers, Dated:08/03/2021.
14) Submitted Diesel generator Bill for M/s-Om Diesel Engineering, Dated:30/09/2021.
15) C.F.O. site visit Dated:14/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **School Building No.15 as Gr + 3rd Floor in 16.45mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. **M/s-Shree Fire Guard Co, bearing License No. MFS-LA/RF-376, MFS-LA/RD-360** and has submitted Certificate on 04/10/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3107.30sq.mtrs.

With reference to above on 14/12/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Society of the Franciscan brothers of Gokhivara" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Booster Pump (7.5 Hp) - 02 Nos.
- B) Booster Pump Starter - 02 Nos.
- C) Smoke Detector - 06 Nos.
- D) LPG Gas Detector - 01 Nos.
- E) Riser (100mm dia) - 04 Nos.
- F) Courtyard Hydrant Valve - 08 Nos.
- G) ABC Type Fire Extinguisher (4 Kg) - 20 Nos.
- H) Hose Reel Pipe - 16 Nos.

- I) Single landing Hydrant Valve - 16 Nos.
- J) Hose Box with Hose Pipe - 20 Nos.
- K) Short Branch Pipe - 20 Nos.
- L) Pressure Gauge - 04 Nos.
- M) 2 Way Inlet - 02 Nos.
- N) Air Release Valve - 04 Nos.
- O) Fire Alarm Panel - 04 Nos.
- P) MCP & Hooter - 16 Nos.
- Q) Co2 Type Fire Extinguisher - 04 Nos.
- R) Manual Fire Alarm System - 04 Nos.
- S) Butterfly Valve - 08 Nos.
- T) NRV - 04 Nos.
- U) Ball Valves - 16 Nos.

This certificate shall be treated valid for the period of one year from the date of issue, it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Fire & Emergency Service Fees of Rs. 5,00,000/- vide Receipt No.609484, DD.No.290029, Dated-21/12/2017 & Rs.5,00,000/- vide Receipt No.609485, DD.No.290030, Dated:21/12/2017 & Now the party has paid Rs.2,87,000/- vide Receipt No.112636, Book No.1127, DD.No.501290 (CSB Bank), Dated:04/12/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to 1) The Deputy Director Town Planning, WCMC
2) Developer- M/s-Society of the Franciscan brothers of Gokhivara.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtratrafficservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2899 /2023-24

DATE: 21 / 12 / 2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Himesh Gupta & Associates,
103, Shubham Heritage,
Behind Gopal Bldg,
Off Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No. 1, 4, 7 & 8 (Ground floor) & 2, 5, 6 (Ground + Mezzanine floor) & Industrial / Office Bldg with Toilet Block (Ground + 1st floor) on land bearing Plot.No.D, S.No.62, H.No.1 Pt of Village:Waliv, Tal:Vasai, Dist:Palghar.

- Ref:-** 1) An application received by M/s-Himesh Gupta & Associates, Dated:16/10/2023 (VP-4502)
2) An application received by Developer M/s-Sridevi Tool Engineers Pvt Ltd, Dated:16/10/2023.
3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:16/10/2023.
4) Total Construction area certificate for M/s-Himesh Gupta & Associates, Dated:16/10/2023.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/262/2016-17, Dated:12/07/2016.
6) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/109/2017-18, Dated:17/05/2017.
7) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/997/2019-20, Dated:28/11/2019.
8) Certificate from License Agency M/s-Shree Fire Guard Co, Dated:17/06/2023 (Form A)
9) Submitted License copy of Maharashtra Fire Services, Dated:18/06/2022.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/12/2023.
11) AMC Certificate by M/s- Sridevi Tool Engineers Pvt Ltd, Dated:28/09/2023.
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:22/05/2023.
11) Structure Stability Certificate for Mr.Arun Bhakri, Dated:23/03/2019.
12) RDP issued by VVCMC/TP/RDP/VP-4502/0257/2013-14, Dated:01/10/2013.
13) Submitted Electric Certificate M/s-S.M. Electricals & Engineers, Dated:23/10/2022.
14) Submitted D.G. Set for M/s-S.M.Electricals & Engineers, Dated:24/10/2023.
15) C.F.O. site visit Dated:11/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial Building No. 1 as Ground floor in 9.00mtrs Height; Building No.2 as Ground + Mezzanine floor in 7.45mtrs Height; Building No.3 Ground + 1st floor in 7.50mtrs Height; Building No.4 as Ground floor in 3.15mtrs Height; Building No.5 as Ground + Mezzanine floor in 9.00mtrs Height; Bldg No.6 as Ground + Mezzanine floor in 9.00mtrs Height; Industrial Building No.7 as Ground floor in 3.15mtrs Height & Bldg No.8 as Ground floor in 3.15mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Shree Fire Guard Co, bearing License No. MFS-LA/RF-318, MFS-LA/RD-307 & has submitted Certificate on 18/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No.1 - 1159.20sq.mtrs; Bldg No.2 - 934.68sq.mtrs; Bldg No.3 - 774.29sq.mtrs; Bldg No.4 - 10.05sq.mtrs; Bldg No.5 - 783.75sq.mtrs; Bldg No.6 - 664.08sq.mtrs; Bldg No.7 - 10.05sq.mtrs & Bldg No.8 - 413.25sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 11/12/2023 for inspection from the point of view of fire prevention &

Huyos h.

21.12.23



protection provided by "M/s-Sridevi Tool Engineers Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Hydrant Pump (50 Hp) - 01 Nos.
- B) Jockey Hydrant Pump (5 Hp) - 01 Nos.
- C) Hydrant Valve - 09 Nos.
- D) Hose Box Double Complete with RRL Pipe & Nozzle - 09 Nos.
- E) 2 Way Inlet - 01 Nos.
- F) Hose Reel Drum Complete - 09 Nos.
- G) Main Pump (50 Hp) - 01 Nos.
- H) Jockey Pump (5 Hp) - 01 Nos.
- I) Sprinkler Head (68 C) - 30 Nos.
- J) Fire Auto Panel - 01 Nos.
- K) Air Release Valve - 01 Nos.
- L) Pressure Gauge - 01 Nos.
- M) Ring 150mm - 01 Nos.
- N) 2 Zone Panel & 4 Zone Panel - 02 Nos.
- O) Smoke Detector - 31 Nos.
- P) MCP - 04 Nos.
- Q) Hooter - 04 Nos.
- R) Fire Extinguisher - 52 Nos.

This No Objection certificate shall be treated valid for the period of one year from the date of issue. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Fire & Emergency Service Fees of Rs. 85,000/- vide Receipt No.226660, DD No.298498, Dated:03/07/2014; Rs.85,000/- vide Receipt No.226661, DD No.298497, Dated:08/07/2014; Rs.80,000/- vide Receipt No.548160, DD.No.970865, Dated-11/05/2017; Rs.80,000/- vide Receipt No.548159, DD.No.970867, Dated-11/05/2017; Rs.80,000/- vide Receipt No.548158, DD.No.970866, Dated-11/05/2017; Rs.40,000/- vide Receipt No.226658, DD.No.298498, Dated-21/06/2016; Rs.40,000/- vide Receipt No.226659, DD.No.726295, Dated-21/06/2016; Rs.80,000/- vide Receipt No.548171, DD.No.970915, Dated-16/05/2017; Rs.80,000/- vide Receipt No.548172, DD.No.970915, Dated-16/05/2017 & Rs.80,000/- vide Receipt No.779395, DD.No.006223, Dated:25/06/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Sridevi Tool Engineers Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2899/2023-24

DATE: 21 / 12 / 2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Himesh Gupta & Associates,
103, Shubham Heritage,
Behind Gopal Bldg,
Off Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial Building No. 1, 4, 7 & 8 (Ground floor) & 2, 5, 6 (Ground + Mezzanine floor) & Industrial / Office Bldg with Toilet Block (Ground + 1st floor) on land bearing Plot.No.D, S.No.62, H.No.1 Pt of Village:Waliv, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Himesh Gupta & Associates, Dated:16/10/2023 (VP-4502)
2) An application received by Developer M/s-Sridevi Tool Engineers Pvt Ltd, Dated:16/10/2023.
3) Work Completion certificate of M/s-Himesh Gupta & Associates, Dated:16/10/2023.
4) Total Construction area certificate for M/s-Himesh Gupta & Associates, Dated:16/10/2023.
5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/262/2016-17, Dated:12/07/2016.
6) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/109/2017-18, Dated:17/05/2017.
7) This office Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/997/2019-20, Dated:28/11/2019.
8) Certificate from License Agency M/s-Shree Fire Guard Co, Dated:17/06/2023 (Form A)
9) Submitted License copy of Maharashtra Fire Services, Dated:18/06/2022.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/12/2023.
11) AMC Certificate by M/s- Sridevi Tool Engineers Pvt Ltd, Dated:28/09/2023.
10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:22/05/2023.
11) Structure Stability Certificate for Mr.Arun Bhakri, Dated:23/03/2019.
12) RDP issued by VVCMC/TP/RDP/VP-4502/0257/2013-14, Dated:01/10/2013.
13) Submitted Electric Certificate M/s-S.M. Electricals & Engineers, Dated:23/10/2022.
14) Submitted D.G. Set for M/s-S.M.Electricals & Engineers, Dated:24/10/2023.
15) C.F.O. site visit Dated:11/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Industrial Building No. 1 as Ground floor in 9.00mtrs Height; Building No.2 as Ground + Mezzanine floor in 7.45mtrs Height; Building No.3 Ground + 1st floor in 7.50mtrs Height; Building No.4 as Ground floor in 3.15mtrs Height; Building No.5 as Ground + Mezzanine floor in 9.00mtrs Height; Bldg No.6 as Ground + Mezzanine floor in 9.00mtrs Height; Industrial Building No.7 as Ground floor in 3.15mtrs Height & Bldg No.8 as Ground floor in 3.15mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Shree Fire Guard Co, bearing License No. MFS-LA/RF-318, MFS-LA/RD-307 & has submitted Certificate on 18/06/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Bldg No.1 - 1159.20sq.mtrs; Bldg No.2 - 934.68sq.mtrs; Bldg No.3 - 774.29sq.mtrs; Bldg No.4 - 10.05sq.mtrs; Bldg No.5 - 783.75sq.mtrs; Bldg No.6 - 664.08sq.mtrs; Bldg No.7 - 10.05sq.mtrs & Bldg No.8 - 413.25sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 11/12/2023 for inspection from the point of view of fire prevention &

protection provided by "M/s-Sridevi Tool Engineers Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Hydrant Pump (50 Hp) - 01 Nos.
- B) Jockey Hydrant Pump (5 Hp) - 01 Nos.
- C) Hydrant Valve - 09 Nos.
- S/D D) Hose Box Double Complete with RRL Pipe & Nozzle - 09 Nos.
- E) 2 Way Inlet - 01 Nos.
- F) Hose Reel Drum Complete - 09 Nos.
- G) Main Pump (50 Hp) - 01 Nos.
- H) Jockey Pump (5 Hp) - 01 Nos.
- I) Sprinkler Head (68 C) - 30 Nos.
- J) Fire Auto Panel - 01 Nos.
- K) Air Release Valve - 01 Nos.
- L) Pressure Gauge - 01 Nos.
- M) Ring 150mm - 01 Nos.
- N) 2 Zone Panel & 4 Zone Panel - 02 Nos.
- O) Smoke Detector - 31 Nos.
- P) MCP - 04 Nos.
- Q) Hooter - 04 Nos.
- R) Fire Extinguisher - 52 Nos.

This No Objection certificate shall be treated valid for the period of one year from the date of issue. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Fire & Emergency Service Fees of Rs. 85,000/- vide Receipt No.226660, DD No.298498, Dated:03/07/2014; Rs.85,000/- vide Receipt No.226661, DD No.298497, Dated:08/07/2014; Rs.80,000/- vide Receipt No.548160, DD.No.970865, Dated-11/05/2017; Rs.80,000/- vide Receipt No.548159, DD.No.970867, Dated-11/05/2017; Rs.80,000/- vide Receipt No.548158, DD.No.970866, Dated-11/05/2017; Rs.40,000/- vide Receipt No.226658, DD.No.298498, Dated-21/06/2016; Rs.40,000/- vide Receipt No.226659, DD.No.726295, Dated-21/06/2016; Rs.80,000/- vide Receipt No.548171, DD.No.970915, Dated-16/05/2017; Rs.80,000/- vide Receipt No.548172, DD.No.970915, Dated-16/05/2017 & Rs.80,000/- vide Receipt No.779395, DD.No.006223, Dated:25/06/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Sridevi Tool Engineers Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



**VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT**



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2944/2023-24

DATE: 27/12/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.

Sub:-**"Final No Objection Certificate" of Industrial Building on land bearing Plot No.1/2, S.No.77, H.No.1 (Pt) of Village:Waliv, Tal:Vasai, Dist:Palghar.**

- Ref:-
- 1) An application received by M/s-Prithvi Arch Consultants, Dated:02/12/2023. (VP - 4192)
 - 2) An application received by Developer M/s-Riddhi Developer, Dated:02/12/2023.
 - 3) Total Construction area certificate for M/s-Prithvi Arch Consultants, Dated:02/12/2023.
 - 4) Work Completed certificate by M/s-Prithvi Arch Consultants, Dated:11/12/2023.
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/385/2016-17, Dated:29/08/2016.
 - 6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/364/2019-20, Dated:25/07/2019.
 - 7) This office Revised Provisional No Objection Certificate No. VVCMC/FIRE/HQ/819/2020-21, Dated:19/01/2021.
 - 8) This office Final No Objection Certificate No.VVCMC/FIRE/HQ/1541/2022/23, Dated:12/09/2022.
 - 9) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/2581/2022-23, Dated:06/12/2022.
 - 10) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/2905/2023-24, Dated:22/12/2023.
 - 11) Certificate from License Agency M/s-Sadanand Fire Systems, Dated:09/11/2023. (Form A)
 - 12) Submitted License copy of Maharashtra Fire Services, Dated:30/03/2023.
 - 13) AMC Certificate by M/s-Riddhi Developer, Dated:11/12/2023
 - 14) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:15/10/2023.
 - 15) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:25/12/2023.
 - 16) Structure Stability Certificate for M/s-Prithvi Arch Consultants, Dated:01/12/2023.
 - 17) RDP issued by VVCMC/TP/RDP/VP-4192/455/2022-23, Dated:27/12/2022.
 - 18) Submitted Electric Certificate M/s-Choice.Electricals, Dated:14/12/2023.
 - 19) Submitted Diesel generator test certificate for M/s-Nidec Industrial Automation India Pvt Ltd, Dated:22/06/2022.
 - 20) C.F.O. site visit Dated:25/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial Building as (Ground floor + 4th floor) in 22.98mtrs Height**, as at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sadanand Fire Systems, bearing License No. MFS-LA/RF-181, MFS-LA/RD-170 & has submitted Certificate on 09/11/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 6916.84sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 25/12/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Riddhi Developer" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

Received
27/12/2023

- A) Vertical Riser - 02 Nos.
- B) Single Landing valves on each floor - 01 Nos.
- C) Courtyard Hydrant - 05 Nos.
- D) Hose Box set with canvas hose - 08 Nos.
- E) Hose reel drum sets with shut up nozzle on each floor - 01 Nos.
- F) Hydrant Main Pump (40 Hp) - 01 Nos.
- G) Sprinkler Main Pump (25 Hp) - 01 Nos.
- H) Sprinkler Jockey Pump (10 Hp) - 01 Nos.
- I) Booster Pump (10 Hp) - 01 Nos.
- J) Siamese Connection at Main Gate - 01 Nos.
- K) Fire Brigade Inlet - 01 Nos.
- L) Fire Extinguisher (Co2 Type) - 11 Nos.
- M) Fire Extinguisher (6 Kg) - 11 Nos.
- N) Fire Buckets with sand - 06 Nos.
- O) Fire Alarm System - 02 Sets.
- P) Smoke Detector - 166 Nos.
- Q) Sprinkler All Floors - 100 Nos.

This No Objection certificate shall be treated valid for the period of one year from the date of issue. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs.85,000/- vide Receipt No. 487344, Dated:01/07/2016; Rs.85,000/- vide Receipt No.487343, Dated:01/07/2016; Rs.85,000/- vide Receipt No.487409, Dated:22/08/2016; Rs.85,000/- vide Receipt No.487408, Dated:22/08/2016; Rs. 10,780 vide Receipt No.1046, Dated:16/03/2004; Rs.1,40,000/- vide Receipt No.487425, Dated:29/08/2016; Rs.1,70,000/- vide Receipt No.779223, Dated:08/04/2019; Rs.3,39,220/- vide Receipt No.818262, Dated:23/07/2019 & Rs.5,00,000/- vide Receipt No.895024, DD.No.338572, Dated:13/01/2021 & Rs.50,000/- vide Receipt No.54694, Book No.547, DD.No.520246 (RBL Bank), Dated:06/12/2022 & Rs.50,000/- vide Receipt No.112737, Book No.8112, DD.No.020369 (HDFC Bank), Dated:19/12/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Riddhi Developer.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensee Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available or www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/2958 /2023-24

DATE: 29 /12 /2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor, Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Industrial / Commercial Building No.1 on land bearing S.No.47, H.No.2/1, 4/2, 4/3 of Village:Bilalpada, Tal:Vasai, Dist:Palghar.

- Ref:-
- 1) An application received by M/s-Ajay Wade & Associates, Dated:06/12/2023. (VP - 5131)
 - 2) An application received by Developer M/s-Aar Kay Enterprises, Dated:06/12/2023.
 - 3) Total Construction area certificate for M/s-Ajay Wade & Associates, Dated:06/12/2023.
 - 4) Work Completed certificate by M/s-Ajay Wade & Associates, Dated:06/12/2023.
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/1460/2021-22, Dated:04/09/2021.
 - 6) Certificate from License Agency M/s-Kinjal Enterprise, Dated:29/11/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:04/09/2023.
 - 8) AMC Certificate by M/s-Aar Kay Enterprises, Dated:08/11/2023
 - 9) License to work the Lift from Govt. of Maharashtra Industries, Energy & Labour, Dated:22/10/2023.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:20/12/2023.
 - 11) Structure Stability Certificate for M/s-Darsh Consultants, Dated:07/11/2023.
 - 12) CC issued by VVCMC/TP/CC/VP-5131/2451/2021-22, Dated:22/09/2021.
 - 13) Submitted Electric Certificate M/s-Zip Engineers, Dated:28/11/2023.
 - 14) Submitted D.G. Set Bill for M/s-Power House, Dated:27/10/2023.
 - 15) C.F.O. site visit Dated:20/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Industrial / Commercial Building No. 1 as (Ground + 3rd floor) in 20.60mtrs Height. as at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Kinjal Enterprise, bearing License No. MFS-LA/RF-438, MFS-LA/RD-411 & has submitted Certificate on 29/11/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2436.04sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **20/12/2023** for inspection from the point of view of fire prevention & protection provided by "M/s-Aar Kay Enterprises" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

1. Risers (100mm) - 02 Nos.
2. Sprinkler Risers (100mm) - 01 Nos.
3. Booster Pump (7.5 Hp) - 01 Nos.
4. Landing Valve at each floor - 03 Nos.
5. Courtyard Ring Hydrants System - 04 Nos.
6. ABC Type Fire Extinguisher (6 Kg) - 05 Nos.
7. Hose Box with Branch Pipe - 04 Nos.
8. 2 Way Fire Inlet - 01 Nos.
9. Butterfly Valve (3", 4") - 12 Nos.
10. Air Release Valve - 01 Nos.
11. Starter for Booster Pump - 01 Nos.



12. Manual Fire Alarm Panel - 01 Nos.
13. MCP Hooter pill box - 04 Nos.
14. Mani Pump (30 Hp) - 01 Nos.
15. Sprinkler Pump (30 Hp) - 01 Nos.
16. Jockey Pump (7.5 Hp) - 02 Nos.
17. Electric Control Panel - 01 Nos.
18. Sprinkler Pendent Type 68° - 204 Nos.
19. Smoke Detector - 50 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs.3,00,000/- vide Receipt No.895542, Book No.8956, DD.No.044905 (HDFC Bank), Dated:23/07/2021 & Rs.1,70,000/- vide Receipt No.895639, Book No.8957, DD.No.125797 (Bharat Bank), Dated:30/08/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Aar Kay Enterprises.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/3637/2023-24

DATE: 16/01/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shape Consultants,
D-1, D-2, Aakanksha Commercial Complex,
Opp HDFC Bank, Achole Road,
Nallasopara (E),
Tal-Vasai, Dist-Palghar.

Sub:-"Final No Objection Certificate" of Residential Building No.1 on land bearing S.No.16A1, H.No.1A/2 & 1A of Village:Virar, Tal:Vasai, Dist:Palghar.

- Ref:-
- 1) An application received by M/s-Shape Consultants, Dated:08/12/2023. (VP - 0039)
 - 2) An application received by Developer M/s-Shree Ganesh Enterprises, Dated:08/12/2023.
 - 3) Total Construction area certificate for M/s-Shape Consultants, Dated:08/12/2023.
 - 4) Work Completed certificate by M/s-Shape Consultants, Dated:08/12/2023.
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/038/2015-16, Dated:17/06/2015.
 - 6) This office Final No Objection Certificate No.VVCMC/FIRE/040/2015-16, Dated:26/06/2015.
 - 7) This office Renewal of No Objection Certificate No.VVCMC/FIRE/HQ/1090/2019-20, Dated:17/12/2019.
 - 8) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/4652/2021-22, Dated:03/12/2021.
 - 9) Certificate from License Agency M/s-Bright Infra System Pvt Ltd, Dated:20/11/2023. (Form A)
 - 10) Submitted License copy of Maharashtra Fire Services, Dated:22/07/2023.
 - 11) AMC Certificate by M/s-Bright Infra System Pvt Ltd, Dated:15/12/2023.
 - 12) License to work the Lift from Govt. of Maharashtra Industries, Energy & Labour, Dated:05/05/2015.
 - 13) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:14/12/2023.
 - 14) Structure Stability Certificate for M/s-Shilplekha Consultants, Dated:24/12/2019.
 - 15) CC issued by CODCO/VVSR/CC/BP-4080/E/3925, Dated:19/05/2009.
 - 16) OC issued by VVCMC/TP/OC/VP-0039/130/2019-20, Dated:04/01/2020.
 - 17) RDP issued by VVCMC/TP/RDP/VP-0039/787/2021-22, Dated:04/01/2022.
 - 18) Submitted Electric Certificate M/s-Maharashtra Electricals, Dated:25/11/2023.
 - 19) Submitted D.G. Set Bill for M/s-Goel Power Controls Pvt Ltd, Dated:24/06/2015.
 - 20) C.F.O. site visit Dated:14/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building No. 1 (Wing-A & B) as (5th / Ground + 7th floor) in 23.25mtrs Height, as at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Bright Infra System Pvt Ltd, bearing License No. MFS-LA/RF-387, MFS-LA/RD-371 & has submitted Certificate on 20/11/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 3219.26sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 14/12/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Shree Ganesh Enterprises" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

1. 450 lpm Submersible Pump - 01 Nos.
2. 400 lpm Booster Pump - 02 Nos.

3. Automatic Smoke Detector - 02 Nos.
4. Single Hydrant Valve External - 04 Nos.
5. Single Hydrant Valve Internal - 14 Nos.
6. Single Door Hose Box - 03 Set.
7. S.S.Branch Pipe - 03 Nos.
8. Hose reel Drum - 14 Nos.
9. Fire Alarm Panel - 02 Nos.
10. MCP & Hooter - 14 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs.2,40,000/- vide Receipt No.312253, Dated:05/06/2015; Rs.96,000/- vide Receipt No.818830, DD.No.117189 (Vasai Vikas Sahakari Bank), Dated:17/12/2019 & Rs.1,00,000/- vide Receipt No.895998, DD.No.118622 (Vasai Vikas Sahakari Bank), Dated:02/12/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Shree Ganesh Enterprises.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/3044/2022-23

DATE: 01/02/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7, 8, "D" Wing, Sethi Palace,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of Residential with Shopline Building on land bearing S.No.317, H.No.12 of Village:Juchandra, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:18/01/2023

- (VP-0784)
- 2) An application received by Developer M/s-Oyster Corporation, Dated:01/01/2023
 - 3) Work Completion certificate of M/s-En Con Project Consultants, Dated:18/01/2023.
 - 4) Built up area certificate for M/s-En Con Project Consultants, Dated:18/01/2023.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/2280/2019-20, Dated:24/01/2020.
 - 6) Certificate from License Agency M/s-Om Surya Enterprises, Dated:11/01/2023 (Form A)
 - 7) AMC Certificate by M/s-Oyster Corporation, Dated:01/01/2023.
 - 8) Submitted License copy of Maharashtra Fire Services, Dated:19/02/2022
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated :Nil.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:27/01/2023.
 - 11) Structure Stability Certificate for Mr:Hiren M. Tanna, Dated:16/03/2022.
 - 12) RDP issued by VVCMC/TP/RDP/VP-0784/304/2014-15, Dated:04/02/2015.
 - 13) Submitted Electric Certificate M/s-Kulswamini Electricals, Dated:12/05/2022.
 - 14) C.F.O. site visit Dated:27/01/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline Building as (Stilt + 7th floor) in 24.40mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Om Surya Enterprises, bearing License No. MFS-LA/F-93 & MFS-LA/D-92 has submitted Certificate on 11/01/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Wing-B – 1636.57sq.mtrs & Wing-C – 1463.62sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **27/01/2023** for inspection from the point of view of fire prevention & protection provided by "M/s-Oyster Corporation" in inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 16 Nos.
- B) Hose Reel Hose has been installed in every floor – 14 Nos.
- C) Hose Box has been installed in Alternate floor – 06 Nos.
- D) Booster Pump – 02 Nos.
- E) Hydrant Valve – 17 Nos.
- F) Fire Alarm Panel – 02 Nos.
- G) MCP & Hooter – 14 Nos.

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006", it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

Recd. 01/Feb/23
N. D. D. S.

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire Cess Fees of Rs.2,40,000/- vide Receipt No.818859, DD.No.049748 (Axis Bank), Dated:21/12/2019.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VCMC
2) Developer- M/s-Oyster Corporation.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available at www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT



Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/3074/2023-24

DATE: 23 / 01 / 2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Vijay Gurav & Associates,
F-11, Cosmos Square,
Chikhaldongri Road,
Global City, Virar (W),
Tal-Vasai, Dist-Palghar.



Sub:-**"Final No Objection Certificate" of Industrial Building on land bearing S.No.70, Plot No.1/3 of Village:Waliv, Tal:Vasai, Dist:Palghar.**

- Ref:-
- 1) An application received by M/s-Vijay Gurav & Associates, Dated:20/12/2023. (VP - 2719)
 - 2) An application received by Developer M/s-Doshi Industrial Construction Pvt Ltd, Dated:20/12/2023.
 - 3) Total Construction area certificate for M/s-Vijay Gurav & Associates, Dated:20/12/2023.
 - 4) Work Completed certificate by M/s-Vijay Gurav & Associates, Dated:20/12/2023.
 - 5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/4483/2021-22, Dated:30/10/2021.
 - 6) Certificate from License Agency M/s-TFPC Infra LLP, Dated:18/12/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:16/09/2023.
 - 8) Submitted AMC Certificate from M/s- TFPC Infra LLP, Dated:18/12/2023
 - 9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:22/12/2023.
 - 10) Structure Stability Certificate for M/s-Vijay Gurav & Associates, Dated:26/10/2023.
 - 11) RDP issued by VVCMC/TP/RDP/VP-2719/336/2022-23, Dated:13/09/2022.
 - 12) Submitted Electric Certificate M/s-The Hind Electric & Engineering Corporation, Dated:02/12/2023.
 - 13) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines Ltd, Dated:25/08/2023.
 - 14) C.F.O. site visit Dated:20/12/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Industrial Building as (Ground + 1st floor) in 10.60mtrs Height.** as at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-TFPC Infra LLP, bearing License No. MFS-LA/RF-474, MFS-LA/RD-457 & has submitted Certificate on 18/12/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 3227.27sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **20/12/2023** for inspection from the point of view of fire prevention & protection provided by **"M/s-Doshi Industrial Construction Pvt Ltd"** In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Main Hydrant Pump (40 Hp) - 01 Nos.
- B) Main Sprinkler Pump (20 Hp) - 01 Nos.
- C) Jockey Hydrant Pump (7.5 Hp) - 01 Nos.
- D) Jockey Sprinkler Pump (7.5 Hp) - 01 Nos.
- E) Stand by Pump (40 Hp) - 01 Nos.
- F) Booster Pump (7.5 Hp) - 01 Nos.
- G) Automatic Booster Pump Starter - 01 Nos.
- H) Automatic Pump Control Panel - 01 Nos.
- I) Courtyard Hydrant Valve - 07 Nos.



alc
Doshi
TFPC

- J) Internal Hydrant Valve - 01 Nos.
- K) 2 Way Breeching Connections - 02 Nos.
- L) Hose Reel Set - 02 Nos.
- M) Hose Box - 08 Nos.
- N) Branch Pipe - 08 Nos.
- O) RRL Hose Pipe - 08 Nos.
- P) ABC Type Fire Extinguisher (4 Kg) - 04 Nos.
- Q) Fire Alarm Control Panel - 01 Nos.
- R) MCP - 02 Nos.
- S) Hooter - 02 Nos.
- T) Smoke Detector - 02 Nos.
- U) Sprinkler Bulb - 94 Nos.
- V) Glo Signage - 05 Nos.
- W) Butterfly Valve - 15 Nos.
- X) NRV - 06 Nos.

This No Objection certificate shall be treated **valid for the period of one year from the date of issue.** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire & Emergency Service Fees of Rs.4,80,000/- vide Receipt No. 895692, Book No.8957, DD.No.034437 (Axis Bank), Dated:07/10/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Doshi Industrial Construction Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/3454/2022-23

DATE: 08/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shah Gattani Cosultants,
103, Lucky Palace, Near SBI Bank,
Station Road, Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building Type HH-57, HH-58, HI-59, HH-60,& HH-61 Cluster – E in Sector F on land bearing New S.No.1, H.No.1, S.No.2, H.No.1, S.No.3, H.No.1, S.No.4, H.No.1, S.No.57, H.No.3, & 6/1, S.No.59, H.No.1/3, S.No.254, H.No.3, 6, 7/1, 7/2 in Village:Achole & S.No.101, 103, 104, 107, 106 in Village:Manikpur & S.No.97B, 105B, 106B, 106, H.No.8, S.No.110, H.No.8/1, in Village:Gokhiware, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Shah Gattani Consultants, Dated:09/01/2023 (VP-0743)
2) An application received by Developer M/s-J.M.G. Realtors Pvt Ltd, Dated:01/12/2022.
3) Work Completion certificate of M/s-Shah Gattani Consultants, Dated:09/01/2023.
4) Built up area certificate for M/s- M/s-Shah Gattani Consultants, Dated:09/01/2023.
5) Cidco issued by Provisional No objection Certificate No. CIDCO/FIRE/KLM/56/04, Dated:09/01/2004.
6) Certificate from License Agency M/s-Vision Fire & Safety Engineering, Dated:20/02/2023. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:04/10/2022
8) AMC Certificate by M/s-J.M.G. Realtors Pvt Ltd, Dated:21/09/2022.
9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:07/01/2022.
10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/02/2023.
11) Structure Stability Certificate for M/s-Vipra Consultants, Dated:27/01/2023.
12) RDP issued by VVCMC/TP/RDP/VP-0743/317/2014-15, Dated:10/02/2015.
13) Submitted Electric Certificate M/s-Sai Sagar Electric Works, Dated:01/02/2023.
14) C.F.O. site visit Dated:17/02/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building Type HH-57, HH-58, HI-59, HH-60,& HH-61 Cluster – E in Sector F as (Stilt / Ground floor + 7th floor) in 23.80mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-491, MFS-LA/RD-473 & has submitted Certificate on 20/02/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 7795.43sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 17/02/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-J.M.G. Realtors Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 45 Nos.
- Co2 Type Fire Extinguishers – 05 Nos.
- Sand Bucket – 05 Nos.
- Hose Reel Hose has been installed in every floor – 35 Nos.
- Hose Box has been installed in Alternate floor – 25 Nos.
- Main Pump – 01 Nos.
- Jockey Pump – 01 Nos.
- Booster Pump – 05 Nos.
- Single Hydrant Valve – 45 Nos.
- Fire Alarm Control Panel - 05 Nos.
- Combine MCP & Hooter – 35 Nos.
- Pendent Sprinkler – 40 Nos.

This No Objection certificate shall be treated valid up to one year It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Fire Cess Fees of Rs. 6.00,000/- vide Receipt No.69127, Book No.692, DD.No.031012 (Kotak Mahindra Bank), Dated:08/03/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-J.M.G. Realtors Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/3454/2022-23

DATE: 08/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shah Gattani Cosultants,
103, Lucky Palace, Near SBI Bank,
Station Road, Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential Building Type HH-57, HH-58, HI-59, HH-60,& HH-61 Cluster – E in Sector F on land bearing New S.No.1, H.No.1, S.No.2, H.No.1, S.No.3, H.No.1, S.No.4, H.No.1, S.No.57, H.No.3, & 6/1, S.No.59, H.No.1/3, S.No.254, H.No.3, 6, 7/1, 7/2 in Village:Achole & S.No.101, 103, 104, 107, 106 in Village:Manikpur & S.No.97B, 105B, 106B, 106, H.No.8, S.No.110, H.No.8/1, in Village:Gokhiware, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Shah Gattani Consultants, Dated:09/01/2023 (VP-0743)
- 2) An application received by Developer M/s-J.M.G. Realtors Pvt Ltd, Dated:01/12/2022.
 - 3) Work Completion certificate of M/s-Shah Gattani Consultants, Dated:09/01/2023.
 - 4) Built up area certificate for M/s- M/s-Shah Gattani Consultants, Dated:09/01/2023.
 - 5) Cidco issued by Provisional No objection Certificate No. CIDCO/FIRE/KLM/56/04, Dated:09/01/2004.
 - 6) Certificate from License Agency M/s-Vision Fire & Safety Engineering, Dated:20/02/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:04/10/2022
 - 8) AMC Certificate by M/s-J.M.G. Realtors Pvt Ltd, Dated:21/09/2022.
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:07/01/2022.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:17/02/2023.
 - 11) Structure Stability Certificate for M/s-Vipra Consultants, Dated:27/01/2023.
 - 12) RDP issued by VVCMC/TP/RDP/VP-0743/317/2014-15, Dated:10/02/2015.
 - 13) Submitted Electric Certificate M/s-Sai Sagar Electric Works, Dated:01/02/2023.
 - 14) C.F.O. site visit Dated:17/02/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Residential Building Type HH-57, HH-58, HI-59, HH-60,& HH-61 Cluster – E in Sector F as (Stilt / Ground floor + 7th floor) in 23.80mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-491, MFS-LA/RD-473 & has submitted Certificate on 20/02/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 7795.43sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 17/02/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-J.M.G. Realtors Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 45 Nos.
- B) Co2 Type Fire Extinguishers – 05 Nos.
- C) Sand Bucket – 05 Nos.
- D) Hose Reel Hose has been installed in every floor – 35 Nos.
- E) Hose Box has been installed in Alternate floor – 25 Nos.
- F) Main Pump – 01 Nos.
- G) Jockey Pump – 01 Nos.
- H) Booster Pump – 05 Nos.
- I) Single Hydrant Valve – 45 Nos.
- J) Fire Alarm Control Panel - 05 Nos.
- K) Combine MCP & Hooter – 35 Nos.
- L) Pendent Sprinkler – 40 Nos.

This No Objection certificate shall be treated **valid up to one year** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has paid Fire Cess Fees of Rs. 6.00,000/- vide Receipt No.69127, Book No.692, DD.No.031012 (Kotak Mahindra Bank), Dated:08/03/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in black ink, appearing to be "D. Pawar", written over the official stamp.

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-J.M.G. Realtors Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/3494/2022-23

DATE: 11/03/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E),
Tal-Vasai, Dist-Palghar.



Sub:- "Final No Objection Certificate" of School Building on land bearing S.No.21, H.No.2 of Village:Waliw, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by M/s-Prithvi Arch Consultants, Dated:25/02/2023.

- (VP-4819)
- 2) An application received by Developer M/s-Society of Pillar, Bombay through its Regional Superior Father Hillario Fernandes, Dated:25/02/2023.
 - 3) Work Completion certificate of M/s-Prithvi Arch Consultants, Dated:25/02/2023.
 - 4) Built up area certificate for M/s-Prithvi Arch Consultants, Dated:25/02/2023.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/902/2016-17, Dated:18/01/2018.
 - 6) Certificate from License Agency M/s-Jay Jivdani Fire Services, Dated:25/02/2023 (Form A).
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:02/01/2023
 - 8) AMC Certificate by M/s-Jay Jivdani Fire Services, Dated: 27/02/2023
 - 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:11/04/2022.
 - 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:25/02/2023.
 - 11) Structure Stability Certificate for M/s-Unitech Structural Engineering, Dated:21/10/2021.
 - 12) RDP issued by VVCMC/TP/RDP/VP-4819/200/2019-20, Dated:21/11/2019.
 - 13) Submitted Electric Certificate M/s-Maa Electricals, Dated:06/12/2022.
 - 14) C.F.O. site visit Dated:25/02/2023.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your School Building, as (Ground floor + 6th floor) in 26.75mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Jay Jivdani Fire Services, bearing License No. MFS-LA/RF-01 & MFS-LA/RD-01 has submitted Certificate on 02/01/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 6143.19sq.mtrs.

With reference to above on 25/02/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "M/s-Society of Pillar, Bombay through its Regional Superior Father Hillario Fernandes" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 11 Nos.
- B) Portable Fire Extinguishers has been installed (02 Kg) – 01 Nos.
- C) Co2 Type Fire Extinguishers has been installed (4.5 Kg) – 02 Nos.
- D) Co2 Type Fire Extinguishers has been installed (2 Kg) – 01 Nos.
- E) Hose Reel Hose has been installed in every floor – 06 Nos.
- F) Hose Box has been installed in Alternate floor – 08 Nos.
- G) Main Hydrant Pump (20 Hp) – 01 Nos.
- H) Booster Pump (7.5 Hp) – 02 Nos.
- I) Submersible Pump (15 Hp) – 01 Nos.
- J) Main Pump Panel – 01 Nos.
- K) 12 Zones Fire Alarm Panel - 01 Nos.
- L) MCP- 12 Nos
- M) Hooter – 12 Nos.

This certificate shall be treated **valid up to one year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has all ready paid Fire Cess Fees of Rs.2,40,000/- vide Receipt No.499082, DD.No.402112, Dated: 30/12/2016; Rs. 2,40,000/- vide Receipt No.609531, DD.No.187284, Dated:09/01/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, WCMC

2) Developer- M/s-Society of Pillar, Bombay through its Regional Superior Father Hillario Fernandes.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtratrafficservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार
विरार (पूर्व)
ता.वसई, जि.पालघर-४०१ ३०५.



दुरध्वनी: ०२५०-२५२५१०१/०२/०३/०४/०५/०६
फॅक्स : ०२५०-२५२५१०७
ई-मेल: vasaivirarcorporation@yahoo.com
जा.क्र. : VVCMC/FIRE/HQ/3514/2022-23
दिनांक: 13/03/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-En Con Project Consultants,
G-7, 8 "D" Wing, Sethi Palace,
Ambadi Road,
Vasai Road (W), Dist-Palghar.



Sub:- Grant of "Final No Objection Certificate" for your Proposed Industrial / Commercial Building on land bearing S.No.35/2 of Village- Waliv, Tal-Vasai, Dist-Palghar.

Ref:- 1) An application received by M/s-En Con Project Consultants, Dated:18/02/2023. (VP- 6237)

- 2) An application received by Developer Mr.Shantilal M. Hariya HUF, Dated:18/02/2023.
- 3) Work Completion certificate of M/s-En Con Project Consultants, Dated:18/02/2023.
- 4) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/727/2020-21, Dated:23/12/2020.
- 5) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/834/2021/2022, Dated:23/07/2021.
- 6) Built up area certificate for M/s-En Con Project Consultants, Dated:18/02/2023.
- 7) Certificate from License Agency M/s-TFPC Infra LLP, Dated:15/02/2023. (Form A)
- 8) Submitted License copy of Maharashtra Fire Services, Dated:23/09/2022.
- 9) AMC Certificate by Developer Mr.Shantilal M. Hariya HUF, Dated:15/02/2023
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:05/12/2022.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/02/2023.
- 12) Structure Stability Certificate for M/s-S.S & Associates, Dated:19/12/2022.
- 13) RDP issued by VVCMC/TP/RDP/VP-6237/195/2021-22, Dated:16/06/2021.
- 14) Submitted Electric Certificate M/s-Shree Hari Electricals Sales & Services, Dated:13/02/2023.
- 15) Submitted D.G.Set Bill of M/s-Electric Power Enterprises, Dated:09/01/2023.
- 16) C.F.O. site visit Dated:28/02/2023.

With reference to Sr.No.1 & 2 above, this office is in received of your application for your Industrial / Commercial Building as (Ground floor + 3rd floor) in 19.80mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- TFPC Infra LLP bearing License No. MFS-LA/RF-474, MFS/LA/RD-457 and has submitted Certificate on 15/02/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2062.86sq.mtrs.

With reference to above on 28/02/2023 representative of this office visited the building situated on the above mentioned address for inspection from the point of view of fire prevention & protection provided by "Mr.Shantilal M. Hariya HUF" following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed (06 Kg) – 04 Nos.
- B) Sand Bucket – 02 Nos.
- C) Hose Reel Hose has been installed in every floor – 03 Nos.
- D) Hose Box – 03 Nos.
- E) Main Hydrant Pump (40Hp) – 01 Nos.
- F) Main Sprinkler Pump (20Hp) – 01 Nos.
- G) Jockey Hydrant Pump (5Hp) – 01 Nos.
- H) Jockey Sprinkler Pump (5Hp) – 01 Nos.
- I) Stand by Pump (40Hp) – 01 Nos.
- J) Booster Pump (5 Hp) – 01 Nos.
- K) Courtyard Hydrant Valve – 03 Nos.
- L) Internal Hydrant Valve – 03 Nos.

- M) Smoke Detector – 02 Nos.
- N) Sprinkler Bulb – 40 Nos.
- O) MCP – 04 Nos.
- P) Hooter – 04 Nos.
- Q) Fire Alarm Control Panel – 01 Nos.

This certificate shall be treated **valid up to One Year** it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under **sub-section (3) of section 3** of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs.1,70,000/- vide Receipt No.819513, DD.No.884941 (Syndicate Bank), Dated:05/11/2020 & Rs.1,30,000/- vide Receipt No.895519, Book No.8956, DD.No.736078 (Canara Bank), Dated:08/07/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer - Mr.Shantilal M. Hariya HUF.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available www.maharashtrafireservice.org or www.mfsindia.org.

Ther
ENCON



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/3523/2022-23

DATE: 16/03/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s – Sanat Mehta & Associates,
Rameshwar Tower,
A-103, Shimpoli Road,
Next to Gokhale School,
Borivali (W), Mumbai- 400 092.



Sub:- “Part Final No Objection Certificate” of Shopping Center Building on S.No.62/B/1, S.No.62/B/2, 62/B/3 of Village:Nilemore, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Sanat Mehta & Associates, Dated:06/02/2023 (VP- 0913)
- 2) An application received by Developer Mr.Peter Fernandis, Dated:25/02/2023.
 - 3) Built up area certificate for M/s-Sanat Mehta & Associates, Dated:06/02/2023.
 - 4) This office issued Provisional No objection Certificate No.VVCMC/FIRE/130/2014-15, Dated:23/07/2014.
 - 5) This office Final No Objection Certificate No.VVCMC/FIRE/HQ/298/2017-18, Dated:14/07/2017.
 - 6) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/2074/2019-20, Dated:27/12/2019.
 - 7) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/4719/2021-22, Dated:24/12/2021.
 - 8) Certificate from License Agency M/s-Bright Infra System Pvt Ltd, Dated:15/02/2023. (Form A)
 - 9) Submitted License copy of Maharashtra Fire Services, Dated:18/08/2022.
 - 10) AMC Certificate by M/s-Tania Infracon Pvt Ltd, Dated:05/08/2022.
 - 11) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:19/07/2017.
 - 12) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:11/03/2023.
 - 13) Structure Stability Certificate for M/s-S.S & Associates, Dated:23/02/2023.
 - 14) RDP issued by VVCMC/TP/RDP/VP-0913/405/2021-22, Dated:30/08/2021.
 - 15) POC issued by VVCMC/TP/POC/VP-0913/102/2017-18, Dated:06/02/2018.
 - 16) Submitted Electric Certificate M/s-Sneha Enterprises, Dated:02/11/2022.
 - 17) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines Ltd, Dated:Nil/09/2016.
 - 18) C.F.O. site visit Dated:11/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Shopping Center Building as (Basement + Ground floor + 4th Part floor) in 21.60mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Bright Infra System Pvt Ltd, bearing License No. MFS-LA/RF-431, MFS-LA/RD-421 & has submitted Certificate on 15/02/2023 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 18183.90sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 11/03/2023 for inspection from the point of view of fire prevention & protection provided by “Mr.Peter Fernandis” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 18 Nos.
- B) Co2 Type Fire Extinguishers – 02 Nos.
- C) Fire Bucket – 04 Nos.
- D) Hose Reel Hose has been installed in every floor – 02 Nos.
- E) Hose Box has been installed in Alternate floor – 02 Nos.
- F) Jockey Pump (5.5 Hp)– 01 Nos.
- G) Hydrant Valve – 02 Nos.
- H) Fire Alarm Control Panel – 01 Nos.
- I) MCP Cum Hooter – 01 Set.
- J) Fire Alarm Panel – 01 Nos.
- K) Sprinkler System – 03 Set.

9326471857
Mr. Peter Fernandis

- L) Smoke Detector – 03 Set.
- M) Heat Detector – 01 Set.
- N) Sign Edges – 01 Set.

This No Objection certificate shall be treated **valid up to one year** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.10,00,000/-, vide Receipt No.705592, DD.No.010970 (Bassein Catholic Bank), Dated:25/09/2019; Rs.3,38,500/- vide Receipt No.818880, DD.No.000813 (Bassein Catholic Bank), Dated:26/12/2019 & Rs.5,97,000/- vide Receipt No.895989, Book No.8960, DD.No.011558 (HDFC Bank), Dated:30/11/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Mr.Peter Fernandis.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from License Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/3529/2022-23

DATE: 16 / 03 / 2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shree Consultants Architect,
B/203, Akanksha Tower,
Nr Rly Station,
Nallasopara (E),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Commercial Building No. 1 on land bearing S.No.256, H.No.3 & 8, S.No.18, H.No.1 & 2 of Village:Gokhiware, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Shree Consultants Architect, Dated:17/02/2023 (VP- 0416)
- 2) An application received by Developer Mr.Usman H. Kasmani, Dated:18/02/2023
 - 3) Work Completion certificate of M/s-Shree Consultants Architect, Dated:21/02/2023.
 - 4) Gross Built up area certificate for M/s-Shree Consultants Architect, Dated:17/02/2023.
 - 5) This office Provisional No objection Certificate No. VVCMC/FIRE/HQ/618/2022-23, Dated:30/06/2022.
 - 6) Certificate from License Agency M/s-Kinjal Enterprises, Dated:13/02/2023. (Form A)
 - 7) Submitted License copy of Maharashtra Fire Services, Dated:15/07/2022
 - 8) AMC Certificate by M/s-Kinjal Enterprises, Dated:01/02/2023.
 - 9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:08/03/2023.
 - 10) Structure Stability Certificate for M/s-GR Consultants, Dated:10/01/2023.
 - 11) RDP issued by VVCMC/TP/RDP/VP-0416/114/2022-23, Dated:30/06/2022.
 - 12) Submitted Electric Certificate M/s-Magan Electricals, Dated:18/02/2023.
 - 13) C.F.O. site visit Dated:08/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Commercial Building No. 1 as (Ground floor + 1st floor) in 9.40mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-Kinjal Enterprises, bearing License No. MFS-LA/RF-372, MFS-LA/RD-362** has submitted **Certificate on 13/02/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009.** This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 308.81sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **08/03/2023** for inspection from the point of view of fire prevention & protection provided by **"Mr. Mr.Usman H. Kasmani"** In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 03 Nos.
- B) Hose Box – 02 Nos.
- C) Main Hydrant Pump (30Hp) – 01 Nos.
- D) Main Sprinkler Pump (20 Hp) – 01 Nos.
- E) Jockey Hydrant Pump (7.5Hp) – 01 Nos.
- F) Booster Pump (7.5Hp) – 01 Nos.
- G) Courtyard Hydrant – 03 Nos.
- H) Fire Alarm Control Panel - 01 Nos.
- I) Hooter Pill Box – 02 Nos.
- J) Smoke Detector – 04 Nos.
- K) Sprinkler – 29 Nos.
- L) Electric Control Panel – 01 Nos.

This No Objection certificate shall be treated **valid up to one year** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of “Maharashtra Fire Prevention and Life Safety Measures Act, 2006” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire Cess Fees of Rs.3,00,000/- vide Receipt No.30502, Book No.306, DD.No.024886 (Bassein Catholic Bank), Dated:22/03/2022 & Rs.80,000/- vide Receipt No.30503, Book No.306, DD.No.024887 (Bassein Catholic Bank), Dated:22/03/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- Mr.Usman H. Kasmani

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



**VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT**

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/3584/2022-23

DATE: 21/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s – Shree Consultants Architect,
B/203, Akanksha Tower,
Nr Railway Station,
Nalasopara (E) - 401 209.

Sub:- “Final No Objection Certificate” of School Building No. 1 on land bearing S.No.399, H.No.6 & 7 of Village:Virar, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by M/s – Shree Consultants Architect,

Dated:06/02/2023. (VP - 0101)

2) An application received by Developer M/s-Laxmi Narayan Bahuudhesiya Sanstha,

Dated:06/02/2023.

3) Gross Built up area certificate for M/s – Shree Consultants Architect

Dated:06/02/2023.

4) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/829/
2017-18, Dated:29/12/2017.

5) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/3336/
2022-23, Dated:17/02/2023.

6) Certificate from License Agency M/s-Vision Fire & Safety Engineering,
Dated:27/12/2022. (Form A)

7) Submitted License copy of Maharashtra Fire Services, Dated:04/10/2022.

8) AMC Certificate by M/s-Laxmi Narayan Bahuudhesiya Sanstha, Dated:06/02/2023.

9) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour, Dated:22/09/2022.

10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:20/03/2023.

11) Structure Stability Certificate for M/s-Shilplekha Consultant, Dated:20/06/2022.

12) RDP issued by VVCMC/TP/RDP/VP-0101/130/2020-21, Dated:11/12/2020.

13) Submitted Electric Certificate M/s-Madhu Electricals, Dated:25/01/2023.

14) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines Ltd,
Dated:10/10/2022.

15) C.F.O. site visit Dated:20/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your School Building No. 1 as (Ground floor + 7th floor) in 30.20mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Vision Fire & Safety Engineering, bearing License No. MFS-LA/RF-491, MFS-LA/RD-473 & has submitted Certificate on 27/12/2022 in “Form A” Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a “Final No Objection Certificate” for your building having built up area admeasuring to 3822.85sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **20/03/2023** for inspection from the point of view of fire prevention & protection provided by “**M/s-Laxmi Narayan Bahuudhesiya Sanstha**” In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 14 Nos.

B) Modular Type Fire Extinguishers (05 Kg) – 02 Nos.

C) Fire Bucket – 04 Nos.

D) Hose Reel Hose has been installed in every floor – 14 Nos.

E) Hose Box has been installed in Alternate floor – 17 Nos.

F) Main Pump - 02 Nos.

G) Jockey Pump – 01 Nos.

H) Hydrant Valve – 17 Nos.

I) Booster Pump - 01 Nos.

J) Fire Alarm Control Panel – 01 Nos.

K) Combine MCP & Hooter – 14 Nos.

L) Hooter - 01 Nos.

M) Pendant Sprinkler - 54 Nos.

Alimkhal S. Vickram

Alimkhal

8097909873

- N) Smoke Detector – 30 Nos.
- O) Heat Detector – 08 Nos.
- P) Sign Edges – 01 Lot.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of “**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**” it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this “N.O.C.” will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of ~~Rs.10,00,000/-~~ vide Receipt No.609473, DD.No.022369 (Bassein Catholic Bank), Dated:12/12/2017 & Rs.50,000/- vide Receipt No.69008, Book No.691, DD.No.315576 (Union Bank), Dated:15/02/2023.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC

2) Developer- M/s-Laxmi Narayan Bahuudhesiya Sanstha.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtralfireservice.org or www.mfsindia.org.

**VASAI-VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT**

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,86
VVC/MC/FIRE/HQ/3585/2022-23

DATE: 21/03/2023

FIRE & EMERGENCY DEPARTMENT

To,

Mr. Umesh Gala Architect,
1st Floor, Tripathi House,
Behind Guridwara,
Off Ambadi Road,
Vasai (W), Dist-Palghar.



Sub:-

"Final No Objection Certificate" of Vehicle Fuel Filling Station on land bearing S.No.65/3 (Pt) & S.No.151 of Village:Dhaniv, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by Mr. Umesh Gala Architect, Dated:14/03/2023.
(VP - 6255)
2) An application received by Developer Mr. Pandurang Kashinath Gharat & Mr. Yograj Pandurang Gharat, Dated:26/09/2022.
3) Built up area certificate for Mr. Umesh Gala Architect, Dated:14/03/2023.
4) Development Completion Certificate from Mr. Umesh Gala Architect, Dated:14/03/2023.
5) This office issued Provisional No objection Certificate No. VVC/MC/FIRE/HQ/1033/2021-22, Dated:10/03/2021.
6) Certificate from License Agency M/s-Fire Bird Fire Services, Dated:03/02/2023 (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:08/02/2022.
8) AMC Certificate by M/s-Chaitali Petroleum, Dated:03/02/2023.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:20/03/2023.
10) Structure Stability Certificate for M/s-Strucbuild Engineers, Dated:02/01/2023.
11) CC issued by VVC/MC/TP/CC/VP-6255/26/2021-22, Dated:22/04/2021.
12) Submitted Electric Certificate M/s-A.S. Consultants, Dated:02/09/2020.
13) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines Ltd, Dated:10/10/2022.
14) C.F.O. site visit Dated:20/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your

Vehicle Fuel Filling Station as Structure - 1 Office Toilet & Meter Room (Ground floor) in 3.20mtrs Height & Structure - 2 Vehicle Fuel Filling Station (Ground floor) in 5.00mtr height. at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Fire Bird Fire Services, bearing License No. MFS-LA/RF-71, MFS-LA/RD-69 has submitted Certificate on 03/02/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to Structure- 1 - 46.55sq.mtrs & Structure - 2 - 160.00mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 20/03/2023 for inspection from the point of view of fire prevention & inspection provided by "Mr. Pandurang Kashinath Gharat & Mr. Yograj Pandurang Gharat" In condition following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (09 Kg) - 06 Nos.
- B) Co2 Type Fire Extinguishers (4.5 Kg) - 01 Nos.
- C) Hose Reel Hose has been installed in every floor - 02 Nos.
- D) Hose Box has been installed in Alternate floor - 04 Nos.
- E) Main Pump (20 Hp) - 02 Nos.
- F) Jockey Pump (5 Hp) - 01 Nos.
- G) Hydrant Valve - 04 Nos.
- H) Panel for Main Pump - 01 Nos.
- I) Fire Alarm Control Panel - 01 Nos.
- J) Smoke Detector - 04 Nos.
- K) MCP - 01 Nos.
- L) Hooter - 02 Nos.
- M) Panel Board 2 Zones - 01 Nos.
- N) Sprinkler - 02 Nos.

This No Objection certificate shall be treated valid up to one year It is your responsibility get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No-Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.1,60,000/-, vide Receipt No.895102, DD.No.029778 (ICICI Bank), Dated:08/02/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC

2) Developer-Mr.Pandurang Kashinath Charat & Mr.Yograj Pandurang Charat.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtratireservice.org or www.mfsindia.org



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 3592-/2022-23

DATE: 24/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Ajay Wade & Associates,
A/6, 1st Floor, Sai Tower,
Ambadi Road, Vasai Road (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of School Building on land bearing S.No.209B,
246 to 253, 255 to 270 of Village:Juchandra, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by M/s-Ajay Wade & Associates, Dated:08/03/2023
(VP - 0570)

2) An application received by Developer M/s-Sealink Construction Co. Pvt Ltd,
Dated:08/03/2023.

3) Construction area certificate for M/s-Ajay Wade & Associates, Dated:08/03/2023

4) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/825/
2021-22, Dated:23/07/2021.

5) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/530/
2022-23, Dated:24/06/2022.

6) Certificate from License Agency M/s-Water Power Engineering Services,
Dated:10/02/2023 (Form A)

7) Submitted License copy of Maharashtra Fire Services, Dated:07/05/2022.

8) AMC Certificate by M/s-Sealink Construction Co. Pvt Ltd, Dated:08/03/2023.

9) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour, Dated:Nil.

10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:20/03/2023.

11) Structure Stability Certificate for M/s-Shah & Shah, Dated:02/03/2023.

12) CC issued by VVCMC/TP/CC/VP-0570/253/2020-21, Dated:31/03/2021.

13) Submitted Electric Certificate M/s-Zip Engineers, Dated:10/02/2023.

14) Submitted Diesel generator test certificate for M/s-Kirloskar Brothers Ltd,
Dated:07/10/2022.

15) C.F.O. site visit Dated:20/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your School Building as (Ground floor + 7th floor) in 29.40mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Water Power Engineering Services, bearing License No. MFS-LA/RF-248, MFS-LA/RD-241 & has submitted Certificate on 10/02/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 5216.90sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on 20/03/2023 for inspection from the point of view of fire prevention & protection provided by "M/s-Sealink Construction Co. Pvt Ltd" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 12 Nos.
- B) Hose Reel Hose has been installed in every floor – 07 Nos.
- C) Hose Box has been installed in Alternate floor – 09 Nos.
- D) Main Pump - 01 Nos.
- E) Jockey Pump – 02 Nos.
- F) Booster Pump - 01 Nos.
- G) Fire Alarm Panel – 01 Nos.
- H) MCP & Hooter Combo – 07 Nos.
- I) Single Hydrant Valve - 13 Nos.
- J) Smoke Detectors - 75 Nos.
- K) Automatic Sprinklers - 376 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).


The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.10,00,000/-, vide Receipt No.895515, Book No. 8956, DD.No.502249 (The Satara Sahakari Bank), Dated:06/07/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you




CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC

2) Developer- M/s-Sealink Construction Co. Pvt Ltd.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/3606/2022-23

DATE: 29/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Jai Mistry Architect,
1, Mayfair Meridian,
Near St. Blaise Church,
Ceaser Road, Andheri (W),
Mumbai - 400 058.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. 23 (Type-T) in Cluster - V on land bearing S.No.195, H.No.1 & 2, S.No.211, H.No.11/1/3, 14/1, S.No.212, H.No.1, 3, 4 & 8/1 & 8/2, S.No.213, 214, 215, 216, S.No.223, H.No.1, 2, 3, S.No.224, H.No.1 to 18, S.No.225, H.No.1, 2, 3/1, 3/2, 4/4, 5, 6 & 8, S.No.226, H.No.3/2, No.227, H.No.1, 2/1, 2/2, 3, 4, 5, S.No.228, H.No.3/2 (Old S.No.) S.No.195B/1 to 13 (New S.No.) of Village: Bolinj, Tal: Vasai, Dist: Palghar.

Ref:- 1) An application received by M/s-Jay Mistry Architect, Dated: 08/02/2023 (VP - 0278)

- 2) An application received by Developer M/s-Mayfair Housing, Dated: 08/02/2023.
- 3) Built up area certificate for M/s-Jay Mistry Architect, Dated: 08/02/2023
- 4) This office issued Provisional No objection Certificate No. VVCMC/FIRE/HQ/1238/2021-22, Dated: 27/08/2021.
- 5) This office Revised & Provisional No Objection Certificate No. VVCMC/FIRE/HQ/530/2022-23, Dated: 24/06/2022.
- 6) Certificate from License Agency M/s-Sai Enterprises, Dated: 24/03/2023 (Form A)
- 7) Certificate from License Agency M/s-Hem Enterprises, Dated: 02/01/2023 (Form-A)
- 8) Submitted License copy of Maharashtra Fire Services, Dated: 27/02/2023.
- 9) AMC Certificate by M/s-Mayfair Housing, Dated: 21/03/2023.
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated: Nil.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 23/03/2023.
- 12) Structure Stability Certificate for M/s-S.P.A. Consulting Engineering, Dated: 23/01/2023.
- 13) CC issued by VVCMC/TP/CC/VP-0278/168/2020-21, Dated: 23/12/2020.
- 14) RDP issued by VVCMC/TP/RDP/VP-0278/814/2021-22, Dated: 05/01/2022
- 15) Submitted Electric Certificate M/s-Sakshi Electrical Engineering, Dated: 21/03/2023.
- 16) Submitted Diesel generator Bill for M/s-Kalpada Power Control, Dated: 21/09/2021.
- 17) C.F.O. site visit Dated: 20/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline Building No. 23 (Type-T) in Cluster - V as (Stilt / Ground floor + 22th floor) in 69.99mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Sai Enterprises, bearing License No. MFS-LA/RF-239, MFS-LA/RF-233 has submitted Certificate on 24/03/2023 & M/s-Hem Enterprises, bearing License No. MFS-LA/RF-12, MFS-LA/RF-14, MFS-LA/RF-04 has submitted Certificate on 19/01/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 7043.48sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **20/03/2023** for inspection from the point of view of fire prevention & protection provided by "M/s-Mayfair Housing" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 30 Nos.
- B) ABC Type Portable Fire Extinguishers has been installed (09 Kg) – 03 Nos.
- C) Courtyard Hydrant System - 04 Nos.
- D) Hose Reel Hose has been installed in every floor – 23 Nos.
- E) Hose Box has been installed in Alternate floor – 22 Nos.
- F) Main Pump (100 Hp) - 01 Set.
- G) Jockey Pump (12.5 Hp) – 02 Set.

[Signature]
9/3/2023

- H) Sprinkler Pump (100 Hp) - 01 Set.
- I) Stand By Pump - 01 Set.
- J) Booster Pump (10 Hp) - 01 Set.
- K) Electric Control Panel - 01 Nos.
- L) Manual Fire Alarm Panel - 01 Nos.
- M) Hooter Pill Box - 23 Nos.
- N) Smoke Detectors - 300 Nos.
- O) Sprinkler Pendant Type - 200 Nos.
- P) Sprinkler Sidewall Type - 333 Nos.
- Q) Fire Bucket - 08 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.1,57,27,286.10/-, vide Receipt No.818984, Book No.8190, DD.No.864299 (Kotak Mahindra Bank), Dated:06/02/2020; Rs.7,31,500/- vide Receipt No.819540, Book No.8196, DD.No.072340 (ICICI Bank), Dated:11/11/2020; Rs.85,000/- vide Receipt No.76113, Book No.46, DD.No.876864 (Kotak Mahindra Bank), Dated:05/03/2013; Rs.85,000/- vide Receipt No.76112, Book No.46, DD.No.876863 (Kotak Mahindra Bank), Dated:05/03/2013 & Rs.90,01,000/- vide Receipt No.895601, Book No.8956, DD.No.073468 (ICICI Bank), Dated:13/08/2021.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



(Signature)

**CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION**

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Mayfair Housing.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/3610/2022-23

DATE: 29/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s. Prithvi Arch Consultants,
122, Gauri Complex,
Near Bank of Baroda,
Vasai Road (E) - 401 210.

Sub:- "Final No Objection Certificate" of Residential Building No. 05 (Wing-C) on land bearing S.No.31, H.No.1, 4A, 4B, & 4C, S.No.34, H.No.1, & 2, S.No.35, H.No.1, 3, 4, 2/1 & 2/2, S.No.36, H.No.1A, 1B, 2A, 2B, 3A & 3B, S.No.37, H.No.1 to 5, 7, 8, 9, 14, 17, 18, 19, 20, 21, 22 & 23, S.No.38, H.No.1/A, 1/B, 4, 5, 7, 8 & 9, S.No.39, H.No.1/A, 1/B, 2A, 2B, 3A, 3B, 4A, 4B, 5, 6, 7, 8, 9, 10, 12, 13, 14/A, 14/B, 15, 16, 17 & 18, S.No.40, H.No.1A, 1B, 2, 3A, 3B, 4, 5A, 5B, 6, 7A & 7B, S.No.41, H.No.2B, 4A, 4B, 7A, 7B, 8A, 8B, 3/A, 3A, 3B, 5A/1, 5A/2, 5A/4, 5B/1, 5B/3, 6A/1, 6A/2, 6A/3, 6B/1 & 6B/2, S.No.42, H.No.1A, 6A & 7A, S.No.43, H.No.1B, 8A/3, 8A/4, 8A/5, 8A/6, 8B/1, 8B/2, 8C/4, S.No.44, H.No.20A/2, S.No.48, H.No.21A, 21B & 22 of Village: Barampur, Tal: Vasai, Dist: Palghar.

Ref:- 1) An application received by M/s. Prithvi Arch Consultants, Dated: 24/03/2023 (VP - 0202)

- 2) An application received by Developer Mr. Jayesh B. Ajmera, Dated: 24/03/2023.
- 3) Built up area certificate for M/s. Prithvi Arch Consultants, Dated: 24/03/2023.
- 4) Work Completed certificate by M/s. Prithvi Arch Consultants, Dated: 24/03/2023
- 5) This office issued Revised Provisional No objection Certificate No. VVCMC/FIRE/HQ/2023/2018-19, Dated: 09/06/2018.
- 6) Certificate from License Agency M/s-Reliance Fire Protection Systems, Dated: 29/03/2023 (Form A)
- 7) Submitted License copy of Maharashtra Fire Services, Dated: 12/11/2022.
- 8) AMC Certificate by M/s-B. J. Enterprises, Dated: 20/03/2023.
- 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated: 23/03/2023.
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 21/03/2023.
- 11) Structure Stability Certificate for Mr. Hiren M. Tanna, Dated: 14/03/2023.
- 12) CC issued by VVCMC/TP/CC/VP-00202/289/2021-22, Dated: 08/10/2021.
- 13) Submitted Electric Certificate M/s-Choice Electricals, Dated: 26/09/2022.
- 14) Submitted Diesel generator test certificate for M/s-M & M Ltd, Dated: Nil.
- 15) C.F.O. site visit Dated: 21/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building No. 05 (Wing - C) as (Basement + Ground floor + 15th floor) in 47.70mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Reliance Fire Protection Systems, bearing License No. MFS-LA/RF-537, MFS-LA/RD-517 & has submitted Certificate on 29/03/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 2963.63sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **21/03/2023** for inspection from the point of view of fire prevention & protection provided by "**Mr. Jayesh B. Ajmera**" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 10 Nos.
- B) Co2 Type Portable Fire Extinguishers has been installed (4.5 Kg) – 02 Nos.
- C) Fire Buckets - 06 Nos.
- D) Hose Reel Hose has been installed in every floor – 16 Nos.
- E) Hose Pipe & Branch Piper - 18 Nos.
- F) Single Hose Box – 02 Nos.
- G) Main Fire Hydrant Pump (100 Hp) - 01 Set.
- H) Hydrant Jockey Pump (10 Hp) – 01 Set.
- I) Main Sprinkler Pump (100 Hp) - 01 Set.
- J) Sprinkler Jockey Pump (10 Hp) - 01 Set.
- K) Booster Pump (7.5 Hp) - 01 Set.

9561040959
Gauri Shirur

- L) Fire Hydrant Control Panel - 01 Set.
- M) Fire Sprinkler Control Panel - 01 Set.
- N) Single Hydrant Valve (Riser) - 16 Nos.
- O) Single Hydrant Valve (Courtyard) - 04 Nos.
- P) Pendant Type Sprinkler 68°C - 195 Nos.
- Q) Extended Coverage Side wall type Sprinklers 68°C - 319 Nos.
- R) 20 zones Fire Alarm Control Panel with P.A. System - 01 Nos.
- S) Amplifier (100 W) - 01 Nos.
- T) Microphone - 01 Nos.
- U) Smoke Detector with Base - 02 Nos.
- V) Hooter - 16 Nos.
- W) Pill Box - 16 Nos.
- X) Signages - 16 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.24,70,000/- vide Receipt No.226692, DD.No.031267, Dated:04/07/2014 & Rs.11,70,000/- vide Receipt No.226693, DD.No.031268 (Vasai Vikas Sahakari Bank), Dated:04/07/2014 & Rs.5,00,000/- vide Receipt No.609406, DD.No.034728, Dated:01/11/2017 & Rs.6,00,000/- vide Receipt No.609405, DD.No.034740 (Vasai Vikas Sahakari Bank), Dated:01/11/2017.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC

2) Developer- Mr. Jayesh B. Ajmera.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/ 3681 /2023-24

DATE: 30/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
M/s-Shah Gattani Consultants,
103, Lucky Palace, Near SBI Bank,
Station Road, Vasai (W),
Tal-Vasai, Dist-Palghar.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building No. 8 on land bearing S.No.354 Scheme A, Plot.No.1 to 8, S.No.354 Scheme C, Plot.No.1 to 8 & S.No.383, H.No.1, 2, 3, 4 of Village:Bolini, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by M/s-Shah Gattani Consultants, Dated:28/03/2023 (VP - 0641)

- 2) An application received by Developer M/s-Mehta Ventures, Dated:18/03/2023.
- 3) Work Completion certificate of M/s-Shah Gattani Consultants, Dated:18/03/2023.
- 4) Gross Built up area certificate for M/s- M/s-Shah Gattani Consultants, Dated:18/03/2023.
- 5) This office Revised Provisional No Objection Certificate No.VVCMC/FIRE/HQ/5113/2022-23, Dated:30/03/2022.
- 6) Certificate from License Agency M/s-Jai Jivdani Fire Services, Dated:25/03/2023. (Form A)
- 7) Submitted License copy of Maharashtra Fire Services, Dated:02/01/2023
- 8) AMC Certificate by M/s-Mehta Ventures, Dated:18/03/2023.
- 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:23/03/2023.
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:28/03/2023.
- 11) Structure Stability Certificate for M/s-AVP Structural Consultants, Dated:13/03/2023.
- 12) RDP issued by VVCMC/TP/RDP/VP-0641/587/2021-22, Dated:02/11/2021.
- 13) Submitted Electric Certificate M/s-Aim Realty Engineering Pvt Ltd, Dated:24/03/2023.
- 14) Diesel Generator Test Certificate of M/s-Kirloskar Oil Engines, Dated:Nil/03/2023
- 15) C.F.O. site visit Dated:28/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential with Shopline Building No. 8 as (Shop / Stilt / Ground floor + 12th floor) in 39.35mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s- Jai Jivdani Fire Services, bearing License No. MFS-LA/RF-01, MFS-LA/RD-01 & has submitted Certificate on 23/03/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 6587.71sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **28/03/2023** for inspection from the point of view of fire prevention & protection provided by "**M/s-Mehta Ventures**" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (04 Kg) – 10 Nos.
- B) Hose Reel Hose has been installed in every floor – 12 Nos.
- C) Hose Box has been installed in Alternate floor – 10 Nos.
- D) Court Yard Hydrant Valve - 05 Nos.
- E) Hydrant Main Pump (30 Hp) – 01 Nos.
- F) Jockey Pump (7.5 Hp) – 01 Nos.
- G) Booster Pump (5 Hp) – 01 Nos.
- H) Single Hydrant Valve – 12 Nos.
- I) Fire Alarm Control Panel - 02 Nos.
- J) MCP & Hooter – 12 Nos.
- K) Manual Fire Alarm System - 01 Nos.
- L) Smoke Detector - 02 Nos.
- M) Sprinkler – 125 Nos.

This No Objection certificate shall be treated valid up to one year. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System, provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Fire Cess Fees of Rs. 5,25,000/- vide Receipt No.609504, DD.No.021262 (Axis Bank), Dated:26/12/2017 & Rs.1,21,500/- vide Receipt No. 30504, Book No.306, DD.No.027529 (Axis Bank), Dated:22/03/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VCMC
2) Developer- M/s-Mehta Ventures.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION
FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110, 2464811, 9822321684, 7775042200, 8975360101, 8888864283, 8888864275

VVCMC/FIRE/HQ/3684/2022-23

DATE: 30/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
Mr. Abhay Raut Architect,
1104, Gold Crest Business Center,
L.T. Road, Borivali (W),
Mumbai- 400 092.

Sub:- "Final No Objection Certificate" of Residential with Shopline Building Type-E on Plot bearing S.No.191, H.No.2 & 3 (Plot No.1, 2, 3 & 4) of Village:Bolini, Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by Mr.Abhay Raut Architect, Dated:11/03/2023 (VP - 1415)

- 2) An application received by Developer M/s-Giriraj Developers, Dated:25/02/2023.
- 3) Built up area certificate for Mr.Abhay Raut Architect, Dated:11/03/2023.
- 4) Work Completed certificate by Mr.Abhay Raut Architect, Dated:11/03/2023
- 5) This office issued Revised Provisional No objection Certificate No.VVCMC/FIRE/HQ/1138/2020-21, Dated:31/03/2021.
- 6) Certificate from License Agency M/s-Jai Jivdani Fire Services, Dated:03/03/2023 (Form A)
- 7) Submitted License copy of Maharashtra Fire Services, Dated:02/01/2023.
- 8) AMC Certificate by M/s-Giriraj Developers, Dated:01/03/2023.
- 9) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:09/03/2023.
- 10) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:24/03/2023.
- 11) Structure Stability Certificate for Mr.Paresh Unnarkar, Dated:25/02/2023.
- 12) RDP issued by VVCMC/TP/RDP/VP-1415/29/2022-23, Dated:17/05/2022.
- 13) Submitted Electric Certificate M/s-Eshwari Electricals, Dated:21/02/2023.
- 14) Submitted Diesel generator test certificate for M/s-Kirloskar Oil Engines, Dated:Nil/02/2023.
- 15) C.F.O. site visit Dated:24/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your **Residential with Shopline Building Type-E as (Part Ground floor + Part Stilt + 16th floor) in 53.15mtrs Height** at above mentioned address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Jai Jivdani Fire Services, bearing License No. MFS-LA/RF-01, MFS-LA/RD-01 & has submitted Certificate on 03/03/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built up area admeasuring to 9485.01sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **24/03/2023** for inspection from the point of view of fire prevention & protection provided by "M/s-Giriraj Developers" In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (04 Kg) – 10 Nos.
- B) Hose Reel Hose has been installed in every floor – 34 Nos.
- C) Hose Box has been installed in Alternate floor – 10 Nos.
- D) Court yard Hydrant Valve - 04 Nos.
- E) Main Pump (30 Hp) - 02 Nos.
- F) Jockey Pump (7.5 Hp) – 01 Nos.
- G) Booster Pump (5 Hp) - 02 Nos.
- H) Fire Alarm Panel – 02 Nos.
- I) Hydrant Pump Panel - 01 Nos.
- J) MCP & Hooter Combo – 02 Nos.
- K) Manual Fire Alarm System - 02 Nos.
- L) Smoke Detectors - 04 Nos.
- M) Automatic Sprinklers - 850 Nos.

This No Objection certificate shall be treated **valid up to one year** It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under **sub-section (3) of section 3** of "**Maharashtra Fire Prevention and Life Safety Measures Act, 2006**" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in: the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid Capitation & Scrutiny Fees of Rs.82,000/-, 1,23,000/- vide Receipt No.312258, 312257, DD.No.042088, 042079, Dated:09/06/2015 & Rs.1,92,000/-, 1,28,000/- vide Receipt No.312254, 312255, DD.No.042046, 042039, Dated:05/06/2015 & Rs.1,60,000/- vide Receipt No.895375, Book No.8954, DD.No.026487 (Axis Bank) & Rs.1,50,000/- vide Receipt No.895537, Book No.8956, DD.No.026807 (Axis Bank).

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC

2) Developer- M/s-Giriraj Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.misindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/ 3726 /2022-23

DATE: 31/03/2023

FIRE & EMERGENCY DEPARTMENT



To,
Mr.Sameer R. Desai, Architect,
Office No. 14, Mirza Nagar
1st Floor, Opp Railway Station,
Virar (E) - 401 305.

Sub: -"Final No Objection Certificate" of School Building on land bearing S.No.252A,
255A, 256, H.No.2 & 4, S.No.257, H.No.2/1, 3, 4, 5, 10/1, 11 of Village:Sandor,
Tal:Vasai, Dist:Palghar.

Ref:- 1) An application received by Mr.Sameer R. Desai, Architect, Dated:28/03/2023.
(VP - 0762)

2) An application received by Developer M/s-Dattani Estate Developers,

Dated:28/03/2023.

3) Built up area certificate for Mr.Sameer R. Desai, Architect, Dated:28/03/2023.

4) Work Completed certificate by Mr.Sameer R. Desai, Architect, Dated:28/03/2023

5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/173/2018-19,
Dated:24/05/2018.

6) This office Final No Objection Certificate No.VVCMC/FIRE/HQ/2322/2020,

Dated:02/03/2020

7) Certificate from License Agency M/s-Viva Enterprise, Dated:24/03/2023
(Form A)

8) Submitted License copy of Maharashtra Fire Services, Dated:22/04/2022.

9) AMC Certificate by M/s-Dattani Estate Developers, Dated:01/01/2022.

10) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour, Dated:31/03/2023.

11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:30/03/2023.

12) Structure Stability Certificate for Mr.Haresh L. Patel, Dated:09/08/2019.

13) RDP issued by VVCMC/TP/RDP/VP-0762/110/2020-21, Dated:09/12/2020.

14) Submitted Electric Certificate Mr.Jignesh Shah, Dated:Nil.

15) Submitted Diesel generator test certificate for M/s-Shyam Global Technoventure
Pvt Ltd, Dated:24/02/2020.

16) C.F.O. site visit Dated:30/03/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your
School Building as (Ground floor + 6th Part floor) in 25.80mtrs Height at above mentioned
address Since the fire fighting arrangements provided is installed by License Agency i.e. M/s-Viva
Enterprises, bearing License No. MFS-LA/RF-217, MFS-LA/RD-211 & has submitted
Certificate on 24/03/2023 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety
Measure Rules 2009. This office is issuing a "Final No Objection Certificate" for your building
having built up area admeasuring to 6568.65sq.mtrs.

With reference to your request, representative of this office visited the building situated on the
above mentioned address on **30/03/2023** for inspection from the point of view of fire prevention &
protection provided by "M/s-Dattani Estate Developers" In inspection following Fire Fighting
arrangements provided were found in satisfactory working condition.

A) ABC Type Portable Fire Extinguishers has been installed

B) Fire Bucket.

C) Hose Reel Hose has been installed in every floor.

D) Hose Box has been installed in Alternate floor.

E) Hydrant Valve.

F) Hydrant Main Pump.

G) Stand by Pump.

H) Booster Pump.

I) Hydrant Control Panel.

J) Manual Call Point.

K) Fire Alarm Panel.

L) Smoke Detectors.

Recd
31-3-2023
A. Thakkar
31-3-2023

This No Objection certificate shall be treated **valid up to one year**. It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted

The Party has already paid Capitation & Scrutiny Fees of Rs. 4,80,000/- vide Receipt No.609480, DD.No.005310 (Vasai Vikas Sahakari Bank), Dated:20/12/2017 & Rs.5,20,000/- vide Receipt No.672729, DD.No.022730 (Bassein Catholic Bank), Dated:24/05/2018.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Dattani Estate Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.



VASAI VIRAR CITY MUNICIPAL CORPORATION FIRE & EMERGENCY DEPARTMENT

Tel. No.: 0250-2525110,2464811,9822321684,7775042200,8975360101,8888864283,8888864275

VVCMC/FIRE/HQ/373/2022-23

DATE: 31/03/2023

FIRE & EMERGENCY DEPARTMENT

To,
M/s-Shape Consultants,
D-1 & D-2,
Aakanksha Commercial Complex,
Opp HDFC Bank, Achole Road,
Nalasopara (E),
Tal-Vasai, Dist.-Palghar.



Sub:- "Final No Objection Certificate" of Residential Building No. 1 (Wing-B) on land bearing S.No.226, H.No.1 to 4 of Village:Rajiwali, Tal:Vasai, Dist:Palghar.

- Ref:- 1) An application received by M/s-Shape Consultants, Dated:09/02/2023 (VP- 0478)
2) An application received by Developer M/s-Raj Developers, Dated:09/02/2023.
3) Work Completion certificate of M/s-Shape Consultants, Dated:09/02/2023.
4) Built up area certificate for M/s-Shape Consultants, Dated:09/02/2023.
5) This office issued Provisional No objection Certificate No.VVCMC/FIRE/HQ/1557/2022-23, Dated:15/09/2022.
6) Certificate from License Agency M/s-Water Power, Dated:05/12/2022. (Form A)
7) Submitted License copy of Maharashtra Fire Services, Dated:07/05/2022.
8) License to work the Lift From Govt. of Maharashtra Industries, Energy & Labour, Dated:05/09/2022.
9) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated:13/02/2023.
10) Structure Stability Certificate for M/s-Shilplekha Consultants, Dated:28/11/2022.
11) RDP issued by VVCMC/TP/RDP/VP-0478, 5088 & 5101/700/2021-22, Dated:28/12/2021.
12) Submitted Electric Certificate M/s-Fame Enterprises, Dated:17/02/2017.
13) Submitted Diesel generator installed certificate for M/s-Fame Enterprises, Dated:30/03/2023.
14) C.F.O. site visit Dated:13/02/2023.

With reference to Sr.No.1 & 2 above, this office is in receipt of your application for your Residential Building No. 1 (Wing-B) as (Stilt / Ground floor + 9th floor) in 29.25mtrs Height at above mentioned address Since the fire fighting arrangements provided is installed by **License Agency i.e. M/s-Water Power**, bearing License No. MFS-LA/RD-241, MFS-LA/RF-248 has submitted Certificate on 05/12/2022 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure Rules 2009. This office is issuing a **"Final No Objection Certificate"** for your building having built up area admeasuring to 2596.36sq.mtrs.

With reference to your request, representative of this office visited the building situated on the above mentioned address on **13/02/2023** for inspection from the point of view of fire prevention & protection provided by **"M/s-Raj Developers"** In inspection following Fire Fighting arrangements provided were found in satisfactory working condition.

- A) ABC Type Portable Fire Extinguishers has been installed (06 Kg) – 12 Nos.
- B) Hose Reel Hose has been installed in every floor – 09 Nos.
- C) Hose Box has been installed in Alternate floor – 10 Nos.
- D) Main Hydrant / Sprinkler Pump (40 Hp) – 02 Nos.
- E) Jockey Pump (12.5 Hp)– 01 Nos.
- F) Booster Pump (7.5 Hp) – 01 Nos.
- G) Fire Alarm Control Panel – 01 Nos.
- H) MCP Cum Hooter – 09 Nos.
- I) Fire Alarm Panel – 01 Nos.
- J) Sprinkler System – 48 Nos.

This No Objection certificate shall be treated valid up to one year It is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew this given Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub- section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The party has already paid Capitation & scrutiny Fees of Rs.2,40,000/- vide Receipt No.487386, DD.No.603701 (RBL Bank), Dated:08/08/2016; Rs.2,10,000/- vide Receipt No.54264, Book No.543, DD.No.004376 (HDFC Bank), Dated:15/09/2022 & Rs.8,86,000/- vide Receipt No.54265, Book No.543, DD.No.004381 (HDFC Bank), Dated:15/09/2022.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



A handwritten signature in blue ink, appearing to be "J. K. Kulkarni".

CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to - 1) The Deputy Director Town Planning, VVCMC
2) Developer- M/s-Raj Developers.

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.

मुख्य कार्यालय, विरार

विरार (पूर्व),

ता. वसई, जि. पालघर - ४०१ ३०५.

दूरध्वनी : ०२५० - २५२५१०१ / ०२/०३/०४/०५/०६

फॅक्स : ०२५० - २५२५१०७

ई-मेल : vasalvirarcorporation@yahoo.com

जावक क्र. : व.वि.श.म./अग्नि/मुका/५०२५/२०
दिनांक : ०८/०३/२०२२



FIRE & EMERGENCY DEPARTMENT

To,
The Deputy Director of Town Planning,
Vasai Virar City Municipal Corporation,
Dist.- Palghar.

Sub:- "Final No Objection Certificate" of Health Centre (Hospital) Building in CFC Plot No. 1
on land bearing S.No.14, H.No.2 to 8, S.No.15, H.No.6 to 12 & 14 to 22, S.No.16, H.No.
1 & 8 of Village: Bolinj, Tal: Vasai, Dist: Palghar.

Ref:- 1) Letter from Deputy Director Town Planning No. V.V.C.M.C./TP/SH/1542/2021-22,
Dated: 19/01/2022.

- 2) An application received by M/s- Ajay Wade & Associates, Dated: 28/12/2021.
- 3) An application received by Developer M/s- Arham Realtors, Dated: 12/01/2022
- 4) Work Completion certificate of M/s- Ajay Wade & Associates, Dated: 28/12/2021.
- 5) This office Provisional No objection Certificate No. VVCMC/FIRE/380/2014-15,
Dated: 23/01/2015.
- 6) Built up area certificate for M/s- Ajay Wade & Associates, Dated: 28/12/2021.
- 7) Certificate from License Agency M/s- Fire Bird Fire Services, Dated: 12/06/2021
(Form A).
- 8) Submitted License copy of Maharashtra Fire Services, Dated: 08/01/2021.
- 9) AMC Certificate by Developer M/s- Arham Realtors, Dated: 12/01/2022
- 10) License to work the Lift From Govt. of Maharashtra Industries, Energy &
Labour.
- 11) Submitted Affidavit & Fire Fighting Installation Photo Copy, Dated: 24/02/2022
- 12) Structure Stability Certificate for Mr. Sureshkumar Panicker, Dated: 14/06/2021
- 13) RDP issued by VVCMC/TP/RDP/VP-0025/657/2021-22, Dated: 22/12/2021.
- 14) Submitted Electric Certificate M/s- Ishwar Electrical Works, Dated: 01/01/2022.
- 15) Diesel Engine Test Certificate of M/s- Sudhir Power Ltd, Dated: 10/03/2018.
- 16) C.F.O. site visit Dated: 24/02/2022.

With reference to Sr.No. 2 & 3 above, this office is in received of your application for your
Hospital Building (Gr + 3 floor) in 15.00mtrs Height at above mentioned address Since the fire
fighting arrangements provided is installed by License Agency i.e. M/s- Fire Bird Fire Services,
bearing License No. MFS-LA/RF-26, MFS-LA/RD-20 and has submitted Certificate on
12/06/2021 in "Form A" Prescribed in Maharashtra Fire Prevention & Life Safety Measure
Rules 2009. This office is issuing a "Final No Objection Certificate" for your building having built
up area admeasuring to 492.46sq.mtrs.

With reference to above on 24/01/2022 representative of this office visited the building
situated on the above mentioned address for inspection from the point of view of fire prevention &
protection provided by "M/s- Arham Realtors" following Fire Fighting arrangements provided were
found in satisfactory working condition.

- A) Portable Fire Extinguishers has been installed in prominent places – 03 Nos.
- B) Hydrant Valve – 05 Nos.
- C) Hose Reel Hose has been installed in every floor – 03 Nos.
- D) Hose Box – 01 Nos.
- E) Main Pump on under ground water storage tank (15hp) - 01 Nos.
- F) Booster Pump on over head water storage tank (7.5hp) – 01 Nos.
- G) Manual Call point cum Hotter – 03 Nos.
- H) Sprinkler – 32 Nos.
- I) Smoke Detector – 27 Nos.
- J) Diesel Generator Set

This certificate shall be treated valid up to 31/12/2022, it is your responsibility to get the same renewed every year after inspection of fire fighting installation and arrangements provided for fire & life safety. After paying renewal fees Fire Brigade Department will renew the Final No Objection Certificate.

Under sub-section (3) of section 3 of "Maharashtra Fire Prevention and Life Safety Measures Act, 2006" it is responsibility of the Owner or the Occupier as the case may be, shall furnish to The Chief Fire Officer a Certificate in a prescribed form twice a year in the Month of January & July regarding maintenance of fire prevention and life safety measure in good repair and efficient condition as specified in sub-section (1).

The Fire Fighting System provided by owner or the Occupier in the premises as per provisional No Objection Certificate shall be well maintained & shall be kept in tip-top working condition at all the time. If the fire protection system is not maintained, retrenched then this "N.O.C." will stand cancelled without any notice & the Owner or the Occupier will be solely responsible to loss of life or property if any, which may please be noted.

The Party has already paid the Rs. 80,000/- vide Receipt No. 226641, Dated: 02/07/2014.

The undersigned reserves right to amend any additional recommendations deemed fit during the stage wise inspection due to the statutory provisions amended from time to time and in the interest of the protection of the Building **If any change of Activity or Transfer of Plot or any future expansion, No Objection Certificate from this office is essential.**

Thanking you



CHIEF FIRE OFFICER
VASAI VIRAR CITY MUNICIPAL CORPORATION

Copy to 1) Architect - M/s- Ajay Wade & Associates
2) Developer- M/s- Arham Realtors

Please Note:- The Developer / Owner / Occupier have to submit the next Testing Certificate of fire fighting system's only from Licensed Agency appointed by Government of Maharashtra on January & July of every year. The list of the License Agencies is available on www.maharashtrafireservice.org or www.mfsindia.org.